



United States Department of the Interior

BUREAU OF RECLAMATION

Great Plains Region

Montana Area Office

P.O. Box 30137

Billings, Montana 59107-0137



IN REPLY REFER TO: MT-450

August 27, 2012

FAXOGRAM: Water Order Change

To: Chief, Power Supply and Billing Division, WAPA, Watertown, South Dakota
Attention: F-6001
Chief, Power Dispatching Branch, WAPA, Loveland, Colorado
Attention: J-4120
Facilities Manager, Hardin, Montana
Attention: MT-300: Tom Tauscher
Project Manager, Mills, Wyoming
Attention: WY-4000, WY-4100, WY-6400
Assistant Superintendent, National Park Service, Lovell, Wyoming
Attention: Valerie Newman

From: Reservoir and River Operations, Billings, Montana

Subject: **Yellowtail Water Release Order - BHR No. 12-48**

CURRENT RESERVOIR CONDITIONS

Elevation: 3628.90 Storage: 901,400 acre-feet; River Release: 1,750 cfs; Inflow: 1,580 cfs;

GENERAL COMMENTS:

The BIA has requested an increase in diversions to the Bighorn Canal to meet increased irrigation demands. In response, the following operation change is required at Yellowtail Dam, Powerplant and Afterbay Dam.

YELLOWTAIL TURBINE RELEASE:

At 1600 hour on Monday, August 27, 2012:

Increase average daily turbine release to 2,230 cfs (\approx 1,240 MW-Hours/day using 43.2 cfs/mw).

AFTERBAY RELEASE AND OPERATION:

At 1600 hour on Monday, August 27, 2012:

Increase diversions to the Bighorn Canal to 550 cfs (gage height = 74.09 with shift of +0.65).

Maintain river release at 1,750 cfs (increase gage height to 59.49 & apply new shift of -0.15).

Increase total release from the Afterbay to 2,300 cfs.

Special Note: To accomplish ongoing contract work on the Afterbay Dam sluice gates and sluice gate water way, the level of the Afterbay must be maintained between the elevations 3186-3190 at all times.

/S/ Tim H. Felchle