

2. AMENDMENT/MODIFICATION NO. 003	3. EFFECTIVE DATE December 6, 2000	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable)
6. ISSUED BY Bureau of Reclamation Lower Colorado Region P.O. Box 61470 Boulder City NV 89006-1470	CODE LC-3112	7. ADMINISTERED BY (If other than Item 6) CODE	

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State, and ZIP code)	(T)	9A. AMENDMENT OF SOLICITATION NO. 01-SQ-30-0050
	T	9B. DATED (SEE ITEM 11) November 9, 2000
		10A. MODIFICATION OF CONTRACT/ORDER NO.
		10B. DATED (SEE ITEM 13)
CODE	FACILITY CODE	

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.

Offerors must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
 (a) By completing Items 8 and 15, and returning 1 copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. **FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER.** If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (if required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

(T)	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT/ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible)

Project Title: Armature Winding, Reconditioned Exciter and Testing Existing Core for Generator at Davis Powerplant, Parker-Davis Project Arizona

Purpose of Amendment: The purpose of this amendment is to provide an additional question submitted by a potential offeror and the response.

Receipt of Quotes: The date for receipt of quotes remains December 15, 2000. The time for receipt of quotes remains 3 p.m., local time. The place for receipt of quotes remains the Bureau of Reclamation, Lower Colorado Regional Office, P.O. Box 61470, Boulder City NV 89006-1470 or for overnight mail Bureau of Reclamation Lower Colorado Regional Office, 400 Railroad Avenue, Boulder City, Nevada 89005.

Acknowledgment: See block 11 above regarding how to acknowledge this amendment. The acknowledgment must be received at the place designated for receipt of offers (see block 9 of the "Solicitation/Contract/Order for Commercial Items," Standard Form 1449).

Offer Modification: See block 11 above if you have submitted your offer and now desire to modify it or withdraw it.

(Continued on the following page(s))

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)	16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)	16C. DATE SIGNED

Description of the Changes:

1. A recent question submitted by a potential offeror and the response follows:

Question: Please clarify section 4.01 a, page 70. Confirm if the bus bars are the leads going from the slip rings up to the generator rotor poles, that is the generator excitation leads.

Answer: No contractor work is required to the generator rotor. The units at Davis are constructed as follows: The generator rotor slip rings are located above the exciter commutator. The generator main field bus bars connect to the slip rings and are routed down the exciter shaft in a groove between the shaft exterior and the exciter rotor. They then continue to the main generator rotor at a splice point or where the exciter shaft and generator shaft are coupled together.

The exciter main generator field bus bars that are required to be reinsulated are only the ones on the exciter shaft.