

Canyon Ferry Powerplant Pick-Sloan Missouri Basin Program

Ancillary Services




Canyon Ferry Ancillary Services	
Spinning Reserve	Yes
Non-Spinning Reserve	Yes
Replacement Reserve	Yes
Regulation/Load Following	No
Black Start	Yes
Voltage Support	Yes

Generators

Canyon Ferry Generators Existing Number and Capacity			
Unit #	Original Capacity (kW)	Capacity Increased (kW)	Present Capacity (kW)
1	16,667	0	16,667
2	16,667	0	16,667
3	16,667	0	16,667
3 Units	50,000	0	50,000

**Canyon Ferry Powerplant
30-100 MW**


Generation




Drought conditions encountered for the fifth consecutive year.

Prime Laboratory Benchmarks





**Benchmark 1
Wholesale Firm Rate**



**Benchmark 2
Reclamation's Production Cost as Percentage of Wholesale Firm Rate**







**Benchmark 3
Production Cost**







FY-02 maintenance costs include extraordinary maintenance costs for stabilization of the riverbank downstream of the powerplant.

**Benchmark 3
Production Cost**




Benchmark 4
Workforce Deployment

Canyon Ferry 2004 Equivalent Work Year Levels						
	Equiv Work Year Charged to Powerplant	Leave Additive	Denver and Washington Equiv Work Year Additive	Total Equiv Work Year Allocated to Powerplant	Total Equiv Work Year per Generating Unit	Total Equiv Work Year per Megawatt
General	2.12	0.24	0.05	2.42	0.81	0.05
Operation	2.80	0.32	0.00	3.12	1.04	0.06
Maintenance	2.37	0.27	0.00	2.64	0.88	0.05
Total Staffing	7.28	0.84	0.05	8.17	2.72	0.16




**Benchmark 5
Availability Factor**




FY-95 – Extended unit outages due to automating and remotely controlling the powerplant.
FY-99, FY-00, FY-01 – Each included a 6-week extended outage for refurbishing the penstock’s fixed-wheel gate and overhauling the hydraulic cylinders.

**Benchmark 6
Forced Outage Factor**




**Benchmark 7
Scheduled Outage Factor**



FY-95 – Automation work on all 3 units

FY-99, FY-00, FY-01 – Each included a 6-week extended outage for refurbishing the penstock's fixed-wheel gate and overhauling the hydraulic cylinders.

Starts



**Canyon Ferry Powerplant
30-100 MW**

Benchmark Data Comparison					
Fiscal Year 2004	Canyon Ferry Powerplant	Reclamation Average 30-100 MW Group	Total Reclamation Average	Industry Average	Best Performers
Wholesale Firm Rate Mills/kWh	14.2	Not Applicable	*21.06	Not Available	Not Available
Production Cost as Percentage of Wholesale Firm Rate	0.78%	Not Applicable	13.5%	Not Applicable	Not Applicable
O&M Cost \$/MWh	3.56	7.90	2.77	48.48	1.23
O&M Costs \$/MW	16,821.07	19,931.46	7,316.97	26,917.84	2,951.22
O&M Equip Work Year per MW	0.12	0.11	0.04	Not Available	0
Availability Factor	91.3	88.1	86.9	**89.2	99.96983495
Forced Outage Factor	0.0	0.3	0.7	**1.9	0.00
Scheduled Outage Factor	8.7	11.5	12.4	**8.9	0.02

*Weighted by Net Generation

**2003 NERC Average

***Energy Information Administration Data

The Missouri River Basin experienced its fifth consecutive year of drought conditions in FY-2004, which resulted in below average generation (MWh).