

RECLAMATION

Managing Water in the West

FOR OFFICIAL USE ONLY

Technical Memorandum No. 3437-NCA-FEA-2016-03
Technical Memo and Appendices A-D

Feasibility Design Steady State Hydraulics and Pump Selection

North Central Arizona Water Supply Study, Arizona
Lower Colorado Region



FOR OFFICIAL USE ONLY

Mission Statements

The mission of the Department of the Interior is to protect and manage the Nation's natural resources and cultural heritage; provide scientific and other information about those resources; and honor its trust responsibilities or special commitments to American Indians, Alaska Natives, and affiliated island communities.

The mission of the Bureau of Reclamation is to manage, develop, and protect water and related resources in an environmentally and economically sound manner in the interest of the American public.

BUREAU OF RECLAMATION
Technical Service Center, Denver, Colorado
Water Conveyance Group, 86-68140

Technical Memorandum No. 3437-NCA-FEA-2016-03

Feasibility Design Steady State
Hydraulics and Pump Selection

North Central Arizona Water Supply Study, Arizona
Lower Colorado Region

Prepared: Michelle Norris
Civil Engineer, Water Conveyance Group 8140

Prepared: Matthew Shaw
Mechanical Engineer, Hydraulic Equipment Group 8420

Technical Review: Linda Bowles
Civil Engineer, Water Conveyance Group 8140

Technical Approval: Chou Cha, P.E.
Civil Engineer, Civil Structures Group 8150

Peer Review: Timothy P. Brown, P.E.
Civil Engineer, Civil Structures Group 8150

Date

REVISIONS					
Date	Description	Prepared	Checked	Technical Approval	Peer Review

Table of Contents

	Page
1. Report Purpose.....	1
2. Project Background.....	1
2.1 Overall Background.....	1
2.2 Alternative/Alignment Discussion.....	1
3. Steady State Modeling and Pump Selection	2
3.1 Steady State Modeling.....	2
3.1.1 Pipeline	2
3.1.1 Pipeline Hydraulics.....	2
3.2 Reach and Spur Descriptions.....	3
3.2.1 Lake Powell to Tuba City Spur Tee.....	3
3.2.2 Bitter Springs Spur.....	3
3.2.3 Tuba City Spur Tee to Gray Mountain	3
3.2.4 Hopi/Tuba City Spur to Keams Canyon.....	4
3.3 Pump Selection	4
3.3.1 Assumptions – Pumps.....	4
3.4 Recommended Considerations for Final Design	6
3.4.1 Steady State Hydraulics	6
3.4.2 Pumps.....	6
4. References.....	8

1. Report Purpose

The purpose of this Technical Memorandum is to communicate the feasibility design steady state hydraulic analysis and pump selection progress for the North Central Arizona Water Supply Feasibility Study (NCAWSFS). This report is a supplemental report addressing only the steady state hydraulics and pump selection and supports the overarching North Central Arizona Pipeline, North Central Arizona Water Supply Study Feasibility Report. The information provide in this study could be used for future transient analysis.

2. Project Background

2.1 Overall Background

The purpose of the proposed NCAWSFS is to construct a filtered bulk surface water supply pipeline to meet existing and future municipal and industrial water demands of the NCAWSFS participants. This water supply is necessary to supplement or replace poor quality water and to meet a portion of the NCAWSFS participants' projected water demands through 2050.

2.2 Alternative/Alignment Discussion

There are two intake options at Lake Powell and two initial pipe alignment connections. Hydraulically, the two intake options are similar, however the east intake option requires approximately 12,200 feet of additional pipe when compared to the west intake option. Downstream of the LeChee tank turnout, the alignment is identical for both alternatives.

In November, 2015, Reclamation Phoenix Area Office (PXA) and Technical Service Center (TSC) decided to select the east intake as an alternative to evaluate the steady state hydraulics and pump selection. This decision was made as a starting point for the hydraulic analysis and did not constitute a final and preferred selection of the intake site and beginning of pipe alignment.

The project pipeline alignment includes all features to convey water to NCAWSFS participants between Lake Powell to the Town of Gray Mountain, Arizona, including spurs to Bitter Springs, Tuba City, and Keams Canyon, Arizona. The project includes the construction of a new pipeline and various appurtenant features such as reservoir-side pumping plant, booster/re-lift plants, forebay tanks, water storage tanks, air chambers, regulating tanks, forebay tanks, pressure reducing valves, valve vaults, and participant delivery vaults within a study area located in Northern Arizona.

Transmission lines are primarily along State Highway 89 between Bodaway Gap to Bitter Springs and along State Highway 160 between State Highway 89 to Tuba City.

3. Steady State Modeling and Pump Selection

This section presents additional detail on the design criteria for the transmission line and turnouts including pipeline hydraulics and design requirements, pipeline appurtenances, pipeline surge, pumping plants and associated facilities, and in-line storage facilities.

3.1 Steady State Modeling

3.1.1 Pipeline

A pipeline beginning at Glen Canyon Dam and Reservoir and ending at Gray Mountain including associated turnouts will serve as the primary conveyance to deliver water. The pipeline is sized to deliver year 2050 maximum day demands, with diameters as large as 40" at the intake, to 4" on low flow tank turnouts.

3.1.1 Pipeline Hydraulics

NCAWSFS hydraulics and pipeline sizing were based on the maximum day demands from 2050, shown in Appendix A. The hydraulic gradient profile is presented in Appendix B.

As discussed in Section 2, the pipeline intake begins downstream of Glen Canyon Dam. The ground elevation downstream of the dam at the site of the proposed reservoir side pumping plant is approximately El. 3655' and the tank elevation at the highest delivery point is approximately El. 6433'. The total rise is approximately 2778 feet. The static head experienced by the system is reduced by on-line water tanks along the alignment, and is generally not designed to exceed 230 psi in order to accommodate a variety of pipe material options in final design. Some areas along the Keams Canyon Spur required higher pressure systems – as high as 270 psi – in order to eliminate the need for pump stations or tanks on the side of steep mesas. These areas are further discussed in Section 3.2.

The hydraulic grade line along the conduit and at each participant delivery location was calculated for maximum day demand in year 2050 and in agreement with existing tank heights provided by PXAO, shown in Appendix C. If an existing tank is not present or if the full tank water surface elevation is unknown, the desired pressure by the NCAWSFS participants would need to be further clarified in the final design phase(s). The hydraulic analysis includes a hydraulic grade line profile illustrating the ground profile, and hydraulic profile. The ground profile was based on contour data from LiDAR data provided to TSC in 2012, and from the 2013 IFSAR data provided for the Tuba City/Hopi Spur.

Hydraulic analyses that predict the pipe hydraulic grade line for each reach and spur were developed using Microsoft Excel and using the Bentley WaterCAD V8i (Bentley, 2014) software program. Pipeline hydraulics for the NCAWSFS feasibility level design were developed in accordance with Reclamation's *Design Standards No. 3, Water Conveyance Systems*, Chapter 11, "General Hydraulic Considerations" (Reclamation, 1994). The Hazen-Williams method was used to calculate pipe friction losses, using a nominal value of 145 for the C coefficient. Typical bend and other minor losses were calculated using

methods described in Chapter 11 of Reclamation (1994) and were applied based on the lengths and alignments of the segment reaches. Surge pressures in the pipe were estimated by adding a 30-percent factor to the static design pressure of the pipe – a full transient analysis has yet to be completed at this stage.

3.2 Reach and Spur Descriptions

The easting and northing coordinates of all tanks and pump stations in Arizona State Plane Coordinates are included in the appendices. Since the completion of this model, PXAO has ground truthed the pump site locations and found that 11 of the pump stations and three of the tanks need to be relocated up or downstream slightly in order to accommodate existing utilities, steep slopes, or significant washes. TSC has not evaluated the movement of these pumping plants as part of this study.

3.2.1 Lake Powell to Tuba City Spur Tee

This reach consists of five pumping plants located along the reach from Lake Powell to the Tuba City spur. Each plant would include canned vertical turbine pumps and will have a forebay tank, air chamber, and electrical power substation. The plant facility would include auxiliary mechanical systems and HVAC units. There are four in-line regulating tank site locations along this reach of the pipeline, listed in Appendix D. Turnouts along this reach include Page Tank, LeChee Tank, Coppermine Tank, Bodaway Gap Tank, and the Bitter Springs Spur. The main transmission line continues southward from the end of this reach.

3.2.2 Bitter Springs Spur

This reach consists of one pumping plant located along the reach from Bodaway Gap to Bitter Springs. Each plant would include canned vertical turbine pumps and will have a forebay tank, air chamber, and electrical power substation. The plant facility would include auxiliary mechanical systems and HVAC units. One additional booster plant will be required at the Cedar Ridge turnout tee. There is one pressure regulating tank site location along this reach of the pipeline, outlined in Appendix D. Turnouts along this reach include Cedar Ridge Tank, and the end point at Bitter Springs Tank.

3.2.3 Tuba City Spur Tee to Gray Mountain

This reach consists of two pumping plants located along the reach from Tuba City Spur Tee to the southernmost delivery point of Gray Mountain. Each plant would include canned vertical turbine pumps and will have a forebay tank, air chamber, and electrical power substation. The plant facility would include auxiliary mechanical systems and HVAC units. There are eight in-line regulating tank site locations along this reach of the pipeline, listed in Appendix D. Turnouts along this reach include Cameron Tank, and the termination of the reach at Gray Mountain.

3.2.4 Hopi/Tuba City Spur to Keams Canyon

This reach consists of ten pumping plants located along the reach from Tuba City Spur Tee to the easternmost delivery point of Keams Canyon. Each plant would include canned vertical turbine pumps and will have a forebay tank, air chamber, and electrical power substation. The plant facility would include auxiliary mechanical systems and HVAC units. There are two in-line regulating tank site locations along this reach of the pipeline, listed in Appendix C. Turnouts along this reach include Tuba City Tank, Moenkopi Tank, Coal Mine Tank, Howell Mesa Tank, Hotevilla Tank, Oraibi Tank, Kykotsmovi Tank, Shungopavi Tank, Sipaulovi Top Tank, Mishongnovi Tank, Sipaulovi Lower Tank, Polacca West Tank, Polacca East Tank, and the termination of the reach at Keams Canyon Tank.

3.3 Pump Selection

Pumps were selected to meet the capacity and total head of the feasibility level steady state design. Pump curves and pump data sheet can be seen in Appendix D.

3.3.1 Assumptions – Pumps

Pump selection for the NCAWSFS relied on the following design assumptions. Further explanation of each assumption follows this summarized list.

- Treated, potable or not potable water with particulates and biologic material removed.
- Chlorine concentrations are less than 3 parts per million (ppm).
- Pumping plants are indoors.
- Ambient temperature in the pumping plants is less than 104 °F (40 °C).
- Each pumping plant has one installed spare pump.
- Canned vertical turbine pumps are used at all pumping plants to simplify pump selection at the feasibility stage.
- Fixed speed pumps with induction motors.
- Range of flow set by the number of identical pumps.
- Forebay tank water surface elevations will meet the pumping plant design requirements.
- Suction pressure of booster pumping plants will meet the pumping plant design requirements.

Treated water:

Water is treated to remove biologic material, including mussels, and particulates but may or may not be potable. Invasive mussel species pose a significant reliability issue. The NCAWSFS assumes that all water in the water supply is free of mussels. Water treatment methods and facilities are not part of this study.

Chlorine concentrations are less than 3 ppm:

Chlorine concentration levels impact pump impeller material selection, which in turn affects pump efficiency. To provide the most efficient pump the NCAWSFS assumes that chlorine levels are less than 3 ppm, which allows for the most options of material selection.

Pumping plants are indoors:

The pumps and motors are indoors protected from the weather.

Ambient pumping plant temperature less than 104 °F (40 °C):

Pumping plant ambient temperature will be conditioned as required to less than the pump motor's rating of 40 degrees Celsius.

Installed spare pump:

Reliability of municipal water supplies is a critical design consideration. To ensure that each pumping plant can operate, even with one pump removed for maintenance, the study assumes that one pump in each pumping plant is a spare pump. Spare pumps also prolong the operational lifetime of each pumping plant by cycling through each installed pump. Cycling through installed pumps means that even at peak flow, one pump sits idle.

Canned vertical turbine pumps:

Pump selection for the NCAWSFS focused on canned vertical turbine pumps. Canned vertical turbine pumps were chosen because this type of pump was more widely available given the pumping plant head and flow requirements of the feasibility study. The design of vertical turbine pumps can also accommodate high heads over a wide range of flows by combining multiple pump stages. The ability to pump a wide range of flows at high pressure head means that the project may be able to lift water with fewer pumping plants.

Drawbacks of pumping plants with canned vertical turbine pumps are increased maintenance and excavation costs. Compared to horizontal split case pumps, canned vertical turbine pumps require more excavation to set the can into the ground. Due to their design, vertical turbine pumps with more moving parts require more routine maintenance than a horizontal split case pumps.

Fixed speed pumps with induction motors:

Variable speed drives were not part of our feasibility study. If required, pumping plant flow output would be changed by turning pumps on or off.

Range of flow set by the number of pumps:

Minimum flow requirements were not part of the feasibility design study. The range of flow at each pumping plant would be set by the number of identical pumps per pumping plant. For example: at a pumping plant with 4 active pumps (and 1 installed spare), each pump supplies approximately 1/4 of the total pumping plant design flow. Subsequent design efforts should document the minimum flow

for each pumping plant to provide pump selections that more closely match the operation conditions. The range of flows the pumps would operate over was not analyzed and was not accounted for in the selection of the number of pumps.

Forebay tank water surface elevations:

Minimum forebay tank water surface elevations will allow gravity flow to pumps and provide adequate net positive suction head to exceed the minimum net positive suction head requirements of the pumps.

Booster pumping plant suction pressure:

Pressure on the suction side of the booster plants will be adequate to supply water to the pumps and adequate net positive suction head to exceed the minimum net positive suction head requirements of the pumps.

3.4 Recommended Considerations for Final Design

3.4.1 Steady State Hydraulics

The steady state hydraulics for this feasibility study is based on the current and most available alignment. As the design continues to be refined into feasibility and final design, it is recommended that the steady state hydraulics be updated to maintain consistency between the alignment changes and hydraulic modeling. Although the hydraulics is not significantly impacted by the location adjustments of the pumping plant as ground truthed, the steady state hydraulic model should be updated with the adjusted location of the pumping plants as well.

3.4.2 Pumps

Pump selection for the NCAWSFS focused on having the same style of pump at every facility in the project (canned vertical turbine type pumps) to provide a baseline comparison and simplify pump selection at the feasibility stage. Pumping plants with low flows and high heads typically require pumps with multiple stages. Pumps with more stages require additional maintenance, and five of the pumping plants for the NCAWSFS have pumps with more than 6 stages. Pumps with greater than 6 stages are not recommended due to the increased number of moving parts and associated increased maintenance. However, the pumping plants below had pumps with more than 6 stages:

Pumping Plant Name	Number of stages	Flow*		Rated TDH	
		(gpm)	(cfs)	(feet)	(psi)
Pumping Plant 6	7	1,049.57	2.34	304	130
Pumping Plant 7	22	31.93	0.07	384.02	170
Bitter Springs	14	457.32	1.02	584	250
Cedar Ridge Turnout Booster	10	139.05	0.31	139	60
Hopi 10 Pumping Plant	10	392.43	0.87	514	220

* Flow includes 3% wear factor


Final design efforts should consider other design alternatives such as using a different pump type, adding pumping plants and/or adjusting the pipe alignment to allow for a wider selection of pump types. Some of the feasibility pump selections, limited by the assumptions made for this feasibility study, would be unsuitable at final design. Final design efforts should compare the cost of pumps with more moving parts and specialized high pressure components such as ANSI high pressure valves against the cost of adding more pumping plants to the system with pumps that require less maintenance such as horizontal split case pumps and lower pressure AWWA valves.

4. References

- [1] "Design Standards No. 3 Water Conveyance Systems, Chapter 11 General Hydraulic Consideration," Bureau of Reclamation, Denver, Colorado 1994.
- [2] "ANSI/HI 9.8, Rotodynamic Pumps for Pump Intake Design", Hydraulic Institute, Parsippany, New Jersey, 2012
- [3] "ANSI/HI 2.3, Rotodynamic (Vertical) Pumps for Design and Application", Hydraulic Institute, Parsippany, New Jersey, 2013
- [4] "NEMA MG 10, Energy Management Guide for Selection and Use of Fixed Frequency Medium AC Squirrel-Cage Polyphase Induction Motors", National Electric Manufacturers Association, Rosslyn, Virginia, 2013.

APPENDIX A

APPENDIX B



APPENDIX C

Tank Summary Table

	Label	Tank Base Elevation (ft)	Maximum Tank Water Elevation (ft)	HGL at Turnout Tee (ft)	X (ft)	Y (ft)	Pumped or Gravity Fed?
End of Pipe (Delivery) Tanks	T-Existing Bitter Springs	5,264.84	5,287.58	5,340.18	781,882.41	2,050,905.62	Gravity
	T-Existing Bodaway Gap	5,473.06	5,492.65	5,602.47	840,347.62	1,929,095.56	Gravity
	T-Existing Cameron	4,531.00	4,551.00	4,584.57	841,457.55	1,765,077.42	Gravity
	T-Existing Cedar Ridge	6,051.48	6,075.13	5,948.73	818,439.43	1,963,387.68	Pumped
	T-Existing Coal Mine	5,969.81	5,998.31	6,156.66	964,106.90	1,818,113.79	Gravity
	T-Existing Copper Mine	6,127.33	6,143.51	6,059.36	853,458.48	2,020,722.97	Pumped
	T-Existing Gray Mountain	4,929.00	4,949.00	N/A end of line	824,554.84	1,735,100.97	Pumped
	T-Existing Hotevilla	6,433.72	6,467.23	6,377.56	1,070,108.49	1,790,145.09	Pumped
	T-Existing Keams Canyon	6,408.00	6,428.00	N/A end of line	1,211,913.75	1,755,208.05	Pumped
	T-Existing Kykotsmovi	5,755.37	5,770.02	6,204.42	1,083,646.03	1,776,907.08	Gravity
	T-Existing LeChee	4,807.76	4,833.48	5,272.94	839,096.96	2,131,005.29	Gravity
	T-Existing Mishongnovi	5,978.07	5,985.27	6,304.69	1,121,494.05	1,750,778.16	Gravity
	T-Existing Moenkopi	4,917.00	4,937.00	5,156.33	905,196.87	1,862,859.68	Gravity
	T-Existing Page	4,377.57	4,419.86	4,743.07	835,702.10	2,150,281.14	Gravity
	T-Existing Polacca East	5,984.51	6,008.16	6,084.65	1,154,610.25	1,765,786.33	Gravity
	T-Existing Polacca West	5,831.59	5,870.25	6,106.00	1,147,298.27	1,759,883.16	Gravity
	T-Existing Shungopavi Water Tower	6,465.27	6,488.99	6,357.97	1,110,305.52	1,756,206.33	Pumped
	T-Existing Sipaulovi Lower	5,788.86	5,812.52	6,281.46	1,121,130.61	1,748,042.78	Gravity
	T-Existing Sipaulovi Top	6,293.25	6,310.81	6,317.36	1,121,066.60	1,752,489.50	Gravity
	T-Existing Tuba City	5,036.25	5,074.11	5,222.53	904,523.94	1,868,810.73	Gravity
	T-Proposed Howell Mesa	5,727.00	5,747.00	6,176.74	1,039,986.92	1,812,269.52	Gravity
	T-Proposed Oraibi	6,062.00	6,082.00	6,377.55	1,078,062.15	1,776,538.95	Gravity
Pump Plant Forebay Tanks	T-Forebay Bitter Springs Spur PP	5,440.45	5,460.00	N/A, in line	827,722.24	1,937,896.41	Pumped
	T-Forebay Hopi PP1	5,077.00	5,101.00	N/A, in line	879,467.57	1,868,244.33	Pumped
	T-Forebay Hopi PP2	5,047.35	5,062.00	N/A, in line	916,029.50	1,849,326.86	Gravity
	T-Forebay Hopi PP3	5,484.02	5,502.00	N/A, in line	916,818.65	1,833,334.29	Pumped
	T-Forebay Hopi PP4	5,776.80	5,798.00	N/A, in line	951,524.57	1,824,151.12	Pumped
	T-Forebay Hopi PP5	6,062.68	6,077.00	N/A, in line	979,816.58	1,811,238.16	Pumped
	T-Forebay Hopi PP6	6,097.38	6,109.00	N/A, in line	1,001,877.03	1,796,922.26	Pumped
	T-Forebay Hopi PP7	6,229.28	6,244.00	N/A, in line	1,004,255.73	1,794,886.03	Pumped
	T-Forebay Hopi PP8	6,005.00	6,022.00	N/A, in line	1,069,163.26	1,800,190.20	Gravity
	T-Forebay Hopi PP9	6,032.26	6,049.00	N/A, in line	1,107,804.91	1,769,930.16	Gravity
	T-Forebay Hopi PP10	5,964.07	5,979.07	N/A, in line	1,192,231.29	1,764,983.40	Gravity
	T-Forebay PP2	4,180.00	4,195.00	N/A, in line	849,439.34	2,147,326.97	Pumped
	T-Forebay PP3	4,710.00	4,725.00	N/A, in line	838,334.71	2,132,920.42	Pumped
	T-Forebay PP4	5,222.00	5,241.00	N/A, in line	839,647.36	2,118,666.50	Pumped
	T-Forebay PP5	5,769.89	5,788.00	N/A, in line	839,209.35	2,089,905.58	Pumped
	T-Forebay PP6	4,392.56	4,412.00	N/A, in line	855,289.36	1,818,181.97	Gravity
	T-Forebay PP7	4,564.00	4,582.00	N/A, in line	839,407.00	1,746,378.87	Pumped
In-Line Regulating Tanks	T-Hopi Reg Tank 1	5,218.00	5,258.00	N/A, in line	890,705.13	1,873,761.41	Pumped
	T-Hopi Reg Tank 2	5,214.86	5,232.00	N/A, in line	897,791.04	1,876,728.04	Gravity
	T-Hopi Reg Tank 3	6,155.00	6,170.00	N/A, in line	990,942.41	1,805,671.70	Pumped
	T-Hopi Reg Tank 4	6,320.00	6,350.00	N/A, in line	1,007,896.24	1,787,598.05	Pumped
	T-Hopi Reg Tank 5	6,307.00	6,335.00	N/A, in line	1,014,720.98	1,798,175.90	Gravity
	T-Hopi Reg Tank 6	6,358.00	6,378.00	N/A, in line	1,071,288.17	1,791,264.76	Pumped
	T-Hopi Reg Tank 7	6,333.00	6,353.00	N/A, in line	1,112,420.12	1,763,757.10	Pumped
	T-Hopi Reg Tank 8	6,317.39	6,329.00	N/A, in line	1,119,875.68	1,755,148.10	Gravity
	T-Reg Tank 1 Bitter Springs Spur	5,925.00	5,950.00	N/A, in line	815,714.31	1,961,696.16	Pumped
	T-Reg Tank 2 Bitter Springs Spur	5,508.00	5,538.00	N/A, in line	792,331.61	2,014,688.71	Gravity
	T-Reg Tank 1	6,109.28	6,135.00	N/A, in line	838,684.38	2,048,067.00	Pumped
	T-Reg Tank 2	5,943.00	5,973.00	N/A, in line	850,544.76	2,014,011.17	Gravity
	T-Reg Tank 3	5,493.00	5,523.00	N/A, in line	839,679.33	1,929,675.08	Gravity
	T-Reg Tank 4	5,153.00	5,178.00	N/A, in line	844,672.76	1,914,947.77	Gravity
	T-Reg Tank 5	4,616.00	4,636.00	N/A, in line	854,620.40	1,864,820.15	Gravity

Horizontal Datum: Arizona State Plane, Central Zone, North American Datum of 1983 (NAD83)

Vertical Datum: NAVD 88

APPENDIX D

Project: North Central Arizona Water Supply Study
Feature: Pumping Plants
Details: PMP-2
Design Level: Feasibility
By: Alan McCann 06/14/2016
Checked: Matthew Shaw 06/21/2016

Grid Scale

Flow: 224.415 gpm
 Head: 75 ft

Distance

37.5587

PUMP CURVE	
Flow (gpm)	Head (ft)
0	913
224.415	904
448.83	894
673.245	880
897.66	867
1122.075	851
1346.49	835
1570.905	818
1795.32	802
2019.735	784
2244.15	768
2468.565	752
2692.98	736
2917.395	721
3141.81	707
3366.225	693
3590.64	682
3815.055	669
4039.47	656
4263.885	646
4488.3	634
4712.715	626
4937.13	617
5161.545	606
5385.96	595
5610.375	579
5834.79	561
6059.205	540
6283.62	515
6508.035	487
6732.45	455
6956.865	417

Head grid line below curve	Distance up to curve
900	6.3561
900	2.1381
825	34.6816
825	27.5579
825	20.8527
825	13.0483
825	4.8935
750	34.1877
750	25.7943
750	17.049
750	8.8014
750	0.7653
675	30.5126
675	22.8304
675	15.9972
675	9.034
675	3.5537
600	34.3862
600	28.287
600	22.839
600	17.0769
600	13.0632
600	8.2808
600	2.9767
525	34.8538
525	27.2472
525	17.9943
525	7.3962
450	32.7213
450	18.6373
450	2.2719
375	21.0507

Project: North Central Arizona Water Supply Study
Feature: Pumping Plants
Details: PMP-3
Design Level: Feasibility
By: Alan McCann 06/14/2016
Checked: Matthew Shaw 06/21/2016

Grid Scale

Flow: 224.415 gpm
 Head: 75 ft

Distance

39.15

PUMP CURVE	
Flow (gpm)	Head (ft)
0	846
224.415	823
448.83	802
673.245	785
897.66	770
1122.075	754
1346.49	741
1570.905	728
1795.32	713
2019.735	699
2244.15	685
2468.565	671
2692.98	660
2917.395	651
3141.81	643
3366.225	636
3590.64	626
3815.055	615
4039.47	600
4263.885	585
4488.3	566
4712.715	544
4937.13	521
5161.545	494
5385.96	465
5610.375	434
5834.79	400
6059.205	366
6283.62	329
6508.035	293

Head grid line below curve	Distance up to curve
825	11.0064
750	37.8633
750	27.3242
750	18.1358
750	10.3657
750	2.3232
675	34.4298
675	27.8072
675	19.9058
675	12.3277
675	5.0379
600	36.8689
600	31.5114
600	26.4481
600	22.6514
600	19.0417
600	13.662
600	7.6227
600	0.2534
525	31.2956
525	21.2231
525	9.7974
450	36.9914
450	23.0146
450	7.829
375	30.7979
375	12.7898
300	34.3179
300	14.8814
225	35.2385

Project: North Central Arizona Water Supply Study
Feature: Pumping Plants
Details: PMP-4
Design Level: Feasibility
By: Alan McCann 06/14/2016
Checked: Matthew Shaw 06/21/2016

Grid Scale

Flow: 224.415 gpm
 Head: 75 ft

Distance

36.5506

PUMP CURVE	
Flow (gpm)	Head (ft)
0	966
224.415	937
448.83	914
673.245	896
897.66	880
1122.075	863
1346.49	849
1570.905	835
1795.32	820
2019.735	806
2244.15	789
2468.565	773
2692.98	756
2917.395	743
3141.81	730
3366.225	720
3590.64	711
3815.055	703
4039.47	693
4263.885	678
4488.3	661
4712.715	641
4937.13	616
5161.545	593
5385.96	565
5610.375	535
5834.79	501
6059.205	467
6283.62	431
6508.035	392

Head grid line below curve	Distance up to curve
900	32.3216
900	18.1542
900	6.9587
825	34.4941
825	26.5706
825	18.7416
825	11.5991
825	4.8542
750	34.3428
750	27.0507
750	19.0198
750	11.1932
750	3.0281
675	32.9664
675	26.8906
675	21.7156
675	17.3398
675	13.5635
675	8.8679
675	1.6516
600	29.9627
600	20.2094
600	7.6193
525	33.0997
525	19.4364
525	4.7962
450	24.8274
450	8.0695
375	27.2833
375	8.4457

Project: North Central Arizona Water Supply Study
Feature: Pumping Plants
Details: PMP-5
Design Level: Feasibility
By: Alan McCann 06/14/2016
Checked: Matthew Shaw 06/21/2016

Grid Scale

Flow: 250 gpm
 Head: 45 ft

Distance

38.5973

PUMP CURVE	
Flow (gpm)	Head (ft)
0	741
250	714
500	689
750	666
1000	645
1250	624
1500	603
1750	583
2000	564
2250	548
2500	536
2750	529
3000	517
3250	499
3500	476
3750	447
4000	414
4250	377
4500	338
4750	296
5000	252

Head grid line below curve	Distance up to curve
720	17.836
675	33.159
675	11.8564
630	30.9994
630	12.7122
585	33.4301
585	15.2464
540	36.4944
540	20.4308
540	6.8324
495	34.8752
495	29.2224
495	18.8339
495	3.838
450	22.05
405	36.2445
405	7.7333
360	14.9094
315	19.6319
270	22.0381
225	23.4125

Project: North Central Arizona Water Supply Study
Feature: Pumping Plants
Details: PMP-6
Design Level: Feasibility
By: Alan McCann 06/14/2016
Checked: Matthew Shaw 06/21/2016

Grid Scale

Flow: 50 gpm
 Head: 40 ft

Distance

35.3855

PUMP CURVE	
Flow (gpm)	Head (ft)
0	571
50	562
100	551
150	539
200	525
250	513
300	498
350	484
400	470
450	455
500	442
550	430
600	419
650	411
700	402
750	390
800	378
850	365
900	351
950	335
1000	320
1050	303
1100	286
1150	268
1200	248
1250	225
1300	200

Head grid line below curve	Distance up to curve
560	9.9791
560	1.3694
520	27.047
520	16.6482
520	4.8366
480	28.8497
480	16.1588
480	3.6948
440	26.4232
440	13.5642
440	1.8185
400	26.2722
400	17.187
400	9.6728
400	1.6672
360	26.9554
360	16.1546
360	4.385
320	27.2322
320	13.4926
280	35.0909
280	20.6923
280	5.5374
240	24.9076
240	6.7714
200	22.4409
160	35.0875

Project: North Central Arizona Water Supply Study
Feature: Pumping Plants
Details: PMP-7
Design Level: Feasibility
By: Alan McCann 06/14/2016
Checked: Matthew Shaw 06/21/2016

Grid Scale

Flow: 2.5 gpm
 Head: 30 ft

Distance

32.6763

PUMP CURVE	
Flow (gpm)	Head (ft)
0	492
2.5	485
5	481
7.5	478
10	475
12.5	470
15	466
17.5	459
20	450
22.5	440
25	429
27.5	415
30	399
32.5	380
35	359
37.5	337
40	314
42.5	290
45	265
47.5	238
50	210

Head grid line below curve	Distance up to curve
480	12.7552
480	5.6514
480	1.0609
450	30.8013
450	26.7362
450	22.0841
450	17.0978
450	9.9244
450	0.3591
420	21.8835
420	9.5608
390	27.0519
390	9.4628
360	21.8701
330	32.0586
330	8.049
300	15.5111
270	22.1227
240	27.4448
210	31.033
210	0.1116

Project: North Central Arizona Water Supply Study
Feature: Pumping Plants
Details: Bitter Springs Turnout Booster Pumping Plant
Design Level: Feasibility
By: Alan McCann 06/14/2016
Checked: Matthew Shaw 06/21/2016

Grid Scale

Flow: 25 gpm
 Head: 45 ft

Distance

31.7312

PUMP CURVE	
Flow (gpm)	Head (ft)
0	781
25	773
50	765
75	756
100	747
125	738
150	731
175	723
200	717
225	710
250	702
275	695
300	686
325	675
350	663
375	647
400	630
425	611
450	591
475	569
500	546
525	522
550	495
575	469
600	440
625	410
650	380
675	349
700	317
725	284
750	252

Rev ->

Head grid line below curve	Distance up to curve
765	11.3509
765	5.9137
720	31.5062
720	25.3206
720	19.1505
720	13.0185
720	7.7988
720	2.3221
675	29.9372
675	24.9834
675	19.3622
675	13.9974
675	7.7849
675	0.1143
630	22.9676
630	12.0925
585	31.5447
585	18.0783
585	4.1327
540	20.4782
540	4.1631
495	18.8205
495	0.3099
450	13.0865
405	24.8581
405	3.8286
360	14.1732
315	23.887
315	1.1816
270	10.1577
225	18.8702

Project: North Central Arizona Water Supply Study
Feature: Pumping Plants
Details: Cedar Ridge Turnout Booster Pumping Plant
Design Level: Feasibility
By: Alan McCann 06/14/2016
Checked: Matthew Shaw 06/21/2016

Grid Scale

Flow: 10 gpm
 Head: 12.5 ft

Distance

30.6921

PUMP CURVE	
Flow (gpm)	Head (ft)
0	205
10	203
20	201
30	198
40	195
50	192
60	188
70	184
80	180
90	175
100	169
110	163
120	155
130	147
140	138
150	128
160	117
170	105
180	92
190	77

Head grid line below curve	Distance up to curve
200	12.7736
200	8.3443
200	1.4385
187.5	25.8611
187.5	18.8996
187.5	10.7162
187.5	2.362
175	23.126
175	11.2858
162.5	29.95
162.5	15.3252
162.5	0.0684
150	13.0435
137.5	23.9472
137.5	2.0265
125	8.1062
112.5	11.9084
100	12.4151
87.5	9.914
75	4.5208

Project: North Central Arizona Water Supply Study
Feature: Pumping Plants
Details: Copermine Turnout Booster Pumping Plant
Design Level: Feasibility
By: Alan McCann 06/14/2016
Checked: Matthew Shaw 06/21/2016

Grid Scale

Flow: 25 gpm
 Head: 12.5 ft

Distance

30.3177

PUMP CURVE	
Flow (gpm)	Head (ft)
0	188
25	184
50	181
75	178
100	175
125	172
150	169
175	166
200	162
225	158
250	153
275	148
300	143
325	136
350	130
375	122
400	114
425	104
450	95
475	85
500	74
525	62
550	50

Head grid line below curve	Distance up to curve
187.5	0.589
175	21.8588
175	14.7956
175	7.3516
175	0.5145
162.5	23.8213
162.5	16.7313
162.5	8.0287
150	29.289
150	18.6338
150	6.8557
137.5	25.879
137.5	12.7488
125	27.5181
125	11.1423
112.5	22.4702
112.5	2.5716
100	10.8744
87.5	17.5115
75	23.2598
62.5	26.8197
50	28.5861
37.5	29.4085

Project: North Central Arizona Water Supply Study
Feature: Pumping Plants
Details: Hopi 1 Pumping Plant
Design Level: Feasibility
By: Alan McCann 06/14/2016
Checked: Matthew Shaw 06/21/2016

Grid Scale

Flow: 250 gpm
 Head: 20 ft

Distance

30.9196

PUMP CURVE	
Flow (gpm)	Head (ft)
0	302
250	292
500	282
750	272
1000	260
1250	248
1500	237
1750	226
2000	220
2250	217
2500	212
2750	203
3000	191
3250	177
3500	160
3750	143
4000	125
4250	107

Head grid line below curve	Distance up to curve
300	3.6528
280	18.5765
280	3.0138
260	17.9197
260	0.4181
240	13.119
220	26.0571
220	9.8937
200	30.6666
200	25.9206
200	17.9391
200	3.9387
180	16.8541
160	25.8432
160	0.6346
140	4.7994
120	8.3427
100	10.8734

Project: North Central Arizona Water Supply Study
Feature: Pumping Plants
Details: Hopi 2 Pumping Plant
Design Level: Feasibility
By: Alan McCann 06/14/2016
Checked: Matthew Shaw 06/21/2016

Grid Scale

Flow: 100 gpm
 Head: 45 ft

Distance

32.2048

PUMP CURVE	
Flow (gpm)	Head (ft)
0	692
100	675
200	663
300	652
400	642
500	632
600	622
700	611
800	600
900	592
1000	584
1100	570
1200	550
1300	527
1400	501
1500	472
1600	441
1700	409
1800	375
1900	340
2000	304
2100	267

Head grid line below curve	Distance up to curve
675	11.8406
675	0.1111
630	23.2858
630	15.9683
630	8.4693
630	1.4356
585	26.2657
585	18.6412
585	11.0688
585	5.3574
540	31.7263
540	21.3453
540	7.4518
495	23.1984
495	4.1109
450	15.7061
405	25.8908
405	2.7281
360	10.5534
315	17.9951
270	24.573
225	30.2063

Project: North Central Arizona Water Supply Study
Feature: Pumping Plants
Details: Hopi 3 Pumping Plant
Design Level: Feasibility
By: Alan McCann 06/14/2016
Checked: Matthew Shaw 06/21/2016

Grid Scale

Flow: 100 gpm
 Head: 40 ft

Distance

34.4868

PUMP CURVE	
Flow (gpm)	Head (ft)
0	560
100	548
200	539
300	530
400	521
500	513
600	504
700	495
800	487
900	480
1000	473
1100	461
1200	444
1300	425
1400	403
1500	379
1600	353
1700	326
1800	298
1900	269
2000	239
2100	208

Head grid line below curve	Distance up to curve
560	0.3434
520	24.1892
520	16.06
520	8.5154
520	1.2663
480	28.1317
480	20.7931
480	13.0956
480	6.2731
440	34.1957
440	28.7589
440	17.935
440	3.8155
400	21.7688
400	2.5377
360	16.2367
320	28.3601
320	4.8405
280	15.878
240	25.378
200	33.6124
200	6.9596

Project: North Central Arizona Water Supply Study
Feature: Pumping Plants
Details: Hopi 4 Pumping Plant
Design Level: Feasibility
By: Alan McCann 06/14/2016
Checked: Matthew Shaw 06/21/2016

Grid Scale

Flow: 100 gpm
 Head: 40 ft

Distance

25.0213

PUMP CURVE	
Flow (gpm)	Head (ft)
0	562
100	549
200	540
300	531
400	520
500	514
600	506
700	497
800	488
900	481
1000	475
1100	462
1200	446
1300	426
1400	404
1500	380
1600	354
1700	327
1800	299
1900	270
2000	240
2100	209

Head grid line below curve	Distance up to curve
560	1.0812
520	18.2875
520	12.5655
520	6.9822
520	0.0134
480	21.3218
480	16.0589
480	10.5558
480	5.0216
480	0.8634
440	21.9937
440	13.9211
440	3.4895
400	16.3031
400	2.5082
360	12.4251
320	21.4626
320	4.2979
280	11.912
240	18.8255
240	0.1529
200	5.5577

Project: North Central Arizona Water Supply Study
Feature: Pumping Plants
Details: Hopi 5 Pumping Plant
Design Level: Feasibility
By: Alan McCann 06/14/2016
Checked: Matthew Shaw 06/18/2016

Grid Scale

Flow: 100 gpm
 Head: 15 ft

Distance

26.1365

PUMP CURVE	
Flow (gpm)	Head (ft)
0	222
100	218
200	214
300	210
400	207
500	204
600	200
700	196
800	193
900	190
1000	187
1100	182
1200	175
1300	167
1400	158
1500	148
1600	137
1700	126
1800	115
1900	103
2000	91
2100	78

Head grid line below curve	Distance up to curve
210	13.968
210	7.3003
210	0.7451
195	20.9637
195	15.1685
195	9.1126
195	2.5699
180	22.9733
180	17.8603
180	12.165
180	3.073
165	17.7694
165	3.9135
150	14.102
135	23.1224
135	4.3353
120	11.2465
105	17.4696
90	22.618
90	1.2848
75	5.0897

Project: North Central Arizona Water Supply Study
Feature: Pumping Plants
Details: Hopi 6 Pumping Plant
Design Level: Feasibility
By: Alan McCann 06/14/2016
Checked: Matthew Shaw 06/18/2016

Grid Scale

Flow: 100 gpm
 Head: 15 ft

Distance

29.9259

PUMP CURVE	
Flow (gpm)	Head (ft)
0	218
100	213
200	210
300	206
400	203
500	199
600	196
700	192
800	189
900	186
1000	183
1100	178
1200	171
1300	163
1400	154
1500	144
1600	133
1700	122
1800	111
1900	99
2000	87
2100	74

Head grid line below curve	Distance up to curve
210	15.5698
210	6.9107
195	29.6838
195	22.2246
195	15.4527
195	8.3442
195	1.6419
180	24.7623
180	18.3721
180	12.6724
180	5.9642
165	26.4391
165	12.2143
150	26.1924
150	7.5098
135	17.5344
120	26.5668
120	4.3579
105	11.2665
90	17.4544
75	23.0877
60	27.1702

Project: North Central Arizona Water Supply Study
Feature: Pumping Plants
Details: Hopi 7 Pumping Plant
Design Level: Feasibility
By: Alan McCann 06/14/2016
Checked: Matthew Shaw 06/18/2016

Grid Scale

Flow: 100 gpm
 Head: 15 ft

Distance

18.5377

PUMP CURVE	
Flow (gpm)	Head (ft)
0	211
100	207
200	203
300	200
400	197
500	193
600	190
700	186
800	183
900	181
1000	177
1100	172
1200	165
1300	157
1400	148
1500	138
1600	127
1700	116
1800	105
1900	93
2000	81

Head grid line below curve	Distance up to curve
210	1.3544
195	14.8316
195	10.3973
195	5.9307
195	2.0662
180	16.2671
180	12.2958
180	7.9887
180	4.3159
180	0.8451
165	14.9489
165	8.8068
165	0.018
150	8.6322
135	15.94
135	3.4758
120	9.0787
105	13.8248
90	18.3411
90	3.8095
75	7.2625

Project: North Central Arizona Water Supply Study
Feature: Pumping Plants
Details: Hopi 8 Pumping Plant
Design Level: Feasibility
By: Alan McCann 06/14/2016
Checked: Matthew Shaw 06/18/2016

Grid Scale

Flow: 100 gpm
 Head: 40 ft

Distance

8.7896

PUMP CURVE	
Flow (gpm)	Head (ft)
0	505
100	499
200	496
300	493
400	492
500	490
600	488
700	483
800	477
900	469
1000	456
1100	441
1200	421
1300	398
1400	370
1500	338
1600	301
1700	260

Head grid line below curve	Distance up to curve
480	5.5179
480	4.1776
480	3.4632
480	2.8406
480	2.6426
480	2.1034
480	1.7093
480	0.5591
440	8.1967
440	6.2861
440	3.4564
440	0.1184
400	4.6771
360	8.303
360	2.2677
320	3.9244
280	4.6115
240	4.3465

Project: North Central Arizona Water Supply Study
Feature: Pumping Plants
Details: Hopi 9 Pumping Plant
Design Level: Feasibility
By: Alan McCann 06/14/2016
Checked: Matthew Shaw 06/18/2016

Grid Scale

Flow: 50 gpm
 Head: 30 ft

Distance

2.9374

PUMP CURVE	
Flow (gpm)	Head (ft)
0	432
50	430
100	429
150	427
200	426
250	425
300	424
350	422
400	420
450	418
500	415
550	410
600	405
650	399
700	391
750	383
800	373
850	361
900	349
950	336
1000	320
1050	304
1100	287
1150	269
1200	250
1250	231
1300	210
1350	190

Head grid line below curve	Distance up to curve
420	1.1677
420	0.98
420	0.8401
420	0.6492
420	0.6045
420	0.4592
420	0.3613
420	0.1764
390	2.9368
390	2.7598
390	2.4034
390	1.9458
390	1.4881
390	0.8376
390	0.1085
360	2.2055
360	1.2515
360	0.1429
330	1.8793
330	0.5477
300	2.0055
300	0.4125
270	1.7054
240	2.8824
240	1.0203
210	2.0258
210	0.0378
180	0.9666

Project: North Central Arizona Water Supply Study
Feature: Pumping Plants
Details: Hopi 10 Pumping Plant
Design Level: Feasibility
By: Alan McCann 06/14/2016
Checked: Matthew Shaw 06/18/2016

Grid Scale

Flow: 25 gpm
 Head: 40 ft

Distance

1.4664

PUMP CURVE	
Flow (gpm)	Head (ft)
0	722.6
25	717.3
50	709.6
75	703.6
100	698.6
125	691.5
150	684.7
175	677.0
200	667.3
225	656.3
250	642.2
275	625.6
300	607.3
325	586.2
350	560.9
375	534.2
400	504.7
425	472.4
450	436.9
475	400.0
500	360.4
525	319.2

Head grid line below curve	Distance up to curve
720	0.0966
680	1.3681
680	1.0839
680	0.8649
680	0.6804
680	0.4219
680	0.1731
640	1.3563
640	1
640	0.5988
640	0.0792
600	0.9372
600	0.2671
560	0.962
560	0.0346
520	0.5193
480	0.9041
440	1.189
400	1.354
400	0.0014
360	0.0152
280	1.4375

Project: North Central Arizona Water Supply Study
Feature: Pumping Plants
Details: Hotevilla Booster Pumping Plant
Design Level: Feasibility
By: Alan McCann 06/14/2016
Checked: Matthew Shaw 06/18/2016

Grid Scale

Flow: 50 gpm
 Head: 10 ft

Distance

28.0471

PUMP CURVE	
Flow (gpm)	Head (ft)
0	147
50	144
100	142
150	140
200	139
250	137
300	136
350	135
400	134
450	132
500	131
550	129
600	127
650	125
700	123
750	120
800	116
850	111
900	106
950	101
1000	95
1050	88
1100	82
1150	75
1200	68
1250	61
1300	53
1350	45
1400	36

Head grid line below curve	Distance up to curve
140	19.9859
140	12.52
140	5.5871
140	0.4102
130	24.3638
130	20.1469
130	17.0848
130	13.4012
130	10.4909
130	6.6995
130	1.9232
120	25.1731
120	18.9955
120	13.1712
120	7.6589
110	27.0533
110	16.4217
110	3.4298
100	17.3804
100	1.6095
90	13.2765
80	23.5504
80	5.5199
70	14.6548
60	22.7954
60	2.1771
50	8.6797
40	14.0789
30	18.0002

Project: North Central Arizona Water Supply Study
Feature: Pumping Plants
Details: Orabi Spur Booster Pumping Plant
Design Level: Feasibility
By: Alan McCann 06/14/2016
Checked:

Grid Scale

Flow: 2.5 gpm
 Head: 2 ft

Distance

30.6493

PUMP CURVE	
Flow (gpm)	Head (ft)
0	30
2.5	30
5	29
7.5	29
10	29
12.5	29
15	28
17.5	28
20	28
22.5	27
25	27
27.5	27
30	27
32.5	26
35	26
37.5	26
40	25
42.5	25
45	25
47.5	24
50	24
52.5	24
55	23
57.5	22
60	22
62.5	21
65	20
67.5	19
70	18
72.5	17
75	16
77.5	15

Head grid line below curve	Distance up to curve
28	24.4333
28	24.5247
28	20.7179
28	16.9405
28	12.74
28	8.6522
28	4.3301
28	0.1294
26	26.3642
26	22.2319
26	17.8095
26	13.5553
26	9.2223
26	4.7981
26	0.4354
24	26.7748
24	22.2285
24	17.6264
24	12.7372
24	7.3882
24	1.0307
22	24.316
22	15.2775
22	5.0935
20	24.6721
20	12.1818
18	29.8362
18	16.1336
18	1.7339
16	17.9503
16	1.87703
14	17.434

80	14
82.5	13
85	12

14	1.485
12	15.9097
10	30.4668

Project: North Central Arizona Water Supply Study
Feature: Pumping Plants
Details: Shungopavi Booster Pumping Plant
Design Level: Feasibility
By: Alan McCann 06/14/2016
Checked: Matthew Shaw 06/18/2016

Grid Scale

Flow: 25 gpm
 Head: 20 ft

Distance


30.5191

PUMP CURVE	
Flow (gpm)	Head (ft)
0	263
25	261
50	258
75	255
100	252
125	249
150	247
175	245
200	243
225	241
250	238
275	235
300	231
325	227
350	223
375	217
400	211
425	204
450	197
475	189
500	180
525	171
550	162
575	153
600	143
625	132
650	122
675	111
700	100
725	89
750	78

Head grid line below curve	Distance up to curve
260	5.1544
260	1.8473
240	27.9249
240	22.7658
240	18.1624
240	14.1004
240	10.569
240	7.987
240	4.5863
240	1.1346
220	26.8384
220	23.2545
220	17.5421
220	11.3516
220	4.5974
200	26.5185
200	16.7322
200	5.9881
180	25.9812
180	13.7856
180	0.7119
160	17.5386
160	3.6868
140	19.6685
140	3.9079
120	18.9952
120	2.5413
100	16.5277
80	30.1742
80	13.7577
60	27.2681

Project:	North Central Arizona Water Supply Study	
Feature:	Pumping Plants	
Details:	PMP-2	
Design Level:	Feasibility	
Number of Active Pumps:	4	
Number of Spare Pumps:	1	
Pump Selection:	Weir-Floway	20MKL
Speed	1775	RPM
Number of Stages:	4	
Rated Flow:	5611.44 gpm	12.5 cfs
Flow Includes a Wear Factor of:	3%	
Rated Total Head:	579 ft	250 psi
Shutoff Head:	913 ft	400 psi
Brake Horsepower:	1010 hp	
Pump Weight:	8300 lbs	
Motor Horsepower:	1250 hp	
Motor Speed:	1800 RPM	Fixed Induction
Motor Voltage:	4160 V	
Motor Enclosure:	WP-II	
Motor Frame:	US Motors 6808P	
Motor Efficiency:	Premium	
Motor Weight:	8500 lbs	
Total Unit Dry Weight (Each):	16800 lbs	


Feature	Letter	Dim (in.)		Feature	Letter	Dim (in.)
Motor	AB	40.8125		Can	BL	152.75
Motor	AG	87.5625		Can	BN	13
Motor	BD	30.5		Can	BP	25.5
Motor	P	42.5		Can	BS	36
Discharge Head	DD	25		Can	BV	48
Discharge Head	DF	16		Can	BY	1.75
Discharge Head	DH	17		Stage	A	11.75
Discharge Head	H	43		Stage	B	14.625
Discharge Head	SF	24		Stage	E	20
Pedestal	C	14		Stage	S	6
				Stage	T	21
				Stage	W	9.5



Estimated By _Matthew Shaw_05/23/2016_
 CHECKED _Alan McCann_05/24/2016_

Project:	North Central Arizona Water Supply Study	
Feature:	Pumping Plants	
Details:	PMP-3	
Design Level:	Feasibility	
Number of Active Pumps:	4	
Number of Spare Pumps:	1	
Pump Selection:	Weir-Floway	18MKH
Speed	1755	RPM
Number of Stages:	5	
Rated Flow:	4624.7 gpm	10.3 cfs
Flow Includes a Wear Factor of:	3%	
Rated Total Head:	554 ft	240 psi
Shutoff Head:	847.7 ft	370 psi
Brake Horsepower:	780 hp	
Pump Weight:	6900 lbs	
Motor Horsepower:	900 hp	
Motor Speed:	1800 RPM	Fixed Induction
Motor Voltage:	4160 V	
Motor Enclosure:	WP-II	
Motor Frame:	US Motors 5012P	
Motor Efficiency:	Premium	
Motor Weight:	5900 lbs	
Total Unit Dry Weight (Each):	12800 lbs	


Feature	Letter	Dim (in.)		Feature	Letter	Dim (in.)
Motor	AB	36.5		Can	BL	151.5
Motor	AG	78.88		Can	BN	10
Motor	BD	24.5		Can	BP	21
Motor	P	71		Can	BS	30
Discharge Head	DD	21		Can	BV	40
Discharge Head	DF	16		Can	BY	1.5
Discharge Head	DH	21		Stage	A	10.5
Discharge Head	H	62		Stage	B	12.5
Discharge Head	SF	20		Stage	E	17.375
Pedestal	C	10		Stage	S	9.5
				Stage	T	21
				Stage	W	8.5



Estimated By Matthew Shaw 06/06/2016
 CHECKED Alan McCann 06/06/2016

Project:	North Central Arizona Water Supply Study	
Feature:	Pumping Plants	
Details:	PMP-4	
Design Level:	Feasibility	
Number of Active Pumps:	3	
Number of Spare Pumps:	1	
Pump Selection:	Weir-Floway	18MKH
Speed	1755	RPM
Number of Stages:	5	
Rated Flow:	4922.37 gpm	10.97 cfs
Flow Includes a Wear Factor of:	3%	
Rated Total Head:	620.5 ft	270 psi
Shutoff Head:	966.8 ft	420 psi
Brake Horsepower:	930 hp	
Pump Weight:	6900 lbs	
Motor Horsepower:	1000 hp	
Motor Speed:	1800 RPM	Fixed Induction
Motor Voltage:	4160 V	
Motor Enclosure:	WP-II	
Motor Frame:	US Motors 5012P	
Motor Efficiency:	Premium	
Motor Weight:	5900 lbs	
Total Unit Dry Weight (Each):	12800 lbs	


Feature	Letter	Dim (in.)		Feature	Letter	Dim (in.)
Motor	AB	36.5		Can	BL	151.5
Motor	AG	78.88		Can	BN	10
Motor	BD	24.5		Can	BP	21
Motor	P	71		Can	BS	30
Discharge Head	DD	21		Can	BV	40
Discharge Head	DF	16		Can	BY	1.5
Discharge Head	DH	21		Stage	A	10.5
Discharge Head	H	62		Stage	B	12.5
Discharge Head	SF	20		Stage	E	17.375
Pedestal	C	11		Stage	S	9.5
				Stage	T	21
				Stage	W	8.5



Estimated By _ Matthew Shaw 06/06/2016
CHECKED _ Alan McCann 06/06/2016

Project:	North Central Arizona Water Supply Study	
Feature:	Pumping Plants	
Details:	Bitter Springs	
Design Level:	Feasibility	
Number of Active Pumps:	1	
Number of Spare Pumps:	1	
Pump Selection:	Weir-Floway	10JKL
Speed	1770	RPM
Number of Stages:	14	
Rated Flow:	457.32 gpm	1.02 cfs
Flow Includes a Wear Factor of:	3%	
Rated Total Head:	584 ft	250 psi
Shutoff Head:	780.7 ft	340 psi
Brake Horsepower:	90 hp	
Pump Weight:	2700 lbs	
Motor Horsepower:	100 hp	
Motor Speed:	1800 RPM	Fixed Induction
Motor Voltage:	460 V	
Motor Enclosure:	WP-I	
Motor Frame:	GE L404TP16	
Motor Efficiency:	Premium	
Motor Weight:	1560 lbs	
Total Unit Dry Weight (Each):	4260 lbs	


Feature	Letter	Dim (in.)		Feature	Letter	Dim (in.)
Motor	AB	19.68		Can	BL	203.5
Motor	AG	45.26		Can	BN	11.25
Motor	BD	16.5		Can	BP	17.75
Motor	P	28.02		Can	BS	14
Discharge Head	DD	12		Can	BV	23
Discharge Head	DF	6		Can	BY	1.25
Discharge Head	DH	12		Stage	A	8
Discharge Head	H	29		Stage	B	8.5
Discharge Head	SF	8		Stage	E	9.8125
Pedestal	C	10		Stage	S	7.5
				Stage	T	9.375
				Stage	W	5.25



Estimated By _Alan McCann_ 06/07/2016 _
CHECKED _Matthew Shaw_ 06/17/2016 _

Project:	North Central Arizona Water Supply Study	
Feature:	Pumping Plants	
Details:	Cedar Ridge Turnout Booster	
Design Level:	Feasibility	
Number of Active Pumps:	1	
Number of Spare Pumps:	1	
Pump Selection:	Weir-Floway	6JKH
Speed	1760	RPM
Number of Stages:	10	
Rated Flow:	139.05 gpm	0.31 cfs
Flow Includes a Wear Factor of:	3%	
Rated Total Head:	139 ft	60 psi
Shutoff Head:	205.2 ft	90 psi
Brake Horsepower:	6.8 hp	
Pump Weight:	1200 lbs	
Motor Horsepower:	7.5 hp	
Motor Speed:	1800 RPM	Fixed Induction
Motor Voltage:	460 V	
Motor Enclosure:	WP-I	
Motor Frame:	GE L213TP10	
Motor Efficiency:	Premium	
Motor Weight:	172 lbs	
Total Unit Dry Weight (Each):	1372 lbs	


Feature	Letter	Dim (in.)		Feature	Letter	Dim (in.)
Motor	AB	9.41		Can	BL	128.4375
Motor	AG	22.44		Can	BN	6.875
Motor	BD	10		Can	BP	11.625
Motor	P	14.78		Can	BS	10.75
Discharge Head	DD	10		Can	BV	18
Discharge Head	DF	4		Can	BY	1.25
Discharge Head	DH	10		Stage	A	8.75
Discharge Head	H	27		Stage	B	5
Discharge Head	SF	6		Stage	E	5.875
Pedestal	C	12		Stage	S	3.375
				Stage	T	5.8125
				Stage	W	2.8125



Estimated By Alan McCann 06/07/2016
CHECKED Matthew Shaw 06/15/2016

Project:	North Central Arizona Water Supply Study	
Feature:	Pumping Plants	
Details:	Coppermine Turnout Booster	
Design Level:	Feasibility	
Number of Active Pumps:	1	
Number of Spare Pumps:	1	
Pump Selection:	Weir-Floway	8JKH
Speed	1760	RPM
Number of Stages:	5	
Rated Flow:	351.23 gpm	0.78 cfs
Flow Includes a Wear Factor of:	3%	
Rated Total Head:	128.97 ft	60 psi
Shutoff Head:	188 ft	80 psi
Brake Horsepower:	14.9 hp	
Pump Weight:	1500 lbs	
Motor Horsepower:	20 hp	
Motor Speed:	1800 RPM	Fixed Induction
Motor Voltage:	460 V	
Motor Enclosure:	WP-I	
Motor Frame:	GE L256TP10	
Motor Efficiency:	Premium	
Motor Weight:	315 lbs	
Total Unit Dry Weight (Each):	1815 lbs	


Feature	Letter	Dim (in.)		Feature	Letter	Dim (in.)
Motor	AB	11.4		Can	BL	114.75
Motor	AG	26.72		Can	BN	8
Motor	BD	10		Can	BP	13.75
Motor	P	17.2		Can	BS	14
Discharge Head	DD	12		Can	BV	23
Discharge Head	DF	6		Can	BY	1.25
Discharge Head	DH	10		Stage	A	7.375
Discharge Head	H	27		Stage	B	7.25
Discharge Head	SF	6		Stage	E	7.75
Pedestal	C	12		Stage	S	4.5
				Stage	T	7.75
Note: Discharge Head	BD	12		Stage	W	3.125



Estimated By Alan McCann_06/07/2016
CHECKED Matthew Shaw_06/15/2016

Project:	North Central Arizona Water Supply Study	
Feature:	Pumping Plants	
Details:	Hopi 1	
Design Level:	Feasibility	
Number of Active Pumps:	4	
Number of Spare Pumps:	1	
Pump Selection:	Weir-Floway	16DKL
Speed	1770	RPM
Number of Stages:	2	
Rated Flow:	3066.31 gpm	6.83 cfs
Flow Includes a Wear Factor of:	3%	
Rated Total Head:	187 ft	80 psi
Shutoff Head:	302.1 ft	130 psi
Brake Horsepower:	180 hp	
Pump Weight:	3400 lbs	
Motor Horsepower:	200 hp	
Motor Speed:	1800 RPM	Fixed Induction
Motor Voltage:	460 V	
Motor Enclosure:	WP-I	
Motor Frame:	GE L445TP20	
Motor Efficiency:	Premium	
Motor Weight:	1890 lbs	
Total Unit Dry Weight (Each):	5290 lbs	


Feature	Letter	Dim (in.)		Feature	Letter	Dim (in.)
Motor	AB	20.94		Can	BL	117.875
Motor	AG	53.44		Can	BN	11.5
Motor	BD	16.5		Can	BP	20
Motor	P	31.44		Can	BS	24
Discharge Head	DD	20		Can	BV	34
Discharge Head	DF	12		Can	BY	1.5
Discharge Head	DH	14		Stage	A	10
Discharge Head	H	46		Stage	B	14.875
Discharge Head	SF	20		Stage	E	16
Pedestal	C	14		Stage	S	8.0625
				Stage	T	17.375
				Stage	W	6.625



Estimated By Alan McCann 06/07/2016
 CHECKED Matthew Shaw 06/14/2016

Project:	North Central Arizona Water Supply Study	
Feature:	Pumping Plants	
Details:	Hopi 2	
Design Level:	Feasibility	
Number of Active Pumps:	3	
Number of Spare Pumps:	1	
Pump Selection:	Weir-Floway	14JKL
Speed	1770	RPM
Number of Stages:	6	
Rated Flow:	1397.71 gpm	3.11 cfs
Flow Includes a Wear Factor of:	3%	
Rated Total Head:	501 ft	220 psi
Shutoff Head:	690.4 ft	300 psi
Brake Horsepower:	210 hp	
Pump Weight:	3800 lbs	
Motor Horsepower:	250 hp	
Motor Speed:	1800 RPM	Fixed Induction
Motor Voltage:	460 V	
Motor Enclosure:	WP-I	
Motor Frame:	GE L447TP20	
Motor Efficiency:	Premium	
Motor Weight:	2580 lbs	
Total Unit Dry Weight (Each):	6380 lbs	


Feature	Letter	Dim (in.)		Feature	Letter	Dim (in.)
Motor	AB	20.94		Can	BL	163.25
Motor	AG	61.94		Can	BN	11.75
Motor	BD	20		Can	BP	20
Motor	P	31.44		Can	BS	20
Discharge Head	DD	16		Can	BV	29
Discharge Head	DF	10		Can	BY	1.5
Discharge Head	DH	15		Stage	A	10
Discharge Head	H	37		Stage	B	12.5
Discharge Head	SF	12		Stage	E	14.0625
Pedestal	C	11		Stage	S	7.75
				Stage	T	13.0625
				Stage	W	6.5



Estimated By Alan McCann 06/07/2016
 CHECKED Matthew Shaw 06/14/2016

Project:	North Central Arizona Water Supply Study	
Feature:	Pumping Plants	
Details:	Hopi 4	
Design Level:	Feasibility	
Number of Active Pumps:	3	
Number of Spare Pumps:	1	
Pump Selection:	Weir-Floway	14JKL
Speed	1770	RPM
Number of Stages:	5	
Rated Flow:	1397.71 gpm	3.11 cfs
Flow Includes a Wear Factor of:	3%	
Rated Total Head:	404 ft	170 psi
Shutoff Head:	561.2 ft	240 psi
Brake Horsepower:	170 hp	
Pump Weight:	3600 lbs	
Motor Horsepower:	200 hp	
Motor Speed:	1800 RPM	Fixed Induction
Motor Voltage:	460 V	
Motor Enclosure:	WP-I	
Motor Frame:	GE L445TP20	
Motor Efficiency:	Premium	
Motor Weight:	1890 lbs	
Total Unit Dry Weight (Each):	5490 lbs	


Feature	Letter	Dim (in.)		Feature	Letter	Dim (in.)
Motor	AB	20.94		Can	BL	150.75
Motor	AG	53.44		Can	BN	11.75
Motor	BD	16.5		Can	BP	20
Motor	P	31.44		Can	BS	20
Discharge Head	DD	16		Can	BV	29
Discharge Head	DF	10		Can	BY	1.5
Discharge Head	DH	15		Stage	A	10
Discharge Head	H	37		Stage	B	12.5
Discharge Head	SF	12		Stage	E	14.0625
Pedestal	C	11		Stage	S	7.75
				Stage	T	13.0625
				Stage	W	6.5



Estimated By Alan McCann 06/07/2016
 CHECKED Matthew Shaw 06/08/2016

Project:	North Central Arizona Water Supply Study	
Feature:	Pumping Plants	
Details:	Hopi 5	
Design Level:	Feasibility	
Number of Active Pumps:	3	
Number of Spare Pumps:	1	
Pump Selection:	Weir-Floway	14JKL
Speed	1770	RPM
Number of Stages:	2	
Rated Flow:	1332.82 gpm	2.97 cfs
Flow Includes a Wear Factor of:	3%	
Rated Total Head:	164 ft	70 psi
Shutoff Head:	222.4 ft	100 psi
Brake Horsepower:	70 hp	
Pump Weight:	2900 lbs	
Motor Horsepower:	75 hp	
Motor Speed:	1800 RPM	Fixed Induction
Motor Voltage:	460 V	
Motor Enclosure:	WP-I	
Motor Frame:	GE L365TP16	
Motor Efficiency:	Premium	
Motor Weight:	1060 lbs	
Total Unit Dry Weight (Each):	3960 lbs	


Feature	Letter	Dim (in.)		Feature	Letter	Dim (in.)
Motor	AB	15.36		Can	BL	113.25
Motor	AG	40.21		Can	BN	11.75
Motor	BD	16.5		Can	BP	20
Motor	P	25.38		Can	BS	20
Discharge Head	DD	16		Can	BV	29
Discharge Head	DF	10		Can	BY	1.5
Discharge Head	DH	15		Stage	A	10
Discharge Head	H	37		Stage	B	12.5
Discharge Head	SF	12		Stage	E	14.0625
Pedestal	C	11		Stage	S	7.75
				Stage	T	13.0625
				Stage	W	6.5



Estimated By Alan McCann 06/07/2016
 CHECKED Matthew Shaw 06/08/2016

Project:	North Central Arizona Water Supply Study	
Feature:	Pumping Plants	
Details:	Hopi 6	
Design Level:	Feasibility	
Number of Active Pumps:	3	
Number of Spare Pumps:	1	
Pump Selection:	Weir-Floway	14JKL
Speed	1770	RPM
Number of Stages:	2	
Rated Flow:	1332.82 gpm	2.97 cfs
Flow Includes a Wear Factor of:	3%	
Rated Total Head:	160 ft	70 psi
Shutoff Head:	218 ft	90 psi
Brake Horsepower:	70 hp	
Pump Weight:	2900 lbs	
Motor Horsepower:	75 hp	
Motor Speed:	1800 RPM	Fixed Induction
Motor Voltage:	460 V	
Motor Enclosure:	WP-I	
Motor Frame:	GE L365TP16	
Motor Efficiency:	Premium	
Motor Weight:	1060 lbs	
Total Unit Dry Weight (Each):	3960 lbs	


Feature	Letter	Dim (in.)		Feature	Letter	Dim (in.)
Motor	AB	15.36		Can	BL	113.25
Motor	AG	40.21		Can	BN	11.75
Motor	BD	16.5		Can	BP	20
Motor	P	25.38		Can	BS	20
Discharge Head	DD	16		Can	BV	29
Discharge Head	DF	10		Can	BY	1.5
Discharge Head	DH	15		Stage	A	10
Discharge Head	H	37		Stage	B	12.5
Discharge Head	SF	12		Stage	E	14.0625
Pedestal	C	11		Stage	S	7.75
				Stage	T	13.0625
				Stage	W	6.5



Estimated By Alan McCann 06/07/2016
 CHECKED Matthew Shaw 06/08/2016

Project:	North Central Arizona Water Supply Study	
Feature:	Pumping Plants	
Details:	Hopi 7	
Design Level:	Feasibility	
Number of Active Pumps:	3	
Number of Spare Pumps:	1	
Pump Selection:	Weir-Floway	14JKL
Speed	1770	RPM
Number of Stages:	2	
Rated Flow:	1332.82 gpm	2.97 cfs
Flow Includes a Wear Factor of:	3%	
Rated Total Head:	154 ft	70 psi
Shutoff Head:	211.3 ft	90 psi
Brake Horsepower:	60 hp	
Pump Weight:	2900 lbs	
Motor Horsepower:	75 hp	
Motor Speed:	1800 RPM	Fixed Induction
Motor Voltage:	460 V	
Motor Enclosure:	WP-I	
Motor Frame:	GE L365TP16	
Motor Efficiency:	Premium	
Motor Weight:	1060 lbs	
Total Unit Dry Weight (Each):	3960 lbs	


Feature	Letter	Dim (in.)		Feature	Letter	Dim (in.)
Motor	AB	15.36		Can	BL	113.25
Motor	AG	40.21		Can	BN	11.75
Motor	BD	16.5		Can	BP	20
Motor	P	25.38		Can	BS	20
Discharge Head	DD	16		Can	BV	29
Discharge Head	DF	10		Can	BY	1.5
Discharge Head	DH	15		Stage	A	10
Discharge Head	H	37		Stage	B	12.5
Discharge Head	SF	12		Stage	E	14.0625
Pedestal	C	11		Stage	S	7.75
				Stage	T	13.0625
				Stage	W	6.5



Estimated By Alan McCann 06/07/2016
 CHECKED Matthew Shaw 06/08/2016

Project:	North Central Arizona Water Supply Study	
Feature:	Pumping Plants	
Details:	Hotevilla Booster Plant	
Design Level:	Feasibility	
Number of Active Pumps:	1	
Number of Spare Pumps:	1	
Pump Selection:	Weir-Floway	12LKM
Speed	1770	RPM
Number of Stages:	2	
Rated Flow:	929.06 gpm	2.07 cfs
Flow Includes a Wear Factor of:	3%	
Rated Total Head:	103 ft	40 psi
Shutoff Head:	147.3 ft	60 psi
Brake Horsepower:	30 hp	
Pump Weight:	1900 lbs	
Motor Horsepower:	40 hp	
Motor Speed:	1800 RPM	Fixed Induction
Motor Voltage:	460 V	
Motor Enclosure:	WP-I	
Motor Frame:	GE L324TP16	
Motor Efficiency:	Premium	
Motor Weight:	700 lbs	
Total Unit Dry Weight (Each):	2600 lbs	


Feature	Letter	Dim (in.)		Feature	Letter	Dim (in.)
Motor	AB	15.36		Can	BL	100.75
Motor	AG	36.93		Can	BN	10
Motor	BD	16.5		Can	BP	16.4375
Motor	P	22.1		Can	BS	18
Discharge Head	DD	15		Can	BV	27
Discharge Head	DF	8		Can	BY	1.25
Discharge Head	DH	13		Stage	A	7
Discharge Head	H	34		Stage	B	9.375
Discharge Head	SF	10		Stage	E	11.625
Pedestal	C	11		Stage	S	6.25
				Stage	T	11.25
				Stage	W	5



Estimated By Alan McCann 06/06/2016
 CHECKED Matthew Shaw 06/07/2016

Project:	North Central Arizona Water Supply Study	
Feature:	Pumping Plants	
Details:	Shungopavi Booster Plant	
Design Level:	Feasibility	
Number of Active Pumps:	1	
Number of Spare Pumps:	1	
Pump Selection:	Weir-Floway	10JKL
Speed	1770	RPM
Number of Stages:	5	
Rated Flow:	503.67 gpm	1.12 cfs
Flow Includes a Wear Factor of:	3%	
Rated Total Head:	179 ft	80 psi
Shutoff Head:	263.5 ft	110 psi
Brake Horsepower:	30 hp	
Pump Weight:	1800 lbs	
Motor Horsepower:	30 hp	
Motor Speed:	1800 RPM	Fixed Induction
Motor Voltage:	460 V	
Motor Enclosure:	WP-I	
Motor Frame:	GE L286TP16	
Motor Efficiency:	Premium	
Motor Weight:	470 lbs	
Total Unit Dry Weight (Each):	2270 lbs	

Feature	Letter	Dim (in.)		Feature	Letter	Dim (in.)
Motor	AB	12.79		Can	BL	127
Motor	AG	29.57		Can	BN	11.25
Motor	BD	16.5		Can	BP	17.75
Motor	P	19.28		Can	BS	14
Discharge Head	DD	12		Can	BV	23
Discharge Head	DF	6		Can	BY	1.25
Discharge Head	DH	12		Stage	A	8
Discharge Head	H	29		Stage	B	8.5
Discharge Head	SF	8		Stage	E	9.8125
Pedestal	C	10		Stage	S	7.5
				Stage	T	9.375
				Stage	W	5.25



Estimated By _ Alan McCann 05/31/2016
 CHECKED _ Matthew Shaw 05/31/2016 _