

Source Name: LAKE BERRYESSA INTAKE

Source #: 001

Chemical	Date	Result	Positive detect?	MCL	Units	Notes
MERCURY	5/17/1999	< 1.00	N	2.00		
METHOXYCHLOR	5/17/1999	< 0.10	N	40.0		
METHYL TERT-BUTYL ETHER (MTBE)	5/17/1999	< 3.00	N	NA		
MONOCHLOROBENZENE	5/17/1999	0.00	N	70.0		
N-BUTYLBENZENE	5/17/1999	0.00	N	NA		
NAPHTHALENE	5/17/1999	0.00	N	NA		
NICKEL	4/20/1998	0.01	N	100		
NICKEL	5/17/1999	< 10.00	N	100		
NITRATE (AS NO3)	4/20/1998	0.00	N	45.0		
NITRATE (AS NO3)	5/17/1999	< 2.00	N	45.0		
NITRITE (N)	4/20/1998	0.00	N	1000		
NITRITE (N)	5/17/1999	< 10.00	N	1000		
O-XYLENE	5/17/1999	0.00	N	1750		
ODOR THRESHOLD @ 60 C	4/20/1998	0.00	N	3.00		
ODOR THRESHOLD @ 60 C	5/17/1999	< 1.00	N	3.00		
OXAMYL	5/17/1999	< 5.00	N	200		
P-ISOPROPYLTOLUENE	5/17/1999	0.00	N	NA		
P-XYLENE	5/17/1999	0.00	N	1750		
PENTACHLOROPHENOL	5/17/1999	< 0.10	N	1.00		
PH (LABORATORY)	4/20/1998	7.90	Y	NA		
PH (LABORATORY)	5/17/1999	8.10	Y	NA		
PICLORAM	5/17/1999	< 1.00	N	500		
POTASSIUM	4/20/1998	0.00	N	NA		
SEC-BUTYLBENZENE	5/17/1999	0.00	N	NA		
SELENIUM	4/20/1998	0.00	N	50.0		
SELENIUM	5/17/1999	< 5.00	N	50.0		
SILVER	4/20/1998	0.00	N	100		
SILVER	5/17/1999	< 10.00	N	100		
SIMAZINE	5/17/1999	< 0.07	N	4.00		
SODIUM	4/20/1998	8.00	Y	NA		
SODIUM	5/17/1999	9.60	Y	NA		
SPECIFIC CONDUCTANCE	4/20/1998	290.00	Y	2200		
SPECIFIC CONDUCTANCE	5/17/1999	330.00	Y	2200		
STYRENE	5/17/1999	0.00	N	100		
SULFATE	4/20/1998	21.00	Y	600		
SULFATE	5/17/1999	24.00	Y	600		
TERT-BUTYLBENZENE	5/17/1999	0.00	N	NA		
TETRACHLOROETHYLENE	5/17/1999	0.00	N	5.00		
THALLIUM	4/20/1998	0.00	N	2.00		
THALLIUM	5/17/1999	< 1.00	N	2.00		
TOLUENE	5/17/1999	0.00	N	150		
TOTAL ALKALINITY (AS CaCO3)	4/20/1998	130.00	Y	NA		
TOTAL ALKALINITY (AS CaCO3)	5/17/1999	130.00	Y	NA		
TOTAL ALPHA	11/26/1993	< 1.00	N	15.0		
TOTAL ALPHA	2/16/1994	0.00	N	15.0		
TOTAL ALPHA	5/25/1994	1.00	N	15.0		
TOTAL ALPHA	5/17/1999	0.82	N	15.0		
TOTAL ALPHA COUNTING ERROR	11/26/1993	1.14	Y	NA		
TOTAL ALPHA COUNTING ERROR	2/16/1994	1.00	Y	NA		
TOTAL ALPHA COUNTING ERROR	5/25/1994	0.80	Y	NA		
TOTAL ALPHA COUNTING ERROR	5/17/1999	0.39	Y	NA		
TOTAL FILTERABLE RESIDUE	4/20/1998	160.00	Y	1500		
TOTAL FILTERABLE RESIDUE	5/17/1999	190.00	Y	1500		
TOTAL HARDNESS (AS CaCO3)	4/20/1998	130.00	Y	NA		
TOTAL HARDNESS (AS CaCO3)	5/17/1999	156.00	Y	NA		
TOTAL TRIHALOMETHANES	5/17/1999	0.00	N	100		
TOXAPHENE	5/17/1999	< 0.50	N	3.00		
TRANS-1,2-DICHLOROETHYLENE	5/17/1999	0.00	N	10.0		

Source Name: LAKE BERRYESSA INTAKE

Source #: 001

Chemical	Date	Result	Positive detect?	MCL	Units	Notes
TRICHLOROETHYLENE	5/17/1999	0.00	N	5.00		
TRICHLOROFLUOROMETHANE	5/17/1999	0.00	N	150		
VINYL CHLORIDE	5/17/1999	0.00	N	.50		
XYLENES (TOTAL)	5/17/1999	0.00	N	1750		
ZINC	4/20/1998	0.00	N	5000		
ZINC	5/17/1999	< 50.00	N	5000		

All Source Chemical Monitoring

Date of report: 7/31/2002

System Name: **Pleasure Cove Resort**

Source Name: **LAKE BERRYESSA INTAKE - RAW**

Source #: **001**

Chemical	Date	Result	Positive detect?	MCL	Units	Notes
1,1,1,2-TETRACHLOROETHANE	10/4/1999	0.00	N	1.00		
1,1,1,2-TETRACHLOROETHANE	10/15/2001	0.00	N	1.00		
1,1,1,2-TETRACHLOROETHANE	3/19/2002	0.00	N	1.00		
1,1,1,2-TETRACHLOROETHANE	6/25/2002	0.00	N	1.00		
1,1,1-TRICHLOROETHANE	10/4/1999	0.00	N	200		
1,1,1-TRICHLOROETHANE	10/15/2001	0.00	N	200		
1,1,1-TRICHLOROETHANE	3/19/2002	0.00	N	200		
1,1,1-TRICHLOROETHANE	6/25/2002	0.00	N	200		
1,1,2,2-TETRACHLOROETHANE	10/4/1999	0.00	N	1.00		
1,1,2,2-TETRACHLOROETHANE	10/15/2001	0.00	N	1.00		
1,1,2,2-TETRACHLOROETHANE	3/19/2002	0.00	N	1.00		
1,1,2,2-TETRACHLOROETHANE	6/25/2002	0.00	N	1.00		
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	10/4/1999	0.00	N	1200		
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	10/15/2001	0.00	N	1200		
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	3/19/2002	0.00	N	1200		
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	6/25/2002	0.00	N	1200		
1,1,2-TRICHLOROETHANE	10/4/1999	0.00	N	5.00		
1,1,2-TRICHLOROETHANE	10/15/2001	0.00	N	5.00		
1,1,2-TRICHLOROETHANE	3/19/2002	0.00	N	5.00		
1,1,2-TRICHLOROETHANE	6/25/2002	0.00	N	5.00		
1,1-DICHLOROETHANE	10/4/1999	0.00	N	5.00	UG/L	
1,1-DICHLOROETHANE	10/15/2001	0.00	N	5.00	UG/L	
1,1-DICHLOROETHANE	3/19/2002	0.00	N	5.00	UG/L	
1,1-DICHLOROETHANE	6/25/2002	0.00	N	5.00	UG/L	
1,1-DICHLOROETHYLENE	10/4/1999	0.00	N	6.00		
1,1-DICHLOROETHYLENE	10/15/2001	0.00	N	6.00		
1,1-DICHLOROETHYLENE	3/19/2002	0.00	N	6.00		
1,1-DICHLOROETHYLENE	6/25/2002	0.00	N	6.00		
1,1-DICHLOROPROPENE	10/4/1999	0.00	N	NA		
1,1-DICHLOROPROPENE	10/15/2001	0.00	N	NA		
1,1-DICHLOROPROPENE	3/19/2002	0.00	N	NA		
1,1-DICHLOROPROPENE	6/25/2002	0.00	N	NA		
1,2,3-TRICHLOROBENZENE	10/4/1999	0.00	N	NA		
1,2,3-TRICHLOROBENZENE	10/15/2001	0.00	N	NA		
1,2,3-TRICHLOROBENZENE	3/19/2002	0.00	N	NA		
1,2,3-TRICHLOROBENZENE	6/25/2002	0.00	N	NA		
1,2,3-TRICHLOROPROPANE	10/4/1999	0.00	N	NA		
1,2,3-TRICHLOROPROPANE	10/15/2001	0.00	N	NA		
1,2,3-TRICHLOROPROPANE	3/19/2002	0.00	N	NA		
1,2,3-TRICHLOROPROPANE	6/25/2002	0.00	N	NA		
1,2,4-TRICHLOROBENZENE	10/4/1999	0.00	N	70.0		
1,2,4-TRICHLOROBENZENE	10/15/2001	0.00	N	70.0		
1,2,4-TRICHLOROBENZENE	3/19/2002	0.00	N	70.0		
1,2,4-TRICHLOROBENZENE	6/25/2002	0.00	N	70.0		
1,2,4-TRIMETHYLBENZENE	10/4/1999	0.00	N	NA		
1,2,4-TRIMETHYLBENZENE	10/15/2001	0.00	N	NA		
1,2,4-TRIMETHYLBENZENE	3/19/2002	0.00	N	NA		
1,2,4-TRIMETHYLBENZENE	6/25/2002	0.00	N	NA		
1,2-DICHLOROBENZENE	10/4/1999	0.00	N	600		

Source Name: LAKE BERRYESSA INTAKE - RAW

Source #: 001

Chemical	Date	Result	Positive detect?	MCL	Units	Notes
1,2-DICHLOROBENZENE	3/19/2002	0.00	N	600		
1,2-DICHLOROBENZENE	6/25/2002	0.00	N	600		
1,2-DICHLOROETHANE	10/4/1999	0.00	N	.50		
1,2-DICHLOROETHANE	10/15/2001	0.00	N	.50		
1,2-DICHLOROETHANE	3/19/2002	0.00	N	.50		
1,2-DICHLOROETHANE	6/25/2002	0.00	N	.50		
1,2-DICHLOROPROPANE	10/4/1999	0.00	N	5.00		
1,2-DICHLOROPROPANE	10/15/2001	0.00	N	5.00		
1,2-DICHLOROPROPANE	3/19/2002	0.00	N	5.00		
1,2-DICHLOROPROPANE	6/25/2002	0.00	N	5.00		
1,3,5-TRIMETHYLBENZENE	10/4/1999	0.00	N	NA		
1,3,5-TRIMETHYLBENZENE	10/15/2001	0.00	N	NA		
1,3,5-TRIMETHYLBENZENE	3/19/2002	0.00	N	NA		
1,3,5-TRIMETHYLBENZENE	6/25/2002	0.00	N	NA		
1,3-DICHLOROBENZENE	10/4/1999	0.00	N	NA		
1,3-DICHLOROBENZENE	10/15/2001	0.00	N	NA		
1,3-DICHLOROBENZENE	3/19/2002	0.00	N	NA		
1,3-DICHLOROBENZENE	6/25/2002	0.00	N	NA		
1,3-DICHLOROPROPANE	10/4/1999	0.00	N	NA		
1,3-DICHLOROPROPANE	10/15/2001	0.00	N	NA		
1,3-DICHLOROPROPANE	3/19/2002	0.00	N	NA		
1,3-DICHLOROPROPANE	6/25/2002	0.00	N	NA		
1,3-DICHLOROPROPENE (TOTAL)	10/4/1999	0.00	N	.50		
1,3-DICHLOROPROPENE (TOTAL)	10/15/2001	0.00	N	.50		
1,3-DICHLOROPROPENE (TOTAL)	3/19/2002	0.00	N	.50		
1,3-DICHLOROPROPENE (TOTAL)	6/25/2002	0.00	N	.50		
1,4-DICHLOROBENZENE	10/4/1999	0.00	N	5.00		
1,4-DICHLOROBENZENE	10/15/2001	0.00	N	5.00		
1,4-DICHLOROBENZENE	3/19/2002	0.00	N	5.00		
1,4-DICHLOROBENZENE	6/25/2002	0.00	N	5.00		
1-PHENYLPROPANE (PROPYLBENZENE)	10/4/1999	0.00	N	NA		
1-PHENYLPROPANE (PROPYLBENZENE)	10/15/2001	0.00	N	NA		
1-PHENYLPROPANE (PROPYLBENZENE)	3/19/2002	0.00	N	NA		
1-PHENYLPROPANE (PROPYLBENZENE)	6/25/2002	0.00	N	NA		
2,2-DICHLOROPROPANE	10/4/1999	0.00	N	NA		
2,2-DICHLOROPROPANE	10/15/2001	0.00	N	NA		
2,2-DICHLOROPROPANE	3/19/2002	0.00	N	NA		
2,2-DICHLOROPROPANE	6/25/2002	0.00	N	NA		
2,4,5-TP (SILVEX)	10/4/1999	0.00	N	50.0		
2,4-D	10/4/1999	0.00	N	70.0		
2-CHLOROTOLUENE	10/4/1999	0.00	N	NA		
2-CHLOROTOLUENE	10/15/2001	0.00	N	NA		
2-CHLOROTOLUENE	3/19/2002	0.00	N	NA		
2-CHLOROTOLUENE	6/25/2002	0.00	N	NA		
4-CHLOROTOLUENE	10/4/1999	0.00	N	NA		
4-CHLOROTOLUENE	10/15/2001	0.00	N	NA		
4-CHLOROTOLUENE	3/19/2002	0.00	N	NA		
4-CHLOROTOLUENE	6/25/2002	0.00	N	NA		
AGRESSIVENESS INDEX	10/4/1999	13.00	Y	NA		
AGRESSIVENESS INDEX	10/15/2001	12.40	Y	NA		
ALACHLOR	10/4/1999	0.00	N	2.00		
ALDRIN	10/4/1999	0.00	N	NA		
ALUMINUM	10/4/1999	< 50.00	N	1000		
ALUMINUM	10/15/2001	95.00	Y	1000		
ANTIMONY	10/4/1999	< 6.00	N	6.00		
ANTIMONY	10/15/2001	< 6.00	N	6.00		
ARSENIC	10/4/1999	< 2.00	N	50.0		
ARSENIC	10/15/2001	< 2.00	N	50.0		

Source Name: LAKE BERRYESSA INTAKE - RAW

Source #: 001

Chemical	Date	Result	Positive detect?	MCL	Units	Notes
ASBESTOS	10/4/1999	< 0.20	N	7.00		
ATRAZINE	10/4/1999	0.00	N	3.00		
BARIUM	10/4/1999	< 100.00	N	1000		
BARIUM	10/15/2001	< 100.00	N	1000		
BENTAZON	10/4/1999	0.00	N	18.0		
BENZENE	10/4/1999	0.00	N	1.00		
BENZENE	10/15/2001	0.00	N	1.00		
BENZENE	3/19/2002	0.00	N	1.00		
BENZENE	6/25/2002	0.00	N	1.00		
BERYLLIUM	10/4/1999	< 1.00	N	4.00		
BERYLLIUM	10/15/2001	< 1.00	N	4.00		
BICARBONATE	10/4/1999	160.00	Y	NA		
BICARBONATE	10/15/2001	180.00	Y	NA		
BORON	10/15/2001	180.00	Y	NA		
BORON	3/19/2002	160.00	Y	NA		
BORON	6/25/2002	190.00	Y	NA		
BROMACIL	10/4/1999	0.00	N	NA		
BROMOBENZENE	10/4/1999	0.00	N	NA		
BROMOBENZENE	10/15/2001	0.00	N	NA		
BROMOBENZENE	3/19/2002	0.00	N	NA		
BROMOBENZENE	6/25/2002	0.00	N	NA		
BROMOCHLOROMETHANE	10/4/1999	0.00	N	NA		
BROMOCHLOROMETHANE	10/15/2001	0.00	N	NA		
BROMOCHLOROMETHANE	3/19/2002	0.00	N	NA		
BROMOCHLOROMETHANE	6/25/2002	0.00	N	NA		
BROMODICHLORMETHANE	10/4/1999	0.00	N	NA		
BROMODICHLORMETHANE	10/15/2001	0.00	N	NA		
BROMODICHLORMETHANE	3/19/2002	0.00	N	NA		
BROMODICHLORMETHANE	6/25/2002	0.00	N	NA		
BROMOFORM	10/4/1999	0.00	N	NA		
BROMOFORM	10/15/2001	0.00	N	NA		
BROMOFORM	3/19/2002	0.00	N	NA		
BROMOFORM	6/25/2002	0.00	N	NA		
BROMOMETHANE	10/4/1999	0.00	N	NA		
BROMOMETHANE	10/15/2001	0.00	N	NA		
BROMOMETHANE	3/19/2002	0.00	N	NA		
BROMOMETHANE	6/25/2002	0.00	N	NA		
BUTACHLOR	10/4/1999	0.00	N	NA		
CADMIUM	10/4/1999	< 1.00	N	5.00		
CADMIUM	10/15/2001	< 1.00	N	5.00		
CALCIUM	10/4/1999	18.00	Y	NA		
CALCIUM	10/15/2001	17.00	Y	NA		
CARBOFURAN	10/4/1999	0.00	N	18.0		
CARBON TETRACHLORIDE	10/4/1999	0.00	N	.50		
CARBON TETRACHLORIDE	10/15/2001	0.00	N	.50		
CARBON TETRACHLORIDE	3/19/2002	0.00	N	.50		
CARBON TETRACHLORIDE	6/25/2002	0.00	N	.50		
CARBONATE	10/4/1999	12.00	Y	NA		
CARBONATE	10/15/2001	4.80	Y	NA		
CHLORDANE	10/4/1999	0.00	N	.10		
CHLORIDE	10/4/1999	4.80	Y	600		
CHLORIDE	10/15/2001	5.60	Y	600		
CHLOROETHANE	10/4/1999	0.00	N	NA		
CHLOROETHANE	10/15/2001	0.00	N	NA		
CHLOROETHANE	3/19/2002	0.00	N	NA		
CHLOROETHANE	6/25/2002	0.00	N	NA		
CHLOROFORM	10/4/1999	0.00	N	NA		
CHLOROFORM	10/15/2001	0.00	N	NA		

Source Name: LAKE BERRYESSA INTAKE - RAW

Source #: 001

Chemical	Date	Result	Positive detect?	MCL	Units	Notes
CHLOROFORM	3/19/2002	0.00	N	NA		
CHLOROFORM	6/25/2002	0.00	N	NA		
CHLOROMETHANE	10/4/1999	0.00	N	NA		
CHLOROMETHANE	10/15/2001	0.00	N	NA		
CHLOROMETHANE	3/19/2002	0.00	N	NA		
CHLOROMETHANE	6/25/2002	0.00	N	NA		
CHLOROTHALONIL	10/4/1999	0.00	N	NA		
CHROMIUM (TOTAL)	10/4/1999	< 10.00	N	50.0		
CHROMIUM (TOTAL)	10/15/2001	< 1.00	N	50.0		
CIS-1,2-DICHLOROETHYLENE	10/4/1999	0.00	N	6.00		
CIS-1,2-DICHLOROETHYLENE	10/15/2001	0.00	N	6.00		
CIS-1,2-DICHLOROETHYLENE	3/19/2002	0.00	N	6.00		
CIS-1,2-DICHLOROETHYLENE	6/25/2002	0.00	N	6.00		
COLOR	10/4/1999	< 3.00	N	15.0		
COLOR	10/15/2001	3.00	Y	15.0		
COPPER	10/4/1999	< 50.00	N	1000		
COPPER	10/15/2001	< 50.00	N	1000		
DALAPON	10/4/1999	0.00	N	200		
DIAZINON	10/4/1999	0.00	N	NA		
DIBROMOCHLOROMETHANE	10/4/1999	0.00	N	NA		
DIBROMOCHLOROMETHANE	10/15/2001	0.00	N	NA		
DIBROMOCHLOROMETHANE	3/19/2002	0.00	N	NA		
DIBROMOCHLOROMETHANE	6/25/2002	0.00	N	NA		
DIBROMOMETHANE	10/4/1999	0.00	N	NA		
DIBROMOMETHANE	10/15/2001	0.00	N	NA		
DIBROMOMETHANE	3/19/2002	0.00	N	NA		
DIBROMOMETHANE	6/25/2002	0.00	N	NA		
DICAMBA	10/4/1999	0.00	N	NA		
DICHLORODIFLUOROMETHANE	10/4/1999	0.00	N	NA		
DICHLORODIFLUOROMETHANE	10/15/2001	0.00	N	NA		
DICHLORODIFLUOROMETHANE	3/19/2002	0.00	N	NA		
DICHLORODIFLUOROMETHANE	6/25/2002	0.00	N	NA		
DICHLOROMETHANE	10/4/1999	0.00	N	5.00		
DICHLOROMETHANE	10/15/2001	0.00	N	5.00		
DICHLOROMETHANE	3/19/2002	0.00	N	5.00		
DICHLOROMETHANE	6/25/2002	0.00	N	5.00		
DIELDRIN	10/4/1999	0.00	N	NA		
DIMETHOATE	10/4/1999	0.00	N	NA		
DINOSEB	10/4/1999	0.00	N	7.00		
DIQUAT	10/4/1999	0.00	N	20.0		
DIURON	10/4/1999	0.00	N	NA		
ENDOTHALL	10/4/1999	0.00	N	100		
ENDRIN	10/4/1999	0.00	N	2.00		
ETBE	3/19/2002	0.00	N			
ETBE	6/25/2002	0.00	N			
ETHYL BENZENE	10/4/1999	0.00	N	700		
ETHYL BENZENE	10/15/2001	0.00	N	700		
ETHYL BENZENE	3/19/2002	0.00	N	700		
ETHYL BENZENE	6/25/2002	0.00	N	700		
ETHYLENE DIBROMIDE	10/4/1999	0.00	N	.05		
FLUORIDE (TEMPERATURE DEPENDENT)	10/4/1999	0.12	Y	1.40		
FLUORIDE (TEMPERATURE DEPENDENT)	10/15/2001	0.16	Y	1.40		
FOAMING AGENTS (MBAS)	10/4/1999	< 0.05	N	500		
FOAMING AGENTS (MBAS)	10/15/2001	< 0.05	N	500		
HEPTACHLOR	10/4/1999	0.00	N	.01		
HEPTACHLOR EPOXIDE	10/4/1999	0.00	N	.01		
HEXACHLOROBENZENE	10/4/1999	0.00	N	1.00		
HEXACHLOROBUTADIENE	10/4/1999	0.00	N	NA		

Source Name: LAKE BERRYESSA INTAKE - RAW

Source #: 001

Chemical	Date	Result	Positive detect?	MCL	Units	Notes
HEXACHLOROBUTADIENE	10/15/2001	0.00	N	NA		
HEXACHLOROBUTADIENE	3/19/2002	0.00	N	NA		
HEXACHLOROBUTADIENE	6/25/2002	0.00	N	NA		
HEXACHLOROCYCLOPENTADIENE	10/4/1999	0.00	N	50.0		
HYDROXIDE	10/4/1999	< 1.00	N	NA		
HYDROXIDE	10/15/2001	< 1.00	N	NA		
IRON	10/4/1999	< 100.00	N	300		
IRON	10/15/2001	100.00	Y	300		
ISOPROPYLBENZENE	10/4/1999	0.00	N	NA		
ISOPROPYLBENZENE	10/15/2001	0.00	N	NA		
ISOPROPYLBENZENE	3/19/2002	0.00	N	NA		
ISOPROPYLBENZENE	6/25/2002	0.00	N	NA		
LAB TURBIDITY	10/4/1999	0.40	Y	5.00		
LAB TURBIDITY	10/15/2001	4.60	Y	5.00		
LEAD	10/4/1999	< 5.00	N	50.0		
LEAD	10/15/2001	< 5.00	N	50.0		
LINDANE (GAMMA-BHC)	10/4/1999	0.00	N	.20		
M, P-XYLENE	10/4/1999	0.00	N	1750		
M, P-XYLENE	10/15/2001	0.00	N	1750		
M, P-XYLENE	3/19/2002	0.00	N	1750		
M, P-XYLENE	6/25/2002	0.00	N	1750		
M-XYLENE	10/4/1999	0.00	N	1750		
M-XYLENE	10/15/2001	0.00	N	1750		
M-XYLENE	3/19/2002	0.00	N	1750		
M-XYLENE	6/25/2002	0.00	N	1750		
MAGNESIUM	10/4/1999	29.00	Y	NA		
MAGNESIUM	10/15/2001	34.00	Y	NA		
MANGANESE	10/4/1999	< 20.00	N	50.0		
MANGANESE	10/15/2001	< 30.00	N	50.0		
MERCURY	10/4/1999	< 1.00	N	2.00		
MERCURY	10/15/2001	< 1.00	N	2.00		
METHOXYCHLOR	10/4/1999	0.00	N	40.0		
METHYL TERT-BUTYL ETHER (MTBE)	10/4/1999	0.00	N	NA		
METHYL TERT-BUTYL ETHER (MTBE)	10/15/2001	0.00	N	NA		
METHYL TERT-BUTYL ETHER (MTBE)	3/19/2002	0.00	N	NA		
METHYL TERT-BUTYL ETHER (MTBE)	6/25/2002	0.00	N	NA		
METOLACHLOR	10/4/1999	0.00	N	NA		
METRIBUZIN	10/4/1999	0.00	N	NA		
MOLINATE	10/4/1999	0.00	N	20.0		
MONOCHLOROBENZENE	10/4/1999	0.00	N	70.0		
MONOCHLOROBENZENE	10/15/2001	0.00	N	70.0		
MONOCHLOROBENZENE	3/19/2002	0.00	N	70.0		
MONOCHLOROBENZENE	6/25/2002	0.00	N	70.0		
N-BUTYLBENZENE	10/4/1999	0.00	N	NA		
N-BUTYLBENZENE	10/15/2001	0.00	N	NA		
N-BUTYLBENZENE	3/19/2002	0.00	N	NA		
N-BUTYLBENZENE	6/25/2002	0.00	N	NA		
NAPHTHALENE	10/4/1999	0.00	N	NA		
NAPHTHALENE	10/15/2001	0.00	N	NA		
NAPHTHALENE	3/19/2002	0.00	N	NA		
NAPHTHALENE	6/25/2002	0.00	N	NA		
NICKEL	10/4/1999	< 10.00	N	100		
NICKEL	10/15/2001	< 10.00	N	100		
NITRATE (AS NO3)	10/4/1999	< 2.00	N	45.0		
NITRATE (AS NO3)	10/15/2001	< 2.00	N	45.0		
NITRITE (N)	10/4/1999	< 10.00	N	1000		
NITRITE (N)	10/15/2001	< 10.00	N	1000		
O-XYLENE	10/4/1999	0.00	N	1750		

Source Name: LAKE BERRYESSA INTAKE - RAW

Source #: 001

Chemical	Date	Result	Positive detect?	MCL	Units	Notes
O-XYLENE	10/15/2001	0.00	N	1750		
O-XYLENE	3/19/2002	0.00	N	1750		
O-XYLENE	6/25/2002	0.00	N	1750		
ODOR THRESHOLD @ 60 C	10/4/1999	1.40	Y	3.00		
ODOR THRESHOLD @ 60 C	10/15/2001	3.00	Y	3.00		
OXAMYL	10/4/1999	0.00	N	200		
P-ISOPROPYLTOLUENE	10/4/1999	0.00	N	NA		
P-ISOPROPYLTOLUENE	10/15/2001	0.00	N	NA		
P-ISOPROPYLTOLUENE	3/19/2002	0.00	N	NA		
P-ISOPROPYLTOLUENE	6/25/2002	0.00	N	NA		
P-XYLENE	10/4/1999	0.00	N	1750		
P-XYLENE	10/15/2001	0.00	N	1750		
P-XYLENE	3/19/2002	0.00	N	1750		
P-XYLENE	6/25/2002	0.00	N	1750		
PENTACHLOROPHENOL	10/4/1999	0.00	N	1.00		
PH (LABORATORY)	10/4/1999	8.50	Y	NA		
PH (LABORATORY)	10/15/2001	8.60	Y	NA		
PICLORAM	10/4/1999	0.00	N	500		
PROMETRYN	10/4/1999	0.00	N	NA		
PROPACHLOR	10/4/1999	0.00	N	NA		
SEC-BUTYLBENZENE	10/4/1999	0.00	N	NA		
SEC-BUTYLBENZENE	10/15/2001	0.00	N	NA		
SEC-BUTYLBENZENE	3/19/2002	0.00	N	NA		
SEC-BUTYLBENZENE	6/25/2002	0.00	N	NA		
SELENIUM	10/4/1999	< 5.00	N	50.0		
SELENIUM	10/15/2001	< 5.00	N	50.0		
SILVER	10/4/1999	< 10.00	N	100		
SILVER	10/15/2001	< 10.00	N	100		
SIMAZINE	10/4/1999	0.00	N	4.00		
SODIUM	10/4/1999	12.00	Y	NA		
SODIUM	10/15/2001	11.00	Y	NA		
SPECIFIC CONDUCTANCE	10/4/1999	320.00	Y	2200		
SPECIFIC CONDUCTANCE	10/15/2001	370.00	Y	2200		
STYRENE	10/4/1999	0.00	N	100		
STYRENE	10/15/2001	0.00	N	100		
STYRENE	3/19/2002	0.00	N	100		
STYRENE	6/25/2002	0.00	N	100		
SULFATE	10/4/1999	20.00	Y	600		
SULFATE	10/15/2001	23.00	N	600		
TAME	3/19/2002	0.00	N			
TAME	6/25/2002	0.00	N			
TERT-BUTYLBENZENE	10/4/1999	0.00	N	NA		
TERT-BUTYLBENZENE	10/15/2001	0.00	N	NA		
TERT-BUTYLBENZENE	3/19/2002	0.00	N	NA		
TERT-BUTYLBENZENE	6/25/2002	0.00	N	NA		
TETRACHLOROETHYLENE	10/4/1999	0.00	N	5.00		
TETRACHLOROETHYLENE	10/15/2001	0.00	N	5.00		
TETRACHLOROETHYLENE	3/19/2002	0.00	N	5.00		
TETRACHLOROETHYLENE	6/25/2002	0.00	N	5.00		
THALLIUM	10/4/1999	< 1.00	N	2.00		
THALLIUM	10/15/2001	< 1.00	N	2.00		
THIOBENCARB	10/4/1999	0.00	N	1.00		
TOLUENE	10/4/1999	0.00	N	150		
TOLUENE	10/15/2001	0.00	N	150		
TOLUENE	3/19/2002	0.00	N	150		
TOLUENE	6/25/2002	0.00	N	150		
TOTAL ALKALINITY (AS CaCO3)	10/4/1999	140.00	Y	NA		
TOTAL ALKALINITY (AS CaCO3)	10/15/2001	160.00	Y	NA		

Source Name: LAKE BERRYESSA INTAKE - RAW

Source #: 001

Chemical	Date	Result	Positive detect?	MCL	Units	Notes
TOTAL ALPHA	10/4/1999	1.92	Y	15.0		
TOTAL ALPHA COUNTING ERROR	10/4/1999	0.88	Y	NA		
TOTAL FILTERABLE RESIDUE	10/4/1999	210.00	Y	1500		
TOTAL FILTERABLE RESIDUE	10/15/2001	210.00	Y	1500		
TOTAL HARDNESS (AS CaCO3)	10/4/1999	160.00	Y	NA		
TOTAL HARDNESS (AS CaCO3)	10/15/2001	180.00	Y	NA		
TOTAL TRIHALOMETHANES	10/4/1999	0.00	N	100		
TOTAL TRIHALOMETHANES	10/15/2001	0.00	N	100		
TOTAL TRIHALOMETHANES	3/19/2002	0.00	N	100		
TOTAL TRIHALOMETHANES	6/25/2002	0.00	N	100		
TOXAPHENE	10/4/1999	0.00	N	3.00		
TRANS-1,2-DICHLOROETHYLENE	10/4/1999	0.00	N	10.0		
TRANS-1,2-DICHLOROETHYLENE	10/15/2001	0.00	N	10.0		
TRANS-1,2-DICHLOROETHYLENE	3/19/2002	0.00	N	10.0		
TRANS-1,2-DICHLOROETHYLENE	6/25/2002	0.00	N	10.0		
TRICHLOROETHYLENE	10/4/1999	0.00	N	5.00		
TRICHLOROETHYLENE	10/15/2001	0.00	N	5.00		
TRICHLOROETHYLENE	3/19/2002	0.00	N	5.00		
TRICHLOROETHYLENE	6/25/2002	0.00	N	5.00		
TRICHLOROFLUOROMETHANE	10/4/1999	0.00	N	150		
TRICHLOROFLUOROMETHANE	10/15/2001	0.00	N	150		
TRICHLOROFLUOROMETHANE	3/19/2002	0.00	N	150		
TRICHLOROFLUOROMETHANE	6/25/2002	0.00	N	150		
Tertiary butyl alcohol (TBA)	3/19/2002	0.00	N	NA		
Tertiary butyl alcohol (TBA)	6/25/2002	0.00	N	NA		
Total Chromium Screen (1 ug/l DLR)	3/19/2002	< 1.00	N	NA		
Total Chromium Screen (1 ug/l DLR)	6/25/2002	1.00	Y	NA		
VANADIUM	10/15/2001	< 3.00	N	NA		
VANADIUM	3/19/2002	4.10	Y	NA		
VANADIUM	6/25/2002	< 3.00	N	NA		
VINYL CHLORIDE	10/4/1999	0.00	N	.50		
VINYL CHLORIDE	10/15/2001	0.00	N	.50		
VINYL CHLORIDE	3/19/2002	0.00	N	.50		
VINYL CHLORIDE	6/25/2002	0.00	N	.50		
XYLENES (TOTAL)	10/4/1999	0.00	N	1750		
XYLENES (TOTAL)	10/15/2001	0.00	N	1750		
XYLENES (TOTAL)	3/19/2002	0.00	N	1750		
XYLENES (TOTAL)	6/25/2002	0.00	N	1750		
ZINC	10/4/1999	< 50.00	N	5000		
ZINC	10/15/2001	< 50.00	N	5000		

All Source Chemical Monitoring

Date of report: 7/31/2002

System Name: **Rancho Monticello Resort**

Source Name: **LAKE BERRYESSA - RAW**

Source #: **001**

Chemical	Date	Result	Positive detect?	MCL	Units	Notes
1,1,1,2-TETRACHLOROETHANE	9/13/1990	0.00	N	1.00		
1,1,1,2-TETRACHLOROETHANE	6/2/1997	0.00	N	1.00		
1,1,1,2-TETRACHLOROETHANE	7/23/2001	0.00	N	1.00		
1,1,1-TRICHLOROETHANE	9/13/1990	0.00	N	200		
1,1,1-TRICHLOROETHANE	6/2/1997	0.00	N	200		
1,1,1-TRICHLOROETHANE	7/23/2001	0.00	N	200		
1,1,2,2-TETRACHLOROETHANE	9/13/1990	0.00	N	1.00		
1,1,2,2-TETRACHLOROETHANE	6/2/1997	0.00	N	1.00		
1,1,2,2-TETRACHLOROETHANE	7/23/2001	0.00	N	1.00		
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	6/2/1997	0.00	N	1200		
1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	7/23/2001	0.00	N	1200		
1,1,2-TRICHLOROETHANE	9/13/1990	0.00	N	5.00		
1,1,2-TRICHLOROETHANE	6/2/1997	0.00	N	5.00		
1,1,2-TRICHLOROETHANE	7/23/2001	0.00	N	5.00		
1,1-DICHLOROETHANE	9/13/1990	0.00	N	5.00	UG/L	
1,1-DICHLOROETHANE	6/2/1997	0.00	N	5.00	UG/L	
1,1-DICHLOROETHANE	7/23/2001	0.00	N	5.00	UG/L	
1,1-DICHLOROETHYLENE	9/13/1990	0.00	N	6.00		
1,1-DICHLOROETHYLENE	6/2/1997	0.00	N	6.00		
1,1-DICHLOROETHYLENE	7/23/2001	0.00	N	6.00		
1,1-DICHLOROPROPENE	9/13/1990	0.00	N	NA		
1,1-DICHLOROPROPENE	6/2/1997	0.00	N	NA		
1,1-DICHLOROPROPENE	7/23/2001	0.00	N	NA		
1,2,3-TRICHLOROBENZENE	9/13/1990	0.00	N	NA		
1,2,3-TRICHLOROBENZENE	6/2/1997	0.00	N	NA		
1,2,3-TRICHLOROBENZENE	7/23/2001	0.00	N	NA		
1,2,3-TRICHLOROPROPANE	9/13/1990	0.00	N	NA		
1,2,3-TRICHLOROPROPANE	6/2/1997	0.00	N	NA		
1,2,3-TRICHLOROPROPANE	7/23/2001	0.00	N	NA		
1,2,3-TRICHLOROPROPANE	6/10/2002	0.00	N	NA		
1,2,4-TRICHLOROBENZENE	9/13/1990	0.00	N	70.0		
1,2,4-TRICHLOROBENZENE	6/2/1997	0.00	N	70.0		
1,2,4-TRICHLOROBENZENE	7/23/2001	0.00	N	70.0		
1,2,4-TRIMETHYLBENZENE	9/13/1990	0.00	N	NA		
1,2,4-TRIMETHYLBENZENE	6/2/1997	0.00	N	NA		
1,2,4-TRIMETHYLBENZENE	7/23/2001	0.00	N	NA		
1,2-DICHLOROBENZENE	9/13/1990	0.00	N	600		
1,2-DICHLOROBENZENE	6/2/1997	0.00	N	600		
1,2-DICHLOROBENZENE	7/23/2001	0.00	N	600		
1,2-DICHLOROETHANE	9/13/1990	0.00	N	.50		
1,2-DICHLOROETHANE	6/2/1997	0.00	N	.50		
1,2-DICHLOROETHANE	7/23/2001	0.00	N	.50		
1,2-DICHLOROPROPANE	9/13/1990	0.00	N	5.00		
1,2-DICHLOROPROPANE	6/2/1997	0.00	N	5.00		
1,2-DICHLOROPROPANE	7/23/2001	0.00	N	5.00		
1,3,5-TRIMETHYLBENZENE	9/13/1990	0.00	N	NA		
1,3,5-TRIMETHYLBENZENE	6/2/1997	0.00	N	NA		
1,3,5-TRIMETHYLBENZENE	7/23/2001	0.00	N	NA		
1,3-DICHLOROBENZENE	9/13/1990	0.00	N	NA		
1,3-DICHLOROBENZENE	6/2/1997	0.00	N	NA		
1,3-DICHLOROBENZENE	7/23/2001	0.00	N	NA		

Source Name: LAKE BERRYESSA - RAW

Source #: 001

Chemical	Date	Result	Positive detect?	MCL	Units	Notes
1,3-DICHLOROPROPANE	9/13/1990	0.00	N	NA		
1,3-DICHLOROPROPANE	6/2/1997	0.00	N	NA		
1,3-DICHLOROPROPANE	7/23/2001	0.00	N	NA		
1,3-DICHLOROPROPENE (TOTAL)	9/13/1990	0.00	N	.50		
1,3-DICHLOROPROPENE (TOTAL)	6/2/1997	0.00	N	.50		
1,3-DICHLOROPROPENE (TOTAL)	7/23/2001	0.00	N	.50		
1,4-DICHLOROBENZENE	9/13/1990	0.00	N	5.00		
1,4-DICHLOROBENZENE	6/2/1997	0.00	N	5.00		
1,4-DICHLOROBENZENE	7/23/2001	0.00	N	5.00		
1-PHENYLPROPANE (PROPYLBENZENE)	9/13/1990	0.00	N	NA		
1-PHENYLPROPANE (PROPYLBENZENE)	6/2/1997	0.00	N	NA		
1-PHENYLPROPANE (PROPYLBENZENE)	7/23/2001	0.00	N	NA		
2,2-DICHLOROPROPANE	9/13/1990	0.00	N	NA		
2,2-DICHLOROPROPANE	6/2/1997	0.00	N	NA		
2,2-DICHLOROPROPANE	7/23/2001	0.00	N	NA		
2,4,5-TP (SILVEX)	6/2/1997	0.00	N	50.0		
2,4,5-TP (SILVEX)	7/23/2001	0.00	N	50.0		
2,4-D	6/2/1997	0.00	N	70.0		
2,4-D	7/23/2001	0.00	N	70.0		
2-CHLOROETHYLVINYL ETHER	9/13/1990	0.00	N	NA		
2-CHLOROTOLUENE	9/13/1990	0.00	N	NA		
2-CHLOROTOLUENE	6/2/1997	0.00	N	NA		
2-CHLOROTOLUENE	7/23/2001	0.00	N	NA		
3-HYDROXCARBOFURAN	6/2/1997	0.00	N	NA		
3-HYDROXCARBOFURAN	7/23/2001	0.00	N	NA		
4-CHLOROTOLUENE	9/13/1990	0.00	N	NA		
4-CHLOROTOLUENE	6/2/1997	0.00	N	NA		
4-CHLOROTOLUENE	7/23/2001	0.00	N	NA		
AGRESSIVENESS INDEX	11/7/1994	12.00	Y	NA		
AGRESSIVENESS INDEX	6/2/1997	12.00	Y	NA		
AGRESSIVENESS INDEX	5/3/1999	12.00	Y	NA		
AGRESSIVENESS INDEX	7/23/2001	12.50	Y	NA		
ALACHLOR	7/23/2001	0.00	N	2.00		
ALDICARB	6/2/1997	0.00	N	NA		
ALDICARB	7/23/2001	0.00	N	NA		
ALDICARB SULFONE	6/2/1997	0.00	N	NA		
ALDICARB SULFONE	7/23/2001	0.00	N	NA		
ALDICARB SULFOXIDE	6/2/1997	0.00	N	NA		
ALDICARB SULFOXIDE	7/23/2001	0.00	N	NA		
ALDRIN	7/23/2001	0.00	N	NA		
ALUMINUM	9/13/1990	< 100.00	N	1000		
ALUMINUM	11/7/1994	180.00	Y	1000		
ALUMINUM	6/2/1997	< 50.00	N	1000		
ALUMINUM	5/3/1999	< 50.00	N	1000		
ALUMINUM	7/23/2001	260.00	Y	1000		
ANTIMONY	11/7/1994	< 6.00	N	6.00		
ANTIMONY	6/2/1997	< 6.00	N	6.00		
ANTIMONY	5/3/1999	< 6.00	N	6.00		
ANTIMONY	7/23/2001	< 6.00	N	6.00		
ARSENIC	9/13/1990	< 10.00	N	50.0		
ARSENIC	11/7/1994	2.20	Y	50.0		
ARSENIC	6/2/1997	3.50	Y	50.0		
ARSENIC	5/3/1999	< 2.00	N	50.0		
ARSENIC	7/23/2001	< 2.00	N	50.0		
ASBESTOS	6/2/1997	< 0.20	N	7.00		
ASBESTOS	7/23/2001	< 0.20	N	7.00		
ATRAZINE	6/2/1997	0.00	N	3.00		
ATRAZINE	7/23/2001	0.00	N	3.00		

Source Name: LAKE BERRYESSA - RAW

Source #: 001

Chemical	Date	Result	Positive detect?	MCL	Units	Notes
BARIUM	9/13/1990	< 100.00	N	1000		
BARIUM	11/7/1994	< 100.00	N	1000		
BARIUM	6/2/1997	< 100.00	N	1000		
BARIUM	5/3/1999	< 100.00	N	1000		
BARIUM	7/23/2001	< 100.00	N	1000		
BENTAZON	7/23/2001	0.00	N	18.0		
BENZENE	9/13/1990	0.00	N	1.00		
BENZENE	6/2/1997	0.00	N	1.00		
BENZENE	7/23/2001	0.00	N	1.00		
BENZENE	6/10/2002	0.00	N	1.00		
BERYLLIUM	11/7/1994	< 1.00	N	4.00		
BERYLLIUM	6/2/1997	< 1.00	N	4.00		
BERYLLIUM	5/3/1999	< 1.00	N	4.00		
BERYLLIUM	7/23/2001	< 1.00	N	4.00		
BICARBONATE	9/13/1990	158.00	Y	NA		
BICARBONATE	11/7/1994	210.00	Y	NA		
BICARBONATE	6/2/1997	150.00	Y	NA		
BICARBONATE	5/3/1999	160.00	Y	NA		
BICARBONATE	7/23/2001	160.00	Y	NA		
BROMACIL	6/2/1997	0.00	N	NA		
BROMACIL	7/23/2001	0.00	N	NA		
BROMOBENZENE	9/13/1990	0.00	N	NA		
BROMOBENZENE	6/2/1997	0.00	N	NA		
BROMOBENZENE	7/23/2001	0.00	N	NA		
BROMOCHLOROMETHANE	9/13/1990	0.00	N	NA		
BROMOCHLOROMETHANE	6/2/1997	0.00	N	NA		
BROMOCHLOROMETHANE	7/23/2001	0.00	N	NA		
BROMODICHLORMETHANE	9/13/1990	0.00	N	NA		
BROMODICHLORMETHANE	6/2/1997	0.00	N	NA		
BROMODICHLORMETHANE	7/23/2001	0.00	N	NA		
BROMOFORM	9/13/1990	0.00	N	NA		
BROMOFORM	6/2/1997	0.00	N	NA		
BROMOFORM	7/23/2001	0.00	N	NA		
BROMOMETHANE	9/13/1990	0.00	N	NA		
BROMOMETHANE	6/2/1997	0.00	N	NA		
BROMOMETHANE	7/23/2001	0.00	N	NA		
BUTACHLOR	6/2/1997	0.00	N	NA		
BUTACHLOR	7/23/2001	0.00	N	NA		
CADMIUM	9/13/1990	< 1.00	N	5.00		
CADMIUM	11/7/1994	< 1.00	N	5.00		
CADMIUM	6/2/1997	< 1.00	N	5.00		
CADMIUM	5/3/1999	< 1.00	N	5.00		
CADMIUM	7/23/2001	< 1.00	N	5.00		
CALCIUM	9/13/1990	19.00	Y	NA		
CALCIUM	11/7/1994	15.00	Y	NA		
CALCIUM	6/2/1997	14.00	Y	NA		
CALCIUM	5/3/1999	16.00	Y	NA		
CALCIUM	7/23/2001	16.00	Y	NA		
CARBARYL	6/2/1997	0.00	N	NA		
CARBARYL	7/23/2001	0.00	N	NA		
CARBOFURAN	6/2/1997	0.00	N	18.0		
CARBOFURAN	7/23/2001	0.00	N	18.0		
CARBON TETRACHLORIDE	9/13/1990	0.00	N	.50		
CARBON TETRACHLORIDE	6/2/1997	0.00	N	.50		
CARBON TETRACHLORIDE	7/23/2001	0.00	N	.50		
CARBONATE	9/13/1990	11.00	Y	NA		
CARBONATE	11/7/1994	< 1.00	N	NA		
CARBONATE	6/2/1997	< 1.00	N	NA		

Source Name: LAKE BERRYESSA - RAW

Source #: 001

Chemical	Date	Result	Positive detect?	MCL	Units	Notes
CARBONATE	5/3/1999	< 1.00	N	NA		
CARBONATE	7/23/2001	14.00	Y	NA		
CHLORDANE	6/2/1997	0.00	N	.10		
CHLORDANE	7/23/2001	0.00	N	.10		
CHLORIDE	9/13/1990	6.00	Y	600		
CHLORIDE	11/7/1994	5.80	Y	600		
CHLORIDE	6/2/1997	3.50	Y	600		
CHLORIDE	5/3/1999	4.80	Y	600		
CHLORIDE	7/23/2001	5.40	Y	600		
CHLOROETHANE	9/13/1990	0.00	N	NA		
CHLOROETHANE	6/2/1997	0.00	N	NA		
CHLOROETHANE	7/23/2001	0.00	N	NA		
CHLOROFORM	9/13/1990	0.00	N	NA		
CHLOROFORM	6/2/1997	0.00	N	NA		
CHLOROFORM	7/23/2001	0.00	N	NA		
CHLOROMETHANE	9/13/1990	0.00	N	NA		
CHLOROMETHANE	6/2/1997	0.00	N	NA		
CHLOROMETHANE	7/23/2001	0.00	N	NA		
CHLOROTHALONIL	6/2/1997	0.00	N	NA		
CHLOROTHALONIL	7/23/2001	0.00	N	NA		
CHROMIUM (TOTAL)	9/13/1990	< 10.00	N	50.0		
CHROMIUM (TOTAL)	11/7/1994	< 10.00	N	50.0		
CHROMIUM (TOTAL)	6/2/1997	< 10.00	N	50.0		
CHROMIUM (TOTAL)	5/3/1999	< 10.00	N	50.0		
CHROMIUM (TOTAL)	7/23/2001	1.40	N	50.0		
CIS-1,2-DICHLOROETHYLENE	9/13/1990	0.00	N	6.00		
CIS-1,2-DICHLOROETHYLENE	6/2/1997	0.00	N	6.00		
CIS-1,2-DICHLOROETHYLENE	7/23/2001	0.00	N	6.00		
COLOR	11/7/1994	10.00	Y	15.0		
COLOR	6/2/1997	< 3.00	N	15.0		
COLOR	5/3/1999	< 3.00	N	15.0		
COLOR	7/23/2001	5.00	Y	15.0		
COPPER	9/13/1990	< 50.00	N	1000		
COPPER	11/7/1994	< 50.00	N	1000		
COPPER	6/2/1997	< 50.00	N	1000		
COPPER	5/3/1999	< 50.00	N	1000		
COPPER	7/23/2001	< 50.00	N	1000		
DALAPON	6/2/1997	0.00	N	200		
DALAPON	7/23/2001	0.00	N	200		
DIAZINON	6/2/1997	0.00	N	NA		
DIAZINON	7/23/2001	0.00	N	NA		
DIBROMOCHLOROMETHANE	9/13/1990	0.00	N	NA		
DIBROMOCHLOROMETHANE	6/2/1997	0.00	N	NA		
DIBROMOCHLOROMETHANE	7/23/2001	0.00	N	NA		
DIBROMOMETHANE	9/13/1990	0.00	N	NA		
DIBROMOMETHANE	6/2/1997	0.00	N	NA		
DIBROMOMETHANE	7/23/2001	0.00	N	NA		
DICAMBA	7/23/2001	0.00	N	NA		
DICHLORODIFLUOROMETHANE	9/13/1990	0.00	N	NA		
DICHLORODIFLUOROMETHANE	6/2/1997	0.00	N	NA		
DICHLORODIFLUOROMETHANE	7/23/2001	0.00	N	NA		
DICHLORODIFLUOROMETHANE	6/10/2002	0.00	N	NA		
DICHLOROMETHANE	9/13/1990	0.00	N	5.00		
DICHLOROMETHANE	6/2/1997	0.00	N	5.00		
DICHLOROMETHANE	7/23/2001	0.00	N	5.00		
DIELDRIN	7/23/2001	0.00	N	NA		
DIMETHOATE	6/2/1997	0.00	N	NA		
DIMETHOATE	7/23/2001	0.00	N	NA		

Source Name: LAKE BERRYESSA - RAW

Source #: 001

Chemical	Date	Result	Positive detect?	MCL	Units	Notes
DINOSEB	6/2/1997	0.00	N	7.00		
DINOSEB	7/23/2001	0.00	N	7.00		
DIQUAT	6/2/1997	0.00	N	20.0		
DIQUAT	7/23/2001	0.00	N	20.0		
DIURON	6/2/1997	0.00	N	NA		
DIURON	7/23/2001	0.00	N	NA		
ENDOTHALL	6/2/1997	0.00	N	100		
ENDOTHALL	7/23/2001	0.00	N	100		
ENDRIN	6/2/1997	0.00	N	2.00		
ENDRIN	7/23/2001	0.00	N	2.00		
ETHYL BENZENE	9/13/1990	0.00	N	700		
ETHYL BENZENE	6/2/1997	0.00	N	700		
ETHYL BENZENE	7/23/2001	0.00	N	700		
ETHYL BENZENE	6/10/2002	0.00	N	700		
ETHYLENE DIBROMIDE	6/2/1997	0.00	N	.05		
ETHYLENE DIBROMIDE	7/23/2001	0.00	N	.05		
FLUORIDE (TEMPERATURE DEPENDENT)	9/13/1990	< 0.10	N	1.40		
FLUORIDE (TEMPERATURE DEPENDENT)	11/7/1994	0.14	Y	1.40		
FLUORIDE (TEMPERATURE DEPENDENT)	6/2/1997	0.14	Y	1.40		
FLUORIDE (TEMPERATURE DEPENDENT)	5/3/1999	< 0.10	N	1.40		
FLUORIDE (TEMPERATURE DEPENDENT)	7/23/2001	0.16	Y	1.40		
FOAMING AGENTS (MBAS)	9/13/1990	< 0.05	N	500		
FOAMING AGENTS (MBAS)	11/7/1994	< 0.05	N	500		
FOAMING AGENTS (MBAS)	6/2/1997	< 0.05	N	500		
FOAMING AGENTS (MBAS)	5/3/1999	< 0.05	N	500		
FOAMING AGENTS (MBAS)	7/23/2001	< 0.05	N	500		
HEPTACHLOR	6/2/1997	0.00	N	.01		
HEPTACHLOR	7/23/2001	0.00	N	.01		
HEPTACHLOR EPOXIDE	6/2/1997	0.00	N	.01		
HEPTACHLOR EPOXIDE	7/23/2001	0.00	N	.01		
HEXACHLOROBENZENE	7/23/2001	0.00	N	1.00		
HEXACHLOROBUTADIENE	9/13/1990	0.00	N	NA		
HEXACHLOROBUTADIENE	6/2/1997	0.00	N	NA		
HEXACHLOROBUTADIENE	7/23/2001	0.00	N	NA		
HEXACHLOROCYCLOPENTADIENE	7/23/2001	0.00	N	50.0		
HYDROXIDE	9/13/1990	< 1.00	N	NA		
HYDROXIDE	11/7/1994	< 1.00	N	NA		
HYDROXIDE	6/2/1997	< 1.00	N	NA		
HYDROXIDE	5/3/1999	< 1.00	N	NA		
HYDROXIDE	7/23/2001	< 1.00	N	NA		
IRON	9/13/1990	< 100.00	N	300		
IRON	11/7/1994	660.00	Y	300		
IRON	6/2/1997	< 100.00	N	300		
IRON	5/3/1999	< 100.00	N	300		
IRON	7/23/2001	< 100.00	N	300		
ISOPROPYLBENZENE	9/13/1990	0.00	N	NA		
ISOPROPYLBENZENE	6/2/1997	0.00	N	NA		
ISOPROPYLBENZENE	7/23/2001	0.00	N	NA		
LAB TURBIDITY	11/7/1994	7.00	Y	5.00		
LAB TURBIDITY	12/21/1994	< 0.10	N	5.00		
LAB TURBIDITY	6/2/1997	0.89	Y	5.00		
LAB TURBIDITY	5/3/1999	1.70	Y	5.00		
LAB TURBIDITY	7/23/2001	1.30	Y	5.00		
LEAD	9/13/1990	< 5.00	N	50.0		
LEAD	6/2/1997	< 5.00	N	50.0		
LEAD	5/3/1999	< 5.00	N	50.0		
LEAD	7/23/2001	< 5.00	N	50.0		
LINDANE (GAMMA-BHC)	6/2/1997	0.00	N	.20		

Source Name: LAKE BERRYESSA - RAW

Source #: 001

Chemical	Date	Result	Positive detect?	MCL	Units	Notes
LINDANE (GAMMA-BHC)	7/23/2001	0.00	N	.20		
M, P-XYLENE	9/13/1990	0.00	N	1750		
M, P-XYLENE	6/2/1997	0.00	N	1750		
M, P-XYLENE	7/23/2001	0.00	N	1750		
M-XYLENE	7/23/2001	0.00	N	1750		
MAGNESIUM	9/13/1990	32.00	Y	NA		
MAGNESIUM	11/7/1994	26.00	Y	NA		
MAGNESIUM	6/2/1997	23.00	Y	NA		
MAGNESIUM	5/3/1999	26.00	Y	NA		
MAGNESIUM	7/23/2001	32.00	Y	NA		
MANGANESE	9/13/1990	< 30.00	N	50.0		
MANGANESE	11/7/1994	56.00	Y	50.0		
MANGANESE	6/2/1997	< 30.00	N	50.0		
MANGANESE	5/3/1999	< 20.00	N	50.0		
MANGANESE	7/23/2001	< 30.00	N	50.0		
MERCURY	9/13/1990	< 0.00	N	2.00		
MERCURY	11/7/1994	< 1.00	N	2.00		
MERCURY	6/2/1997	< 1.00	N	2.00		
MERCURY	5/3/1999	< 1.00	N	2.00		
MERCURY	7/23/2001	< 1.00	N	2.00		
METHOMYL	6/2/1997	0.00	N	NA		
METHOMYL	7/23/2001	0.00	N	NA		
METHOXYCHLOR	6/2/1997	0.00	N	40.0		
METHOXYCHLOR	7/23/2001	0.00	N	40.0		
METHYL TERT-BUTYL ETHER (MTBE)	6/2/1997	0.00	N	NA		
METHYL TERT-BUTYL ETHER (MTBE)	7/23/2001	0.00	N	NA		
METHYL TERT-BUTYL ETHER (MTBE)	6/10/2002	0.00	N	NA		
METOLACHLOR	6/2/1997	0.00	N	NA		
METOLACHLOR	7/23/2001	0.00	N	NA		
METRIBUZIN	6/2/1997	0.00	N	NA		
METRIBUZIN	7/23/2001	0.00	N	NA		
MOLINATE	6/2/1997	0.00	N	20.0		
MOLINATE	7/23/2001	0.00	N	20.0		
MONOCHLORO BENZENE	9/13/1990	0.00	N	70.0		
MONOCHLORO BENZENE	6/2/1997	0.00	N	70.0		
MONOCHLORO BENZENE	7/23/2001	0.00	N	70.0		
N-BUTYLBENZENE	9/13/1990	0.00	N	NA		
N-BUTYLBENZENE	6/2/1997	0.00	N	NA		
N-BUTYLBENZENE	7/23/2001	0.00	N	NA		
NAPHTHALENE	6/2/1997	0.00	N	NA		
NAPHTHALENE	7/23/2001	0.00	N	NA		
NICKEL	11/7/1994	< 10.00	N	100		
NICKEL	6/2/1997	< 10.00	N	100		
NICKEL	5/3/1999	< 10.00	N	100		
NICKEL	7/23/2001	< 10.00	N	100		
NITRATE (AS NO3)	9/13/1990	< 0.10	N	45.0		
NITRATE (AS NO3)	11/7/1994	< 4.50	N	45.0		
NITRATE (AS NO3)	1/22/1997	< 4.50	N	45.0		
NITRATE (AS NO3)	4/7/1997	< 4.50	N	45.0		
NITRATE (AS NO3)	6/2/1997	< 4.50	N	45.0		
NITRATE (AS NO3)	5/3/1999	< 2.00	N	45.0		
NITRATE (AS NO3)	7/23/2001	< 2.00	N	45.0		
NITRITE (N)	11/7/1994	14.00	N	1000		
NITRITE (N)	6/2/1997	< 10.00	N	1000		
NITRITE (N)	5/3/1999	< 10.00	N	1000		
NITRITE (N)	7/23/2001	< 10.00	N	1000		
O-XYLENE	9/13/1990	0.00	N	1750		
O-XYLENE	6/2/1997	0.00	N	1750		

Source Name: LAKE BERRYESSA - RAW

Source #: 001

Chemical	Date	Result	Positive detect?	MCL	Units	Notes
O-XYLENE	7/23/2001	0.00	N	1750		
ODOR THRESHOLD @ 60 C	11/7/1994	< 17.00	N	3.00		
ODOR THRESHOLD @ 60 C	6/2/1997	3.00	Y	3.00		
ODOR THRESHOLD @ 60 C	5/3/1999	< 1.00	N	3.00		
ODOR THRESHOLD @ 60 C	7/23/2001	6.00	Y	3.00		
OXAMYL	6/2/1997	0.00	N	200		
OXAMYL	7/23/2001	0.00	N	200		
P-ISOPROPYLTOLUENE	9/13/1990	0.00	N	NA		
P-ISOPROPYLTOLUENE	6/2/1997	0.00	N	NA		
P-ISOPROPYLTOLUENE	7/23/2001	0.00	N	NA		
P-XYLENE	7/23/2001	0.00	N	1750		
PENTACHLOROPHENOL	6/2/1997	0.00	N	1.00		
PENTACHLOROPHENOL	7/23/2001	0.00	N	1.00		
PH (LABORATORY)	9/13/1990	8.90	Y	NA		
PH (LABORATORY)	11/7/1994	8.30	Y	NA		
PH (LABORATORY)	6/2/1997	7.90	Y	NA		
PH (LABORATORY)	5/3/1999	8.30	Y	NA		
PH (LABORATORY)	7/23/2001	8.70	Y	NA		
PICLORAM	6/2/1997	0.00	N	500		
PICLORAM	7/23/2001	0.00	N	500		
POTASSIUM	9/13/1990	1.60	Y	NA		
PROMETRYN	6/2/1997	0.00	N	NA		
PROMETRYN	7/23/2001	0.00	N	NA		
PROPACHLOR	6/2/1997	0.00	N	NA		
PROPACHLOR	7/23/2001	0.00	N	NA		
Perchlorate	6/10/2002	0.00	N			
SEC-BUTYLBENZENE	9/13/1990	0.00	N	NA		
SEC-BUTYLBENZENE	6/2/1997	0.00	N	NA		
SEC-BUTYLBENZENE	7/23/2001	0.00	N	NA		
SELENIUM	9/13/1990	< 5.00	N	50.0		
SELENIUM	11/7/1994	< 5.00	N	50.0		
SELENIUM	6/2/1997	< 5.00	N	50.0		
SELENIUM	5/3/1999	< 5.00	N	50.0		
SELENIUM	7/23/2001	< 5.00	N	50.0		
SILVER	9/13/1990	< 10.00	N	100		
SILVER	11/7/1994	< 10.00	N	100		
SILVER	6/2/1997	< 10.00	N	100		
SILVER	5/3/1999	< 10.00	N	100		
SILVER	7/23/2001	< 10.00	N	100		
SIMAZINE	6/2/1997	0.00	N	4.00		
SIMAZINE	7/23/2001	0.00	N	4.00		
SODIUM	9/13/1990	10.00	Y	NA		
SODIUM	11/7/1994	18.00	Y	NA		
SODIUM	6/2/1997	9.70	Y	NA		
SODIUM	5/3/1999	10.00	Y	NA		
SODIUM	7/23/2001	11.00	Y	NA		
SPECIFIC CONDUCTANCE	9/13/1990	350.00	Y	2200		
SPECIFIC CONDUCTANCE	11/7/1994	420.00	Y	2200		
SPECIFIC CONDUCTANCE	6/2/1997	220.00	Y	2200		
SPECIFIC CONDUCTANCE	5/3/1999	340.00	Y	2200		
SPECIFIC CONDUCTANCE	7/23/2001	370.00	Y	2200		
STYRENE	9/13/1990	0.00	N	100		
STYRENE	6/2/1997	0.00	N	100		
STYRENE	7/23/2001	0.00	N	100		
SULFATE	9/13/1990	21.00	Y	600		
SULFATE	11/7/1994	25.00	Y	600		
SULFATE	6/2/1997	22.00	Y	600		
SULFATE	5/3/1999	25.00	Y	600		

Source Name: LAKE BERRYESSA - RAW

Source #: 001

Chemical	Date	Result	Positive detect?	MCL	Units	Notes
SULFATE	7/23/2001	22.00	N	600		
TERT-BUTYLBENZENE	9/13/1990	0.00	N	NA		
TERT-BUTYLBENZENE	6/2/1997	0.00	N	NA		
TERT-BUTYLBENZENE	7/23/2001	0.00	N	NA		
TETRACHLOROETHYLENE	9/13/1990	0.00	N	5.00		
TETRACHLOROETHYLENE	6/2/1997	0.00	N	5.00		
TETRACHLOROETHYLENE	7/23/2001	0.00	N	5.00		
THALLIUM	11/7/1994	< 2.00	N	2.00		
THALLIUM	6/2/1997	< 2.00	N	2.00		
THALLIUM	5/3/1999	< 1.00	N	2.00		
THALLIUM	7/23/2001	< 2.00	N	2.00		
THIOBENCARB	6/2/1997	0.00	N	1.00		
THIOBENCARB	7/23/2001	0.00	N	1.00		
TOLUENE	9/13/1990	0.00	N	150		
TOLUENE	6/2/1997	0.00	N	150		
TOLUENE	7/23/2001	0.00	N	150		
TOLUENE	6/10/2002	0.00	N	150		
TOTAL ALKALINITY (AS CaCO3)	9/13/1990	170.00	Y	NA		
TOTAL ALKALINITY (AS CaCO3)	11/7/1994	170.00	Y	NA		
TOTAL ALKALINITY (AS CaCO3)	6/2/1997	120.00	Y	NA		
TOTAL ALKALINITY (AS CaCO3)	5/3/1999	130.00	Y	NA		
TOTAL ALKALINITY (AS CaCO3)	7/23/2001	160.00	Y	NA		
TOTAL ALPHA	1/22/1997	2.21	N	15.0		
TOTAL ALPHA	4/7/1997	1.39	N	15.0		
TOTAL ALPHA	6/2/1997	1.21	N	15.0		
TOTAL ALPHA	7/23/2001	0.19	N	15.0		
TOTAL ALPHA COUNTING ERROR	1/22/1997	0.81	Y	NA		
TOTAL ALPHA COUNTING ERROR	4/7/1997	0.85	Y	NA		
TOTAL ALPHA COUNTING ERROR	6/2/1997	0.67	Y	NA		
TOTAL ALPHA COUNTING ERROR	7/23/2001	0.58	Y	NA		
TOTAL FILTERABLE RESIDUE	9/13/1990	230.00	Y	1500		
TOTAL FILTERABLE RESIDUE	11/7/1994	190.00	Y	1500		
TOTAL FILTERABLE RESIDUE	6/2/1997	160.00	Y	1500		
TOTAL FILTERABLE RESIDUE	5/3/1999	180.00	Y	1500		
TOTAL FILTERABLE RESIDUE	7/23/2001	180.00	Y	1500		
TOTAL HARDNESS (AS CaCO3)	9/13/1990	180.00	Y	NA		
TOTAL HARDNESS (AS CaCO3)	11/7/1994	140.00	Y	NA		
TOTAL HARDNESS (AS CaCO3)	6/2/1997	130.00	Y	NA		
TOTAL HARDNESS (AS CaCO3)	5/3/1999	147.00	Y	NA		
TOTAL HARDNESS (AS CaCO3)	7/23/2001	170.00	Y	NA		
TOTAL TRIHALOMETHANES	9/13/1990	0.00	N	100		
TOTAL TRIHALOMETHANES	6/2/1997	0.00	N	100		
TOTAL TRIHALOMETHANES	7/23/2001	0.00	N	100		
TOXAPHENE	6/2/1997	0.00	N	3.00		
TOXAPHENE	7/23/2001	0.00	N	3.00		
TRANS-1,2-DICHLOROETHYLENE	9/13/1990	0.00	N	10.0		
TRANS-1,2-DICHLOROETHYLENE	6/2/1997	0.00	N	10.0		
TRANS-1,2-DICHLOROETHYLENE	7/23/2001	0.00	N	10.0		
TRICHLOROETHYLENE	9/13/1990	0.00	N	5.00		
TRICHLOROETHYLENE	6/2/1997	0.00	N	5.00		
TRICHLOROETHYLENE	7/23/2001	0.00	N	5.00		
TRICHLOROFLUOROMETHANE	9/13/1990	0.00	N	150		
TRICHLOROFLUOROMETHANE	6/2/1997	0.00	N	150		
TRICHLOROFLUOROMETHANE	7/23/2001	0.00	N	150		
VINYL CHLORIDE	9/13/1990	0.00	N	.50		
VINYL CHLORIDE	6/2/1997	0.00	N	.50		
VINYL CHLORIDE	7/23/2001	0.00	N	.50		
XYLENES (TOTAL)	9/13/1990	0.00	N	1750		

Source Name: LAKE BERRYESSA - RAW

Source #: 001

Chemical	Date	Result	Positive detect?	MCL	Units	Notes
XYLENES (TOTAL)	6/2/1997	0.00	N	1750		
XYLENES (TOTAL)	7/23/2001	0.00	N	1750		
XYLENES (TOTAL)	6/10/2002	0.00	N	1750		
ZINC	9/13/1990	< 50.00	N	5000		
ZINC	11/7/1994	< 50.00	N	5000		
ZINC	6/2/1997	< 50.00	N	5000		
ZINC	5/3/1999	< 50.00	N	5000		
ZINC	7/23/2001	< 50.00	N	5000		

No raw water bacteriological
Monitoring completed

Spanish Flat Water District

System No. : 2810014 Surface_source?: Yes

Enforcement Actions

ID	Status	Date signed	Month	Type	#	Remarks	Status	Date complie
ENF	SA	10/4/1999					P	
CIT	FL	10/10/2001	January, 1996	03	02-03-01C-055	Failure to sample-l&c	P	
CIT	FL	11/16/1998	September, 1998	10	02-03-98C-063		C	12/10/1998
CIT	OX	11/16/1998	September, 1998	10	02-03-98C-063		C	12/10/1998

All Bacti Samples

Date	Location	Type	CL ₂	Total	Fecal	Comments
12/15/1997	Hosebib At Spanish Flatwater District Office	Routine	1.3	A	A	
1/26/1998	Hosebib At Water Office	Routine	2.1	A	A	
2/9/1998	Hosebib At Water Office	Routine	1.2	A	A	
3/9/1998	Hosebib At Spanish Flatwater District Office	Routine	0.9	A	A	
4/20/1998	Hosebib At Spanish Flatwater District Office	Routine	0.8	A	A	
5/4/1998	Hosebib At Spanish Flatwater District Office	Routine	0.4	A	A	
6/15/1998	Hosebib At Water Office	Routine	1.2	A	A	
7/13/1998	Hosebib At Spanish Flatwater District Office	Routine	1.5	A	A	
8/10/1998	Hosebib At Water Office	Routine	0.8	A	A	
9/8/1998	Hosebib At Spanish Flatwater District Office	Routine	<0.1	A	A	
10/19/1998	Hosebib At Water Office	Routine	0.8	A	A	
11/16/1998	Hosebib At Water Office	Routine	0.6	A	A	
12/28/1998	Hosebib At Spanish Flatwater District Office	Routine	1.7	A	A	
1/25/1999	Hosebib At Spanish Flatwater District Office	Routine	1.7	A	A	
2/22/1999	Hosebib At Spanish Flatwater District Office	Routine	1.2	A	A	
3/22/1999	Hosebib At Spanish Flatwater District Office	Routine	1.6	A	A	
4/5/1999	Hosebib At Spanish Flatwater District Office	Routine	1.5	A	A	
5/3/1999	Hosebib At Spanish Flatwater District Office	Routine	>2.5	A	A	
6/1/1999	Hosebib At Water Office	Routine	1.5	A	A	
6/28/1999	Hosebib At Spanish Flatwater District Office	Routine	1.5	A	A	
7/26/1999	Hosebib At Water Office	Routine	1.5	A	A	
8/9/1999	Hosebib At Spanish Flatwater District Office	Routine	0.4	A	A	
9/7/1999	Hosebib At Water Office	Routine	1.2	A	A	
10/4/1999	Hosebib At Water Office	Routine	1.0	A	A	
11/1/1999	Hosebib At Spanish Flatwater District Office	Routine	0.7	A	A	
12/27/1999	Hosebib At Water Office	Routine	1.1	A	A	
1/24/2000	Hosebib At Water Office	Routine	0.5	A	A	
2/22/2000	Hosebib At Water Office	Routine	1.2	A	A	
3/20/2000	Hosebib At Water Office	Routine	0.8	A	A	
4/17/2000	Hosebib At Water Office	Routine	0.8	A	A	
5/15/2000	Hosebib At Water Office	Routine	1.0	A	A	
6/12/2000	Hosebib At Spanish Flatwater District Office	Routine	1.1	A	A	
7/10/2000	Hosebib At Spanish Flatwater District Office	Routine	1.3	A	A	
8/7/2000	HB @ water office	Routine		A	A	
9/18/2000	Hosebib At Water Office	Routine	1.5	A	A	
10/30/2000	Hosebib @ Water Office	Routine	2.2	A	A	
11/13/2000	Hosebib @ Water Office	Routine	0.3	A	A	

Date	Location	Type	CL ₂	Total	Fecal	Comments
12/28/2000	Hosebib @ Office	Routine	1.7	A	A	
1/8/2001	Hosebib @ Water Office	Routine	0.8	A	A	
2/20/2001	Hosebib At Spanish Flatwater District Office	Routine	0.5	A	A	
3/5/2001	Hosebib At Spanish Flatwater District Office	Routine	0.3	A	A	
4/2/2001	Hosebib @ Water Office	Routine	0.7	A	A	
5/29/2001	Hosebib @ Water Office	Routine	1.9	A	A	
6/25/2001	Hosebib At Spanish Flatwater District Office	Routine	0.9	A	A	
7/23/2001	Hosebib At Spanish Flatwater District Office	Routine	<0.1	P	A	
7/27/2001	Water Plant	Repeat		A	A	
7/27/2001	Water Office	Repeat		A	A	
7/27/2001	4101 Knoxville Rd.	Repeat		A	A	
7/27/2001	4312 #11 Spanish Flat Loop Rd.	Repeat		A	A	
8/24/2001	Hosebib @ Water Office	Routine	0.9	A	A	
9/17/2001	Hosebib @ Water Office	Routine	1.1	A	A	
10/15/2001	Hosebib @ Water Office	Routine	1.2	A	A	
11/26/2001	Hosebib @ Water Office	Routine	2.0	A	A	
12/10/2001	Hosebib @ Water Office	Routine	2.5	A	A	
1/7/2002	Hosebib @ Water Office	Routine	1.8	A	A	
2/4/2002	Hosebib @ Water Office	Routine	1.8	A	A	
3/4/2002	Hosebib At Water Office	Routine	0.8	A	A	
4/1/2002	Hosebib @ Water Office	Routine	>3.5	A	A	
5/13/2002	Hosebib @ Water Office	Routine	>3.5	A	A	
6/10/2002	Hosebib @ Water Office	Routine	0.8	A	A	