

May 2025

| DAY | ELEV | STORAGE ACRE-FEET | | COMPUTED* INFLOW AF. | CCWA INFLOW AF. | PRECIP ON RES. SURF. AF. | RELEASE - AF. | | | | EVAPORATION | | PRECIP INCHES |
|---------|--------|-------------------|--------|-------------------------|--------------------|-----------------------------|---------------|--------------|--------|----------|-------------|-------|------------------|
| | | IN LAKE | CHANGE | | | | TUNNEL | HILTON CREEK | OUTLET | SPILLWAY | AF. | INCH | |
| | 744.73 | 168,741 | | | | | | | | | | | |
| 1 | 744.70 | 168,656 | -85 | 27.6 | 0.0 | 0.0 | 59.5 | 13.3 | 15.0 | 0.0 | 24.8 | 0.130 | 0.00 |
| 2 | 744.68 | 168,599 | -57 | 29.8 | 0.0 | 11.8 | 50.3 | 13.3 | 14.0 | 0.0 | 21.0 | 0.110 | 0.05 |
| 3 | 744.66 | 168,542 | -57 | 41.1 | 0.0 | 0.0 | 43.1 | 13.3 | 15.0 | 0.0 | 26.7 | 0.140 | 0.00 |
| TOTALS | | | -199 | 98.5 | 0.0 | 11.8 | 152.9 | 39.9 | 44.0 | 0.0 | 72.5 | 0.380 | 0.05 |
| AVERAGE | | 168,599 | | | | | | | | | | | |

Comments: *Computed inflow is the sum of change in storage, releases and evaporation minus precip on the reservoir surface and CCWA inflow.
Indicated outlet release includes leakage from outlet valves and spillway gates.
Data based on a 24 hour period ending 0800.

