



January 2024

DAY	ELEV	STORAGE ACRE-FEET		COMPUTED* INFLOW AF.	CCWA INFLOW AF.	PRECIP ON RES. SURF. AF.	RELEASE - AF.				EVAPORATION		PRECIP INCHES
		IN LAKE	CHANGE				TUNNEL	HILTON CREEK	OUTLET	SPILLWAY	AF.	INCH	
	746.87	174,872											
1	746.91	174,988	116	150.0	16.2	0.0	20.5	13.3	10.0	0.0	6.3	0.040	0.00
2	746.94	175,075	87	139.0	0.0	0.0	21.3	13.3	9.0	0.0	7.9	0.050	0.00
3	746.98	175,192	117	69.0	0.0	101.5	25.7	13.3	10.0	0.0	4.7	0.030	0.42
4	746.99	175,221	29	93.0	0.0	0.0	28.2	13.3	10.0	0.0	12.6	0.080	0.00
5	747.00	175,250	29	96.0	0.0	0.0	29.3	13.3	9.0	0.0	15.7	0.100	0.00
6	747.02	175,308	58	122.0	0.0	0.0	28.5	13.3	10.0	0.0	12.6	0.080	0.00
7	747.02	175,308	0	21.0	0.0	33.8	27.8	13.3	9.0	0.0	4.7	0.030	0.14
8	747.03	175,337	29	95.0	0.0	0.0	29.9	13.3	10.0	0.0	12.6	0.080	0.00
9	747.04	175,366	29	91.0	0.0	0.0	28.1	13.3	10.0	0.0	11.0	0.070	0.00
10	747.05	175,395	29	88.0	0.0	2.4	29.5	13.3	9.0	0.0	9.4	0.060	0.01
11	747.02	175,308	-87	-29.0	0.0	7.3	28.4	13.3	10.0	0.0	14.1	0.090	0.03
12	747.04	175,366	58	125.0	0.0	0.0	28.5	13.3	9.0	0.0	15.7	0.100	0.00
13	747.05	175,395	29	91.0	0.0	0.0	29.0	13.3	10.0	0.0	9.4	0.060	0.00
14	747.05	175,395	0	58.0	0.0	2.4	28.7	13.3	9.0	0.0	9.4	0.060	0.01
15	747.04	175,366	-29	27.0	0.0	0.0	29.0	13.2	9.0	0.0	4.7	0.030	0.00
16	747.04	175,366	0	62.0	0.0	0.0	29.1	13.3	10.0	0.0	9.4	0.060	0.00
17	747.04	175,366	0	58.0	0.0	4.8	31.5	13.3	9.0	0.0	9.4	0.060	0.02
18	747.04	175,366	0	65.0	0.0	0.0	33.6	13.2	9.0	0.0	9.4	0.060	0.00
19	747.04	175,366	0	59.0	0.0	0.0	33.7	13.4	6.0	0.0	6.3	0.040	0.00
20	747.07	175,424	58	91.0	0.0	31.5	34.9	13.3	2.0	0.0	14.2	0.090	0.13
21	747.07	175,424	0	-7.0	0.0	60.5	32.5	13.3	3.0	0.0	4.7	0.030	0.25
22	747.14	175,657	233	119.0	0.0	169.5	33.4	13.3	2.0	0.0	6.3	0.040	0.70
23	747.21	175,860	203	231.0	0.0	29.1	33.7	13.3	2.0	0.0	7.9	0.050	0.12
24	747.28	176,064	204	270.0	0.0	2.4	35.0	13.3	3.0	0.0	17.3	0.110	0.01
25	747.33	176,209	145	187.0	0.0	7.3	32.6	13.4	2.0	0.0	1.6	0.010	0.03
26	747.36	176,296	87	143.0	2.0	0.0	33.4	6.7	2.0	0.0	15.8	0.100	0.00
27	747.38	176,355	59	114.0	5.9	0.0	30.4	13.4	3.0	0.0	14.2	0.090	0.00
28	747.41	176,442	87	135.0	5.9	0.0	27.7	13.3	2.0	0.0	11.1	0.070	0.00
29	747.43	176,500	58	109.0	5.9	0.0	27.3	13.3	2.0	0.0	14.2	0.090	0.00
30	747.45	176,558	58	112.0	1.7	0.0	26.1	13.4	2.0	0.0	14.2	0.090	0.00
31	747.47	176,616	58	112.0	0.0	0.0	27.3	13.3	2.0	0.0	11.1	0.070	0.00
TOTALS			1,744	3,096.0	37.6	452.5	914.6	405.9	204.0	0.0	317.9	2.020	1.87
AVERAGE		175,617											

Comments: *Computed inflow is the sum of change in storage, releases and evaporation minus precip on the reservoir surface and ccwa inflow.
 Indicated outlet release includes leakage from outlet valves and spillway gates.
 Data based on a 24 hour period ending 0800.