



— BUREAU OF —  
RECLAMATION

March 2024

DAY	ELEV	STORAGE ACRE-FEET		COMPUTED* INFLOW AF.	CCWA INFLOW AF.	PRECIP ON RES. SURF. AF.	RELEASE - AF.				EVAPORATION		PRECIP INCHES
		IN LAKE	CHANGE				TUNNEL	HILTON CREEK	OUTLET	SPILLWAY	AF.	INCH	
	752.54	191,873											
1	752.65	192,213	340	1,388.0	0.0	0.0	28.0	13.9	7.0	983.0	15.7	0.080	0.00
2	752.86	192,868	655	1,588.0	0.0	178.5	27.1	13.9	78.0	985.0	7.9	0.040	0.69
3	753.10	193,617	749	2,771.0	0.0	59.7	27.2	14.0	360.0	1,665.0	15.8	0.080	0.23
4	753.06	193,492	-125	2,259.0	0.0	0.0	27.3	14.0	429.0	1,892.0	21.7	0.110	0.00
5	752.97	193,211	-281	1,896.0	0.0	0.0	27.2	14.0	224.0	1,890.0	21.7	0.110	0.00
6	752.86	192,868	-343	1,698.0	0.0	0.0	28.1	14.0	88.0	1,887.0	23.6	0.120	0.00
7	752.82	192,743	-125	1,788.0	0.0	106.0	27.8	14.0	88.0	1,885.0	3.9	0.020	0.41
8	752.75	192,525	-218	1,596.0	0.0	7.8	27.1	14.0	267.0	1,492.0	21.6	0.110	0.03
9	752.88	192,930	405	1,337.0	0.0	0.0	27.9	14.0	59.0	811.0	19.7	0.100	0.00
10	753.06	193,492	562	1,051.0	0.0	0.0	29.4	13.4	401.0	29.0	15.8	0.080	0.00
11	753.24	194,054	562	1,055.0	0.0	0.0	24.3	14.0	435.0	0.0	19.8	0.100	0.00
12	753.39	194,522	468	969.0	0.0	0.0	28.8	14.0	436.0	0.0	21.8	0.110	0.00
13	753.53	194,958	436	945.0	0.0	0.0	31.3	14.0	438.0	0.0	25.8	0.130	0.00
14	753.65	195,334	376	904.0	0.0	0.0	34.9	14.1	451.0	0.0	27.8	0.140	0.00
15	753.76	195,680	346	874.0	0.0	0.0	34.6	14.1	449.0	0.0	29.8	0.150	0.00
16	753.84	195,932	252	843.0	0.0	0.0	32.8	14.1	496.0	0.0	47.7	0.240	0.00
17	753.88	196,058	126	705.0	0.0	0.0	34.7	14.2	500.0	0.0	29.8	0.150	0.00
18	753.93	196,216	158	730.0	0.0	0.0	34.0	14.2	500.0	0.0	23.9	0.120	0.00
19	753.99	196,405	189	772.0	0.0	0.0	35.1	14.2	500.0	0.0	33.9	0.170	0.00
20	754.00	196,436	31	616.0	0.0	0.0	40.7	14.2	500.0	0.0	29.9	0.150	0.00
21	754.03	196,531	95	695.0	0.0	0.0	50.3	14.2	500.0	0.0	35.9	0.180	0.00
22	754.03	196,531	0	604.0	0.0	0.0	60.2	14.2	500.0	0.0	29.9	0.150	0.00
23	754.07	196,625	94	511.0	0.0	165.2	46.3	14.2	500.0	0.0	21.9	0.110	0.63
24	754.09	196,688	63	643.0	0.0	5.2	36.6	14.2	500.0	0.0	33.9	0.170	0.02
25	754.11	196,783	95	642.0	0.0	15.7	34.9	14.2	500.0	0.0	14.0	0.070	0.06
26	754.11	196,783	0	579.0	0.0	0.0	37.0	14.2	500.0	0.0	27.9	0.140	0.00
27	754.09	196,688	-95	482.0	0.0	0.0	32.8	14.2	500.0	0.0	29.9	0.150	0.00
28	753.59	195,146	-1,542	855.0	0.0	0.0	30.8	14.2	500.0	1,826.0	25.8	0.130	0.00
29	753.03	193,398	-1,748	802.0	0.0	0.0	30.2	14.1	500.0	1,974.0	31.5	0.160	0.00
30	752.76	192,556	-842	1,628.0	0.0	509.1	31.5	14.1	500.0	2,433.0	0.0	0.000	1.97
31	752.53	191,842	-714	5,830.0	0.0	479.4	31.6	14.1	500.0	6,478.0	0.0	0.000	1.86
<b>TOTALS</b>			<b>-31</b>	<b>39,056.0</b>	<b>0.0</b>	<b>1,526.6</b>	<b>1,030.5</b>	<b>436.2</b>	<b>12,206.0</b>	<b>26,230.0</b>	<b>708.3</b>	<b>3.570</b>	<b>5.90</b>
<b>AVERAGE</b>		<b>194,681</b>											

**Comments:** \*Computed inflow is the sum of change in storage, releases and evaporation minus precip on the reservoir surface and ccwa inflow.  
Indicated outlet release includes leakage from outlet valves and spillway gates.  
Data based on a 24 hour period ending 0800.