



April 2026

DAY	ELEV	STORAGE ACRE-FEET		COMPUTED* INFLOW AF.	CCWA INFLOW AF.	PRECIP ON RES. SURF. AF.	RELEASE - AF.				EVAPORATION		PRECIP INCHES
		IN LAKE	CHANGE				TUNNEL	HILTON CREEK	OUTLET	SPILLWAY	AF.	INCH	
	753.08	193,523											
1	753.06	193,492	-31	184.4	0.0	18.2	44.8	14.4	164.0	0.0	10.4	0.050	0.07
2	753.02	193,367	-125	144.5	0.0	0.0	47.5	14.4	164.0	0.0	43.6	0.210	0.00
3	753.01	193,336	-31	230.0	0.0	0.0	41.1	14.4	164.0	0.0	41.5	0.200	0.00
4	752.99	193,274	-62	192.9	0.0	0.0	40.2	14.4	163.0	0.0	37.3	0.180	0.00
5	752.97	193,211	-63	210.3	0.0	0.0	38.1	14.2	165.0	0.0	56.0	0.270	0.00
6	752.91	193,024	-187	82.7	0.0	0.0	38.7	14.2	165.0	0.0	51.8	0.250	0.00
7	752.87	192,899	-125	140.9	0.0	0.0	47.8	14.7	162.0	0.0	41.4	0.200	0.00
8	752.84	192,806	-93	182.4	0.0	0.0	52.5	14.4	163.0	0.0	45.5	0.220	0.00
9	752.81	192,712	-94	182.9	0.0	0.0	51.9	14.4	163.0	0.0	47.6	0.230	0.00
10	753.77	195,712	3,000	3,272.1	0.0	0.0	54.0	14.4	164.0	0.0	39.7	0.190	0.00
11	752.75	192,525	-3,187	-2,998.4	11.7	33.6	29.6	14.4	163.0	0.0	26.9	0.130	0.13
12	752.76	192,556	31	149.9	12.5	100.8	26.9	14.4	164.0	0.0	26.9	0.130	0.39
13	752.73	192,462	-94	140.3	12.5	2.6	29.7	14.4	164.0	0.0	41.3	0.200	0.01
14	752.70	192,369	-93	148.2	12.5	0.0	31.9	14.3	162.0	0.0	45.5	0.220	0.00
15	752.67	192,275	-94	153.7	10.8	0.0	37.7	14.4	163.0	0.0	43.4	0.210	0.00
16	752.63	192,150	-125	136.8	0.1	0.0	43.3	14.3	163.0	0.0	41.3	0.200	0.00
17	752.60	192,058	-92	173.8	0.0	0.0	49.3	14.3	163.0	0.0	39.2	0.190	0.00
18	752.55	191,903	-155	125.0	0.0	0.0	53.2	14.3	163.0	0.0	49.5	0.240	0.00
19	752.49	191,719	-184	102.7	0.0	0.0	54.7	14.4	164.0	0.0	53.6	0.260	0.00
20	752.46	191,626	-93	187.3	0.0	0.0	53.5	14.3	163.0	0.0	49.5	0.240	0.00
21	752.42	191,503	-123	136.9	0.0	12.9	53.2	14.3	162.0	0.0	43.3	0.210	0.05
22	752.41	191,472	-31	97.7	0.0	108.1	41.8	14.3	156.0	0.0	24.7	0.120	0.42
23	752.35	191,287	-185	53.1	0.0	2.6	21.0	14.3	154.0	0.0	51.4	0.250	0.01
24	752.31	191,164	-123	131.8	0.0	0.0	35.1	14.3	156.0	0.0	49.4	0.240	0.00
25	752.26	191,010	-154	84.4	0.0	0.0	35.9	14.3	143.0	0.0	45.2	0.220	0.00
26	752.23	190,917	-93	105.2	0.0	12.8	38.3	14.3	144.0	0.0	14.4	0.070	0.05
27	752.19	190,763	-154	59.7	0.0	0.0	24.5	14.3	142.0	0.0	32.9	0.160	0.00
28	752.13	190,609	-154	87.3	0.0	0.0	38.9	14.2	143.0	0.0	45.2	0.220	0.00
29	752.08	190,424	-185	71.9	0.0	0.0	50.4	14.3	143.0	0.0	49.2	0.240	0.00
30	752.03	190,301	-123	132.9	0.0	0.0	50.4	14.3	142.0	0.0	49.2	0.240	0.00
<b>TOTALS</b>			<b>-3,222</b>	<b>4,103.3</b>	<b>60.1</b>	<b>291.6</b>	<b>1,255.9</b>	<b>430.3</b>	<b>4,754.0</b>	<b>0.0</b>	<b>1,236.8</b>	<b>5.990</b>	<b>1.13</b>
<b>AVERAGE</b>		<b>192,164</b>											

**Comments:** \*Computed inflow is the sum of change in storage, releases and evaporation minus precip on the reservoir surface and CCWA inflow.  
 Indicated outlet release includes leakage from outlet valves and spillway gates.  
 Data based on a 24 hour period ending 0800.