



May 2023

DAY	ELEV	STORAGE ACRE-FEET		COMPUTED* INFLOW AF.	CCWA INFLOW AF.	PRECIP ON RES. SURF. AF.	RELEASE - AF.				EVAPORATION		PRECIP INCHES
		IN LAKE	CHANGE				TUNNEL	HILTON CREEK	OUTLET	SPILLWAY	AF.	INCH	
	753.71	195,523											
1	753.74	195,617	94	558.0	0.0	0.0	68.8	12.4	340.0	0.0	42.4	0.200	0.00
2	753.63	195,271	-346	216.0	0.0	0.0	59.2	12.5	342.0	0.0	148.1	0.700	0.00
3	753.69	195,460	189	636.0	0.0	0.0	49.1	12.5	343.0	0.0	42.3	0.200	0.00
4	753.77	195,712	252	628.0	0.0	73.2	47.0	12.5	375.0	0.0	14.8	0.070	0.28
5	753.82	195,869	157	623.0	0.0	5.2	44.0	12.5	391.0	0.0	23.3	0.110	0.02
6	753.85	195,964	95	583.0	0.0	0.0	44.2	12.5	391.0	0.0	40.3	0.190	0.00
7	753.86	195,995	31	529.0	0.0	0.0	43.9	12.6	395.0	0.0	46.6	0.220	0.00
8	753.86	195,995	0	490.0	0.0	0.0	42.8	12.5	388.0	0.0	46.6	0.220	0.00
9	753.85	195,964	-31	480.0	0.0	0.0	65.4	13.6	390.0	0.0	42.4	0.200	0.00
10	753.83	195,901	-63	426.0	0.0	0.0	55.5	13.9	390.0	0.0	29.7	0.140	0.00
11	753.83	195,901	0	473.0	0.0	0.0	70.7	14.0	342.0	0.0	46.6	0.220	0.00
12	753.84	195,932	31	489.0	0.0	0.0	68.6	13.9	339.0	0.0	36.0	0.170	0.00
13	753.83	195,901	-31	434.0	0.0	0.0	68.2	13.9	340.0	0.0	42.4	0.200	0.00
14	753.81	195,838	-63	406.0	0.0	0.0	70.4	14.0	327.0	0.0	57.2	0.270	0.00
15	753.81	195,838	0	405.0	0.0	0.0	59.3	13.9	285.0	0.0	46.6	0.220	0.00
16	753.81	195,838	0	384.0	1.9	0.0	53.8	13.9	278.0	0.0	40.3	0.190	0.00
17	753.80	195,806	-32	353.0	0.2	0.0	54.0	14.0	292.0	0.0	25.4	0.120	0.00
18	753.80	195,806	0	375.0	0.0	0.0	54.5	14.0	232.0	0.0	74.2	0.350	0.00
19	753.80	195,806	0	324.0	0.0	0.0	52.9	14.0	204.0	0.0	53.0	0.250	0.00
20	753.80	195,806	0	318.0	0.0	0.0	55.3	14.0	198.0	0.0	50.8	0.240	0.00
21	753.80	195,806	0	318.0	0.0	0.0	54.1	14.0	199.0	0.0	50.8	0.240	0.00
22	753.79	195,775	-31	277.0	0.0	0.0	53.9	13.9	198.0	0.0	42.4	0.200	0.00
23	753.78	195,743	-32	285.0	0.0	0.0	61.5	14.0	197.0	0.0	44.5	0.210	0.00
24	753.78	195,743	0	288.0	0.0	0.0	65.7	14.0	183.0	0.0	25.4	0.120	0.00
25	753.77	195,712	-31	255.0	0.0	0.0	63.9	14.0	170.0	0.0	38.1	0.180	0.00
26	753.77	195,712	0	264.0	0.0	0.0	67.2	14.0	151.0	0.0	31.8	0.150	0.00
27	753.78	195,743	31	281.0	0.0	0.0	62.7	14.0	131.0	0.0	42.4	0.200	0.00
28	753.78	195,743	0	257.0	0.0	0.0	68.0	14.0	130.0	0.0	44.5	0.210	0.00
29	753.79	195,775	32	270.0	0.0	0.0	65.7	14.0	129.0	0.0	29.7	0.140	0.00
30	753.79	195,775	0	243.0	0.0	0.0	67.1	14.0	130.0	0.0	31.8	0.150	0.00
31	753.80	195,806	31	259.0	0.0	0.0	67.3	14.0	128.0	0.0	19.1	0.090	0.00
TOTALS			283	12,127.0	2.1	78.4	1,824.7	421.0	8,328.0	0.0	1,349.5	6.370	0.30
AVERAGE		195,792											

Comments: *Computed inflow is the sum of change in storage, releases and evaporation minus precip on the reservoir surface and ccwa inflow.
Indicated outlet release includes leakage from outlet valves and spillway gates.
Data based on a 24 hour period ending 0800.