

June 2024

DAY	ELEV	STORAGE ACRE-FEET		COMPUTED* INFLOW AF.	CCWA INFLOW AF.	PRECIP ON RES. SURF. AF.	RELEASE - AF.				EVAPORATION		PRECIP INCHES
		IN LAKE	CHANGE				TUNNEL	HILTON CREEK	OUTLET	SPILLWAY	AF.	INCH	
	754.19	197,003											
1	754.19	197,003	0	270.0	0.0	0.0	50.3	14.2	128.0	0.0	77.5	0.360	0.00
2	754.16	196,940	-63	170.3	0.0	0.0	48.1	14.2	128.0	0.0	43.0	0.200	0.00
3	754.16	196,940	0	242.6	0.0	0.0	48.9	14.2	130.0	0.0	49.5	0.230	0.00
4	754.15	196,909	-31	202.4	0.0	0.0	48.2	14.2	128.0	0.0	43.0	0.200	0.00
5	754.14	196,877	-32	214.9	0.0	0.0	48.8	14.2	128.0	0.0	55.9	0.260	0.00
6	754.13	196,846	-31	211.4	0.0	0.0	48.6	14.2	128.0	0.0	51.6	0.240	0.00
7	754.13	196,846	0	256.3	0.0	0.0	48.6	14.2	129.0	0.0	64.5	0.300	0.00
8	754.11	196,783	-63	188.0	0.0	0.0	48.6	14.2	128.0	0.0	60.2	0.280	0.00
9	754.08	196,657	-126	108.4	0.0	0.0	47.0	14.2	128.0	0.0	45.2	0.210	0.00
10	754.07	196,625	-32	209.2	0.0	0.0	42.1	14.2	129.0	0.0	55.9	0.260	0.00
11	754.05	196,594	-31	208.1	0.0	0.0	47.5	14.2	128.0	0.0	49.4	0.230	0.00
12	754.02	196,499	-95	157.1	0.0	0.0	51.9	14.2	128.0	0.0	58.0	0.270	0.00
13	754.00	196,436	-63	165.2	0.0	0.0	43.8	14.2	110.0	0.0	60.2	0.280	0.00
14	753.98	196,373	-63	136.1	0.0	0.0	42.3	14.2	91.0	0.0	51.6	0.240	0.00
15	753.98	196,373	0	188.7	0.0	0.0	42.3	14.2	72.0	0.0	60.2	0.280	0.00
16	753.95	196,279	-94	91.5	0.0	0.0	40.0	14.2	69.0	0.0	62.3	0.290	0.00
17	753.94	196,247	-32	149.8	0.0	0.0	47.1	14.2	69.0	0.0	51.5	0.240	0.00
18	753.91	196,153	-94	43.3	0.0	0.0	53.8	14.2	69.0	0.3	0.0	0.000	0.00
19	753.89	196,090	-63	144.5	0.0	0.0	58.8	14.2	68.0	0.0	66.5	0.310	0.00
20	753.85	195,964	-126	56.1	0.0	0.0	36.7	14.2	69.0	0.0	62.2	0.290	0.00
21	753.82	195,869	-95	103.0	0.0	0.0	59.0	14.2	69.0	0.0	55.8	0.260	0.00
22	753.80	195,806	-63	132.0	0.0	0.0	58.2	14.2	69.0	0.0	53.6	0.250	0.00
23	753.77	195,712	-94	110.0	0.0	0.0	57.5	14.2	68.0	0.0	64.3	0.300	0.00
24	753.74	195,617	-95	115.7	0.0	0.0	56.8	14.2	69.0	0.0	70.7	0.330	0.00
25	753.72	195,554	-63	154.8	0.0	0.0	58.3	14.3	68.0	0.0	77.2	0.360	0.00
26	753.68	195,428	-126	97.0	0.0	0.0	58.4	14.2	69.0	0.0	81.4	0.380	0.00
27	753.64	195,302	-126	81.6	0.0	0.0	59.0	14.2	68.0	0.0	66.4	0.310	0.00
28	753.59	195,146	-156	33.8	0.0	0.0	56.7	14.2	59.0	0.0	59.9	0.280	0.00
29	753.55	195,021	-125	62.2	0.0	0.0	58.5	14.2	61.0	0.0	53.5	0.250	0.00
30	753.52	194,927	-94	101.2	0.0	0.0	58.0	14.2	61.0	0.0	62.0	0.290	0.00
TOTALS			-2,076	4,405	0.0	0.0	1,523.8	426.1	2,818.0	0.3	1,713.0	7.980	0.00
AVERAGE		196,194											

Comments: *Computed inflow is the sum of change in storage, releases and evaporation minus precip on the reservoir surface and ccwa inflow.
Indicated outlet release includes leakage from outlet valves and spillway gates.
Data based on a 24 hour period ending 0800.

