

August 2025

DAY	ELEV	STORAGE ACRE-FEET		COMPUTED*	CCWA	PRECIP ON	RELEASE - AF.				EVAPORATION		PRECIP
		IN LAKE	CHANGE	INFLOW AF.	INFLOW AF.	RES. SURF. AF.	TUNNEL	HILTON CREEK	OUTLET	SPILLWAY	AF.	INCH	INCHES
	740.73	157,711											
1	740.68	157,576	-135	14.2	0.0	0.0	58.1	12.9	22.0	0.0	56.2	0.310	0.00
2	740.63	157,441	-135	11.0	0.0	0.0	56.0	12.9	21.0	0.0	56.1	0.310	0.00
3	740.58	157,307	-134	-5.2	0.0	0.0	57.7	12.9	22.0	0.0	36.2	0.200	0.00
4	740.53	157,174	-133	-13.1	0.0	0.0	41.6	12.9	22.0	0.0	43.4	0.240	0.00
5	740.48	157,040	-134	-1.8	0.0	0.0	55.7	12.9	22.0	0.0	41.6	0.230	0.00
6	740.43	156,907	-133	18.7	0.0	0.0	56.4	12.9	21.0	0.0	61.4	0.340	0.00
7	740.38	156,774	-133	25.4	0.0	0.0	64.0	12.9	22.0	0.0	59.5	0.330	0.00
8	740.33	156,640	-134	14.2	0.0	0.0	64.6	12.9	22.0	0.0	48.7	0.270	0.00
9	740.28	156,507	-133	10.2	0.0	0.0	61.5	12.9	22.0	0.0	46.8	0.260	0.00
10	740.23	156,374	-133	43.1	0.0	0.0	63.9	12.8	22.0	0.0	77.4	0.430	0.00
11	740.17	156,214	-160	-11.2	0.0	0.0	54.6	12.8	22.0	0.0	59.4	0.330	0.00
12	740.13	156,107	-107	31.9	0.0	0.0	50.2	12.8	22.0	0.0	53.9	0.300	0.00
13	740.08	155,947	-160	-20.7	0.0	0.0	53.4	12.8	21.0	0.0	52.1	0.290	0.00
14	740.03	155,841	-106	20.6	0.0	0.0	52.3	12.8	22.0	0.0	39.5	0.220	0.00
15	739.98	155,707	-134	8.2	0.0	0.0	53.6	12.8	22.0	0.0	53.8	0.300	0.00
16	739.93	155,574	-133	-0.9	0.0	0.0	50.7	12.8	22.0	0.0	46.6	0.260	0.00
17	739.89	155,468	-106	34.2	0.0	0.0	51.6	12.8	22.0	0.0	53.8	0.300	0.00
18	739.85	155,361	-107	28.9	0.0	0.0	36.6	12.8	22.0	0.0	64.5	0.360	0.00
19	739.80	155,228	-133	14.4	0.0	0.0	48.1	12.8	22.0	0.0	64.5	0.360	0.00
20	739.75	155,094	-134	-6.7	0.0	0.0	47.8	12.8	22.0	0.0	44.7	0.250	0.00
21	739.71	154,988	-106	50.5	0.0	0.0	53.7	12.8	22.0	0.0	68.0	0.380	0.00
22	739.66	154,854	-134	22.5	9.0	0.0	53.9	12.8	22.0	0.0	76.8	0.430	0.00
23	739.62	154,748	-106	42.2	11.9	0.0	61.0	12.8	22.0	0.0	64.3	0.360	0.00
24	739.57	154,616	-132	-0.5	11.9	0.0	60.5	12.7	22.0	0.0	48.2	0.270	0.00
25	739.53	154,511	-105	24.7	11.9	0.0	51.6	12.7	22.0	0.0	55.3	0.310	0.00
26	739.48	154,379	-132	0.3	11.9	0.0	59.5	12.8	22.0	0.0	49.9	0.280	0.00
27	739.45	154,301	-78	37.4	11.9	0.0	44.5	12.7	22.0	0.0	48.1	0.270	0.00
28	739.39	154,143	-158	-13.9	1.8	0.0	52.3	12.8	22.0	0.0	58.8	0.330	0.00
29	739.35	154,037	-106	34.9	0.0	0.0	47.5	12.7	22.0	0.0	58.7	0.330	0.00
30	739.30	153,906	-131	5.8	0.0	0.0	52.2	12.8	22.0	0.0	49.8	0.280	0.00
31	739.27	153,827	-79	64.2	0.0	0.0	49.8	12.7	22.0	0.0	58.7	0.330	0.00
TOTALS			-3,884	483.5	70.3	0.0	1,664.9	397.2	679.0	0.0	1,696.7	9.460	0.00
AVERAGE		155,632											

Comments: *Computed inflow is the sum of change in storage, releases and evaporation minus precip on the reservoir surface and CCWA inflow.
Indicated outlet release includes leakage from outlet valves and spillway gates.
Data based on a 24 hour period ending 0800.