



September 2023

DAY	ELEV	STORAGE ACRE-FEET		COMPUTED* INFLOW AF.	CCWA INFLOW AF.	PRECIP ON RES. SURF. AF.	RELEASE - AF.				EVAPORATION		PRECIP INCHES
		IN LAKE	CHANGE				TUNNEL	HILTON CREEK	OUTLET	SPILLWAY	AF.	INCH	
	750.15	184,573											
1	750.08	184,332	-241	-44.0	12.9	0.0	76.7	13.6	66.0	0.0	53.4	0.280	0.00
2	750.04	184,242	-90	89.0	13.2	5.0	78.1	13.5	66.0	0.0	40.0	0.210	0.02
3	749.97	184,031	-211	-51.0	13.1	0.0	77.6	13.5	65.0	0.0	17.1	0.090	0.00
4	749.92	183,880	-151	8.0	13.1	0.0	57.2	13.5	65.0	0.0	36.2	0.190	0.00
5	749.87	183,729	-151	5.0	4.4	0.0	37.0	13.5	66.0	0.0	43.8	0.230	0.00
6	749.81	183,548	-181	-9.0	0.0	0.0	53.3	13.5	65.0	0.0	39.9	0.210	0.00
7	749.78	183,458	-90	80.0	0.0	0.0	56.0	13.5	66.0	0.0	34.2	0.180	0.00
8	749.71	183,247	-211	-38.0	0.0	0.0	55.1	13.5	65.0	0.0	39.9	0.210	0.00
9	749.66	183,096	-151	24.0	0.0	0.0	48.6	13.5	65.0	0.0	47.4	0.250	0.00
10	749.60	182,916	-180	3.0	0.0	0.0	46.9	13.5	66.0	0.0	56.9	0.300	0.00
11	749.55	182,767	-149	22.0	0.0	0.0	44.6	13.5	65.0	0.0	47.4	0.250	0.00
12	749.50	182,618	-149	22.0	0.0	0.0	54.3	13.5	65.0	0.0	37.9	0.200	0.00
13	749.44	182,439	-179	-7.0	0.0	0.0	59.6	13.5	65.0	0.0	34.1	0.180	0.00
14	749.39	182,290	-149	35.0	0.0	0.0	60.5	13.5	66.0	0.0	43.5	0.230	0.00
15	749.33	182,111	-179	-9.0	0.0	0.0	60.3	13.5	64.0	0.0	32.1	0.170	0.00
16	749.27	181,932	-179	-33.0	0.0	0.0	59.4	13.4	66.0	0.0	7.6	0.040	0.00
17	749.22	181,783	-149	39.0	0.0	0.0	60.1	13.4	65.0	0.0	49.1	0.260	0.00
18	749.17	181,634	-149	7.0	0.0	0.0	45.9	13.4	65.0	0.0	32.1	0.170	0.00
19	749.12	181,485	-149	13.0	0.0	0.0	44.0	13.5	65.0	0.0	39.6	0.210	0.00
20	749.07	181,306	-179	-37.0	0.0	0.0	28.0	13.4	65.0	0.0	35.8	0.190	0.00
21	749.02	181,187	-119	25.0	0.0	0.0	42.9	13.4	65.0	0.0	22.6	0.120	0.00
22	748.97	181,038	-149	13.0	0.0	0.0	42.3	13.4	65.0	0.0	41.4	0.220	0.00
23	748.92	180,889	-149	5.0	0.0	0.0	44.1	13.4	66.0	0.0	30.1	0.160	0.00
24	748.86	180,710	-179	-30.0	0.0	0.0	42.3	13.4	65.0	0.0	28.2	0.150	0.00
25	748.82	180,591	-119	37.0	0.0	2.5	55.7	13.4	65.0	0.0	24.4	0.130	0.01
26	748.76	180,412	-179	-26.0	0.0	0.0	56.0	13.4	65.0	0.0	18.8	0.100	0.00
27	748.71	180,263	-149	30.0	0.0	0.0	62.5	13.4	54.0	0.0	48.8	0.260	0.00
28	748.66	180,114	-149	10.0	0.0	0.0	61.1	13.4	45.0	0.0	39.4	0.210	0.00
29	748.62	179,995	-119	26.0	0.0	0.0	63.0	13.4	40.0	0.0	28.1	0.150	0.00
30	748.56	179,819	-176	-36.0	0.0	0.0	61.9	13.4	37.0	0.0	28.1	0.150	0.00
TOTALS			-4,754	173.0	56.7	7.5	1,635.0	403.7	1,873.0	0.0	1,077.9	5.700	0.03
AVERAGE		182,062											

Comments: *Computed inflow is the sum of change in storage, releases and evaporation minus precip on the reservoir surface and ccwa inflow.
 Indicated outlet release includes leakage from outlet valves and spillway gates.
 Data based on a 24 hour period ending 0800.