

October 2022

DAY	ELEV	STORAGE ACRE-FEET		COMPUTED* INFLOW AF.	CCWA INFLOW AF.	PRECIP ON RES. SURF. AF.	RELEASE - AF.				EVAPORATION		PRECIP INCHES
		IN LAKE	CHANGE				TUNNEL	HILTON CREEK	OUTLET	SPILLWAY	AF.	INCH	
	695.65	65,436											
1	695.56	65,301	-135	-27.6	23.9	0.0	57.2	6.9	50.6	0.6	16.0	0.170	0.00
2	695.50	65,211	-90	13.6	23.7	0.0	64.2	6.9	40.6	0.6	15.0	0.160	0.00
3	695.44	65,121	-90	9.2	23.5	0.0	64.6	6.8	35.7	0.6	15.0	0.160	0.00
4	695.35	64,987	-134	-31.1	5.8	0.0	62.5	6.9	24.6	0.6	14.1	0.150	0.00
5	695.31	64,927	-60	44.0	5.8	0.0	71.8	6.9	14.6	0.6	15.9	0.170	0.00
6	695.23	64,807	-120	0.6	5.8	0.0	85.8	6.8	11.7	0.6	21.5	0.230	0.00
7	695.16	64,702	-105	15.5	5.9	0.0	85.7	7.0	12.5	0.6	20.6	0.220	0.00
8	695.07	64,553	-149	-26.6	5.9	0.0	89.5	6.9	12.6	0.6	18.7	0.200	0.00
9	695.00	64,463	-90	25.2	5.9	0.0	85.1	6.9	12.6	0.6	15.9	0.170	0.00
10	694.95	64,388	-75	5.5	5.9	0.0	51.4	6.9	12.6	0.6	14.9	0.160	0.00
11	694.90	64,313	-75	2.4	5.9	0.0	49.2	6.9	13.6	0.6	13.0	0.140	0.00
12	694.85	64,239	-74	-0.4	5.9	0.0	48.2	6.9	12.6	0.6	11.2	0.120	0.00
13	694.79	64,149	-90	-9.5	5.9	0.0	53.3	7.0	12.5	0.6	13.0	0.140	0.00
14	694.74	64,074	-75	2.4	5.9	0.0	52.1	6.8	12.6	0.6	11.2	0.120	0.00
15	694.70	64,014	-60	15.7	5.9	1.2	51.6	6.7	12.7	0.6	11.2	0.120	0.01
16	694.64	63,925	-89	-14.2	5.9	0.0	52.3	6.8	12.6	0.6	8.4	0.090	0.00
17	694.60	63,865	-60	23.3	6.0	0.0	52.5	7.0	12.5	0.6	16.7	0.180	0.00
18	694.54	63,777	-88	-9.7	5.8	0.0	52.9	6.9	12.6	0.6	11.1	0.120	0.00
19	694.51	63,732	-45	29.4	0.0	0.0	46.5	6.8	4.7	0.6	15.8	0.170	0.00
20	694.46	63,659	-73	14.1	0.0	0.0	57.4	6.9	4.6	0.6	17.6	0.190	0.00
21	694.37	63,526	-133	-22.5	0.0	0.0	73.2	6.9	7.6	0.6	22.2	0.240	0.00
22	694.31	63,437	-89	13.6	0.0	2.5	78.1	6.9	6.6	0.6	12.9	0.140	0.02
23	694.22	63,305	-132	-26.8	0.0	0.0	80.0	6.9	7.6	0.6	10.1	0.110	0.00
24	694.13	63,172	-133	-30.8	0.0	0.0	73.4	6.8	6.7	0.6	14.7	0.160	0.00
25	694.11	63,142	-30	28.7	0.0	0.0	26.1	6.9	7.6	0.6	17.5	0.190	0.00
26	694.08	63,083	-59	-5.5	0.0	0.0	24.7	6.8	6.7	0.6	14.7	0.160	0.00
27	694.01	62,995	-88	-35.4	0.0	0.0	24.7	6.8	6.7	0.6	13.8	0.150	0.00
28	693.97	62,936	-59	22.7	0.0	0.0	54.7	6.9	7.6	0.6	11.9	0.130	0.00
29	693.91	62,847	-89	2.9	0.0	0.0	67.6	6.9	7.6	0.6	9.2	0.100	0.00
30	693.83	62,729	-118	-23.5	0.0	0.0	65.7	6.8	6.7	0.6	14.7	0.160	0.00
31	693.78	62,655	-74	25.6	0.0	0.0	68.0	6.9	7.6	0.6	16.5	0.180	0.00
TOTALS			-2,781	30.8	159.3	3.7	1,870.0	213.1	418.1	18.6	455.0	4.900	0.03
AVERAGE		63,937											

Comments: *Computed inflow is the sum of change in storage, releases and evaporation minus precip on the reservoir surface and ccwa inflow.
 Indicated outlet release includes leakage from outlet valves and spillway gates.
 Data based on a 24 hour period ending 0800.