

UNITED STATES DEPARTMENT OF THE INTERIOR
U.S. BUREAU OF RECLAMATION-CENTRAL VALLEY PROJECT-CALIFORNIA

CONTRA COSTA CANAL AT PUMPING PLANT #1
WATER QUALITY REPORT

APRIL 2008

RUN DATE: May 5, 2008

ELECTRICAL CONDUCTIVITY, UMHOS

DAY	HIGH	LOW	MEAN
1	407	385	393
2	440	405	421
3	447	433	443
4	455	439	446
5	462	452	458
6	470	462	467
7	471	450	463
8	456	450	455
9	464	453	460
10	454	448	452
11	446	437	440
12	449	439	445
13	469	449	463
14	481	467	476
15	483	479	481
16	489	479	485
17	496	488	494
18	498	490	496
19	497	493	495
20	494	484	489
21	0	0	0
22	490	489	489
23	493	490	491
24	497	493	495
25	529	495	499
26	0	0	0
27	0	0	0
28	0	0	0
29	532	515	526
30	535	532	533

Comments:

0 reading indicates that the station was out of service.