

UNITED STATES DEPARTMENT OF THE INTERIOR
U.S. BUREAU OF RECLAMATION-CENTRAL VALLEY PROJECT-CALIFORNIA

COLLINSVILLE BOTTOM ON THE SACRAMENTO RIVER

FEBRUARY 2003

WATER QUALITY REPORT

RUN DATE: March 4, 2003

ELECTRICAL CONDUCTIVITY, UMHOS

DAY	HIGH	LOW	MEAN
1	205	180	194
2	197	173	188
3	204	183	191
4	221	185	200
5	204	179	190
6	206	190	197
7	210	190	201
8	202	189	196
9	224	194	202
10	1,848	197	340
11	5,422	202	1,262
12	7,089	221	1,891
13	7,584	210	2,217
14	4,249	218	1,349
15	1,684	197	602
16	1,213	187	363
17	647	173	263
18	390	164	199
19	284	173	195
20	262	169	184
21	186	156	175
22	206	166	179
23	203	166	184
24	200	157	175
25	211	153	173
26	198	158	169
27	185	159	172
28	195	167	178

Comments:

0 reading indicates that the station was out of service.