

UNITED STATES DEPARTMENT OF THE INTERIOR
U.S. BUREAU OF RECLAMATION-CENTRAL VALLEY PROJECT-CALIFORNIA

DELTA MENDOTA CANAL AT CHECK 20
WATER QUALITY REPORT

DECEMBER 2015

RUN DATE: January 5, 2016

ELECTRICAL CONDUCTIVITY, UMHOS

DAY	HIGH	LOW	MEAN	TDS
1	865	761	821	523
2	891	797	857	546
3	822	778	801	511
4	817	775	793	506
5	819	780	795	507
6	825	777	801	511
7	782	769	776	496
8	823	778	798	509
9	795	761	783	500
10	788	762	771	492
11	821	787	805	513
12	806	792	798	509
13	836	796	810	517
14	837	795	815	520
15	847	809	826	526
16	859	820	837	533
17	850	823	839	535
18	898	834	861	548
19	881	772	814	519
20	900	790	830	529
21	908	879	895	569
22	0	0	0	0
23	0	0	0	0
24	865	828	841	536
25	863	812	834	531
26	851	812	831	530
27	877	852	864	550
28	894	861	884	562
29	867	860	864	550
30	896	864	880	560
31	922	876	904	575
TOTAL			24,028	

Comments:

0 reading indicates that the station was out of service.