

UNITED STATES DEPARTMENT OF THE INTERIOR
U.S. BUREAU OF RECLAMATION-CENTRAL VALLEY PROJECT-CALIFORNIA

DELTA MENDOTA CANAL AT CHECK 21
WATER QUALITY REPORT

DECEMBER 2019

RUN DATE: January 7, 2020

ELECTRICAL CONDUCTIVITY, UMHOS

DAY	HIGH	LOW	MEAN	TDS
1	514	281	352	234
2	555	422	490	319
3	534	474	516	335
4	509	407	466	304
5	500	380	429	281
6	548	395	463	302
7	449	317	384	253
8	524	380	441	289
9	511	280	370	245
10	509	312	389	256
11	469	337	416	273
12	466	354	416	273
13	421	343	388	256
14	472	371	411	270
15	372	289	337	224
16	352	276	318	213
17	432	286	366	242
18	439	330	387	255
19	393	344	378	250
20	413	332	383	253
21	407	347	382	252
22	405	354	381	251
23	397	358	377	249
24	379	349	362	240
25	379	348	359	238
26	449	354	382	252
27	504	379	438	287
28	518	423	461	301
29	524	419	481	313
30	528	414	479	312
31	515	413	481	313
TOTAL			12,683	

Comments:

0 reading indicates that the station was out of service.