

UNITED STATES DEPARTMENT OF THE INTERIOR
U.S. BUREAU OF RECLAMATION-CENTRAL VALLEY PROJECT-CALIFORNIA

DELTA MENDOTA CANAL AT HEADWORKS
WATER QUALITY REPORT

FEBRUARY 2007

RUN DATE: March 8, 2007

ELECTRICAL CONDUCTIVITY, UMHOS

DAY	HIGH	LOW	MEAN	TDS
1	684	435	503	327
2	724	439	538	348
3	706	444	545	353
4	732	436	548	355
5	751	431	559	361
6	758	425	552	357
7	772	423	570	368
8	779	426	573	370
9	787	424	546	353
10	794	433	562	363
11	793	424	536	347
12	784	423	548	355
13	772	412	526	341
14	759	425	533	345
15	755	424	548	355
16	739	407	544	352
17	747	405	542	351
18	744	403	523	339
19	697	407	520	337
20	713	406	535	347
21	746	399	544	352
22	765	393	531	344
23	761	382	509	331
24	781	376	538	348
25	765	376	483	314
26	771	379	521	338
27	775	369	529	343
28	776	372	526	341
TOTAL			15,032	

Comments:

0 reading indicates that the station was out of service.