

UNITED STATES DEPARTMENT OF THE INTERIOR
U.S. BUREAU OF RECLAMATION-CENTRAL VALLEY PROJECT-CALIFORNIA

DELTA MENDOTA CANAL AT HEADWORKS
WATER QUALITY REPORT

MARCH 2015

RUN DATE: April 1, 2015

ELECTRICAL CONDUCTIVITY, UMHOS

DAY	HIGH	LOW	MEAN	TDS
1	1,036	471	722	462
2	1,012	439	616	397
3	810	444	584	377
4	817	419	588	379
5	824	434	610	393
6	822	439	575	371
7	762	439	568	367
8	742	440	545	353
9	786	449	554	358
10	756	442	545	353
11	753	459	522	339
12	803	436	517	336
13	786	406	509	331
14	811	416	494	321
15	714	424	493	321
16	644	428	563	364
17	612	522	570	368
18	621	583	602	388
19	632	566	605	390
20	622	611	617	397
21	622	594	615	396
22	658	623	645	415
23	660	646	654	420
24	664	653	660	424
25	651	616	633	407
26	630	596	615	396
27	678	622	653	420
28	673	647	660	424
29	708	642	674	433
30	783	667	712	456
31	734	579	665	427
TOTAL			18,585	

Comments:

0 reading indicates that the station was out of service.