

UNITED STATES DEPARTMENT OF THE INTERIOR
U.S. BUREAU OF RECLAMATION-CENTRAL VALLEY PROJECT-CALIFORNIA

MAY 2002

**DELTA MENDOTA CANAL AT HEADWORKS
WATER QUALITY REPORT**

RUN DATE: June 5, 2002

ELECTRICAL CONDUCTIVITY, UMHOS

DAY	HIGH	LOW	MEAN	TDS
1	501	334	383	253
2	497	344	396	261
3	499	352	401	264
4	513	355	415	272
5	518	378	420	276
6	495	365	410	269
7	488	375	413	271
8	482	372	411	270
9	490	385	427	280
10	482	385	429	281
11	460	385	415	272
12	465	385	412	271
13	467	382	412	271
14	487	379	420	276
15	502	382	422	277
16	508	383	420	276
17	505	383	420	276
18	526	384	426	279
19	525	384	423	277
20	556	386	440	288
21	561	395	439	287
22	553	395	459	300
23	521	413	458	299
24	478	402	435	285
25	504	410	449	293
26	585	434	509	331
27	617	461	559	361
28	688	497	582	376
29	684	508	576	372
30	657	497	570	368
31	658	493	568	367
TOTAL			13,919	

Comments:

0 reading indicates that the station was out of service.