

UNITED STATES DEPARTMENT OF THE INTERIOR
U.S. BUREAU OF RECLAMATION-CENTRAL VALLEY PROJECT-CALIFORNIA

DELTA MENDOTA CANAL AT HEADWORKS
WATER QUALITY REPORT

AUGUST 2018

RUN DATE: September 6, 2018

ELECTRICAL CONDUCTIVITY, UMHOS

DAY	HIGH	LOW	MEAN	TDS
1	358	235	266	180
2	393	248	269	182
3	351	246	266	180
4	428	233	272	184
5	310	231	259	176
6	320	226	257	175
7	300	216	247	169
8	358	220	249	170
9	416	223	264	179
10	362	221	256	174
11	490	228	281	190
12	450	234	290	195
13	474	236	290	195
14	469	243	307	206
15	459	243	299	201
16	451	257	313	209
17	446	253	323	216
18	413	285	327	218
19	475	299	344	229
20	430	284	336	224
21	409	286	328	219
22	443	296	344	229
23	412	327	367	243
24	417	341	376	248
25	466	417	436	285
26	580	466	515	334
27	585	518	561	363
28	0	0	0	0
29	0	0	0	0
30	0	0	0	0
31	0	0	0	0
TOTAL			8,642	

Comments:

0 reading indicates that the station was out of service.