



February 2023

DAY	ELEV	STORAGE		COMPUTED* INFLOW C.F.S.	RELEASE - C.F.S.				EVAPORATION		PRECIP INCHES
		1000 ACRE-FEET			RIVER			PUMPING	C. F. S.	INCHES	
		IN LAKE	CHANGE	POWER	SPILL	OUTLET	PLANT				
		500.5									
1	416.58	500.4	-0.1	4,041	4,009	3	0	56	13	0.05	0.00
2	416.57	500.3	-0.1	3,988	3,956	7	0	52	13	0.05	0.00
3	416.47	499.5	-0.8	3,807	4,144	7	0	51	5	0.02	0.01
4	416.27	498.0	-1.6	3,546	4,282	4	0	60	0	0.00	0.43
5	416.54	500.1	2.1	5,266	4,120	6	0	58	3	0.01	0.03
6	417.06	504.2	4.1	5,871	3,703	3	0	63	21	0.08	0.00
7	417.24	505.7	1.4	4,845	4,038	7	0	58	16	0.06	0.00
8	417.43	507.2	1.5	4,844	4,008	6	0	47	16	0.06	0.00
9	417.71	509.4	2.2	5,422	4,222	5	0	49	16	0.06	0.00
10	417.93	511.2	1.8	5,275	4,298	5	0	57	27	0.10	0.00
11	418.26	513.9	2.7	5,568	4,138	7	0	59	22	0.08	0.00
12	418.51	515.9	2.0	5,276	4,166	3	0	62	27	0.10	0.00
13	418.78	518.1	2.2	5,236	4,038	3	0	62	33	0.12	0.00
14	419.07	520.4	2.3	5,279	3,985	10	0	59	41	0.15	0.00
15	419.30	522.3	1.9	5,254	4,208	8	0	57	36	0.13	0.00
16	419.45	523.5	1.2	4,932	4,223	9	0	56	27	0.10	0.00
17	419.58	524.6	1.1	4,502	3,873	9	0	56	30	0.11	0.00
18	419.63	525.0	0.4	4,444	4,146	4	0	64	25	0.09	0.00
19	419.67	525.3	0.3	4,346	4,086	6	0	67	22	0.08	0.00
20	419.77	526.1	0.8	4,564	4,051	7	0	73	22	0.08	0.00
21	419.88	527.0	0.9	4,743	4,180	6	0	61	44	0.16	0.00
22	420.05	528.4	1.4	4,801	4,018	9	0	56	17	0.06	0.00
23	420.28	530.3	1.9	5,297	4,271	7	0	54	11	0.04	0.01
24	420.74	534.1	3.8	5,985	4,021	3	0	52	0	0.00	0.67
25	421.00	536.2	2.1	5,303	4,160	6	0	55	3	0.01	0.01
26	421.14	537.4	1.2	4,967	4,313	11	0	57	0	0.00	0.40
27	421.70	542.0	4.7	6,522	4,113	6	0	58	0	0.00	0.36
28	422.85	551.6	9.6	8,967	4,061	10	0	49	0	0.00	0.79
TOTALS			51.0	142,891	114,831	177	0	1,608	490	1.80	2.71
ACRE-FEET			51,000	283,424	227,767	351	0	3,189	972		

* COMPUTED INFLOW IS THE SUM OF CHANGE IN STORAGE, RELEASES, PUMPING AND EVAPORATION

SUMMARY

Release (ACRE-FEET)				Precipitation	
Power	227,767	Outlet	0	This month =	2.71
Spill	351	Pumping Plant	3,189	October 01, 2022 To date =	25.43
Total =		231,308			