



September 2023

DAY	ELEV	STORAGE		COMPUTED* INFLOW C.F.S.	RELEASE - C.F.S.			PUMPING PLANT	EVAPORATION		PRECIP INCHES
		1000 ACRE-FEET			RIVER				C. F. S.	INCHES	
		IN LAKE	CHANGE	POWER	SPILL	OUTLET					
		728.5									
1	441.91	724.8	-3.7	2,194	3,747	0	0	249	65	0.20	0.00
2	441.71	722.9	-1.9	2,851	3,573	0	0	237	19	0.06	0.00
3	441.53	721.1	-1.7	2,962	3,607	0	0	216	19	0.06	0.00
4	441.29	718.8	-2.3	2,670	3,534	0	0	241	68	0.21	0.00
5	441.11	717.1	-1.7	2,932	3,484	0	0	260	68	0.21	0.00
6	440.76	713.7	-3.4	2,182	3,562	0	0	257	67	0.21	0.00
7	440.54	711.6	-2.1	2,311	3,040	0	0	253	87	0.27	0.00
8	440.35	709.7	-1.8	2,417	3,001	13	0	246	80	0.25	0.00
9	440.27	709.0	-0.8	2,893	2,946	0	0	240	96	0.30	0.00
10	440.13	707.6	-1.3	2,567	2,917	0	0	240	90	0.28	0.00
11	439.90	705.4	-2.2	2,223	3,009	0	0	235	93	0.29	0.00
12	439.65	703.0	-2.4	2,131	3,025	0	0	236	76	0.24	0.00
13	439.46	701.2	-1.8	2,144	2,487	256	0	235	83	0.26	0.00
14	439.22	698.9	-2.3	2,241	3,090	10	0	220	79	0.25	0.00
15	439.06	697.4	-1.5	2,572	3,046	0	0	228	70	0.22	0.00
16	438.85	695.4	-2.0	2,368	3,053	0	0	237	86	0.27	0.00
17	438.62	693.2	-2.2	2,225	3,029	0	0	225	73	0.23	0.00
18	438.35	690.6	-2.6	1,958	2,968	7	0	217	60	0.19	0.00
19	438.21	689.3	-1.3	2,769	3,119	12	0	224	85	0.27	0.00
20	437.99	687.2	-2.1	2,288	3,034	9	0	230	69	0.22	0.00
21	437.84	685.8	-1.4	2,633	3,048	7	0	226	66	0.21	0.00
22	437.66	684.1	-1.7	2,503	3,080	0	0	223	57	0.18	0.00
23	437.44	682.0	-2.1	2,162	2,925	0	0	221	63	0.20	0.00
24	437.21	679.8	-2.2	2,154	2,968	0	0	221	60	0.19	0.00
25	437.01	677.9	-1.9	2,450	3,118	0	0	221	63	0.20	0.00
26	436.77	675.7	-2.2	2,201	3,045	14	0	214	62	0.20	0.00
27	436.48	673.0	-2.7	2,037	3,137	7	0	204	59	0.19	0.00
28	436.28	671.1	-1.9	2,482	3,145	12	0	202	68	0.22	0.00
29	436.07	669.1	-2.0	2,277	2,988	10	0	196	75	0.24	0.00
30	435.84	667.0	-2.1	2,211	3,053	7	0	204	28	0.09	0.04
<b>TOTALS</b>			<b>-61.3</b>	<b>72,008</b>	<b>93,778</b>	<b>364</b>	<b>0</b>	<b>6,858</b>	<b>2,034</b>	<b>6.41</b>	<b>0.04</b>
<b>ACRE-FEET</b>			<b>-61,300</b>	<b>142,828</b>	<b>186,009</b>	<b>722</b>	<b>0</b>	<b>13,603</b>	<b>4,034</b>		

\* COMPUTED INFLOW IS THE SUM OF CHANGE IN STORAGE, RELEASES, PUMPING AND EVAPORATION

SUMMARY

Release (ACRE-FEET)				Precipitation	
Power	186,009	Outlet	0	This month =	0.04
Spill	722	Pumping Plant	13,603	October 01, 2022 To date =	30.85
Total =		200,334			