



September 2026

DAY	ELEV	STORAGE 1000 ACRE-FEET		COMPUTED* INFLOW C.F.S.	RELEASE - C.F.S.			EVAPORATION**		PRECIP** INCHES
		IN LAKE	CHANGE		POWER	SPILL	OUTLET	C.F.S.	INCHES	
		1,772.8								
1	2,324.35	1,769.0	-3.7	-101	1,659	0	0	130	0.33	0.00
2	2,324.08	1,765.4	-3.6	-53	1,714	0	0	55	0.14	0.02
3	2,323.82	1,762.0	-3.5	18	1,743	0	0	24	0.06	0.35
4	2,323.58	1,758.8	-3.2	144	1,729	0	0	27	0.07	0.12
5	2,323.34	1,755.6	-3.2	177	1,726	0	0	63	0.16	0.01
6	2,323.11	1,752.5	-3.1	221	1,723	0	0	43	0.11	0.02
7	2,322.89	1,749.6	-2.9	316	1,744	0	0	47	0.12	0.00
8	2,322.65	1,746.4	-3.2	277	1,765	0	0	117	0.30	0.00
9	2,322.44	1,743.6	-2.8	373	1,660	0	0	117	0.30	0.00
10	2,322.24	1,741.0	-2.7	519	1,756	0	0	101	0.26	0.00
11	2,321.99	1,737.6	-3.3	35	1,641	0	0	66	0.17	0.00
12	2,321.67	1,733.4	-4.2	-280	1,754	0	0	97	0.25	0.00
13	2,321.41	1,730.0	-3.4	113	1,774	0	0	70	0.18	0.00
14	2,321.15	1,726.5	-3.4	125	1,790	0	0	66	0.17	0.00
15	2,320.91	1,723.4	-3.2	161	1,686	0	0	70	0.18	0.00
16	2,320.65	1,720.0	-3.4	117	1,763	0	0	77	0.20	0.00
17	2,320.39	1,716.5	-3.4	71	1,713	0	0	81	0.21	0.00
18	2,320.15	1,713.4	-3.2	222	1,744	0	0	69	0.18	0.00
19	2,319.95	1,710.8	-2.6	365	1,631	0	0	58	0.15	0.00
20	2,319.70	1,707.5	-3.3	206	1,782	0	0	73	0.19	0.00
21	2,319.47	1,704.5	-3.0	285	1,733	0	0	69	0.18	0.00
22	2,319.28	1,702.0	-2.5	194	1,366	0	0	81	0.21	0.00
23	2,319.12	1,699.9	-2.1	107	1,085	0	0	77	0.20	0.00
24	2,318.92	1,697.3	-2.6	115	1,354	0	0	77	0.20	0.00
25	2,318.73	1,694.8	-2.5	-171	999	0	0	77	0.20	0.00
26	2,318.57	1,692.7	-2.1	99	1,076	0	0	73	0.19	0.00
27	2,318.35	1,689.9	-2.9	-167	1,211	0	0	65	0.17	0.00
28	2,318.20	1,687.9	-2.0	51	975	0	0	61	0.16	0.00
29	2,318.07	1,686.2	-1.7	191	975	0	0	69	0.18	0.00
30	2,317.94	1,684.5	-1.7	197	987	0	0	61	0.16	0.00
TOTALS			-88.4	3,927	46,258	0	0	2,161	5.58	0.52
ACRE-FEET			-88,400	7,789	91,753	0	0	4,286		

Comments: * COMPUTED INFLOW IS THE SUM OF CHANGE IN STORAGE, RELEASES, AND EVAPORATION
** Evaporation and precipitation records taken from station at Trinity River Hatchery.

SUMMARY

Release (ACRE-FEET)				Precipitation	
Power	91,753		Outlet	This month	0.52
Spill	0		Total	October 01, 2025 To date	31.54