

Hydropower Modeling Attachment: Alternative Plan 1, SWP, Existing Conditions

**Upper San Joaquin River Basin Storage
Investigation, California**

Prepared by:

**United States Department of the Interior
Bureau of Reclamation
Mid-Pacific Region**



**U.S. Department of the Interior
Bureau of Reclamation**

August 2014

Mission Statements

The mission of the Department of the Interior is to protect and provide access to our Nation's natural and cultural heritage and honor our trust responsibilities to Indian Tribes and our commitments to island communities.

The mission of the Bureau of Reclamation is to manage, develop, and protect water and related resources in an environmentally and economically sound manner in the interest of the American public.

Energy generated (GWh) at Alamo Dam: Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Total
1922	Above Normal	11.23	10.87	11.13	2.47	4.01	6.06	8.43	8.66	9.09	8.75	9.54	8.41	98.65
1923	Below Normal	8.07	7.23	6.51	11.23	10.15	11.23	7.76	9.52	9.71	9.60	10.71	9.83	111.55
1924	Critical	8.14	7.23	6.30	5.15	5.26	3.73	4.92	6.60	6.85	6.15	6.02	5.70	72.05
1925	Dry	3.70	2.83	2.45	1.54	2.08	3.96	7.92	10.38	10.61	10.47	11.23	10.69	77.86
1926	Dry	8.43	7.52	6.50	2.95	3.61	4.01	6.38	8.96	9.18	9.05	9.96	9.24	85.79
1927	Wet	7.28	6.47	5.60	3.08	4.82	7.37	8.98	9.36	9.83	9.42	10.17	9.00	91.38
1928	Above Normal	8.68	7.79	7.07	11.23	10.51	7.28	8.96	9.25	9.68	9.28	9.96	8.85	108.54
1929	Critical	8.45	7.60	6.92	11.23	10.15	5.78	4.06	6.00	6.21	5.60	5.49	4.99	82.48
1930	Dry	3.43	2.60	2.25	1.44	2.34	2.68	6.51	8.52	8.81	8.34	8.77	8.22	63.91
1931	Critical	5.97	5.06	4.40	2.14	2.74	2.58	5.68	7.65	7.89	7.09	6.96	6.50	64.66
1932	Dry	4.12	3.42	2.93	1.74	2.97	3.37	6.29	8.08	8.30	8.11	8.78	8.18	66.29
1933	Critical	6.26	5.50	4.77	2.37	3.00	3.33	6.41	8.71	9.02	8.25	8.33	7.87	73.82
1934	Critical	5.37	4.27	3.70	1.90	2.34	2.67	6.09	8.19	8.46	7.59	1.08	0.29	51.95
1935	Below Normal	4.06	10.03	7.92	1.71	2.74	3.27	8.10	10.43	3.50	11.23	11.23	10.87	85.09
1936	Below Normal	9.02	8.09	6.97	3.03	4.35	8.86	8.98	9.77	10.25	9.82	10.62	9.40	99.16
1937	Below Normal	9.06	8.14	7.38	11.23	10.15	10.76	9.00	9.49	9.96	9.62	10.44	9.13	114.36
1938	Wet	8.74	7.84	7.06	11.23	10.15	11.23	8.56	9.93	10.41	9.51	11.15	8.94	114.75
1939	Dry	8.53	7.60	6.72	11.23	10.15	11.23	9.16	9.97	1.81	11.15	6.41	10.87	104.83
1940	Above Normal	10.05	4.24	10.20	1.43	2.08	4.38	8.05	10.53	7.75	10.91	11.23	10.87	91.72
1941	Wet	8.76	7.82	6.74	4.70	5.53	11.23	7.68	8.33	8.74	8.54	9.43	8.17	95.67
1942	Wet	7.78	6.93	6.14	11.23	10.15	11.23	9.92	8.69	9.14	8.82	9.67	8.49	108.19
1943	Wet	8.16	7.29	6.53	11.23	10.15	10.40	9.63	8.84	10.29	9.96	10.88	9.56	113.92
1944	Dry	9.18	8.22	7.37	11.01	10.42	5.86	6.49	8.42	8.61	8.36	8.98	8.40	101.32
1945	Below Normal	6.34	5.50	4.78	2.68	3.38	11.23	8.96	9.37	9.84	9.44	10.18	9.01	90.71
1946	Below Normal	8.68	7.79	7.57	11.23	8.45	7.98	8.46	8.87	9.30	8.94	9.75	8.62	105.64
1947	Dry	8.30	7.44	6.71	11.23	10.15	7.34	8.74	10.11	10.45	10.15	11.01	10.06	111.69
1948	Below Normal	8.67	7.77	6.86	7.92	7.71	4.28	6.12	5.95	0.31	11.23	11.23	10.87	88.92
1949	Dry	9.04	8.07	6.97	2.97	3.63	3.72	8.75	9.95	10.33	10.01	10.83	9.86	94.13
1950	Below Normal	8.61	7.73	6.85	2.56	2.94	3.12	7.35	9.35	0.31	11.23	11.23	10.87	82.15
1951	Above Normal	8.84	7.88	6.83	11.23	10.15	11.23	8.36	9.17	9.63	9.24	10.07	8.91	111.54
1952	Wet	8.59	7.69	6.94	11.23	10.51	8.91	7.30	8.22	8.59	8.48	9.45	8.11	104.02
1953	Wet	7.69	6.81	5.99	11.23	10.15	11.23	10.38	8.78	9.01	8.79	9.68	8.72	112.06
1954	Above Normal	7.84	6.99	6.20	9.96	10.15	7.88	8.13	10.36	10.01	9.57	11.23	10.86	109.18
1955	Dry	8.56	7.62	6.58	3.46	4.35	4.28	6.77	8.66	8.84	8.75	9.59	8.91	86.37
1956	Wet	6.98	6.20	5.37	11.23	10.51	11.23	9.56	10.07	10.56	10.14	11.08	9.79	112.72
1957	Above Normal	9.44	8.47	7.61	11.23	10.15	8.52	6.72	4.75	0.35	10.71	11.23	10.76	99.94
1958	Wet	8.34	7.44	6.43	3.43	6.06	11.23	9.73	10.27	10.76	10.41	11.23	9.98	105.31
1959	Below Normal	9.60	8.57	7.66	11.23	10.15	11.23	7.75	9.84	1.77	10.95	11.23	10.87	110.85
1960	Dry	8.74	7.80	6.72	2.88	3.15	3.39	8.67	10.90	5.19	11.23	7.20	10.87	86.74
1961	Dry	10.18	9.12	7.86	3.95	4.33	3.43	7.29	9.27	9.52	9.38	7.50	3.65	85.48
1962	Below Normal	0.82	6.84	11.23	1.13	1.72	4.00	7.40	9.49	0.32	11.23	11.23	10.87	76.28
1963	Wet	9.00	8.03	6.95	5.68	6.24	6.96	8.33	8.80	9.22	8.87	9.67	8.56	96.31
1964	Dry	8.25	7.38	8.36	11.23	6.17	6.33	8.94	9.14	9.60	9.21	9.98	8.82	103.41
1965	Wet	8.53	7.63	6.91	11.02	10.15	8.08	8.18	8.56	8.46	8.67	9.44	8.39	104.02
1966	Below Normal	7.94	7.10	6.38	11.23	10.15	8.76	7.90	9.82	8.94	10.00	11.16	10.28	109.66
1967	Wet	8.34	7.41	6.42	4.42	7.08	7.43	9.04	9.47	9.93	9.59	10.48	9.20	98.81
1968	Below Normal	8.84	7.91	7.10	11.23	10.51	11.23	8.85	9.13	9.44	9.22	10.22	9.30	112.98
1969	Wet	8.01	7.13	6.25	8.96	10.15	11.23	8.65	9.19	9.63	9.38	10.40	9.03	108.01
1970	Wet	8.71	7.56	6.78	11.23	10.15	11.23	8.43	9.15	9.61	9.21	10.04	8.88	110.98
1971	Wet	8.57	7.67	6.92	11.23	10.15	10.39	7.57	9.76	9.80	9.87	11.01	10.18	113.12
1972	Below Normal	8.10	7.19	6.22	3.93	5.69	6.46	8.09	9.92	10.18	10.00	11.04	10.16	96.98
1973	Above Normal	8.33	7.43	6.46	5.45	8.08	8.15	8.78	9.43	9.92	9.47	10.28	9.09	100.87
1974	Wet	8.77	7.86	7.11	11.23	10.15	11.23	9.21	9.38	9.86	9.48	10.40	9.15	113.83
1975	Wet	8.80	7.86	7.04	11.23	10.15	11.23	8.95	9.18	9.66	9.23	9.96	8.83	112.12
1976	Critical	8.49	7.62	6.92	11.23	10.51	7.28	7.62	9.77	1.76	10.95	6.64	10.87	99.66
1977	Critical	9.38	8.40	7.21	2.81	3.11	2.56	1.24	0.25	0.29	0.45	0.38	0.29	36.37
1978	Above Normal	0.11	1.88	10.52	1.22	3.09	5.84	8.19	8.49	8.92	8.56	9.25	8.15	74.22
1979	Below Normal	7.85	7.01	6.35	11.23	10.15	7.89	8.48	9.01	9.48	9.10	9.86	8.69	105.10
1980	Above Normal	8.34	7.46	6.74	11.23	10.51	11.23	8.54	9.05	9.49	9.28	10.25	8.87	110.99
1981	Dry	8.46	7.53	6.67	11.23	10.15	9.08	7.42	9.65	1.75	11.23	10.52	10.87	104.56
1982	Wet	9.12	8.16	7.00	5.37	6.06	11.23	10.22	9.92	10.41	10.08	11.11	9.69	108.37
1983	Wet	9.41	8.41	11.23	11.23	10.15	11.23	7.24	7.78	8.49	9.19	8.72	7.74	110.82
1984	Wet	8.25	7.41	11.23	11.23	10.51	11.23	8.42	9.28	9.71	9.34	10.18	9.02	115.81
1985	Dry	8.68	7.79	7.94	11.23	10.15	10.07	8.33	8.72	9.19	8.79	9.51	8.41	108.81
1986	Wet	8.10	7.27	6.59	11.23	10.15	11.23	9.28	9.80	10.30	9.96	10.91	9.50	114.32
1987	Dry	9.11	8.16	7.30	11.23	10.15	7.86	6.30	8.51	8.80	7.86	7.75	7.35	100.38
1988	Critical	4.85	3.75	3.22	1.73	2.56	2.26	4.21	5.60	5.81	5.26	5.13	4.85	49.23
1989	Dry	3.13	2.37	2.06	1.43	2.12	2.21	8.44	10.92	6.32	11.23	10.86	10.87	71.96
1990	Critical	9.45	8.45	7.27	3.00	3.43	3.07	5.48	7.34	7.62	6.83	6.70	6.35	74.99
1991	Critical	4.15	3.19	2.75	1.61	2.08	2.20	4.29	5.30	2.13	6.15	5.95	5.67	45.47
1992	Critical	3.59	2.59	2.40	1.43	1.93	1.99	4.22	5.62	5.81	0.39	0.36	2.88	33.21
1993	Above Normal	7.24	0.65	9.22	1.40	4.55	5.90	8.21	9.28	4.17	9.95	10.88	9.87	81.32
1994	Critical	8.70	7.80	6.89	9.17	9.15	5.89	6.94	8.82	6.51	9.19	1.82	8.32	89.20
1995	Wet	0.95	2.35	11.23	1.12	4.07	5.45	9.69	9.96	10.45	10.08	10.99	9.65	85.99
1996	Wet	9.28	8.32	7.48	11.23	10.51	9.98	9.12	9.33	9.79	9.40	10.20	9.02	113.66
1997	Wet	8.69	7.80	7.05	11.23	10.15	11.23	8.48	8.96	9.38	9.08	9.98	8.75	110.78
1998	Wet	8.38	7.49	6.69	11.23	10.15	11.23	8.42	9.26	9.72	9.51	10.50	9.08	111.66
1999	Wet	8.64	8.77	8.52	11.23	10.15	11.23	8.48	9.17	9.61	9.27	10.10	8.93	114.10
2000	Above Normal	8.61	7.72	6.97	11.23	10.51	8.93	8.31	10.26	10.51	10.37	11.23	10.47	115.12
2001	Dry	8.53	7.63	6.64	4.97	5.01	3.75	6.38	8.65	8.94	8.04	7.92	7.50	83.96
2002	Dry	4.92	3.82	3.28	2.23	3.57	4.34	9.05	9.23	9.66	9.29	9.97	8.83	78.19
2003	Above Normal	8.50	3.20	9.28	2.26	3.39	4.18	6.91	8.83	0.73	10.56	11.23	10.63	79.70
Average		7.69	6.85	6.80	7.10	7.08	7.39	7.80	8.86	7.92	9.11	9.33	8.72	94.64
Wet		8.15	7.37	7.38	9.18	9.01	10.23	8.83	9.25	9.67	9.40	10.26	9.01	107.72
Above Normal		8.10	6.22	8.19	6.70	7.27	7.47	8.13	9.01	7.52	9.72	10.53	9.65	98.48
Below Normal		7.55	7.64	7.13	7.26	7.02	7.88	8.09	9.28	6.67	10.1			

Energy generated (GWh) at Alamo Dam: Alternative1_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Total
1922	Above Normal	11.23	10.87	11.13	3.20	4.10	6.16	8.76	9.11	10.28	9.98	10.91	9.63	105.36
1923	Below Normal	9.25	8.34	7.51	11.23	10.15	11.23	10.13	1.56	0.99	11.23	11.23	10.87	103.72
1924	Critical	10.76	9.72	8.62	8.22	7.64	4.71	5.68	7.66	3.94	0.39	0.35	0.29	67.98
1925	Dry	4.47	8.89	11.23	1.96	2.75	3.31	6.90	8.79	9.22	9.10	9.93	9.24	85.79
1926	Dry	7.28	6.51	5.66	3.15	3.62	4.30	6.35	9.93	7.85	10.36	11.23	10.50	86.74
1927	Wet	2.01	9.62	8.08	3.34	4.78	7.44	8.75	9.12	7.03	10.14	10.88	9.72	90.91
1928	Above Normal	9.41	8.52	7.81	11.23	10.51	7.11	8.83	9.80	2.03	11.23	11.23	10.87	108.58
1929	Critical	10.06	9.12	8.17	10.35	9.75	5.33	4.98	6.75	6.98	0.39	0.36	0.29	72.53
1930	Dry	1.66	1.17	11.23	1.71	2.45	2.83	6.51	8.54	1.37	9.41	9.75	9.21	65.84
1931	Critical	6.53	5.49	4.74	2.26	2.86	2.75	5.67	7.63	7.87	7.07	0.36	0.28	53.51
1932	Dry	1.46	4.02	11.23	1.79	3.05	3.56	6.25	7.99	8.90	8.77	9.49	8.88	75.39
1933	Critical	7.04	6.30	5.56	3.24	3.15	3.29	6.16	8.71	9.15	8.24	8.14	7.71	76.69
1934	Critical	5.06	4.05	3.49	1.98	2.45	2.96	6.44	8.68	8.97	8.03	0.36	0.29	52.76
1935	Below Normal	4.86	10.78	8.54	1.84	2.89	3.48	8.31	10.71	2.55	11.23	11.23	10.87	87.29
1936	Below Normal	10.64	9.63	8.36	3.68	4.24	7.00	9.27	9.75	10.87	10.51	11.23	10.08	105.26
1937	Below Normal	9.75	8.83	8.07	11.23	10.15	11.23	8.90	9.39	10.56	10.24	11.05	9.75	119.15
1938	Wet	9.36	8.47	6.98	11.23	10.15	11.23	8.45	8.98	9.45	9.91	10.91	9.55	114.67
1939	Dry	9.13	8.21	7.34	11.23	10.15	11.23	8.44	10.07	2.49	11.23	6.88	10.87	107.27
1940	Above Normal	10.74	2.34	11.23	1.75	1.76	4.29	8.05	10.52	8.41	11.23	11.23	10.87	92.42
1941	Wet	9.45	8.51	7.07	4.70	5.53	11.23	7.68	8.33	9.45	9.25	10.14	8.88	100.22
1942	Wet	8.49	7.64	6.49	11.23	10.15	11.23	9.91	8.66	9.80	9.49	10.33	9.16	112.58
1943	Wet	8.83	7.96	7.22	11.23	10.15	10.76	9.79	9.82	10.87	10.64	11.23	10.24	118.74
1944	Dry	9.86	8.91	8.07	9.94	8.82	5.30	6.49	8.43	9.09	8.83	9.43	8.85	102.02
1945	Below Normal	6.77	5.93	5.21	3.13	3.37	11.23	8.97	9.38	10.56	10.16	10.90	9.73	95.34
1946	Below Normal	9.40	8.51	8.39	11.23	8.45	8.01	8.50	8.91	10.05	9.69	10.50	9.37	111.01
1947	Dry	9.05	8.18	7.45	11.23	10.15	7.35	8.74	10.15	10.76	10.48	11.23	10.40	115.17
1948	Below Normal	8.96	8.06	7.15	8.01	7.52	4.22	6.13	6.27	0.31	11.23	11.23	10.87	89.96
1949	Dry	9.05	8.08	6.98	2.98	3.63	3.72	8.75	9.96	10.36	10.04	10.86	9.89	94.30
1950	Below Normal	8.63	7.75	6.86	2.47	2.84	3.09	7.34	9.35	0.61	11.23	11.23	10.87	82.27
1951	Above Normal	9.14	8.19	6.82	11.23	10.15	11.23	8.36	9.17	10.34	9.95	10.78	9.62	114.98
1952	Wet	9.30	8.40	7.64	11.23	10.51	8.91	7.30	7.74	8.08	8.65	9.52	8.33	105.61
1953	Wet	7.95	7.13	11.03	11.23	10.15	11.23	8.61	8.59	9.57	9.33	10.18	9.21	114.21
1954	Above Normal	8.45	7.61	6.84	11.23	10.15	8.18	8.19	10.44	10.82	9.66	11.23	10.87	113.67
1955	Dry	8.79	7.85	6.81	3.66	4.35	4.27	6.72	8.59	8.84	8.76	9.58	8.91	87.13
1956	Wet	7.00	6.22	5.40	9.49	10.51	11.23	9.57	10.08	10.87	10.86	11.23	10.51	112.97
1957	Above Normal	10.16	9.18	8.33	11.23	10.15	8.52	6.72	4.79	1.03	11.23	11.23	10.87	103.44
1958	Wet	9.03	8.12	7.12	4.11	6.06	11.23	9.73	10.27	10.87	11.12	11.23	10.69	109.58
1959	Below Normal	10.30	9.28	8.36	11.23	10.15	11.23	7.55	9.58	2.08	11.23	11.23	10.87	113.09
1960	Dry	9.03	8.09	7.01	3.14	3.10	3.40	8.68	10.86	5.83	11.23	7.73	10.87	88.97
1961	Dry	9.98	8.94	7.72	4.16	4.53	3.51	7.31	9.29	9.54	9.40	7.66	3.64	85.68
1962	Below Normal	0.99	6.78	11.23	1.13	1.72	4.00	7.40	9.50	1.00	11.23	11.23	10.87	77.08
1963	Wet	9.69	8.72	7.64	6.36	6.24	6.96	8.33	8.80	9.93	9.58	10.38	9.27	101.90
1964	Dry	8.95	8.09	9.07	11.23	6.18	6.33	8.93	9.13	9.60	9.21	9.99	8.83	105.54
1965	Wet	8.53	7.64	6.92	11.08	10.15	8.06	8.18	8.58	8.90	9.42	10.20	9.15	106.81
1966	Below Normal	8.68	7.83	7.11	11.23	10.15	8.73	7.90	9.82	9.44	10.53	11.23	10.81	113.46
1967	Wet	8.87	7.94	6.95	4.93	7.07	7.43	9.04	9.46	9.91	10.28	11.17	9.90	102.95
1968	Below Normal	9.54	8.07	7.80	11.23	10.51	11.23	8.89	9.35	10.28	10.09	11.17	10.27	118.43
1969	Wet	8.74	7.85	6.93	7.85	10.15	11.23	8.61	9.14	9.59	10.05	11.07	9.70	110.91
1970	Wet	9.38	8.24	7.46	11.23	10.15	11.23	8.43	9.19	10.36	9.96	10.79	9.63	116.05
1971	Wet	9.31	8.41	7.66	11.23	10.15	10.43	7.56	9.74	10.03	10.30	11.23	10.62	116.67
1972	Below Normal	8.53	7.63	6.65	4.37	5.69	6.46	8.09	9.92	10.19	10.00	11.05	10.17	98.75
1973	Above Normal	8.34	7.44	6.47	5.47	8.09	8.17	8.76	9.44	10.63	10.18	10.99	9.80	103.78
1974	Wet	9.48	8.57	7.82	11.23	10.15	11.23	9.13	9.26	10.45	10.07	10.96	9.74	118.09
1975	Wet	9.40	8.47	7.67	11.23	10.15	11.15	9.05	9.29	10.47	10.04	10.78	9.64	117.34
1976	Critical	9.30	8.42	7.71	11.23	10.51	7.32	7.58	9.72	1.75	10.89	6.75	10.87	102.05
1977	Critical	9.30	8.32	7.14	2.80	3.10	2.55	1.72	0.25	0.31	0.45	0.37	0.29	36.60
1978	Above Normal	0.11	1.67	10.53	1.22	3.09	5.74	8.18	8.90	10.00	9.68	10.46	9.43	79.01
1979	Below Normal	8.72	7.85	7.10	11.23	10.15	9.26	8.78	9.06	10.24	9.84	10.59	9.43	112.25
1980	Above Normal	9.09	8.21	7.50	11.23	10.51	11.23	7.98	8.61	9.74	9.52	10.41	9.13	113.16
1981	Dry	8.75	7.86	7.07	11.23	10.15	10.51	7.60	9.90	2.50	11.23	10.57	10.87	108.24
1982	Wet	9.96	8.98	7.81	6.13	6.12	11.23	10.22	9.92	10.87	10.79	11.23	10.40	113.66
1983	Wet	10.01	8.52	11.23	11.23	10.15	11.23	7.24	7.78	8.49	9.19	9.43	8.44	112.94
1984	Wet	8.25	7.41	11.23	11.23	10.51	11.23	8.42	9.28	10.42	10.05	10.89	9.73	118.65
1985	Dry	9.39	8.50	8.65	11.23	10.15	10.07	8.33	8.72	9.68	9.28	10.00	8.89	112.89
1986	Wet	8.59	7.75	7.07	11.23	10.15	10.18	9.50	9.81	10.87	10.67	11.23	10.22	117.27
1987	Dry	9.83	8.87	8.01	11.23	10.15	7.86	6.08	8.19	8.81	7.91	7.80	7.41	102.15
1988	Critical	5.00	3.93	3.42	2.03	2.52	2.25	4.21	5.60	5.81	5.26	5.13	4.85	50.01
1989	Dry	3.13	2.37	2.06	1.43	2.12	2.21	8.43	10.91	6.23	11.23	10.29	10.87	71.28
1990	Critical	9.52	8.52	7.32	2.99	3.43	3.07	5.48	7.35	7.62	6.83	6.71	6.35	75.19
1991	Critical	4.16	3.19	2.75	1.61	2.08	2.20	4.29	5.11	2.12	6.18	5.98	5.70	45.37
1992	Critical	3.61	2.40	2.53	1.43	1.92	1.99	4.22	5.61	5.81	0.39	0.36	2.82	33.09
1993	Above Normal	7.15	0.57	9.30	1.40	4.54	5.88	8.21	9.30	4.67	10.64	11.23	10.58	83.47
1994	Critical	9.41	8.47	7.56	9.81	9.08	5.86	6.94	8.82	6.54	9.20	1.87	8.32	91.88
1995	Wet	0.80	2.17	11.23	1.13	4.07	5.45	9.69	9.96	10.87	10.79	11.23	10.36	87.75
1996	Wet	9.99	9.02	8.10	6.92	7.06	7.35	8.92	9.12	10.28	9.89	10.69	9.53	106.87
1997	Wet	9.21	8.34	7.51	11.23	10.15	11.23	8.50	8.98	10.11	9.81	10.71	9.47	115.25
1998	Wet	9.11	8.21	7.41	11.23	10.15	11.23	8.40	8.77	9.19	8.96	10.55	9.28	112.49
1999	Wet	9.84	8.97	9.26	11.23	10.15	11.18	8.44	9.20	10.34	10.00	10.84	9.66	119.11
2000	Above Normal	9.34	8.45	7.69	11.23	10.51	8.90	8.30	10.33	10.87	11.14	11.23	10.87	118.86
2001	Dry	9.24	8.33	7.33	5.22	4.61	3.64	6.43	8.72	9.08	8.17	8.05	7.63	86.45
2002	Dry	5.03	3.92	3.37	2.31	3.57	4.34	9.02	9.20	9.64	9.27	9.95	8.82	78.44
2003	Above Normal	8.49	3.68	8.80	2.38	3.48	4.22	6.91	8.83	1.07	10.91	11.23	10.87	80.87
Average		8.06	7.37	7.60	7.16	7.05	7.37	7.81	8.77	7.85	9.39	9.43	8.93	96.78
Wet		8.48	7.97	7.96	9.02	8.87	10.10	8.75	9.15	9.89	9.97	10.73	9.66	110.55
Above Normal		8.47	6.39	8.54	6.90	7.25	7.47	8.10	9.10	7.49	10.45	11.01	10.28	101.47
Below Normal		8.22	8.2											

Difference in Energy generated (GWh) at Alamo Dam: Alternative1_2005 minus Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Average
1922	Above Normal	0.00	0.00	0.00	0.73	0.09	0.10	0.33	0.45	1.19	1.23	1.37	1.22	0.56
1923	Below Normal	1.18	1.11	1.00	0.00	0.00	0.00	2.37	(7.96)	(8.72)	1.63	0.52	1.04	(0.65)
1924	Critical	2.62	2.49	2.32	3.07	2.38	0.98	0.76	1.06	(2.91)	(5.76)	(5.67)	(5.41)	(0.34)
1925	Dry	0.77	6.06	8.78	0.42	0.67	(0.65)	(1.02)	(1.59)	(1.39)	(1.37)	(1.30)	(1.45)	0.66
1926	Dry	(1.15)	(1.01)	(0.84)	0.20	0.01	0.29	(0.03)	0.97	(1.33)	1.31	1.27	1.26	0.08
1927	Wet	(5.27)	3.15	2.48	0.26	(0.04)	0.07	(0.23)	(0.24)	(2.80)	0.72	0.71	0.72	(0.04)
1928	Above Normal	0.73	0.73	0.74	0.00	0.00	(0.17)	(0.13)	0.55	(7.65)	1.95	1.27	2.02	0.00
1929	Critical	1.61	1.52	1.25	(0.88)	(0.40)	(0.45)	0.92	0.75	0.77	(5.21)	(5.13)	(4.70)	(0.83)
1930	Dry	(1.77)	(1.43)	8.98	0.27	0.11	0.15	0.00	0.02	(7.44)	1.07	0.98	0.99	0.16
1931	Critical	0.56	0.43	0.34	0.12	0.12	0.17	(0.01)	(0.02)	(0.02)	(0.02)	(6.60)	(6.22)	(0.93)
1932	Dry	(2.66)	0.60	8.30	0.05	0.08	0.19	(0.04)	(0.09)	0.60	0.66	0.71	0.70	0.76
1933	Critical	0.78	0.80	0.79	0.87	0.15	(0.04)	(0.25)	0.00	0.13	(0.01)	(0.19)	(0.16)	0.24
1934	Critical	(0.31)	(0.22)	(0.21)	0.08	0.11	0.29	0.35	0.49	0.51	0.44	(0.72)	0.00	0.07
1935	Below Normal	0.80	0.75	0.62	0.13	0.15	0.21	0.21	0.28	(0.95)	0.00	0.00	0.00	0.18
1936	Below Normal	1.62	1.54	1.39	0.65	(0.11)	(1.86)	0.29	(0.02)	0.62	0.69	0.61	0.68	0.51
1937	Below Normal	0.69	0.69	0.69	0.00	0.00	0.47	(0.10)	(0.10)	0.60	0.62	0.61	0.62	0.40
1938	Wet	0.62	0.63	(0.08)	0.00	0.00	0.00	(0.11)	(0.95)	(0.96)	0.40	(0.24)	0.61	(0.01)
1939	Dry	0.60	0.61	0.62	0.00	0.00	0.00	(0.72)	0.10	0.68	0.08	0.47	0.00	0.20
1940	Above Normal	0.69	(1.90)	1.03	0.32	(0.32)	(0.09)	0.00	(0.01)	0.66	0.32	0.00	0.00	0.06
1941	Wet	0.69	0.69	0.33	0.00	0.00	0.00	0.00	0.00	0.71	0.71	0.71	0.71	0.38
1942	Wet	0.71	0.71	0.35	0.00	0.00	0.00	(0.01)	(0.03)	0.66	0.67	0.66	0.67	0.37
1943	Wet	0.67	0.67	0.69	0.00	0.00	0.36	0.16	(0.02)	0.58	0.68	0.35	0.68	0.40
1944	Dry	0.68	0.69	0.70	(1.07)	(1.60)	(0.56)	0.00	0.01	0.48	0.47	0.45	0.45	0.06
1945	Below Normal	0.43	0.43	0.43	0.45	(0.01)	0.00	0.01	0.01	0.72	0.72	0.72	0.72	0.39
1946	Below Normal	0.72	0.72	0.82	0.00	0.00	0.03	0.04	0.04	0.75	0.75	0.75	0.75	0.45
1947	Dry	0.75	0.74	0.74	0.00	0.00	0.01	0.00	0.04	0.31	0.33	0.22	0.34	0.29
1948	Below Normal	0.29	0.29	0.29	0.09	(0.19)	(0.06)	0.01	0.32	0.00	0.00	0.00	0.00	0.09
1949	Dry	0.01	0.01	0.01	0.01	0.00	0.00	0.00	0.01	0.03	0.03	0.03	0.03	0.01
1950	Below Normal	0.02	0.02	0.01	(0.09)	(0.10)	(0.03)	(0.01)	0.00	0.30	0.00	0.00	0.00	0.01
1951	Above Normal	0.30	0.31	(0.01)	0.00	0.00	0.00	0.00	0.00	0.71	0.71	0.71	0.71	0.29
1952	Wet	0.71	0.71	0.70	0.00	0.00	0.00	0.00	(0.48)	(0.51)	0.17	0.07	0.22	0.13
1953	Wet	0.26	0.32	1.44	0.00	0.00	0.00	(1.77)	(0.19)	0.56	0.54	0.50	0.49	0.18
1954	Above Normal	0.61	0.62	0.64	1.27	0.00	0.30	0.06	0.08	0.81	0.09	0.00	0.01	0.37
1955	Dry	0.23	0.23	0.23	0.20	0.00	(0.01)	(0.05)	(0.07)	0.00	0.01	(0.01)	0.00	0.06
1956	Wet	0.02	0.02	0.03	(1.74)	0.00	0.00	0.01	0.01	0.31	0.72	0.15	0.72	0.02
1957	Above Normal	0.72	0.71	0.72	0.00	0.00	0.00	0.00	0.04	0.68	0.52	0.00	0.11	0.29
1958	Wet	0.69	0.68	0.69	0.68	0.00	0.00	0.00	0.00	0.11	0.71	0.00	0.71	0.36
1959	Below Normal	0.70	0.71	0.70	0.00	0.00	0.00	(0.20)	(0.26)	0.31	0.28	0.00	0.00	0.19
1960	Dry	0.29	0.29	0.29	0.26	(0.05)	0.01	0.01	(0.04)	0.64	0.00	0.53	0.00	0.19
1961	Dry	(0.20)	(0.18)	(0.14)	0.21	0.20	0.08	0.02	0.02	0.02	0.02	0.16	(0.01)	0.02
1962	Below Normal	0.17	(0.06)	0.00	0.00	0.00	0.00	0.00	0.01	0.68	0.00	0.00	0.00	0.07
1963	Wet	0.69	0.69	0.69	0.68	0.00	0.00	0.00	0.00	0.71	0.71	0.71	0.71	0.47
1964	Dry	0.70	0.71	0.71	0.00	0.01	0.00	(0.01)	(0.01)	0.00	0.00	0.01	0.01	0.18
1965	Wet	0.00	0.01	0.01	0.06	0.00	(0.02)	0.00	0.02	0.44	0.75	0.76	0.76	0.23
1966	Below Normal	0.74	0.73	0.73	0.00	0.00	(0.03)	0.00	0.00	0.50	0.53	0.07	0.53	0.32
1967	Wet	0.53	0.53	0.53	0.51	(0.01)	0.00	0.00	(0.01)	(0.02)	0.69	0.69	0.70	0.35
1968	Below Normal	0.70	0.16	0.70	0.00	0.00	0.00	0.04	0.22	0.84	0.87	0.95	0.97	0.45
1969	Wet	0.73	0.72	0.68	(1.11)	0.00	0.00	(0.04)	(0.05)	(0.04)	0.67	0.67	0.67	0.24
1970	Wet	0.67	0.68	0.68	0.00	0.00	0.00	0.00	0.04	0.75	0.75	0.75	0.75	0.42
1971	Wet	0.74	0.74	0.74	0.00	0.00	0.04	(0.01)	(0.02)	0.23	0.43	0.22	0.44	0.30
1972	Below Normal	0.43	0.44	0.43	0.44	0.00	0.00	0.00	0.00	0.01	0.00	0.01	0.01	0.15
1973	Above Normal	0.01	0.01	0.01	0.02	0.01	0.02	(0.02)	0.01	0.71	0.71	0.71	0.71	0.24
1974	Wet	0.71	0.71	0.71	0.00	0.00	0.00	(0.08)	(0.12)	0.59	0.59	0.56	0.59	0.36
1975	Wet	0.60	0.61	0.63	0.00	0.00	(0.08)	0.10	0.11	0.81	0.81	0.82	0.81	0.44
1976	Critical	0.81	0.80	0.79	0.00	0.00	0.04	(0.04)	(0.05)	(0.01)	(0.06)	0.11	0.00	0.20
1977	Critical	(0.08)	(0.08)	(0.07)	(0.01)	(0.01)	(0.01)	0.48	0.00	0.02	0.00	(0.01)	0.00	0.02
1978	Above Normal	0.00	(0.21)	0.01	0.00	0.00	(0.10)	(0.01)	0.41	1.08	1.12	1.21	1.28	0.40
1979	Below Normal	0.87	0.84	0.75	0.00	0.00	1.37	0.30	0.05	0.76	0.74	0.73	0.74	0.60
1980	Above Normal	0.75	0.75	0.76	0.00	0.00	0.00	(0.56)	(0.44)	0.25	0.24	0.16	0.26	0.18
1981	Dry	0.29	0.33	0.40	0.00	0.00	1.43	0.18	0.25	0.75	0.00	0.05	0.00	0.31
1982	Wet	0.84	0.82	0.81	0.76	0.06	0.00	0.00	0.00	0.46	0.71	0.12	0.71	0.44
1983	Wet	0.60	0.11	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.71	0.70	0.18
1984	Wet	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.71	0.71	0.71	0.71	0.24
1985	Dry	0.71	0.71	0.71	0.00	0.00	0.00	0.00	0.00	0.49	0.49	0.49	0.48	0.34
1986	Wet	0.49	0.48	0.48	0.00	0.00	(1.05)	0.22	0.01	0.57	0.71	0.32	0.72	0.25
1987	Dry	0.72	0.71	0.71	0.00	0.00	0.00	(0.22)	(0.32)	0.01	0.05	0.05	0.06	0.15
1988	Critical	0.15	0.18	0.20	0.30	(0.04)	(0.01)	0.00	0.00	0.00	0.00	0.00	0.00	0.07
1989	Dry	0.00	0.00	0.00	0.00	0.00	0.00	(0.01)	(0.01)	(0.09)	0.00	(0.57)	0.00	(0.06)
1990	Critical	0.07	0.07	0.05	(0.01)	0.00	0.00	0.00	0.01	0.00	0.00	0.01	0.00	0.02
1991	Critical	0.01	0.00	0.00	0.00	0.00	0.00	0.00	(0.19)	(0.01)	0.03	0.03	0.03	(0.01)
1992	Critical	0.02	(0.19)	0.13	0.00	(0.01)	0.00	0.00	(0.01)	0.00	0.00	0.00	(0.06)	(0.01)
1993	Above Normal	(0.09)	(0.08)	0.08	0.00	(0.01)	(0.02)	0.00	0.02	0.50	0.69	0.35	0.71	0.18
1994	Critical	0.71	0.67	0.67	0.64	(0.07)	(0.03)	0.00	0.00	0.03	0.01	0.05	0.00	0.22
1995	Wet	(0.15)	(0.18)	0.00	0.01	0.00	0.00	0.00	0.00	0.42	0.71	0.24	0.71	0.15
1996	Wet	0.71	0.70	0.62	(4.31)	(3.45)	(2.63)	(0.20)	(0.21)	0.49	0.49	0.49	0.51	(0.57)
1997	Wet	0.52	0.54	0.46	0.00	0.00	0.00	0.02	0.02	0.73	0.73	0.73	0.72	0.37
1998	Wet	0.73	0.72	0.72	0.00	0.00	0.00	(0.02)	(0.49)	(0.53)	(0.55)	0.05	0.20	0.07
1999	Wet	1.20	0.20	0.74	0.00	0.00	(0.05)	(0.04)	0.03	0.73	0.73	0.74	0.73	0.42
2000	Above Normal	0.73	0.73	0.72	0.00	0.00	(0.03)	(0.01)	0.07	0.36	0.77	0.00	0.40	0.31
2001	Dry	0.71	0.70	0.69	0.25	(0.40)	(0.11)	0.05	0.07	0.14	0.13	0.13	0.13	0.21
2002	Dry	0.11	0.10	0.09	0.08	0.00	0.00	(0.03)	(0.03)	(0.02)	(0.02)	(0.02)	(0.01)	0.02
2003	Above Normal	(0.01)	0.48	(0.48)	0.12	0.09	0.04	0.00	0.00	0.34	0.35	0.00	0.24	0.10
Average		0.37	0.52	0.79	0.06	(0.03)	(0.02)	0.01	(0.09)	(0.07)	0.28	0.10	0.21	0.18
Wet		0.34	0.60	0.58	(0.16)	(0.13)	(0.13)	(0.08)	(0.10)	0.22	0.58	0.47	0.64	0.24
Above Normal		0.37	0.18	0.35	0.21	(0.01)	0.00	(0.03)	0.10	(0.03)	0.73	0.48	0.64	0.25
Below Normal		0.67	0.60	0.61	0.12	(0.02)	0.01	0.21	(0.53)	(0.26)	0.49	0.36	0.43	0.23
Dry		0.04	0.55	1.72	0.05	(0.05)	0.05	(0.10)	(0.04)	(0.34)	0.18	0.20	0.17	0.20
Critical		0.58	0.54	0.52	0.35	0.19	0.08	0.18	0.17	(0.12)	(0.88)	(1.51)	(1.38)	(0.11)

Percent Difference in Energy generated (GWh) at Alamo Dam: Alternative1_2005 minus Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September
1922	Above Normal	0%	0%	0%	30%	2%	2%	4%	5%	13%	14%	14%	15%
1923	Below Normal	15%	15%	15%	0%	0%	0%	31%	-84%	-90%	17%	5%	11%
1924	Critical	32%	34%	37%	60%	45%	26%	15%	16%	-42%	-94%	-94%	-95%
1925	Dry	21%	214%	358%	27%	32%	-16%	-13%	-15%	-13%	-13%	-12%	-14%
1926	Dry	-14%	-13%	-13%	7%	0%	7%	0%	11%	-14%	14%	13%	14%
1927	Wet	-72%	49%	44%	8%	-1%	1%	-3%	-3%	-28%	8%	7%	8%
1928	Above Normal	8%	9%	10%	0%	0%	-2%	-1%	6%	-79%	21%	13%	23%
1929	Critical	19%	20%	18%	-8%	-4%	-8%	23%	13%	12%	-93%	-93%	-94%
1930	Dry	-52%	-55%	399%	19%	5%	6%	0%	0%	-84%	13%	11%	12%
1931	Critical	9%	8%	8%	6%	4%	7%	0%	0%	0%	0%	-95%	-96%
1932	Dry	-65%	18%	283%	3%	3%	6%	-1%	-1%	7%	8%	8%	9%
1933	Critical	12%	15%	17%	37%	5%	-1%	-4%	0%	1%	0%	-2%	-2%
1934	Critical	-6%	-5%	-6%	4%	5%	11%	6%	6%	6%	6%	-67%	0%
1935	Below Normal	20%	7%	8%	8%	5%	6%	3%	3%	-27%	0%	0%	0%
1936	Below Normal	18%	19%	20%	21%	-3%	-21%	3%	0%	6%	7%	6%	7%
1937	Below Normal	8%	8%	9%	0%	0%	4%	-1%	-1%	6%	6%	6%	7%
1938	Wet	7%	8%	-1%	0%	0%	0%	-1%	-10%	-9%	4%	-2%	7%
1939	Dry	7%	8%	9%	0%	0%	0%	-8%	1%	38%	1%	7%	0%
1940	Above Normal	7%	-45%	10%	22%	-15%	-2%	0%	0%	9%	3%	0%	0%
1941	Wet	8%	9%	5%	0%	0%	0%	0%	0%	8%	8%	8%	9%
1942	Wet	9%	10%	6%	0%	0%	0%	0%	0%	7%	8%	7%	8%
1943	Wet	8%	9%	11%	0%	0%	3%	2%	0%	6%	7%	3%	7%
1944	Dry	7%	8%	9%	-10%	-15%	-10%	0%	0%	6%	6%	5%	5%
1945	Below Normal	7%	8%	9%	17%	0%	0%	0%	0%	7%	8%	7%	8%
1946	Below Normal	8%	9%	11%	0%	0%	0%	0%	0%	8%	8%	8%	9%
1947	Dry	9%	10%	11%	0%	0%	0%	0%	0%	3%	3%	2%	3%
1948	Below Normal	3%	4%	4%	1%	-2%	-1%	0%	5%	0%	0%	0%	0%
1949	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1950	Below Normal	0%	0%	0%	-4%	-3%	-1%	0%	0%	97%	0%	0%	0%
1951	Above Normal	3%	4%	0%	0%	0%	0%	0%	0%	7%	8%	7%	8%
1952	Wet	8%	9%	10%	0%	0%	0%	0%	-6%	-6%	2%	1%	3%
1953	Wet	3%	5%	15%	0%	0%	0%	-17%	-2%	6%	6%	5%	6%
1954	Above Normal	8%	9%	10%	13%	0%	4%	1%	1%	8%	1%	0%	0%
1955	Dry	3%	3%	3%	6%	0%	0%	-1%	-1%	0%	0%	0%	0%
1956	Wet	0%	0%	1%	-15%	0%	0%	0%	0%	3%	7%	1%	7%
1957	Above Normal	8%	8%	9%	0%	0%	0%	1%	194%	5%	0%	0%	1%
1958	Wet	8%	9%	11%	20%	0%	0%	0%	0%	1%	7%	0%	7%
1959	Below Normal	7%	8%	9%	0%	0%	0%	-3%	-3%	18%	3%	0%	0%
1960	Dry	3%	4%	4%	9%	-2%	0%	0%	0%	12%	0%	7%	0%
1961	Dry	-2%	-2%	-2%	5%	5%	2%	0%	0%	0%	0%	2%	0%
1962	Below Normal	21%	-1%	0%	0%	0%	0%	0%	0%	213%	0%	0%	0%
1963	Wet	8%	9%	10%	12%	0%	0%	0%	0%	8%	8%	7%	8%
1964	Dry	8%	10%	8%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1965	Wet	0%	0%	0%	1%	0%	0%	0%	0%	5%	9%	8%	9%
1966	Below Normal	9%	10%	11%	0%	0%	0%	0%	0%	6%	5%	1%	5%
1967	Wet	6%	7%	8%	12%	0%	0%	0%	0%	0%	7%	7%	8%
1968	Below Normal	8%	2%	10%	0%	0%	0%	0%	2%	9%	9%	9%	10%
1969	Wet	9%	10%	11%	-12%	0%	0%	0%	-1%	0%	7%	6%	7%
1970	Wet	8%	9%	10%	0%	0%	0%	0%	0%	8%	8%	7%	8%
1971	Wet	9%	10%	11%	0%	0%	0%	0%	0%	2%	4%	2%	4%
1972	Below Normal	5%	6%	7%	11%	0%	0%	0%	0%	0%	0%	0%	0%
1973	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	7%	7%	7%	8%
1974	Wet	8%	9%	10%	0%	0%	0%	-1%	-1%	6%	6%	5%	6%
1975	Wet	7%	8%	9%	0%	0%	-1%	1%	1%	8%	9%	8%	9%
1976	Critical	10%	10%	11%	0%	0%	1%	-1%	-1%	-1%	-1%	2%	0%
1977	Critical	-1%	-1%	-1%	0%	0%	0%	39%	0%	7%	0%	-3%	0%
1978	Above Normal	0%	-11%	0%	0%	0%	-2%	0%	5%	12%	13%	13%	16%
1979	Below Normal	11%	12%	12%	0%	0%	17%	4%	1%	8%	8%	7%	9%
1980	Above Normal	9%	10%	11%	0%	0%	0%	-7%	-5%	3%	3%	2%	3%
1981	Dry	3%	4%	6%	0%	0%	16%	2%	3%	43%	0%	0%	0%
1982	Wet	9%	10%	12%	14%	1%	0%	0%	0%	4%	7%	1%	7%
1983	Wet	6%	1%	0%	0%	0%	0%	0%	0%	0%	0%	8%	9%
1984	Wet	0%	0%	0%	0%	0%	0%	0%	0%	7%	8%	7%	8%
1985	Dry	8%	9%	9%	0%	0%	0%	0%	0%	5%	6%	5%	6%
1986	Wet	6%	7%	7%	0%	0%	-9%	2%	0%	6%	7%	3%	8%
1987	Dry	8%	9%	10%	0%	0%	0%	-3%	-4%	0%	1%	1%	1%
1988	Critical	3%	5%	6%	17%	-2%	0%	0%	0%	0%	0%	0%	0%
1989	Dry	0%	0%	0%	0%	0%	0%	0%	0%	-1%	0%	-5%	0%
1990	Critical	1%	1%	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1991	Critical	0%	0%	0%	0%	0%	0%	0%	-4%	0%	0%	1%	1%
1992	Critical	1%	-7%	5%	0%	-1%	0%	0%	0%	0%	0%	0%	-2%
1993	Above Normal	-1%	-12%	1%	0%	0%	0%	0%	0%	12%	7%	3%	7%
1994	Critical	8%	9%	10%	7%	-1%	-1%	0%	0%	0%	0%	3%	0%
1995	Wet	-16%	-8%	0%	1%	0%	0%	0%	0%	4%	7%	2%	7%
1996	Wet	8%	8%	8%	-38%	-33%	-26%	-2%	-2%	5%	5%	5%	6%
1997	Wet	6%	7%	7%	0%	0%	0%	0%	0%	8%	8%	7%	8%
1998	Wet	9%	10%	11%	0%	0%	0%	0%	-5%	-5%	-6%	0%	2%
1999	Wet	14%	2%	9%	0%	0%	0%	0%	0%	8%	8%	7%	8%
2000	Above Normal	8%	9%	10%	0%	0%	0%	0%	1%	3%	7%	0%	4%
2001	Dry	8%	9%	10%	5%	-8%	-3%	1%	1%	2%	2%	2%	2%
2002	Dry	2%	3%	3%	4%	0%	0%	0%	0%	0%	0%	0%	0%
2003	Above Normal	0%	15%	-5%	5%	3%	1%	0%	0%	47%	3%	0%	2%
Average		4%	8%	20%	4%	0%	0%	1%	-1%	7%	2%	-1%	1%
Wet		3%	8%	9%	0%	-1%	-1%	-1%	-1%	2%	6%	5%	7%
Above Normal		4%	0%	5%	6%	-1%	0%	0%	1%	20%	8%	5%	7%
Below Normal		10%	8%	9%	4%	0%	0%	3%	-5%	19%	5%	3%	5%
Dry		-2%	13%	62%	4%	1%	0%	-1%	0%	0%	2%	3%	2%
Critical		7%	7%	9%	10%	4%	3%	6%	3%	-1%	-15%	-29%	-24%

Energy generated (GWh) at Castaic: Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Total
1922	Above Normal	96.83	76.46	51.63	15.36	33.78	61.03	70.96	63.60	61.30	64.76	65.42	60.47	721.60
1923	Below Normal	51.36	47.02	39.28	76.68	84.29	88.44	63.13	62.64	59.65	69.49	64.89	54.42	761.29
1924	Critical	40.75	37.34	25.24	22.34	20.20	24.28	31.65	29.84	27.79	32.94	24.70	17.94	335.01
1925	Dry	1.31	0.14	0.10	5.39	11.36	59.02	52.80	67.29	64.36	76.54	70.15	57.40	465.86
1926	Dry	42.27	38.80	24.93	15.73	15.66	30.40	39.54	58.53	55.43	65.93	60.39	49.39	497.00
1927	Wet	34.99	31.93	19.58	11.03	19.04	70.10	76.92	70.37	68.32	72.17	72.91	67.54	614.90
1928	Above Normal	58.66	53.72	45.45	50.78	52.17	38.62	77.46	70.03	67.92	72.01	72.56	66.96	726.34
1929	Critical	57.92	52.98	44.50	44.97	40.04	29.46	27.61	27.61	25.26	30.02	22.58	16.37	419.32
1930	Dry	0.61	0.14	0.10	4.06	12.87	22.30	47.81	46.77	44.27	52.35	44.33	34.72	310.33
1931	Critical	18.31	15.29	6.96	13.39	13.12	20.96	35.17	33.68	31.99	38.27	28.49	20.61	276.24
1932	Dry	3.01	0.64	0.10	9.30	12.69	27.12	51.90	50.95	47.82	56.71	51.04	41.33	352.61
1933	Critical	26.72	23.89	13.42	14.42	14.08	24.17	38.95	40.78	39.04	46.39	36.11	26.89	344.86
1934	Critical	8.80	5.73	0.10	12.44	11.51	21.84	37.07	35.77	34.29	40.81	1.73	1.40	211.49
1935	Below Normal	24.38	27.30	17.27	12.55	13.64	25.42	67.16	67.61	64.72	83.21	76.34	62.37	541.97
1936	Below Normal	46.88	43.06	28.21	16.65	14.93	92.25	63.90	73.06	71.11	75.18	75.94	70.31	671.48
1937	Below Normal	61.49	56.35	47.87	49.89	69.34	92.30	60.68	67.82	65.71	69.51	70.21	64.71	775.88
1938	Wet	55.49	51.02	42.96	61.60	72.64	89.82	53.25	61.01	58.73	62.07	62.67	57.48	728.74
1939	Dry	47.86	44.18	40.77	65.87	84.52	92.93	76.35	65.70	47.47	82.24	76.35	70.20	794.44
1940	Above Normal	55.33	50.81	55.81	14.56	13.73	35.13	66.72	68.08	65.25	80.50	73.85	60.39	640.16
1941	Wet	45.02	41.36	26.91	21.19	32.63	92.27	48.02	56.30	53.73	56.87	57.40	52.67	584.37
1942	Wet	43.02	39.60	32.45	83.29	54.96	92.94	84.76	62.84	60.50	63.98	64.62	59.63	742.59
1943	Wet	50.42	46.22	38.55	53.32	66.39	92.92	78.52	70.21	68.10	71.96	72.76	67.18	776.55
1944	Dry	58.04	53.40	45.15	46.25	41.27	33.03	51.34	50.48	47.47	56.31	49.75	39.87	572.36
1945	Below Normal	24.55	21.59	11.72	18.36	15.69	81.08	63.70	70.22	68.18	72.11	72.77	67.38	587.35
1946	Below Normal	58.51	53.57	76.32	47.30	61.38	76.12	72.15	66.10	63.84	67.45	68.20	63.11	774.05
1947	Dry	54.14	49.53	41.60	51.50	46.46	42.20	74.21	70.50	67.99	76.50	73.32	63.69	711.64
1948	Below Normal	51.41	47.12	35.40	30.91	27.52	24.89	37.17	60.26	1.53	84.49	77.45	63.35	541.50
1949	Dry	47.77	43.87	28.83	19.79	16.41	27.95	74.42	70.13	67.71	75.64	72.84	63.82	609.18
1950	Below Normal	51.99	47.63	36.37	19.36	17.02	24.06	61.56	61.03	1.50	82.46	75.52	61.75	540.25
1951	Above Normal	46.26	42.51	45.87	73.01	83.50	92.27	58.39	68.04	65.91	69.53	70.32	65.11	780.72
1952	Wet	56.16	51.43	43.35	68.66	72.12	65.59	57.79	52.61	49.87	52.86	53.39	48.71	672.54
1953	Wet	38.76	35.84	60.24	59.26	53.57	92.95	89.03	62.37	58.85	65.09	63.31	56.20	735.47
1954	Above Normal	45.17	41.27	31.69	40.57	39.12	55.87	67.06	67.01	64.00	76.76	71.41	58.48	658.41
1955	Dry	43.24	39.72	25.65	14.65	14.85	32.17	57.69	57.13	53.86	63.94	58.83	48.11	509.84
1956	Wet	33.82	30.84	18.73	60.54	86.50	92.28	67.06	73.58	71.67	75.63	76.44	70.76	757.85
1957	Above Normal	61.85	56.81	48.30	55.07	53.69	50.53	57.09	56.32	1.60	79.31	72.67	59.45	652.69
1958	Wet	44.19	40.54	26.25	6.28	39.95	81.95	64.64	71.62	69.65	73.55	74.47	68.54	661.63
1959	Below Normal	59.29	54.69	46.33	65.48	62.29	90.79	64.47	64.09	56.57	80.46	73.62	60.19	778.27
1960	Dry	44.89	41.19	26.75	15.18	13.64	24.18	71.72	71.32	68.63	85.97	79.27	72.49	615.23
1961	Dry	56.94	52.37	36.24	18.45	17.47	23.52	61.19	60.67	57.61	68.48	62.78	54.89	570.61
1962	Below Normal	14.74	70.92	30.00	12.94	11.48	32.60	61.93	62.02	1.54	83.81	76.85	62.87	521.70
1963	Wet	47.26	43.47	28.56	32.38	40.80	65.88	71.20	65.53	63.23	66.66	67.51	62.52	655.00
1964	Dry	53.53	48.97	72.15	35.30	44.25	48.14	76.33	68.50	66.37	70.10	70.87	65.61	720.12
1965	Wet	56.70	51.89	43.77	63.63	70.68	66.47	70.05	63.28	60.78	65.43	65.51	59.91	738.10
1966	Below Normal	50.33	45.98	37.63	64.48	71.20	64.97	64.32	63.67	60.73	72.50	67.17	55.55	718.53
1967	Wet	41.15	37.72	24.78	12.05	42.76	67.28	75.23	68.16	66.02	69.88	70.62	65.11	640.76
1968	Below Normal	55.98	51.42	50.52	74.30	59.07	92.89	74.47	62.08	59.38	67.43	64.07	55.21	766.82
1969	Wet	42.81	39.16	28.24	64.56	80.95	92.28	53.96	61.63	59.32	62.79	63.43	58.13	707.26
1970	Wet	57.91	35.07	37.23	58.78	67.03	92.57	66.32	67.96	65.86	69.66	70.29	65.03	753.71
1971	Wet	56.09	51.35	43.28	76.91	59.20	70.51	62.10	62.85	59.81	71.41	65.48	53.52	732.51
1972	Below Normal	38.71	35.47	22.35	7.35	32.41	59.87	67.01	65.59	62.79	73.21	68.19	57.04	589.99
1973	Above Normal	43.11	39.52	26.86	14.43	48.99	86.23	61.32	70.28	68.33	72.08	72.85	67.44	671.44
1974	Wet	58.55	53.63	45.37	76.21	84.50	92.89	75.96	67.29	65.23	68.87	69.59	64.20	822.29
1975	Wet	55.06	50.57	42.55	58.64	56.05	89.75	76.92	69.16	67.13	70.82	71.60	66.29	774.54
1976	Critical	57.40	52.54	44.36	50.63	47.29	41.47	63.86	63.67	46.87	80.86	73.96	67.09	690.00
1977	Critical	51.32	47.11	31.28	15.26	13.74	19.67	27.52	6.15	1.66	1.83	1.75	1.40	218.69
1978	Above Normal	0.18	0.14	0.10	12.06	12.55	56.60	69.61	63.25	60.97	64.42	65.09	60.13	465.10
1979	Below Normal	51.05	46.69	38.98	49.90	69.00	92.25	58.80	65.88	63.76	67.29	67.99	62.82	734.41
1980	Above Normal	53.72	49.23	41.31	54.27	80.52	92.30	52.70	60.52	58.12	61.55	62.17	56.96	723.37
1981	Dry	47.28	43.67	36.19	60.28	58.90	61.13	62.45	63.16	7.24	84.56	77.38	65.34	667.58
1982	Wet	49.70	45.61	30.13	29.87	38.51	92.26	65.80	63.43	66.23	70.05	70.73	65.04	687.36
1983	Wet	65.03	60.48	92.04	50.75	84.14	92.29	44.95	44.25	51.69	52.06	40.89	45.02	723.59
1984	Wet	44.40	41.63	91.95	58.96	87.53	92.28	59.28	69.11	66.94	70.80	71.52	66.23	820.63
1985	Dry	57.33	52.50	75.35	42.92	54.99	78.33	71.61	65.66	63.49	67.00	67.65	62.68	759.51
1986	Wet	53.72	49.11	41.21	46.51	41.82	92.29	62.41	68.35	66.31	69.91	70.83	65.19	727.66
1987	Dry	55.88	51.49	43.38	57.21	53.36	36.58	38.05	36.92	35.61	42.03	31.53	22.84	504.88
1988	Critical	4.25	1.29	0.10	8.73	12.77	19.19	28.34	26.17	23.67	28.23	21.15	15.39	189.28
1989	Dry	0.18	0.14	0.10	2.64	11.90	19.43	69.46	70.49	67.58	85.25	78.12	66.09	471.38
1990	Critical	50.29	46.25	30.68	15.57	14.62	22.14	34.21	32.65	30.88	36.73	27.42	19.90	361.34
1991	Critical	2.48	0.14	0.10	7.01	11.10	18.77	28.68	26.70	24.58	33.15	24.61	17.82	195.14
1992	Critical	1.27	0.14	0.10	5.34	11.08	19.03	28.39	26.11	23.64	1.66	1.73	30.22	148.71
1993	Above Normal	15.97	0.14	20.19	12.18	34.27	58.79	69.15	64.86	62.26	73.32	70.94	62.32	544.39
1994	Critical	50.72	46.43	35.56	38.06	32.84	38.44	58.66	57.97	54.77	67.74	26.92	63.55	571.66
1995	Wet	19.41	73.81	62.28	12.79	28.64	49.32	79.42	71.74	69.73	73.58	74.53	68.79	684.04
1996	Wet	59.71	54.91	46.54	66.08	71.40	81.65	77.35	69.44	67.35	71.14	71.91	66.55	804.03
1997	Wet	57.63	52.79	44.59	67.81	79.12	92.58	63.84	63.33	61.01	64.38	65.15	60.07	772.30
1998	Wet	50.78	46.64	38.93	58.18	81.67	88.32	68.07	62.21	59.82	63.30	64.07	58.71	740.70
1999	Wet	56.18	56.86	49.62	58.03	81.58	92.96	74.06	68.43	66.17	69.95	70.80	65.52	810.16
2000	Above Normal	56.59	51.81	43.70	53.30	53.63	56.73	69.47	68.62	65.71	76.68	71.57	59.89	727.70
2001	Dry	45.82	42.06	28.95	21.32	19.13	24.37	38.35	37.61	36.23	43.16	32.27	23.33	392.60
2002	Dry	4.54	1.53	0.10	0.10	12.44	33.24	78.55	70.67	68.50	72.41	73.30		

Energy generated (GWh) at Castaic: Alternative1_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Total
1922	Above Normal	96.83	76.46	51.63	25.24	33.60	60.57	70.71	63.72	65.89	69.37	70.03	64.85	748.90
1923	Below Normal	55.51	51.44	43.73	69.32	59.84	92.90	86.37	56.58	5.87	90.67	86.49	75.09	773.81
1924	Critical	62.10	57.47	44.32	36.53	27.87	27.34	35.16	33.79	32.16	1.71	1.68	1.40	361.53
1925	Dry	39.38	45.17	48.86	16.39	13.69	24.86	58.42	57.73	55.87	66.18	60.78	49.98	537.31
1926	Dry	35.65	32.64	20.44	20.50	16.14	32.19	44.58	64.49	62.11	76.23	69.84	57.20	532.01
1927	Wet	42.28	51.94	35.14	15.20	16.14	69.27	75.19	68.68	70.99	77.44	78.20	72.81	673.28
1928	Above Normal	64.02	58.99	50.69	55.09	50.23	36.62	75.60	70.63	33.90	87.39	85.38	76.32	744.86
1929	Critical	65.39	60.12	48.65	41.27	34.04	28.80	31.91	30.41	28.36	1.74	1.74	1.40	373.83
1930	Dry	6.24	10.97	58.22	14.44	12.73	22.05	46.74	45.70	36.71	59.13	49.43	38.44	400.80
1931	Critical	20.70	17.10	8.44	15.43	13.35	21.20	35.11	33.62	31.92	38.19	1.76	1.40	238.22
1932	Dry	15.50	27.78	35.82	14.32	12.48	27.50	52.87	51.93	53.10	62.21	57.04	47.30	457.85
1933	Critical	33.12	30.35	19.41	20.54	14.35	23.51	37.37	38.34	37.72	44.85	33.82	24.78	358.16
1934	Critical	6.08	3.20	0.84	11.35	11.84	22.58	38.70	37.60	36.31	43.22	1.73	1.40	214.85
1935	Below Normal	26.42	29.19	18.81	13.58	13.82	25.83	68.69	69.33	11.44	94.82	90.18	74.41	536.52
1936	Below Normal	58.34	54.03	37.67	19.92	14.82	67.57	77.46	72.87	75.34	79.40	80.15	74.54	712.11
1937	Below Normal	65.73	60.63	52.19	49.53	68.63	92.30	59.60	66.82	69.10	72.84	73.52	68.08	798.97
1938	Wet	58.84	54.49	42.04	78.78	76.40	92.53	56.46	59.92	57.60	65.30	65.89	60.76	769.01
1939	Dry	51.12	47.56	44.25	72.17	84.52	92.93	70.43	66.89	64.35	86.67	80.95	74.95	836.79
1940	Above Normal	60.27	55.72	67.44	17.49	12.46	34.59	66.70	68.06	69.54	84.81	78.17	64.71	679.96
1941	Wet	49.36	45.72	28.99	21.21	32.63	92.27	48.02	56.30	58.15	61.28	61.82	57.09	612.84
1942	Wet	47.46	44.07	34.63	70.89	54.55	92.94	84.99	62.77	64.85	68.32	68.96	63.99	758.42
1943	Wet	54.82	50.63	42.99	51.76	62.16	92.92	80.53	70.38	72.70	76.57	77.37	71.80	804.63
1944	Dry	62.71	58.04	49.81	47.80	38.64	32.26	51.03	50.17	50.06	58.84	52.16	42.30	593.82
1945	Below Normal	26.89	23.94	14.23	21.13	15.63	80.18	63.81	70.32	72.70	76.64	77.30	71.91	614.68
1946	Below Normal	63.05	58.13	80.83	51.78	61.38	76.36	72.43	66.38	68.55	72.18	72.93	67.82	811.82
1947	Dry	58.88	54.27	46.34	56.35	46.48	41.92	74.06	70.53	69.78	78.48	75.14	65.34	737.57
1948	Below Normal	52.94	48.68	36.85	32.10	26.97	24.69	37.21	60.44	1.53	84.46	77.43	63.33	546.63
1949	Dry	47.75	43.86	28.82	19.74	16.44	27.88	74.39	70.15	67.82	75.81	72.96	63.90	609.52
1950	Below Normal	52.03	47.67	36.38	19.05	16.85	23.95	61.55	61.01	3.41	84.35	77.41	63.64	547.10
1951	Above Normal	48.16	44.43	44.28	73.01	65.83	92.27	58.39	68.04	70.33	73.95	74.74	69.53	782.96
1952	Wet	60.60	55.89	47.84	74.57	72.12	65.59	57.79	51.79	48.97	56.33	56.85	52.42	700.76
1953	Wet	42.69	39.63	64.06	57.20	65.76	92.95	73.59	61.57	62.91	68.59	67.27	60.67	756.89
1954	Above Normal	50.05	46.10	36.95	46.63	41.52	58.69	67.43	67.44	65.63	77.93	72.72	59.77	690.86
1955	Dry	44.52	41.01	26.92	16.15	14.84	32.08	57.29	56.70	53.89	63.89	58.82	48.19	514.30
1956	Wet	33.94	30.98	18.95	60.48	86.50	92.28	67.12	73.63	76.14	80.10	80.92	75.24	776.28
1957	Above Normal	66.35	61.32	52.84	59.57	53.64	50.50	57.12	56.35	5.88	83.59	76.95	63.72	687.83
1958	Wet	48.49	44.85	30.59	10.62	39.95	81.95	64.64	71.62	74.07	77.97	78.89	72.96	696.60
1959	Below Normal	63.73	59.15	50.82	70.22	75.56	87.31	63.11	62.63	31.84	83.29	76.35	62.77	786.78
1960	Dry	47.47	43.71	29.16	17.13	13.56	24.31	71.89	71.33	68.65	85.78	79.24	71.81	624.04
1961	Dry	56.48	51.93	36.10	19.12	18.07	23.75	61.30	60.80	57.74	68.64	62.92	54.82	571.67
1962	Below Normal	13.08	71.50	30.70	12.94	11.48	32.60	61.93	62.02	5.81	88.09	81.13	67.15	538.43
1963	Wet	51.56	47.79	32.90	36.71	40.80	65.88	71.20	65.53	67.65	71.08	71.93	66.94	689.97
1964	Dry	57.97	53.43	76.57	39.72	44.14	48.45	76.29	68.47	66.40	70.13	70.90	65.65	738.12
1965	Wet	56.74	51.93	43.81	63.87	70.72	65.72	70.06	63.36	65.29	70.27	70.28	64.58	756.63
1966	Below Normal	54.97	50.63	42.22	68.61	70.84	64.77	64.32	63.68	64.02	75.82	70.48	58.84	749.20
1967	Wet	44.45	41.04	28.11	15.26	42.73	67.28	75.24	68.15	66.00	74.28	75.03	69.52	667.09
1968	Below Normal	60.41	52.54	47.81	56.22	59.19	92.89	74.13	62.27	63.61	72.70	68.50	58.72	768.99
1969	Wet	45.58	42.09	30.51	39.71	71.83	92.28	53.53	61.23	58.90	66.77	67.41	62.13	691.97
1970	Wet	61.89	39.13	41.35	61.05	62.91	92.37	62.04	68.25	70.59	74.39	75.03	69.75	778.75
1971	Wet	60.84	56.10	48.03	81.51	82.86	70.70	62.00	62.74	62.41	74.18	68.24	56.27	785.88
1972	Below Normal	41.47	38.24	25.13	10.19	32.49	59.90	67.00	65.57	62.85	73.25	68.24	57.10	601.43
1973	Above Normal	43.18	39.59	26.94	14.55	49.04	86.26	61.32	70.29	72.76	76.51	77.28	71.86	689.58
1974	Wet	63.00	58.10	49.87	66.54	84.50	92.89	75.96	67.09	69.43	73.06	73.77	68.45	842.66
1975	Wet	59.38	54.87	46.90	64.19	58.48	86.43	77.66	69.86	72.29	76.02	76.80	71.44	814.32
1976	Critical	62.58	57.69	49.49	55.68	47.51	41.41	63.56	63.34	46.79	80.39	73.53	66.62	708.59
1977	Critical	50.89	46.70	30.97	15.24	13.73	19.67	27.52	6.15	1.66	1.83	1.75	1.40	217.51
1978	Above Normal	0.18	2.06	0.10	12.06	12.55	54.72	69.06	64.19	66.19	71.65	70.69	63.96	487.41
1979	Below Normal	53.55	49.41	40.24	46.89	38.71	75.51	74.26	66.69	69.01	72.59	73.29	68.10	728.25
1980	Above Normal	59.08	54.51	46.56	49.48	72.14	92.30	50.97	58.97	60.90	64.22	64.82	59.86	733.81
1981	Dry	50.31	46.70	39.36	62.93	54.75	66.24	63.67	64.59	37.91	88.17	81.08	70.08	725.79
1982	Wet	54.40	50.34	34.85	34.39	38.59	92.26	65.80	63.44	70.65	74.48	75.16	69.47	723.83
1983	Wet	60.13	70.11	92.04	50.75	84.14	92.29	44.95	44.25	51.69	52.06	45.33	49.44	737.18
1984	Wet	44.40	41.63	91.95	58.96	87.53	92.28	59.28	69.12	71.37	75.22	75.95	70.65	838.34
1985	Dry	61.77	56.96	79.78	47.40	54.99	78.33	71.61	65.66	66.51	70.03	70.68	65.71	789.43
1986	Wet	56.76	52.16	44.28	49.58	41.82	82.74	72.31	68.37	70.74	74.35	75.26	69.62	757.99
1987	Dry	60.33	55.96	47.88	61.70	53.37	36.60	37.01	35.76	36.38	42.55	32.46	24.09	524.09
1988	Critical	5.83	2.97	2.19	10.48	12.75	19.19	28.34	26.17	23.67	28.23	21.15	15.39	196.36
1989	Dry	0.18	0.14	0.10	2.62	11.89	19.41	69.40	70.43	67.52	85.25	78.12	66.82	471.88
1990	Critical	50.96	46.87	31.15	15.56	14.62	22.15	34.22	32.66	30.88	36.74	27.42	19.90	363.13
1991	Critical	2.49	0.14	0.10	7.01	11.10	18.77	28.68	26.70	24.71	33.34	24.74	17.91	195.69
1992	Critical	1.33	0.14	0.10	6.03	11.08	19.03	28.39	26.10	23.63	1.66	1.73	30.22	149.44
1993	Above Normal	16.33	0.14	21.15	12.18	34.23	58.53	69.13	64.90	66.71	78.59	76.13	67.36	565.38
1994	Critical	55.73	51.41	40.44	42.31	32.65	38.36	58.66	57.97	54.84	67.78	26.58	63.65	590.38
1995	Wet	20.95	75.72	62.32	12.86	28.63	49.32	79.42	71.74	74.15	78.00	78.95	73.21	705.27
1996	Wet	64.15	59.37	50.51	45.37	53.90	71.25	75.96	68.09	70.37	74.08	74.84	69.60	777.49
1997	Wet	60.70	55.95	47.30	73.34	78.80	92.59	64.39	63.53	65.63	69.01	69.79	64.70	805.73
1998	Wet	55.43	51.30	43.60	62.74	55.91	92.96	68.06	61.35	58.88	62.30	67.48	62.39	742.40
1999	Wet	62.35	58.23	51.05	55.73	68.79	92.58	65.45	68.56	70.72	74.51	75.37	70.07	813.41
2000	Above Normal	61.16	56.40	48.31	57.96	53.91	55.79	69.21	68.67	70.06	81.39	75.99	63.98	762.83
2001	Dry	49.65	45.97	32.65	24.34	17.91	24.09	38.59	37.88	36.96	43.95	32.96	23.96	408.91
2002	Dry	5.10	2.07	0.55	0.54	12.55	33.20	78.34	70.47	68.34	72.25			

Difference in Energy generated (GWh) at Castaic: Alternative1_2005 minus Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Average
1922	Above Normal	0.00	0.00	0.00	9.88	(0.18)	(0.46)	(0.25)	0.12	4.59	4.61	4.61	4.38	2.28
1923	Below Normal	4.15	4.42	4.45	(7.36)	(24.45)	4.46	23.24	(6.06)	(53.78)	21.18	21.60	20.67	1.04
1924	Critical	21.35	20.13	19.08	14.19	7.67	3.06	3.51	3.95	4.37	(31.23)	(23.02)	(16.54)	2.21
1925	Dry	38.07	45.03	48.76	11.00	2.33	(34.16)	5.62	(9.56)	(8.49)	(10.36)	(9.37)	(7.42)	5.95
1926	Dry	(6.62)	(6.16)	(4.49)	4.77	0.48	1.79	5.04	5.96	6.68	10.30	9.45	7.81	2.92
1927	Wet	7.29	20.01	15.56	4.17	(2.90)	(0.83)	(1.73)	(1.69)	2.67	5.27	5.29	5.27	4.87
1928	Above Normal	5.36	5.27	5.24	4.31	(1.94)	(2.00)	(1.86)	0.60	(34.02)	15.38	12.82	9.36	1.54
1929	Critical	7.47	7.14	4.15	(3.70)	(6.00)	(0.66)	4.30	2.80	3.10	(28.28)	(20.84)	(14.97)	(3.79)
1930	Dry	5.63	10.83	58.12	10.38	(0.14)	(0.25)	(1.07)	(1.07)	(7.56)	6.78	5.10	3.72	7.54
1931	Critical	2.39	1.81	1.48	2.04	0.23	0.24	(0.06)	(0.06)	(0.07)	(0.08)	(26.73)	(19.21)	(3.17)
1932	Dry	12.49	27.14	35.72	5.02	(0.21)	0.38	0.97	0.98	5.28	5.50	6.00	5.97	8.77
1933	Critical	6.40	6.46	5.99	6.12	0.27	(0.66)	(1.58)	(2.44)	(1.32)	(1.54)	(2.29)	(2.11)	1.11
1934	Critical	(2.72)	(2.53)	0.74	(1.09)	0.33	0.74	1.63	1.83	2.02	2.41	0.00	0.00	0.28
1935	Below Normal	2.04	1.89	1.54	1.03	0.18	0.41	1.53	1.72	(53.28)	11.61	13.84	12.04	(0.45)
1936	Below Normal	11.46	10.97	9.46	3.27	(0.11)	(24.68)	13.56	(0.19)	4.23	4.22	4.21	4.23	3.39
1937	Below Normal	4.24	4.28	4.32	(0.36)	(0.71)	0.00	(1.08)	(1.00)	3.39	3.33	3.31	3.37	1.92
1938	Wet	3.35	3.47	(0.92)	17.18	3.76	2.71	3.21	(1.09)	(1.13)	3.23	3.22	3.28	3.36
1939	Dry	3.26	3.38	3.48	6.30	0.00	0.00	(5.92)	1.19	16.88	4.43	4.60	4.75	3.53
1940	Above Normal	4.94	4.91	11.63	2.93	(1.27)	(0.54)	(0.02)	(0.02)	4.29	4.31	4.32	4.32	3.32
1941	Wet	4.34	4.36	2.08	0.02	0.00	0.00	0.00	0.00	4.42	4.41	4.42	4.42	2.37
1942	Wet	4.44	4.47	2.18	(12.40)	(0.41)	0.00	0.23	(0.07)	4.35	4.34	4.34	4.36	1.32
1943	Wet	4.40	4.41	4.44	(1.56)	(4.23)	0.00	2.01	0.17	4.60	4.61	4.61	4.62	2.34
1944	Dry	4.67	4.64	4.66	1.55	(2.63)	(0.77)	(0.31)	(0.31)	2.59	2.53	2.41	2.43	1.79
1945	Below Normal	2.34	2.35	2.51	2.77	(0.06)	(0.90)	0.11	0.10	4.52	4.53	4.53	4.53	2.28
1946	Below Normal	4.54	4.56	4.51	4.48	0.00	0.24	0.28	0.28	4.71	4.73	4.73	4.71	3.15
1947	Dry	4.74	4.74	4.74	4.85	0.02	(0.28)	(0.15)	0.03	1.79	1.98	1.82	1.65	2.16
1948	Below Normal	1.53	1.56	1.45	1.19	(0.55)	(0.20)	0.04	0.18	0.00	(0.03)	(0.02)	(0.02)	0.43
1949	Dry	(0.02)	(0.01)	(0.01)	(0.05)	0.03	(0.07)	(0.03)	0.02	0.11	0.17	0.12	0.08	0.03
1950	Below Normal	0.04	0.04	0.01	(0.31)	(0.37)	(0.11)	(0.01)	(0.02)	1.91	1.89	1.89	1.89	0.57
1951	Above Normal	1.90	1.92	(1.59)	0.00	(17.67)	0.00	0.00	0.00	4.42	4.42	4.42	4.42	0.19
1952	Wet	4.44	4.46	4.49	5.91	0.00	0.00	0.00	(0.82)	(0.90)	3.47	3.46	3.71	2.35
1953	Wet	3.93	3.79	3.82	(2.06)	12.19	0.00	(15.44)	(0.80)	4.06	3.50	3.96	4.47	1.79
1954	Above Normal	4.88	4.83	5.26	6.06	2.40	2.82	0.37	0.43	1.63	1.17	1.31	1.29	2.70
1955	Dry	1.28	1.29	1.27	1.50	(0.01)	(0.09)	(0.40)	(0.43)	0.03	(0.05)	(0.01)	0.08	0.37
1956	Wet	0.12	0.14	0.22	(0.06)	0.00	0.00	0.06	0.05	4.47	4.47	4.48	4.48	1.54
1957	Above Normal	4.50	4.51	4.54	4.50	(0.05)	(0.03)	0.03	0.03	4.28	4.28	4.28	4.27	2.93
1958	Wet	4.30	4.31	4.34	4.34	0.00	0.00	0.00	0.00	4.42	4.42	4.42	4.42	2.91
1959	Below Normal	4.44	4.46	4.49	4.74	13.27	(3.48)	(1.36)	(1.46)	(24.73)	2.83	2.73	2.58	0.71
1960	Dry	2.58	2.52	2.41	1.95	(0.08)	0.13	0.17	0.01	0.02	(0.19)	(0.03)	(0.68)	0.73
1961	Dry	(0.46)	(0.44)	(0.14)	0.67	0.60	0.23	0.11	0.13	0.13	0.16	0.14	(0.07)	0.09
1962	Below Normal	(1.66)	0.58	0.70	0.00	0.00	0.00	0.00	0.00	4.27	4.28	4.28	4.28	1.39
1963	Wet	4.30	4.32	4.34	4.33	0.00	0.00	0.00	0.00	4.42	4.42	4.42	4.42	2.91
1964	Dry	4.44	4.46	4.42	4.42	(0.11)	0.31	(0.04)	(0.03)	0.03	0.03	0.03	0.04	1.50
1965	Wet	0.04	0.04	0.04	0.24	0.04	(0.75)	0.01	0.08	4.51	4.84	4.77	4.67	1.54
1966	Below Normal	4.64	4.65	4.59	4.13	(0.36)	(0.20)	0.00	0.01	3.29	3.32	3.31	3.29	2.56
1967	Wet	3.30	3.32	3.33	3.21	(0.03)	0.00	0.01	(0.01)	(0.02)	4.40	4.41	4.41	2.19
1968	Below Normal	4.43	1.12	(2.71)	(18.08)	0.12	0.00	(0.34)	0.19	4.23	5.27	4.43	3.51	0.18
1969	Wet	2.77	2.93	2.27	(24.85)	(9.12)	0.00	(0.43)	(0.40)	(0.42)	3.98	3.98	4.00	(1.27)
1970	Wet	3.98	4.06	4.12	2.27	(4.12)	(0.20)	(4.28)	0.29	4.73	4.73	4.74	4.72	2.09
1971	Wet	4.75	4.75	4.75	4.60	23.66	0.19	(0.10)	(0.11)	2.60	2.77	2.76	2.75	4.45
1972	Below Normal	2.76	2.77	2.78	2.84	0.08	0.03	(0.01)	(0.02)	0.06	0.04	0.05	0.06	0.95
1973	Above Normal	0.07	0.07	0.08	0.12	0.05	0.03	0.00	0.01	4.43	4.43	4.43	4.42	1.51
1974	Wet	4.45	4.47	4.50	(9.67)	0.00	0.00	0.00	(0.20)	4.20	4.19	4.18	4.25	1.70
1975	Wet	4.32	4.30	4.35	5.55	2.43	(3.32)	0.74	0.70	5.16	5.20	5.20	5.15	3.32
1976	Critical	5.18	5.15	5.13	5.05	0.22	(0.06)	(0.30)	(0.33)	(0.08)	(0.47)	(0.43)	(0.47)	1.55
1977	Critical	(0.43)	(0.41)	(0.31)	(0.02)	(0.01)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.10)
1978	Above Normal	0.00	1.92	0.00	0.00	0.00	0.00	(1.88)	(0.55)	0.94	5.22	7.23	5.60	3.83
1979	Below Normal	2.50	2.72	1.26	(3.01)	(30.29)	(16.74)	15.46	0.81	5.25	5.30	5.30	5.28	(0.51)
1980	Above Normal	5.36	5.28	5.25	(4.79)	(8.38)	0.00	(1.73)	(1.55)	2.78	2.67	2.65	2.90	0.87
1981	Dry	3.03	3.03	3.17	2.65	(4.15)	5.11	1.22	1.43	30.67	3.61	3.70	4.74	4.85
1982	Wet	4.70	4.73	4.72	4.52	0.08	0.00	0.00	0.01	4.42	4.43	4.43	4.43	3.04
1983	Wet	(4.90)	9.63	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	4.44	4.42	1.13
1984	Wet	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	4.43	4.42	4.43	4.42	1.48
1985	Dry	4.44	4.46	4.43	4.48	0.00	0.00	0.00	0.00	3.02	3.03	3.03	3.03	2.49
1986	Wet	3.04	3.05	3.07	3.07	0.00	(9.55)	9.90	0.02	4.43	4.44	4.43	4.43	2.53
1987	Dry	4.45	4.47	4.50	4.49	0.01	0.02	(1.04)	(1.16)	0.77	0.52	0.93	1.25	1.60
1988	Critical	1.58	1.68	2.09	1.75	(0.02)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.59
1989	Dry	0.00	0.00	0.00	(0.02)	(0.01)	(0.02)	(0.06)	(0.06)	(0.06)	0.00	0.00	0.73	0.04
1990	Critical	0.67	0.62	0.47	(0.01)	0.00	0.01	0.01	0.01	0.00	0.01	0.00	0.00	0.15
1991	Critical	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.13	0.19	0.13	0.09	0.05
1992	Critical	0.06	0.00	0.00	0.69	0.00	0.00	0.00	(0.01)	(0.01)	0.00	0.00	0.00	0.06
1993	Above Normal	0.36	0.00	0.96	0.00	(0.04)	(0.26)	(0.02)	0.04	4.45	5.27	5.19	5.04	1.75
1994	Critical	5.01	4.98	4.88	4.25	(0.19)	(0.08)	0.00	0.00	0.07	0.04	(0.34)	0.10	1.56
1995	Wet	1.54	1.91	0.04	0.07	(0.01)	0.00	0.00	0.00	4.42	4.42	4.42	4.42	1.77
1996	Wet	4.44	4.46	3.97	(20.71)	(17.50)	(10.40)	(1.39)	(1.35)	3.02	2.94	2.93	3.05	(2.21)
1997	Wet	3.07	3.16	2.71	5.53	(0.32)	0.01	0.55	0.20	4.62	4.63	4.64	4.63	2.79
1998	Wet	4.65	4.66	4.67	4.56	(25.76)	4.64	(0.01)	(0.86)	(0.94)	(1.00)	3.41	3.68	0.14
1999	Wet	6.17	1.37	1.43	(2.30)	(12.79)	(0.38)	(8.61)	0.13	4.55	4.56	4.57	4.55	0.27
2000	Above Normal	4.57	4.59	4.61	4.66	0.28	(0.94)	(0.26)	0.05	4.35	4.71	4.42	4.09	2.93
2001	Dry	3.83	3.91	3.70	3.02	(1.22)	(0.28)	0.24	0.27	0.73	0.79	0.69	0.63	1.36
2002	Dry	0.56	0.54	0.45	0.44	0.11	(0.04)	(0.21)	(0.20)	(0.16)	(0.16)	(0.17)	(0.16)	0.08
2003	Above Normal	(0.15)	(0.15)	(0.38)	0.69	0.58	0.21	(0.01)	(0.01)	2.16	2.15	2.14	2.15	0.78
Average		3.66	4.26	4.61	1.42	(1.30)	(1.07)	0.53	(0.09)	0.66	2.49	2.39	2.53	1.67
Wet		3.36	4.25	3.25	(0.16)	(1.35)	(0.69)	(0.59)	(0.22)	3.12	3.89	4.24	4.29	1.95
Above Normal		2.65	2.76	2.97	2.36	(2.19)	(0.25)	(0.36)	0.05	0.72	5.05	4.68	4.21	1.89
Below Normal		3.39	3.31	2.81	(0.33)	(3.09)	(2.94)	3.67	(0.39)	(6.85)	5.18	5.30	5.03	1.26
Dry		4.80	6.32	9.73	3.75	(0.28)	(1.56)	0.23	(0.16)	2.91	1.62	1.58	1.59	2.54
Critical		3.91	3.75	3.64	2.44	0.21	0.22	0.63	0.48	0.				

Percent Difference in Energy generated (GWh) at Castaic: Alternative1_2005 minus Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September
1922	Above Normal	0%	0%	0%	64%	-1%	-1%	0%	0%	7%	7%	7%	7%
1923	Below Normal	8%	9%	11%	-10%	-29%	5%	37%	-10%	-90%	30%	33%	38%
1924	Critical	52%	54%	76%	64%	38%	13%	11%	13%	16%	-95%	-93%	-92%
1925	Dry	>1,000%	>1,000%	>1,000%	204%	21%	-58%	11%	-14%	-13%	-14%	-13%	-13%
1926	Dry	-16%	-16%	-18%	30%	3%	6%	13%	10%	12%	16%	16%	16%
1927	Wet	21%	63%	79%	38%	-15%	-1%	-2%	-2%	4%	7%	7%	8%
1928	Above Normal	9%	10%	12%	8%	-4%	-5%	-2%	1%	-50%	21%	18%	14%
1929	Critical	13%	13%	9%	-8%	-15%	-2%	16%	10%	12%	-94%	-92%	-91%
1930	Dry	923%	>1,000%	>1,000%	256%	-1%	-1%	-2%	-2%	-17%	13%	12%	11%
1931	Critical	13%	12%	21%	15%	2%	1%	0%	0%	0%	0%	-94%	-93%
1932	Dry	415%	>1,000%	>1,000%	54%	-2%	1%	2%	2%	11%	10%	12%	14%
1933	Critical	24%	27%	45%	42%	2%	-3%	-4%	-6%	-3%	-3%	-6%	-8%
1934	Critical	-31%	-44%	740%	-9%	3%	3%	4%	5%	6%	6%	0%	0%
1935	Below Normal	8%	7%	9%	8%	1%	2%	2%	3%	-82%	14%	18%	19%
1936	Below Normal	24%	25%	34%	20%	-1%	-27%	21%	0%	6%	6%	6%	6%
1937	Below Normal	7%	8%	9%	-1%	-1%	0%	-2%	-1%	5%	5%	5%	5%
1938	Wet	6%	7%	-2%	28%	5%	3%	6%	-2%	-2%	5%	5%	6%
1939	Dry	7%	8%	9%	10%	0%	0%	-8%	2%	36%	5%	6%	7%
1940	Above Normal	9%	10%	21%	20%	-9%	-2%	0%	0%	7%	5%	6%	7%
1941	Wet	10%	11%	8%	0%	0%	0%	0%	0%	8%	8%	8%	8%
1942	Wet	10%	11%	7%	-15%	-1%	0%	0%	0%	7%	7%	7%	7%
1943	Wet	9%	10%	12%	-3%	-6%	0%	3%	0%	7%	6%	6%	7%
1944	Dry	8%	9%	10%	3%	-6%	-2%	-1%	-1%	5%	4%	5%	6%
1945	Below Normal	10%	11%	21%	15%	0%	-1%	0%	0%	7%	6%	6%	7%
1946	Below Normal	8%	9%	6%	9%	0%	0%	0%	0%	7%	7%	7%	7%
1947	Dry	9%	10%	11%	9%	0%	-1%	0%	0%	3%	3%	2%	3%
1948	Below Normal	3%	3%	4%	4%	-2%	-1%	0%	0%	0%	0%	0%	0%
1949	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1950	Below Normal	0%	0%	0%	-2%	-2%	0%	0%	0%	127%	2%	3%	3%
1951	Above Normal	4%	5%	-3%	0%	-21%	0%	0%	0%	7%	6%	6%	7%
1952	Wet	8%	9%	10%	9%	0%	0%	0%	-2%	-2%	7%	6%	8%
1953	Wet	10%	11%	6%	-3%	23%	0%	-17%	-1%	7%	5%	6%	8%
1954	Above Normal	11%	12%	17%	15%	6%	5%	1%	1%	3%	2%	2%	2%
1955	Dry	3%	3%	5%	10%	0%	0%	-1%	-1%	0%	0%	0%	0%
1956	Wet	0%	0%	1%	0%	0%	0%	0%	0%	6%	6%	6%	6%
1957	Above Normal	7%	8%	9%	8%	0%	0%	0%	0%	268%	5%	6%	7%
1958	Wet	10%	11%	17%	69%	0%	0%	0%	0%	6%	6%	6%	6%
1959	Below Normal	7%	8%	10%	7%	21%	-4%	-2%	-2%	-44%	4%	4%	4%
1960	Dry	6%	6%	9%	13%	-1%	1%	0%	0%	0%	0%	0%	-1%
1961	Dry	-1%	-1%	0%	4%	3%	1%	0%	0%	0%	0%	0%	0%
1962	Below Normal	-11%	1%	2%	0%	0%	0%	0%	0%	277%	5%	6%	7%
1963	Wet	9%	10%	15%	13%	0%	0%	0%	0%	7%	7%	7%	7%
1964	Dry	8%	9%	6%	13%	0%	1%	0%	0%	0%	0%	0%	0%
1965	Wet	0%	0%	0%	0%	0%	-1%	0%	0%	7%	7%	7%	8%
1966	Below Normal	9%	10%	12%	6%	-1%	0%	0%	0%	5%	5%	5%	6%
1967	Wet	8%	9%	13%	27%	0%	0%	0%	0%	0%	6%	6%	7%
1968	Below Normal	8%	2%	-5%	-24%	0%	0%	0%	0%	7%	8%	7%	6%
1969	Wet	6%	7%	8%	-38%	-11%	0%	-1%	-1%	-1%	6%	6%	7%
1970	Wet	7%	12%	11%	4%	-6%	0%	-6%	0%	7%	7%	7%	7%
1971	Wet	8%	9%	11%	6%	40%	0%	0%	0%	4%	4%	4%	5%
1972	Below Normal	7%	8%	12%	39%	0%	0%	0%	0%	0%	0%	0%	0%
1973	Above Normal	0%	0%	0%	1%	0%	0%	0%	0%	6%	6%	6%	7%
1974	Wet	8%	8%	10%	-13%	0%	0%	0%	0%	6%	6%	6%	7%
1975	Wet	8%	9%	10%	9%	4%	-4%	1%	1%	8%	7%	7%	8%
1976	Critical	9%	10%	12%	10%	0%	0%	0%	-1%	0%	-1%	-1%	-1%
1977	Critical	-1%	-1%	-1%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1978	Above Normal	0%	>1,000%	0%	0%	0%	-3%	-1%	1%	9%	11%	9%	6%
1979	Below Normal	5%	6%	3%	-6%	-44%	-18%	26%	1%	8%	8%	8%	8%
1980	Above Normal	10%	11%	13%	-9%	-10%	0%	-3%	-3%	5%	4%	4%	5%
1981	Dry	6%	7%	9%	4%	-7%	8%	2%	2%	424%	4%	5%	7%
1982	Wet	9%	10%	16%	15%	0%	0%	0%	0%	7%	6%	6%	7%
1983	Wet	-8%	16%	0%	0%	0%	0%	0%	0%	0%	0%	11%	10%
1984	Wet	0%	0%	0%	0%	0%	0%	0%	0%	7%	6%	6%	7%
1985	Dry	8%	8%	6%	10%	0%	0%	0%	0%	5%	5%	4%	5%
1986	Wet	6%	6%	7%	7%	0%	-10%	16%	0%	7%	6%	6%	7%
1987	Dry	8%	9%	10%	8%	0%	0%	-3%	-3%	2%	1%	3%	5%
1988	Critical	37%	130%	>1,000%	20%	0%	0%	0%	0%	0%	0%	0%	0%
1989	Dry	0%	0%	0%	-1%	0%	0%	0%	0%	0%	0%	0%	1%
1990	Critical	1%	1%	2%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1991	Critical	0%	0%	0%	0%	0%	0%	0%	0%	1%	1%	1%	1%
1992	Critical	5%	0%	0%	13%	0%	0%	0%	0%	0%	0%	0%	0%
1993	Above Normal	2%	0%	5%	0%	0%	0%	0%	0%	7%	7%	7%	8%
1994	Critical	10%	11%	14%	11%	-1%	0%	0%	0%	0%	0%	-1%	0%
1995	Wet	8%	3%	0%	1%	0%	0%	0%	0%	6%	6%	6%	6%
1996	Wet	7%	8%	9%	-31%	-25%	-13%	-2%	-2%	4%	4%	4%	5%
1997	Wet	5%	6%	6%	8%	0%	0%	1%	0%	8%	7%	7%	8%
1998	Wet	9%	10%	12%	8%	-32%	5%	0%	-1%	-2%	5%	6%	6%
1999	Wet	11%	2%	3%	-4%	-16%	0%	-12%	0%	7%	7%	6%	7%
2000	Above Normal	8%	9%	11%	9%	1%	-2%	0%	0%	7%	6%	6%	7%
2001	Dry	8%	9%	13%	14%	-6%	-1%	1%	1%	2%	2%	2%	3%
2002	Dry	12%	35%	450%	440%	1%	0%	0%	0%	0%	0%	0%	0%
2003	Above Normal	0%	0%	0%	9%	4%	1%	0%	0%	154%	3%	3%	4%
Average		23%	9%	25%	19%	-1%	-1%	1%	0%	16%	2%	1%	2%
Wet		7%	10%	10%	5%	-2%	-1%	-1%	0%	5%	6%	6%	7%
Above Normal		5%	5%	7%	11%	-3%	-1%	-1%	0%	36%	7%	7%	7%
Below Normal		7%	8%	9%	5%	-4%	-3%	6%	-1%	17%	7%	8%	8%
Dry		78%	5%	29%	60%	0%	-3%	1%	0%	26%	3%	3%	4%
Critical		11%	18%	76%	13%	2%	1%	2%	2%	3%	-16%	-24%	-24%

Energy generated (GWh) at DCanyon: Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Total
1922	Above Normal	115.90	119.97	100.47	22.98	39.44	60.02	73.72	76.20	79.95	74.65	83.43	79.11	925.84
1923	Below Normal	78.09	71.07	62.85	98.81	86.56	104.44	67.34	85.20	85.16	81.19	93.33	90.08	1,004.12
1924	Critical	75.81	69.31	56.99	33.33	37.54	31.30	43.70	61.74	63.25	54.26	53.22	52.01	632.46
1925	Dry	32.71	25.70	20.64	11.04	17.67	34.19	71.59	94.48	94.26	89.86	101.25	98.25	691.64
1926	Dry	78.25	71.94	58.37	16.70	25.67	35.69	57.17	81.28	81.23	77.34	87.35	84.67	755.66
1927	Wet	67.58	61.97	50.26	19.07	38.80	71.46	79.83	83.77	87.86	81.84	90.23	85.38	818.05
1928	Above Normal	84.50	77.03	68.77	95.78	96.01	58.89	80.18	83.44	87.24	81.29	88.91	84.12	986.16
1929	Critical	82.45	75.37	67.41	90.19	87.57	45.53	35.65	56.04	57.28	49.32	48.39	45.19	740.39
1930	Dry	30.43	23.70	18.98	10.44	20.52	25.13	57.71	78.71	79.86	72.78	77.58	75.59	571.43
1931	Critical	54.58	47.61	38.86	13.31	21.12	23.08	50.84	71.71	73.18	62.87	61.81	59.52	578.49
1932	Dry	36.15	31.13	24.90	12.50	25.90	31.44	54.95	73.59	73.88	69.64	77.01	74.85	585.94
1933	Critical	57.87	52.43	42.63	14.08	22.37	30.03	57.80	81.52	83.23	73.00	74.06	72.45	661.47
1934	Critical	48.14	39.32	31.94	12.77	18.71	24.39	54.70	77.01	78.63	67.48	1.76	1.28	456.13
1935	Below Normal	30.30	97.42	74.19	12.06	23.57	30.48	71.32	94.90	18.75	99.28	110.44	107.32	770.03
1936	Below Normal	84.54	77.99	63.40	17.34	32.66	83.44	81.71	87.46	91.66	85.40	94.30	89.22	889.12
1937	Below Normal	88.26	80.52	71.84	102.17	101.59	107.21	79.96	82.64	86.71	81.20	90.31	85.28	1,057.69
1938	Wet	83.86	76.52	67.66	109.48	113.93	140.46	73.21	84.00	87.98	76.42	94.28	82.06	1,089.86
1939	Dry	80.53	73.11	63.28	96.92	73.49	136.00	82.08	89.96	1.49	97.38	47.44	117.85	959.53
1940	Above Normal	95.90	37.36	98.13	12.51	19.43	41.52	70.80	95.73	63.57	94.30	105.76	102.70	837.71
1941	Wet	81.61	74.96	60.83	33.60	43.74	117.99	66.10	69.77	73.18	69.03	79.03	74.84	844.68
1942	Wet	73.41	66.68	57.77	82.39	111.89	136.64	88.66	75.71	79.49	74.38	83.83	79.47	1,010.32
1943	Wet	78.54	71.36	62.76	97.70	113.45	93.44	83.73	85.77	89.73	84.14	94.41	89.51	1,044.54
1944	Dry	88.23	80.35	70.79	91.81	88.34	51.98	57.15	77.12	77.31	72.33	79.20	77.05	911.66
1945	Below Normal	58.42	52.33	42.63	17.27	26.45	139.96	81.54	83.77	87.92	81.93	90.29	85.43	847.94
1946	Below Normal	84.47	77.02	70.70	113.78	79.02	77.79	74.45	78.77	82.50	81.57	85.99	81.56	983.06
1947	Dry	80.70	73.47	65.14	96.80	102.26	59.36	77.61	91.65	93.50	88.13	97.57	93.91	1,020.10
1948	Below Normal	82.52	75.69	64.38	54.83	56.17	34.17	55.08	49.12	1.41	99.17	109.66	106.79	788.99
1949	Dry	84.03	77.30	62.87	18.29	27.34	33.42	77.70	90.04	92.40	86.87	96.01	92.23	838.50
1950	Below Normal	82.22	75.41	64.57	22.85	27.14	29.35	64.39	84.96	1.35	96.74	106.83	103.92	759.73
1951	Above Normal	81.73	75.21	61.19	132.92	108.49	135.49	75.39	81.40	85.36	79.52	88.80	84.27	1,089.77
1952	Wet	83.41	75.92	67.30	107.18	106.34	74.98	60.52	66.71	69.85	66.36	77.12	73.10	928.79
1953	Wet	71.44	64.67	90.26	107.53	109.85	136.25	95.33	78.24	79.38	74.92	84.73	81.20	1,073.80
1954	Above Normal	74.81	68.17	58.41	70.86	75.53	68.16	71.28	93.99	87.74	80.04	102.73	99.78	951.50
1955	Dry	79.46	72.91	59.12	20.75	32.32	38.19	59.20	78.60	78.38	74.91	84.07	81.59	759.50
1956	Wet	64.79	59.33	48.13	111.17	110.57	138.69	86.09	88.99	93.31	87.00	97.40	92.48	1,077.95
1957	Above Normal	91.48	83.32	73.70	117.65	112.95	69.04	58.59	37.22	1.62	92.61	101.57	99.00	938.75
1958	Wet	77.44	71.14	57.87	22.08	52.08	122.05	85.51	88.56	92.81	87.01	98.21	92.99	947.75
1959	Below Normal	91.65	83.36	73.13	97.99	98.95	114.85	67.88	89.28	1.54	95.70	106.68	103.59	1,024.60
1960	Dry	81.97	75.24	61.11	16.20	21.40	29.83	76.66	99.25	36.02	102.12	54.90	120.69	775.39
1961	Dry	96.58	88.70	72.70	24.05	30.62	29.33	63.92	84.30	84.43	80.39	60.81	25.07	740.90
1962	Below Normal	0.91	64.97	126.69	8.65	15.08	37.94	64.81	86.26	1.44	98.31	108.74	105.81	719.61
1963	Wet	83.23	76.53	62.23	44.87	53.21	66.97	73.36	78.08	81.75	76.34	85.24	80.89	862.70
1964	Dry	80.09	72.85	79.29	93.31	58.47	63.01	79.30	81.60	85.60	79.80	88.42	83.67	945.41
1965	Wet	82.94	75.48	67.21	90.32	95.15	74.18	72.01	76.26	74.30	74.71	83.35	79.17	945.08
1966	Below Normal	76.88	69.93	61.54	97.08	101.53	75.76	68.68	88.22	76.41	84.89	97.48	94.20	992.60
1967	Wet	77.46	70.87	57.77	27.83	58.02	69.99	79.09	82.78	86.74	81.21	91.06	86.25	869.07
1968	Below Normal	85.08	77.41	68.30	95.85	117.93	123.00	78.83	81.44	82.77	78.13	89.20	85.81	1,063.75
1969	Wet	75.44	68.87	57.72	66.25	126.59	142.68	74.05	77.07	80.84	76.10	87.35	82.86	1,015.82
1970	Wet	81.23	73.80	63.91	105.01	120.27	139.02	76.17	81.29	85.29	79.40	88.61	84.03	1,078.03
1971	Wet	83.24	75.72	67.15	98.29	115.13	90.32	65.87	87.96	85.80	83.59	96.02	92.94	1,042.03
1972	Below Normal	74.81	68.51	55.40	24.93	46.50	61.39	70.81	89.44	89.87	85.29	96.76	93.48	857.19
1973	Above Normal	77.85	71.34	58.73	35.69	66.33	75.65	78.71	84.13	88.32	82.06	91.00	86.18	895.99
1974	Wet	85.34	77.72	69.17	98.52	85.15	115.45	80.15	81.74	85.90	80.10	90.29	85.75	1,035.28
1975	Wet	84.68	76.91	67.66	112.61	112.86	101.27	79.72	82.21	86.32	80.22	88.40	83.75	1,056.61
1976	Critical	82.72	75.43	67.37	95.16	100.14	58.94	67.00	88.84	1.55	96.22	50.91	113.67	897.95
1977	Critical	89.08	81.83	66.61	15.95	21.36	21.04	5.60	1.12	1.78	1.82	1.78	1.33	309.30
1978	Above Normal	1.02	0.37	87.71	9.35	27.95	57.13	71.99	75.25	79.01	73.63	81.34	76.87	641.62
1979	Below Normal	76.05	69.12	61.53	95.90	96.21	77.29	76.36	79.34	83.36	77.68	86.20	81.61	960.65
1980	Above Normal	80.46	73.27	65.01	98.18	104.33	140.46	72.87	75.70	79.46	74.99	85.74	81.19	1,031.66
1981	Dry	79.62	72.26	62.62	112.20	114.97	76.42	65.01	87.75	1.80	99.88	92.14	110.44	975.11
1982	Wet	86.43	79.32	64.49	41.54	50.87	139.29	89.52	94.81	88.98	83.38	94.86	89.94	993.43
1983	Wet	88.59	80.50	131.64	115.72	106.09	142.69	59.29	62.37	65.58	62.22	72.99	69.26	1,056.94
1984	Wet	75.33	68.85	131.66	106.34	111.09	140.58	76.22	82.57	86.38	80.65	89.96	85.41	1,135.04
1985	Dry	84.46	76.96	74.58	112.52	104.12	87.67	73.57	77.78	81.80	76.08	84.17	79.65	1,013.36
1986	Wet	78.87	71.87	64.01	94.43	91.77	135.68	81.53	84.41	88.69	83.07	93.58	88.40	1,056.31
1987	Dry	87.00	79.29	69.59	112.09	112.16	62.55	56.79	80.04	81.84	70.04	69.10	67.65	948.14
1988	Critical	43.05	34.02	27.33	12.20	21.69	20.27	36.94	52.17	53.46	46.09	45.06	43.99	436.27
1989	Dry	27.65	21.51	17.27	10.40	18.46	20.13	74.39	99.49	48.10	99.90	93.51	111.95	642.76
1990	Critical	88.60	81.48	66.17	16.82	23.71	25.71	48.91	68.89	70.56	60.54	59.44	58.14	668.97
1991	Critical	36.75	28.88	23.20	11.42	17.46	19.85	37.79	48.84	14.24	55.37	53.58	52.56	399.94
1992	Critical	32.35	23.71	20.68	10.39	16.54	18.50	37.01	52.26	53.45	1.79	1.76	18.39	286.83
1993	Above Normal	67.10	0.81	89.98	10.20	43.18	58.27	72.09	83.09	27.38	86.48	96.68	92.60	727.86
1994	Critical	83.33	76.33	65.19	64.80	68.38	48.94	60.57	80.04	53.20	79.14	1.75	74.85	756.52
1995	Wet	0.88	18.60	128.62	8.55	38.60	52.74	84.64	87.33	91.56	85.70	95.71	90.60	783.53
1996	Wet	89.35	81.41	71.96	105.44	108.68	90.23	80.71	83.04	87.08	81.18	90.17	85.38	1,054.63
1997	Wet	84.46	76.99	68.43	110.72	93.76	135.71	74.55	77.29	80.93	75.87	85.86	81.48	1,046.05
1998	Wet	80.26	72.99	63.96	110.65	83.73	110.78	71.92	81.55	77.06	87.99	83.26	1,001.87	
1999	Wet	81.50	81.98	81.06	108.61	77.59	116.44	76.74	81.61	85.43	79.94	89.23	84.58	1,044.71
2000	Above Normal	83.70	76.25	67.64	103.87	100.13	74.82	73.30	93.11	93.56	89.20	99.97	96.68	1,052.23
2001	Dry	79.99	73.44	60.63	31.94	35.31	31.62	57.60	81.50	83.23				

Energy generated (GWh) at DCanyon: Alternative1_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Total
1922	Above Normal	115.90	119.97	100.47	30.67	39.99	60.47	74.98	78.17	88.35	83.19	93.57	89.13	974.86
1923	Below Normal	87.82	80.40	71.06	99.52	106.58	136.75	92.50	1.17	7.47	107.31	119.73	115.53	1,025.84
1924	Critical	101.41	93.52	79.76	58.24	56.05	38.43	50.82	71.81	31.19	1.80	1.72	1.28	586.03
1925	Dry	27.93	80.85	128.69	14.43	23.27	30.31	60.26	79.74	81.63	77.96	87.03	84.51	776.61
1926	Dry	67.41	62.13	50.81	19.79	26.28	37.74	56.27	90.24	65.39	89.30	100.13	96.61	762.10
1927	Wet	10.47	94.40	75.48	20.61	36.52	70.61	77.77	81.58	57.35	88.71	96.91	92.02	802.43
1928	Above Normal	91.20	83.72	75.56	101.22	95.29	57.60	78.69	88.71	4.73	101.82	111.09	106.33	995.96
1929	Critical	97.53	89.86	78.60	74.27	72.05	42.81	44.38	63.11	64.55	1.80	1.77	1.27	632.00
1930	Dry	0.96	0.37	113.62	12.51	20.69	25.75	57.74	79.08	1.53	84.31	88.18	86.13	570.87
1931	Critical	60.51	52.14	42.61	14.67	21.77	23.97	50.69	71.51	72.99	62.70	1.78	1.22	476.56
1932	Dry	0.88	32.05	129.27	12.94	26.04	32.64	54.46	72.53	78.93	75.27	83.17	80.95	679.13
1933	Critical	64.87	59.74	49.70	21.48	22.71	28.53	55.43	81.97	84.92	73.28	72.45	70.89	685.97
1934	Critical	44.69	36.77	29.78	14.16	19.80	26.71	58.00	81.67	83.39	71.52	1.76	1.28	469.53
1935	Below Normal	34.28	102.45	78.07	13.10	24.24	31.80	73.23	97.52	7.64	117.04	129.16	125.92	834.45
1936	Below Normal	100.16	92.79	76.61	22.89	31.33	67.10	82.46	87.25	97.72	91.48	100.38	95.31	945.48
1937	Below Normal	94.35	86.63	77.96	101.49	102.11	120.11	78.85	81.54	86.45	95.58	90.60	91.07	1,107.51
1938	Wet	89.15	81.89	66.78	90.03	89.17	145.10	71.99	74.99	78.91	80.46	91.59	87.21	1,047.27
1939	Dry	85.65	78.32	68.54	101.00	73.38	133.10	74.54	91.13	7.63	103.56	51.41	123.84	992.10
1940	Above Normal	102.10	16.13	109.41	15.21	16.45	40.73	70.77	95.69	69.39	100.43	111.88	108.82	857.01
1941	Wet	87.73	81.09	63.73	33.61	43.74	109.72	66.10	69.77	79.46	75.31	85.31	81.12	876.69
1942	Wet	79.69	72.96	60.82	96.53	112.38	135.75	88.77	75.50	85.55	80.44	89.78	85.43	1,063.60
1943	Wet	84.53	77.38	68.85	98.52	115.26	96.29	85.68	85.80	96.03	90.41	100.50	95.61	1,094.86
1944	Dry	94.35	86.50	77.05	87.71	79.00	48.88	57.20	77.30	81.61	76.47	83.18	81.06	930.31
1945	Below Normal	62.21	56.03	46.42	21.32	26.45	120.99	81.66	83.89	94.33	88.32	96.70	91.83	870.15
1946	Below Normal	90.86	83.41	78.18	120.06	79.02	78.08	74.79	79.13	89.16	83.64	92.67	88.21	1,037.21
1947	Dry	87.35	80.09	71.72	103.77	102.37	59.43	77.52	92.01	96.30	90.96	100.50	96.87	1,058.89
1948	Below Normal	85.07	78.25	66.80	55.80	54.79	33.66	55.15	52.42	1.41	99.16	109.70	106.81	799.02
1949	Dry	84.07	77.34	62.90	18.28	27.32	33.37	77.69	90.16	92.63	87.12	96.28	92.51	839.67
1950	Below Normal	82.38	75.58	64.69	22.02	26.27	29.08	64.38	84.94	4.06	99.43	109.52	106.61	768.96
1951	Above Normal	84.42	77.90	61.17	132.92	128.94	135.49	75.39	81.40	91.64	85.80	95.08	90.55	1,140.70
1952	Wet	89.69	82.20	73.58	111.83	106.33	74.97	60.51	64.12	67.06	69.81	79.45	75.65	955.20
1953	Wet	74.31	67.86	105.34	127.67	101.70	119.14	76.56	76.41	84.44	79.90	89.32	85.70	1,088.35
1954	Above Normal	80.45	73.80	64.45	81.48	79.70	70.83	71.81	94.70	95.82	80.51	104.82	101.83	1,000.20
1955	Dry	81.51	74.94	61.07	22.50	32.29	38.05	58.71	77.94	78.41	74.97	84.05	81.59	766.03
1956	Wet	64.92	59.50	48.39	84.02	110.60	138.74	86.15	89.06	99.66	93.35	103.74	98.83	1,076.96
1957	Above Normal	97.82	89.66	80.03	123.91	112.95	68.99	58.62	37.61	7.70	98.69	107.66	105.09	988.73
1958	Wet	83.53	77.22	63.95	28.16	52.08	121.86	85.51	88.56	99.09	93.29	104.49	99.27	997.01
1959	Below Normal	97.93	89.64	79.41	104.04	83.81	113.47	66.10	86.99	4.40	99.22	109.71	106.73	1,041.45
1960	Dry	84.79	78.02	63.93	18.79	21.16	30.07	76.76	98.91	42.90	100.34	60.64	117.16	793.47
1961	Dry	94.56	86.85	71.36	25.73	32.12	29.90	64.07	84.49	84.62	80.58	62.52	24.94	741.74
1962	Below Normal	0.91	64.85	127.12	8.65	15.08	37.94	64.81	86.27	7.52	104.39	114.81	111.89	744.24
1963	Wet	89.31	82.61	68.30	50.95	53.21	66.97	73.36	78.08	88.03	82.62	91.51	87.16	912.11
1964	Dry	86.37	79.12	85.58	99.60	58.53	63.05	79.26	81.56	85.66	79.86	88.48	83.73	970.80
1965	Wet	83.01	75.55	67.27	90.70	95.33	73.82	72.04	76.48	77.69	81.43	90.11	85.93	969.36
1966	Below Normal	83.47	76.50	68.04	102.80	100.98	75.52	68.69	88.25	80.84	89.59	102.19	98.91	1,035.78
1967	Wet	82.14	75.55	62.44	32.40	57.96	69.99	79.11	82.72	86.67	87.42	97.23	92.43	906.06
1968	Below Normal	91.26	78.91	74.52	128.14	118.00	123.93	79.26	83.52	90.11	85.64	97.41	94.11	1,144.81
1969	Wet	81.49	74.96	63.10	58.19	117.57	142.68	73.59	76.61	80.37	81.94	93.18	88.72	1,032.40
1970	Wet	87.08	79.67	69.81	102.41	117.90	139.36	76.22	81.66	91.95	86.03	95.28	90.68	1,118.05
1971	Wet	89.89	82.34	73.73	104.31	87.97	90.72	65.74	87.79	87.52	87.49	99.88	96.81	1,054.19
1972	Below Normal	78.66	72.36	59.25	28.82	46.52	61.39	70.80	89.40	89.93	85.35	96.83	93.54	872.85
1973	Above Normal	77.94	71.43	58.82	35.87	66.40	75.69	78.71	84.14	94.61	88.35	97.29	92.47	921.72
1974	Wet	91.63	84.01	75.46	120.95	85.17	115.07	79.79	81.12	91.51	85.70	95.60	91.11	1,097.12
1975	Wet	90.12	82.43	73.40	115.87	109.66	97.46	80.62	83.12	93.56	87.39	95.68	90.97	1,100.28
1976	Critical	89.95	82.58	74.41	102.54	101.16	59.20	66.62	88.35	1.55	95.67	52.18	112.66	926.87
1977	Critical	88.25	81.04	65.94	15.90	21.32	21.03	10.67	1.12	1.78	1.82	1.78	1.33	311.98
1978	Above Normal	1.02	0.99	84.99	9.35	27.97	55.96	71.80	79.39	88.61	83.40	91.97	87.92	683.37
1979	Below Normal	83.10	76.25	67.22	84.64	81.70	82.42	77.40	80.09	90.42	84.63	93.07	88.45	989.39
1980	Above Normal	87.35	80.11	71.91	96.17	108.38	137.11	69.26	72.74	82.60	78.21	88.06	83.71	1,055.61
1981	Dry	82.33	75.30	66.36	117.09	112.08	88.75	66.64	89.99	8.08	105.49	90.86	117.78	1,020.75
1982	Wet	93.73	86.56	71.53	48.02	51.11	139.23	89.54	84.82	95.27	89.67	101.16	96.24	1,046.88
1983	Wet	94.88	80.51	131.64	115.72	106.09	142.69	59.29	62.37	65.58	62.22	79.27	75.54	1,075.80
1984	Wet	75.33	68.85	131.66	106.34	111.48	140.58	76.23	82.57	92.66	86.94	96.24	91.70	1,160.58
1985	Dry	90.75	83.24	80.87	118.80	104.12	87.67	73.57	77.79	86.10	80.38	88.47	83.95	1,055.71
1986	Wet	83.17	76.17	68.31	98.73	91.77	89.24	81.58	84.46	95.02	89.40	99.92	94.73	1,052.50
1987	Dry	93.33	85.61	75.90	118.36	112.16	62.59	54.67	77.05	81.72	70.37	69.44	68.03	969.23
1988	Critical	44.34	35.62	29.19	14.93	21.50	20.21	36.95	52.17	53.46	46.09	45.06	43.99	443.51
1989	Dry	27.65	21.51	17.27	10.39	18.43	20.10	74.32	99.39	47.14	99.90	87.52	113.01	636.63
1990	Critical	89.37	82.17	66.74	16.81	23.71	25.71	48.92	68.91	70.57	60.55	59.45	58.15	671.06
1991	Critical	36.76	28.89	23.21	11.42	17.45	19.85	37.78	46.86	14.13	55.69	53.85	52.85	398.74
1992	Critical	32.51	21.77	22.08	10.39	16.53	18.50	37.00	52.25	53.44	1.79	1.76	17.84	285.86
1993	Above Normal	66.16	0.81	89.92	10.20	43.13	58.11	72.09	83.24	31.37	92.44	102.66	98.80	748.93
1994	Critical	89.60	82.17	71.03	70.51	67.90	48.80	60.57	80.04	53.54	79.22	1.85	75.03	780.26
1995	Wet	0.98	15.70	128.24	8.65	38.59	52.73	84.64	87.33	97.84	91.98	101.99	96.88	805.55
1996	Wet	95.63	87.69	77.51	62.36	66.10	71.86	78.95	81.25	91.47	85.70	94.55	89.88	982.95
1997	Wet	89.01	81.67	72.46	103.14	93.01	135.54	74.77	77.51	87.44	82.35	92.35	87.95	1,077.20
1998	Wet	86.74	79.46	70.42	117.16	113.20	105.24	71.86	75.03	78.67	74.13	90.18	85.68	1,047.77
1999	Wet	92.05	85.06	89.30	129.25	98.10	106.08	76.36	81.80	91.90	86.41	95.73	91.07	1,123.11
2000	Above Normal	90.19	82.72	74.08	110.64	100.74	74.34	73.15	93.84	100.24	95.94	106.87	103.64	1,106.39
2001	Dry	86.07	79.54	66.50	34.67	32.27								

Difference in Energy generated (GWh) at DCanyon: Alternative1_2005 minus Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Average
1922	Above Normal	0.00	0.00	0.00	7.69	0.55	0.45	1.26	1.97	8.40	8.54	10.14	10.02	4.09
1923	Below Normal	9.73	9.33	8.21	0.71	20.02	32.31	25.16	(84.03)	(77.69)	26.12	26.40	25.45	1.81
1924	Critical	25.60	24.21	22.77	24.91	18.51	7.13	7.12	10.07	(32.06)	(52.46)	(51.50)	(50.73)	(3.87)
1925	Dry	(4.78)	55.15	108.05	3.39	5.60	(3.88)	(11.33)	(14.74)	(12.63)	(11.90)	(14.22)	(13.74)	7.08
1926	Dry	(10.84)	(9.81)	(7.56)	3.09	0.61	2.05	(0.90)	8.96	(15.84)	11.96	12.78	11.94	0.54
1927	Wet	(57.11)	32.43	25.22	1.54	(2.28)	(0.85)	(2.06)	(2.19)	(30.51)	6.87	6.68	6.64	(1.30)
1928	Above Normal	6.70	6.69	6.79	5.44	(0.72)	(1.29)	(1.49)	5.27	(82.51)	20.53	22.18	22.21	0.82
1929	Critical	15.08	14.49	11.19	(15.92)	(15.52)	(2.72)	8.73	7.07	7.27	(47.52)	(46.62)	(43.92)	(9.03)
1930	Dry	(29.47)	(23.33)	94.64	2.07	0.17	0.62	0.03	0.37	(78.33)	11.53	10.60	10.54	(0.05)
1931	Critical	5.93	4.53	3.75	1.36	0.65	0.89	(0.15)	(0.20)	(0.19)	(0.17)	(60.03)	(58.30)	(8.49)
1932	Dry	(35.27)	0.92	104.37	0.44	0.14	1.20	(0.49)	(1.06)	5.05	5.63	6.16	6.10	7.77
1933	Critical	7.00	7.31	7.07	7.40	0.34	(1.50)	(2.37)	0.45	1.69	0.28	(1.61)	(1.56)	2.04
1934	Critical	(3.45)	(2.55)	(2.16)	1.39	1.09	2.32	3.30	4.66	4.76	4.04	0.00	0.00	1.12
1935	Below Normal	3.98	5.03	3.88	1.04	0.67	1.32	1.91	2.62	(11.11)	17.76	18.72	18.60	5.37
1936	Below Normal	15.62	14.80	13.21	5.55	(1.33)	(16.34)	0.75	(0.21)	6.06	6.08	6.08	6.09	4.70
1937	Below Normal	6.09	6.11	6.12	(0.68)	0.52	12.90	(1.11)	(1.10)	5.13	5.25	5.27	5.32	4.15
1938	Wet	5.29	5.37	(0.88)	(19.45)	(24.76)	4.64	(1.22)	(9.01)	(9.07)	4.04	(2.69)	5.15	(3.55)
1939	Dry	5.12	5.21	5.26	4.08	(0.11)	(2.90)	(7.54)	1.17	6.14	6.18	3.97	5.99	2.71
1940	Above Normal	6.20	(21.23)	11.28	2.70	(2.98)	(0.79)	(0.03)	(0.04)	5.82	6.13	6.12	6.12	1.61
1941	Wet	6.12	6.13	2.90	0.01	0.00	(8.27)	0.00	0.00	6.28	6.28	6.28	6.28	2.67
1942	Wet	6.28	6.28	3.05	14.14	0.49	(0.89)	0.11	(0.21)	6.06	6.06	5.95	5.96	4.44
1943	Wet	5.99	6.02	6.09	0.82	1.81	2.85	1.95	0.03	6.30	6.27	6.09	6.10	4.19
1944	Dry	6.12	6.15	6.26	(4.10)	(9.34)	(3.10)	0.05	0.18	4.30	4.14	3.98	4.01	1.55
1945	Below Normal	3.79	3.70	3.79	4.05	0.00	(18.97)	0.12	0.12	6.41	6.39	6.41	6.40	1.85
1946	Below Normal	6.39	6.39	7.48	6.28	0.00	0.29	0.34	0.36	6.66	6.63	6.68	6.65	4.51
1947	Dry	6.65	6.62	6.58	6.97	0.11	0.07	(0.09)	0.36	2.80	2.83	2.93	2.96	3.23
1948	Below Normal	2.55	2.56	2.42	0.97	(1.38)	(0.51)	0.07	3.30	0.00	(0.01)	0.04	0.02	0.84
1949	Dry	0.04	0.04	0.03	(0.01)	(0.02)	(0.05)	(0.01)	0.12	0.23	0.25	0.27	0.28	0.10
1950	Below Normal	0.16	0.17	0.12	(0.83)	(0.87)	(0.27)	(0.01)	(0.02)	2.71	2.69	2.69	2.69	0.77
1951	Above Normal	2.69	2.69	(0.02)	0.00	20.45	0.00	0.00	0.00	6.28	6.28	6.28	6.28	4.24
1952	Wet	6.28	6.28	6.28	4.65	(0.01)	(0.01)	(0.01)	(2.59)	(2.79)	3.45	2.33	2.55	2.20
1953	Wet	2.87	3.19	15.08	20.14	(8.15)	(17.11)	(18.77)	(1.83)	5.06	4.98	4.59	4.50	1.21
1954	Above Normal	5.64	5.63	6.04	10.62	4.17	2.67	0.53	0.71	8.08	0.47	2.09	2.05	4.06
1955	Dry	2.05	2.03	1.95	1.75	(0.03)	(0.14)	(0.49)	(0.66)	0.03	0.06	(0.02)	0.00	0.54
1956	Wet	0.13	0.17	0.26	(27.15)	0.03	0.05	0.06	0.07	6.35	6.35	6.34	6.35	(0.08)
1957	Above Normal	6.34	6.34	6.33	6.26	0.00	(0.05)	0.03	0.39	6.08	6.08	6.09	6.09	4.17
1958	Wet	6.09	6.08	6.08	6.08	0.00	(0.19)	0.00	0.00	6.28	6.28	6.28	6.28	4.11
1959	Below Normal	6.28	6.28	6.28	6.05	(15.14)	(1.38)	(1.78)	(2.29)	2.86	3.52	3.03	3.14	1.40
1960	Dry	2.82	2.78	2.82	2.59	(0.24)	0.24	0.10	(0.34)	6.88	(1.78)	5.74	(3.53)	1.51
1961	Dry	(2.02)	(1.85)	(1.34)	1.68	1.50	0.57	0.15	0.19	0.19	0.19	1.71	(0.13)	0.07
1962	Below Normal	0.00	(0.12)	0.43	0.00	0.00	0.00	0.00	0.00	6.08	6.08	6.07	6.08	2.05
1963	Wet	6.08	6.08	6.07	6.08	0.00	0.00	0.00	0.00	6.28	6.28	6.27	6.27	4.12
1964	Dry	6.28	6.27	6.29	6.29	0.06	0.04	(0.04)	(0.04)	0.06	0.06	0.06	0.06	2.12
1965	Wet	0.07	0.07	0.06	0.38	0.18	(0.36)	0.03	0.22	3.39	6.72	6.76	6.76	2.02
1966	Below Normal	6.59	6.57	6.50	5.72	(0.55)	(0.24)	0.01	0.03	4.43	4.70	4.71	4.71	3.60
1967	Wet	4.68	4.68	4.67	4.57	(0.06)	0.00	0.02	(0.06)	(0.07)	6.21	6.17	6.18	3.08
1968	Below Normal	6.18	1.50	6.22	32.29	0.07	0.93	0.43	2.08	7.34	7.51	8.21	8.30	6.76
1969	Wet	6.05	6.09	5.38	(8.06)	(9.02)	0.00	(0.46)	(0.46)	(0.47)	5.84	5.83	5.86	1.38
1970	Wet	5.85	5.87	5.90	(2.60)	(2.37)	0.34	0.05	0.37	6.66	6.63	6.67	6.65	3.34
1971	Wet	6.65	6.62	6.58	6.02	(27.16)	0.40	(0.13)	(0.17)	1.72	3.90	3.86	3.87	1.01
1972	Below Normal	3.85	3.85	3.85	3.89	0.02	0.00	(0.01)	(0.04)	0.06	0.06	0.07	0.06	1.31
1973	Above Normal	0.09	0.09	0.09	0.18	0.07	0.04	0.00	0.01	6.29	6.29	6.29	6.29	2.14
1974	Wet	6.29	6.29	6.29	22.43	0.02	(0.38)	(0.36)	(0.62)	5.61	5.60	5.31	5.36	5.15
1975	Wet	5.44	5.52	5.74	3.26	(3.20)	(3.81)	0.90	0.91	7.24	7.17	7.28	7.22	3.64
1976	Critical	7.23	7.15	7.04	7.38	1.02	0.26	(0.38)	(0.49)	0.00	(0.55)	1.27	(1.01)	2.41
1977	Critical	(0.83)	(0.79)	(0.67)	(0.05)	(0.04)	(0.01)	5.07	0.00	0.00	0.00	0.00	0.00	0.22
1978	Above Normal	0.00	0.62	(2.72)	0.00	0.02	(1.17)	(0.19)	4.14	9.60	9.77	10.63	11.05	3.48
1979	Below Normal	7.05	7.13	5.69	(11.26)	(14.51)	5.13	1.04	0.75	7.06	6.95	6.87	6.84	2.40
1980	Above Normal	6.89	6.84	6.90	(2.01)	4.05	(3.35)	(3.61)	(2.96)	3.14	3.22	2.32	2.52	2.00
1981	Dry	2.71	3.04	3.74	4.89	(2.89)	12.33	1.63	2.24	6.28	5.61	(1.28)	7.34	3.80
1982	Wet	7.30	7.24	7.04	6.48	0.24	(0.06)	0.02	0.01	6.29	6.29	6.30	6.30	4.45
1983	Wet	6.29	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	6.28	6.28	1.57
1984	Wet	0.00	0.00	0.00	0.00	0.39	0.00	0.01	0.00	6.28	6.29	6.28	6.29	2.13
1985	Dry	6.29	6.28	6.29	6.28	0.00	0.00	0.00	0.01	4.30	4.30	4.30	4.30	3.53
1986	Wet	4.30	4.30	4.30	4.30	0.00	(46.44)	0.05	0.05	6.33	6.33	6.34	6.33	(0.32)
1987	Dry	6.33	6.32	6.31	6.27	0.00	0.04	(2.12)	(2.99)	(0.12)	0.33	0.34	0.38	1.76
1988	Critical	1.29	1.60	1.86	2.73	(0.19)	(0.06)	0.01	0.00	0.00	0.00	0.00	0.00	0.60
1989	Dry	0.00	0.00	0.00	(0.01)	(0.03)	(0.03)	(0.07)	(0.10)	(0.96)	0.00	(5.99)	1.06	(0.51)
1990	Critical	0.77	0.69	0.57	(0.01)	0.00	0.00	0.01	0.02	0.01	0.01	0.01	0.01	0.17
1991	Critical	0.01	0.01	0.01	0.00	(0.01)	0.00	(0.01)	(1.98)	(0.11)	0.32	0.27	0.29	(0.10)
1992	Critical	0.16	(1.94)	1.40	0.00	(0.01)	0.00	(0.01)	(0.01)	(0.01)	0.00	0.00	(0.55)	(0.08)
1993	Above Normal	(0.94)	0.00	(0.06)	0.00	(0.05)	(0.16)	0.00	0.15	3.99	5.96	5.98	6.20	1.76
1994	Critical	6.27	5.84	5.84	5.71	(0.48)	(0.14)	0.00	0.00	0.34	0.08	0.10	0.18	1.98
1995	Wet	0.10	(2.90)	(0.38)	0.10	(0.01)	(0.01)	0.00	0.00	6.28	6.28	6.28	6.28	1.84
1996	Wet	6.28	6.28	5.55	(43.08)	(42.58)	(18.37)	(1.76)	(1.79)	4.39	4.52	4.38	4.50	(5.97)
1997	Wet	4.55	4.68	4.03	(7.58)	(0.75)	(0.17)	0.22	0.22	6.51	6.48	6.49	6.47	2.60
1998	Wet	6.48	6.47	6.46	6.51	29.47	(5.54)	(0.06)	(2.69)	(2.88)	(2.93)	2.19	2.42	3.83
1999	Wet	10.55	3.08	8.24	20.64	20.51	(10.36)	(0.38)	0.19	6.47	6.47	6.50	6.49	6.53
2000	Above Normal	6.49	6.47	6.44	6.77	0.61	(0.48)	(0.15)	0.73	6.68	6.74	6.90	6.96	4.51
2001	Dry	6.08	6.10	5.87	2.73	(3.04)	(0.78)	0.48	0.68	1.31	1.21	1.20	1.19	1.92
2002	Dry	0.98	0.92	0.85	0.65	(0.01)	(0.05)	(0.26)	(0.27)	(0.19)	(0.18)	(0.20)	(0.18)	0.17
2003	Above Normal	(0.18)	5.12	(5.12)	1.02	0.85	0.31	(0.02)	(0.01)	3.06	3.05	3.04	3.05	1.18
Average		2.70	4.49	8.04	2.40	(0.67)	(0.99)	0.02	(0.90)	(0.90)	3.24	2.49	2.70	1.89
Wet		2.65	5.47	5.39	0.78	(2.59)	(4.02)	(0.84)	(0.75)	2.46	5.33	5.42	5.74	2.09
Above Normal		3.33	1.61	3.00	3.22	2.25	(0.32)	(0.31)	0.86	(1.26)	6.92	7.34	7.40	2.84
Below Normal		5.59	5.24	5.30	3.84	(0.89)	1.08	1.92	(5.60)	(2.43)	7.12	7.23	7.17	2.97
Dry		(1.72)	4.05	19.47	2.73	(0.42)	0.35	(1.16)	(0.33)	(3.92)	2.25	1.80	2.14	2.10
Critical		5.42	5.05	4.89	2.91									

Percent Difference in Energy generated (GWh) at DCanyon: Alternative1_2005 minus Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September
1922	Above Normal	0%	0%	0%	33%	1%	1%	2%	3%	11%	11%	12%	13%
1923	Below Normal	12%	13%	13%	1%	23%	31%	37%	-99%	-91%	32%	28%	28%
1924	Critical	34%	35%	40%	75%	49%	23%	16%	16%	-51%	-97%	-97%	-98%
1925	Dry	-15%	215%	523%	31%	32%	-11%	-16%	-16%	-13%	-13%	-14%	-14%
1926	Dry	-14%	-14%	-13%	19%	2%	6%	-2%	11%	-20%	15%	15%	14%
1927	Wet	-85%	52%	50%	8%	-6%	-1%	-3%	-3%	-35%	8%	7%	8%
1928	Above Normal	8%	9%	10%	6%	-1%	-2%	-2%	6%	-95%	25%	25%	26%
1929	Critical	18%	19%	17%	-18%	-18%	-6%	24%	13%	13%	-96%	-96%	-97%
1930	Dry	-97%	-98%	499%	20%	1%	2%	0%	0%	-98%	16%	14%	14%
1931	Critical	11%	10%	10%	10%	3%	4%	0%	0%	0%	0%	-97%	-98%
1932	Dry	-98%	3%	419%	4%	1%	4%	-1%	-1%	7%	8%	8%	8%
1933	Critical	12%	14%	17%	53%	2%	-5%	-4%	1%	2%	0%	-2%	-2%
1934	Critical	-7%	-6%	-7%	11%	6%	10%	6%	6%	6%	6%	0%	0%
1935	Below Normal	13%	5%	5%	9%	3%	4%	3%	3%	-59%	18%	17%	17%
1936	Below Normal	18%	19%	21%	32%	-4%	-20%	1%	0%	7%	7%	6%	7%
1937	Below Normal	7%	8%	9%	-1%	1%	12%	-1%	-1%	6%	6%	6%	6%
1938	Wet	6%	7%	-1%	-18%	-22%	3%	-2%	-11%	-10%	5%	-3%	6%
1939	Dry	6%	7%	8%	4%	0%	-2%	-9%	1%	412%	6%	8%	5%
1940	Above Normal	6%	-57%	11%	22%	-15%	-2%	0%	0%	9%	7%	6%	6%
1941	Wet	7%	8%	5%	0%	0%	-7%	0%	0%	9%	9%	8%	8%
1942	Wet	9%	9%	5%	17%	0%	-1%	0%	0%	8%	8%	7%	7%
1943	Wet	8%	8%	10%	1%	2%	3%	2%	0%	7%	7%	6%	7%
1944	Dry	7%	8%	9%	-4%	-11%	-6%	0%	0%	6%	6%	5%	5%
1945	Below Normal	6%	7%	9%	23%	0%	-14%	0%	0%	7%	8%	7%	7%
1946	Below Normal	8%	8%	11%	6%	0%	0%	0%	0%	8%	9%	8%	8%
1947	Dry	8%	9%	10%	7%	0%	0%	0%	0%	3%	3%	3%	3%
1948	Below Normal	3%	3%	4%	2%	-2%	-1%	0%	7%	0%	0%	0%	0%
1949	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1950	Below Normal	0%	0%	0%	-4%	-3%	-1%	0%	0%	201%	3%	3%	3%
1951	Above Normal	3%	4%	0%	0%	19%	0%	0%	0%	7%	8%	7%	7%
1952	Wet	8%	8%	9%	4%	0%	0%	0%	-4%	-4%	5%	3%	3%
1953	Wet	4%	5%	17%	19%	-7%	-13%	-20%	-2%	6%	7%	5%	6%
1954	Above Normal	8%	8%	10%	15%	6%	4%	1%	1%	9%	1%	2%	2%
1955	Dry	3%	3%	3%	8%	0%	0%	-1%	-1%	0%	0%	0%	0%
1956	Wet	0%	0%	1%	-24%	0%	0%	0%	0%	7%	7%	7%	7%
1957	Above Normal	7%	8%	9%	5%	0%	0%	1%	375%	7%	6%	6%	6%
1958	Wet	8%	9%	11%	28%	0%	0%	0%	0%	7%	7%	6%	7%
1959	Below Normal	7%	8%	9%	6%	-15%	-1%	-3%	-3%	186%	4%	3%	3%
1960	Dry	3%	4%	5%	16%	-1%	1%	0%	0%	19%	-2%	10%	-3%
1961	Dry	-2%	-2%	-2%	7%	5%	2%	0%	0%	0%	0%	3%	-1%
1962	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	422%	6%	6%	6%
1963	Wet	7%	8%	10%	14%	0%	0%	0%	0%	8%	8%	7%	8%
1964	Dry	8%	9%	8%	7%	0%	0%	0%	0%	0%	0%	0%	0%
1965	Wet	0%	0%	0%	0%	0%	0%	0%	0%	5%	9%	8%	9%
1966	Below Normal	9%	9%	11%	6%	-1%	0%	0%	0%	6%	6%	5%	5%
1967	Wet	6%	7%	8%	16%	0%	0%	0%	0%	0%	8%	7%	7%
1968	Below Normal	7%	2%	9%	34%	0%	1%	1%	3%	9%	10%	9%	10%
1969	Wet	8%	9%	9%	-12%	-7%	0%	-1%	-1%	-1%	8%	7%	7%
1970	Wet	7%	8%	9%	-2%	-2%	0%	0%	0%	8%	8%	8%	8%
1971	Wet	8%	9%	10%	6%	-24%	0%	0%	0%	2%	5%	4%	4%
1972	Below Normal	5%	6%	7%	16%	0%	0%	0%	0%	0%	0%	0%	0%
1973	Above Normal	0%	0%	0%	1%	0%	0%	0%	0%	7%	8%	7%	7%
1974	Wet	7%	8%	9%	23%	0%	0%	0%	-1%	7%	7%	6%	6%
1975	Wet	6%	7%	8%	3%	-3%	-4%	1%	1%	8%	9%	8%	9%
1976	Critical	9%	9%	10%	8%	1%	0%	-1%	-1%	0%	-1%	2%	-1%
1977	Critical	-1%	-1%	-1%	0%	0%	0%	91%	0%	0%	0%	0%	0%
1978	Above Normal	0%	168%	-3%	0%	0%	-2%	0%	6%	12%	13%	13%	14%
1979	Below Normal	9%	10%	9%	-12%	-15%	7%	1%	1%	8%	9%	8%	8%
1980	Above Normal	9%	9%	11%	-2%	4%	-2%	-5%	-4%	4%	4%	3%	3%
1981	Dry	3%	4%	6%	4%	-3%	16%	3%	3%	349%	6%	-1%	7%
1982	Wet	8%	9%	11%	16%	0%	0%	0%	0%	7%	8%	7%	7%
1983	Wet	7%	0%	0%	0%	0%	0%	0%	0%	0%	0%	9%	9%
1984	Wet	0%	0%	0%	0%	0%	0%	0%	0%	7%	8%	7%	7%
1985	Dry	7%	8%	8%	6%	0%	0%	0%	0%	5%	6%	5%	5%
1986	Wet	5%	6%	7%	5%	0%	-34%	0%	0%	7%	8%	7%	7%
1987	Dry	7%	8%	9%	6%	0%	0%	-4%	-4%	0%	0%	0%	1%
1988	Critical	3%	5%	7%	22%	-1%	0%	0%	0%	0%	0%	0%	0%
1989	Dry	0%	0%	0%	0%	0%	0%	0%	0%	-2%	0%	-6%	1%
1990	Critical	1%	1%	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1991	Critical	0%	0%	0%	0%	0%	0%	0%	-4%	-1%	1%	1%	1%
1992	Critical	0%	-8%	7%	0%	0%	0%	0%	0%	0%	0%	0%	-3%
1993	Above Normal	-1%	0%	0%	0%	0%	0%	0%	0%	15%	7%	6%	7%
1994	Critical	8%	8%	9%	9%	-1%	0%	0%	0%	1%	0%	6%	0%
1995	Wet	11%	-16%	0%	1%	0%	0%	0%	0%	7%	7%	7%	7%
1996	Wet	7%	8%	8%	-41%	-39%	-20%	-2%	-2%	5%	6%	5%	5%
1997	Wet	5%	6%	6%	-7%	-1%	0%	0%	0%	8%	9%	8%	8%
1998	Wet	8%	9%	10%	6%	35%	-5%	0%	-3%	-4%	-4%	2%	3%
1999	Wet	13%	4%	10%	19%	26%	-9%	0%	0%	8%	8%	7%	8%
2000	Above Normal	8%	8%	10%	7%	1%	-1%	0%	1%	7%	8%	7%	7%
2001	Dry	8%	8%	10%	9%	-9%	-2%	1%	1%	2%	2%	2%	2%
2002	Dry	2%	3%	3%	4%	0%	0%	0%	0%	0%	0%	0%	0%
2003	Above Normal	0%	18%	-6%	5%	3%	1%	0%	0%	283%	3%	3%	3%
Average		2%	9%	24%	7%	0%	0%	1%	-1%	25%	3%	2%	2%
Wet		3%	7%	8%	3%	-2%	-3%	-1%	-1%	3%	7%	6%	7%
Above Normal		4%	15%	4%	8%	1%	0%	1%	1%	54%	8%	8%	9%
Below Normal		8%	7%	8%	8%	-1%	1%	3%	-6%	51%	8%	8%	8%
Dry		-9%	10%	84%	8%	1%	0%	-2%	0%	37%	3%	3%	3%
Critical		7%	7%	9%	14%	3%	2%	11%	3%	-3%	-16%	-24%	-25%

Energy generated (GWh) at Mojave Dam: Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Total
1922	Above Normal	11.97	10.19	8.61	1.98	3.38	5.15	6.53	6.58	6.91	6.48	7.22	6.82	81.82
1923	Below Normal	6.62	5.99	5.38	8.55	7.49	8.97	5.99	7.35	7.35	7.05	8.08	7.78	86.60
1924	Critical	6.44	5.85	4.89	2.88	3.24	2.71	3.96	5.33	5.47	4.72	4.63	4.51	54.63
1925	Dry	2.75	2.12	1.78	0.96	1.52	3.14	6.16	8.14	8.14	7.79	8.76	8.47	59.73
1926	Dry	6.65	6.08	5.01	1.45	2.21	3.08	5.12	7.01	7.03	6.72	7.57	7.31	65.24
1927	Wet	5.74	5.22	4.31	1.65	3.34	6.13	7.05	7.22	7.58	7.09	7.80	7.35	70.48
1928	Above Normal	7.17	6.50	5.89	8.29	8.30	5.09	7.08	7.19	7.53	7.04	7.69	7.25	85.02
1929	Critical	6.99	6.36	5.77	7.80	7.56	3.94	3.26	4.84	4.96	4.30	4.22	3.92	63.92
1930	Dry	2.55	1.95	1.64	0.91	1.77	2.17	5.16	6.78	6.90	6.32	6.73	6.53	49.41
1931	Critical	4.62	4.00	3.34	1.15	1.82	2.00	4.58	6.19	6.32	5.47	5.37	5.15	50.01
1932	Dry	3.04	2.58	2.14	1.08	2.23	2.71	4.92	6.35	6.39	6.05	6.68	6.47	50.64
1933	Critical	4.90	4.41	3.66	1.22	1.93	2.59	5.16	7.01	7.18	6.33	6.42	6.26	57.07
1934	Critical	4.08	3.29	2.75	1.11	1.61	2.11	4.91	6.64	6.78	5.86	0.22	0.16	39.52
1935	Below Normal	2.57	8.26	6.36	1.05	2.03	2.63	6.33	8.17	1.70	8.59	9.55	9.25	66.49
1936	Below Normal	7.18	6.59	5.43	1.50	2.81	7.34	7.03	7.54	7.91	7.40	8.15	7.68	76.56
1937	Below Normal	7.49	6.80	6.15	8.83	8.91	9.24	6.87	7.13	7.49	7.04	7.82	7.35	91.12
1938	Wet	7.11	6.46	5.79	9.47	9.79	12.21	6.31	7.25	7.61	6.64	8.16	7.08	93.88
1939	Dry	6.83	6.17	5.42	8.42	6.40	11.68	7.25	7.75	0.19	8.43	4.17	10.15	82.86
1940	Above Normal	8.15	3.13	8.40	1.09	1.67	3.57	6.29	8.25	5.53	8.17	9.15	8.85	72.25
1941	Wet	6.94	6.34	5.22	2.89	3.75	10.29	5.69	6.03	6.33	6.00	6.85	6.46	72.79
1942	Wet	6.22	5.62	4.95	7.16	9.67	11.73	7.81	6.53	6.87	6.46	7.26	6.85	87.13
1943	Wet	6.66	6.02	5.37	8.44	9.77	8.03	7.39	7.40	7.74	7.29	8.17	7.71	89.99
1944	Dry	7.49	6.79	6.06	7.90	7.59	4.48	5.11	6.65	6.67	6.28	6.87	6.66	78.55
1945	Below Normal	4.95	4.40	3.66	1.50	2.28	12.16	7.01	7.22	7.59	7.10	7.81	7.36	73.04
1946	Below Normal	7.17	6.50	6.24	9.63	6.77	6.67	6.60	6.79	7.12	6.68	7.44	7.03	84.64
1947	Dry	6.84	6.20	5.58	8.37	8.83	5.13	6.87	7.90	8.07	7.63	8.44	8.10	87.96
1948	Below Normal	7.01	6.39	5.52	4.74	4.85	2.96	4.93	4.26	0.18	8.59	9.48	9.20	68.11
1949	Dry	7.14	6.54	5.39	1.59	2.35	2.88	6.88	7.76	7.98	7.53	8.30	7.95	72.29
1950	Below Normal	6.98	6.37	5.53	1.97	2.34	2.53	5.74	7.32	0.17	8.38	9.24	8.96	65.53
1951	Above Normal	6.95	6.36	5.25	11.56	9.28	11.59	6.49	7.02	7.37	6.89	7.68	7.26	93.70
1952	Wet	7.07	6.41	5.76	9.26	9.18	6.46	5.41	5.78	6.04	5.78	6.70	6.31	80.16
1953	Wet	6.06	5.45	7.91	9.13	9.50	11.70	8.37	6.74	6.85	6.50	7.34	7.01	92.56
1954	Above Normal	6.34	5.75	5.00	6.13	6.52	5.87	6.33	8.10	7.57	6.95	8.89	8.60	82.05
1955	Dry	6.75	6.16	5.07	1.80	2.78	3.29	5.28	6.78	6.77	6.50	7.29	7.05	65.52
1956	Wet	5.50	5.00	4.13	9.70	9.45	11.87	7.40	7.67	8.05	7.54	8.42	7.96	92.69
1957	Above Normal	7.76	7.04	6.31	10.17	9.75	5.96	5.24	3.24	0.20	8.02	8.79	8.54	81.02
1958	Wet	6.58	6.01	4.96	1.91	4.47	10.64	7.36	7.64	8.01	7.54	8.50	8.01	81.63
1959	Below Normal	7.79	7.05	6.26	8.51	8.57	9.87	6.04	7.69	0.19	8.29	9.23	8.93	88.42
1960	Dry	6.97	6.36	5.24	1.40	1.85	2.58	6.78	8.54	3.18	8.84	4.81	10.39	66.94
1961	Dry	8.21	7.51	6.23	2.08	2.64	2.53	5.70	7.26	7.30	6.98	5.30	2.22	63.96
1962	Below Normal	0.02	5.50	10.85	0.76	1.30	3.27	5.78	7.43	0.18	8.51	9.40	9.12	62.12
1963	Wet	7.08	6.47	5.34	3.85	4.56	5.75	6.49	6.74	7.06	6.62	7.38	6.97	74.31
1964	Dry	6.79	6.14	6.98	7.89	5.01	5.40	7.01	7.03	7.39	6.92	7.65	7.21	81.42
1965	Wet	7.04	6.37	5.75	7.77	8.18	6.37	6.39	6.58	6.42	6.48	7.22	6.82	81.39
1966	Below Normal	6.52	5.90	5.27	8.38	8.75	6.52	6.11	7.61	6.61	7.37	8.44	8.13	85.61
1967	Wet	6.58	5.99	4.95	2.41	4.98	6.01	6.97	7.14	7.49	7.04	7.88	7.44	74.88
1968	Below Normal	7.22	6.54	5.85	8.31	10.18	10.56	6.98	7.02	7.16	6.78	7.72	7.40	91.72
1969	Wet	6.40	5.81	4.95	5.71	11.01	12.21	6.38	6.66	6.99	6.61	7.57	7.15	87.45
1970	Wet	6.99	6.13	5.48	9.10	10.33	12.09	6.55	7.02	7.37	6.88	7.67	7.24	92.85
1971	Wet	7.06	6.39	5.75	8.50	9.93	7.77	5.86	7.58	7.41	7.26	8.32	8.02	89.85
1972	Below Normal	6.35	5.79	4.75	2.16	3.99	5.27	6.29	7.71	7.77	7.40	8.38	8.06	73.92
1973	Above Normal	6.61	6.03	5.04	3.09	5.70	6.59	6.86	7.26	7.64	7.11	7.87	7.42	77.22
1974	Wet	7.24	6.56	5.92	8.52	7.37	9.91	7.09	7.06	7.43	6.95	7.82	7.39	89.26
1975	Wet	7.19	6.49	5.79	9.74	9.75	8.71	7.04	7.09	7.46	6.95	7.65	7.22	91.08
1976	Critical	7.01	6.36	5.77	8.23	8.65	5.09	5.95	7.66	0.23	8.33	4.46	9.79	77.53
1977	Critical	7.58	6.92	5.71	1.38	1.84	1.82	0.71	0.14	0.16	0.28	0.24	0.17	26.95
1978	Above Normal	0.03	0.00	0.74	0.81	2.40	4.90	6.38	6.50	6.83	6.39	7.05	6.63	55.46
1979	Below Normal	6.45	5.83	5.27	8.29	8.49	6.63	6.57	6.85	7.21	6.74	7.46	7.04	82.83
1980	Above Normal	6.83	6.18	5.57	8.50	8.99	12.21	6.28	6.54	6.87	6.52	7.43	7.00	88.92
1981	Dry	6.76	6.10	5.37	9.69	9.92	6.58	5.79	7.56	0.23	8.65	7.99	9.52	84.16
1982	Wet	7.35	6.71	5.53	3.57	4.36	12.11	7.70	7.33	7.69	7.23	8.21	7.75	85.54
1983	Wet	7.62	6.90	11.26	9.83	9.30	12.21	5.11	5.40	5.97	5.43	6.06	5.99	91.08
1984	Wet	6.49	5.90	11.26	9.03	9.54	12.22	6.55	7.12	7.45	6.99	7.78	7.36	97.69
1985	Dry	7.16	6.50	6.57	9.53	8.99	7.54	6.53	6.71	7.07	6.60	7.28	6.86	87.34
1986	Wet	6.68	6.06	5.48	8.16	7.93	11.83	7.01	7.28	7.66	7.20	8.10	7.61	91.00
1987	Dry	7.38	6.70	5.96	9.70	9.69	5.40	5.09	6.89	7.07	6.08	6.00	5.85	81.81
1988	Critical	3.64	2.83	2.35	1.06	1.87	1.76	3.38	4.51	4.63	4.02	3.93	3.82	37.80
1989	Dry	2.32	1.76	1.49	0.90	1.59	1.74	6.60	8.57	4.20	8.65	8.10	9.64	55.56
1990	Critical	7.54	6.89	5.67	1.46	2.04	2.22	4.41	5.94	6.10	5.26	5.17	5.03	57.73
1991	Critical	3.10	2.39	2.00	0.99	1.50	1.72	3.45	4.22	1.28	4.82	4.66	4.56	34.69
1992	Critical	2.72	1.95	1.78	0.90	1.43	1.61	3.39	4.52	4.63	0.22	0.22	1.65	25.02
1993	Above Normal	5.69	0.00	7.70	0.89	3.70	5.00	6.39	7.17	2.42	7.49	8.36	7.98	62.79
1994	Critical	7.08	6.45	5.58	5.60	5.90	4.22	5.41	6.90	4.63	6.87	0.22	6.48	65.34
1995	Wet	0.02	1.50	11.07	0.75	3.31	4.53	7.47	7.53	7.90	7.42	8.28	7.80	67.58
1996	Wet	7.59	6.88	6.16	9.09	9.36	7.75	7.13	7.16	7.52	7.03	7.80	7.35	90.82
1997	Wet	7.16	6.50	5.86	9.56	8.10	11.83	6.42	6.68	6.99	6.58	7.44	7.03	90.15
1998	Wet	6.80	6.16	5.48	9.57	7.26	9.52	6.37	6.71	7.04	6.69	7.63	7.18	86.41
1999	Wet	6.91	7.12	6.94	9.22	6.75	10.18	6.59	7.03	7.36	6.93	7.72	7.29	90.04
2000	Above Normal	7.09	6.43	5.79	8.98	8.65	6.45	6.49	8.01	8.06	7.73	8.65	8.34	90.67
2001	Dry	6.79	6.20	5.20	2.76	3.05	2.73	5.14	7.01	7.17	6.21	6.12	5.97	64.35
2002	Dry	3.68	2.88	2.39	1.41	2.68	3.47	7.16	7.17	7.51	7.05	7.70	7.25	60.35
2003	Above Normal	7.05	2.38	7.92	1.68	2.73	3.42	5.40	6.92	0.13	7.96	8.74	8.48	62.81
Average		6.19	5.57	5.56	5.28	5.75	6.45	6.06	6.82	5.92	6.77	7.09	7.07	74.53
Wet		6.54	6.02	6.21	7.08	7.73	9.62	6.77	6.94	7.24	6.81	7.68	7.24	85.87
Above Normal		6.80	5.00	6.59	5.26	5.92	6.32	6.31	6.90	5.59	7.23	8.13	7.76	77.81
Below Normal		6.02	6.28	5.89	5.30	5.63	6.76	6.31	7.15	4.90	7.57	8.44	8.09	78.34
Dry		5.89	5.26	4.64	4.32	4.51	4.25	6.03	7.33	6.07	7.18	6.99	7.42	69.89
Critical		5.48	4.81	4.11	2.82									

Energy generated (GWh) at Mojave Dam: Alternative1_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Total
1922	Above Normal	11.97	10.19	8.61	2.64	3.43	5.19	6.64	6.75	7.64	7.22	8.10	7.68	86.06
1923	Below Normal	7.45	6.79	6.09	8.63	9.21	11.74	8.14	0.17	0.69	9.28	10.34	9.95	88.48
1924	Critical	8.63	7.92	6.83	5.03	4.84	3.32	4.57	6.19	2.74	0.23	0.22	0.16	50.68
1925	Dry	2.37	6.85	11.02	1.25	2.00	2.62	5.38	6.88	7.06	6.77	7.54	7.29	67.03
1926	Dry	5.72	5.24	4.36	1.71	2.26	3.25	5.05	7.78	5.68	7.74	8.66	8.33	65.78
1927	Wet	0.87	7.99	6.47	1.78	3.14	6.06	6.88	7.03	4.98	7.68	8.37	7.92	69.17
1928	Above Normal	7.74	7.07	6.47	8.75	8.23	4.97	6.96	7.65	0.46	8.81	9.60	9.15	85.86
1929	Critical	8.29	7.60	6.73	6.42	6.22	3.70	4.01	5.45	5.58	0.23	0.22	0.16	54.61
1930	Dry	0.03	0.00	9.75	1.09	1.78	2.23	5.17	6.81	0.19	7.31	7.64	7.43	49.43
1931	Critical	5.13	4.38	3.66	1.27	1.87	2.07	4.56	6.17	6.30	5.45	0.23	0.15	41.24
1932	Dry	0.02	2.70	11.08	1.12	2.24	2.81	4.88	6.26	6.82	6.54	7.21	6.99	58.67
1933	Critical	5.50	5.03	4.26	1.86	1.96	2.46	4.96	7.05	7.32	6.36	6.29	6.13	59.18
1934	Critical	3.78	3.07	2.56	1.23	1.70	2.31	5.19	7.03	7.19	6.21	0.22	0.16	40.65
1935	Below Normal	2.91	8.69	6.70	1.13	2.08	2.74	6.49	8.40	0.72	10.12	11.16	10.85	71.99
1936	Below Normal	8.53	7.86	6.57	1.98	2.70	5.76	7.28	7.52	8.43	7.92	8.68	8.20	81.43
1937	Below Normal	8.01	7.32	6.67	8.77	9.00	10.30	6.78	7.04	7.93	7.49	8.27	7.80	95.38
1938	Wet	7.57	6.92	5.72	7.81	7.72	12.62	6.20	6.48	6.84	6.99	7.93	7.52	90.32
1939	Dry	7.27	6.62	5.87	8.77	6.39	11.43	6.61	7.85	0.71	8.96	4.51	10.66	85.65
1940	Above Normal	8.69	1.32	9.37	1.32	1.42	3.51	6.28	8.25	6.03	8.69	9.67	9.38	73.93
1941	Wet	7.46	6.86	5.46	2.89	3.75	9.59	5.69	6.03	6.87	6.54	7.39	6.99	75.52
1942	Wet	6.76	6.16	5.21	8.37	9.71	11.65	7.82	6.51	7.39	6.98	7.77	7.36	91.69
1943	Wet	7.17	6.53	5.90	8.52	9.93	8.27	7.56	7.40	8.28	7.83	8.69	8.23	94.31
1944	Dry	8.01	7.31	6.60	7.53	6.78	4.21	5.11	6.66	7.04	6.64	7.21	7.00	80.10
1945	Below Normal	5.28	4.72	3.98	1.84	2.28	10.55	7.02	7.23	8.14	7.65	8.36	7.91	74.96
1946	Below Normal	7.71	7.05	6.88	10.17	6.77	6.70	6.63	6.83	7.69	7.25	8.02	7.60	89.30
1947	Dry	7.41	6.77	6.14	8.97	8.84	5.13	6.86	7.93	8.31	7.88	8.69	8.35	91.28
1948	Below Normal	7.22	6.61	5.72	4.82	4.73	2.91	4.94	4.54	0.18	8.59	9.48	9.21	68.95
1949	Dry	7.15	6.54	5.39	1.58	2.35	2.88	6.88	7.77	8.00	7.55	8.32	7.97	72.38
1950	Below Normal	6.99	6.38	5.54	1.90	2.26	2.51	5.74	7.32	0.40	8.61	9.47	9.19	66.31
1951	Above Normal	7.18	6.59	5.25	11.56	11.02	11.59	6.49	7.02	7.91	7.43	8.22	7.80	98.06
1952	Wet	7.61	6.95	6.30	9.66	9.18	6.46	5.41	5.55	5.80	6.07	6.89	6.53	82.41
1953	Wet	6.31	5.72	9.20	10.84	8.79	10.23	6.77	6.59	7.28	6.93	7.73	7.39	93.78
1954	Above Normal	6.83	6.23	5.52	7.04	6.88	6.10	6.38	8.16	8.26	6.99	9.06	8.78	86.23
1955	Dry	6.93	6.34	5.24	1.95	2.78	3.28	5.24	6.72	6.77	6.51	7.29	7.05	66.10
1956	Wet	5.51	5.01	4.15	7.38	9.46	11.87	7.41	7.68	8.60	8.08	8.96	8.51	92.62
1957	Above Normal	8.31	7.58	6.85	10.71	9.75	5.95	5.24	3.28	0.73	8.54	9.31	9.06	85.31
1958	Wet	7.10	6.53	5.48	2.43	4.47	10.62	7.36	7.64	8.55	8.08	9.04	8.55	85.85
1959	Below Normal	8.32	7.58	6.80	9.03	7.28	9.76	5.89	7.49	0.47	8.59	9.48	9.19	89.88
1960	Dry	7.21	6.60	5.48	1.63	1.82	2.60	6.79	8.52	3.77	8.69	5.30	10.09	68.50
1961	Dry	8.04	7.35	6.11	2.23	2.77	2.58	5.71	7.28	7.32	6.99	5.45	2.21	64.04
1962	Below Normal	0.02	5.49	10.88	0.76	1.30	3.27	5.78	7.43	0.70	9.04	9.92	9.64	64.23
1963	Wet	7.60	6.99	5.86	4.37	4.56	5.75	6.49	6.74	7.59	7.16	7.91	7.51	78.53
1964	Dry	7.33	6.68	7.51	8.43	5.02	5.41	7.01	7.03	7.39	6.92	7.65	7.21	83.59
1965	Wet	7.04	6.37	5.76	7.81	8.19	6.34	6.39	6.60	6.71	7.06	7.80	7.40	83.47
1966	Below Normal	7.08	6.46	5.83	8.87	8.70	6.50	6.11	7.61	6.99	7.77	8.85	8.53	89.30
1967	Wet	6.98	6.39	5.35	2.80	4.98	6.01	6.98	7.14	7.48	7.57	8.41	7.96	78.05
1968	Below Normal	7.75	6.66	6.38	11.06	10.18	10.64	7.01	7.20	7.79	7.43	8.43	8.12	98.65
1969	Wet	6.92	6.34	5.41	5.01	10.27	12.21	6.34	6.62	6.95	7.11	8.07	7.65	88.90
1970	Wet	7.49	6.64	5.98	8.88	10.15	12.12	6.55	7.05	7.94	7.45	8.24	7.81	96.30
1971	Wet	7.63	6.96	6.31	9.02	7.61	7.81	5.85	7.56	7.56	7.59	8.65	8.35	90.90
1972	Below Normal	6.68	6.12	5.08	2.49	3.99	5.27	6.29	7.71	7.77	7.40	8.38	8.07	75.25
1973	Above Normal	6.62	6.03	5.04	3.10	5.70	6.61	6.85	7.26	8.17	7.65	8.41	7.96	79.40
1974	Wet	7.78	7.10	6.46	10.44	7.37	9.88	7.06	7.00	7.91	7.43	8.27	7.85	94.55
1975	Wet	7.65	6.97	6.29	10.02	9.47	8.38	7.11	7.17	8.08	7.57	8.27	7.84	94.82
1976	Critical	7.63	6.98	6.37	8.87	8.73	5.11	5.92	7.62	0.23	8.28	4.57	9.70	80.01
1977	Critical	7.51	6.85	5.65	1.38	1.84	1.82	1.15	0.14	0.17	0.28	0.23	0.17	27.19
1978	Above Normal	0.03	0.00	7.36	0.81	2.41	4.80	6.37	6.85	7.66	7.23	7.96	7.58	59.06
1979	Below Normal	7.06	6.44	5.76	7.31	7.05	7.08	6.85	6.91	7.82	7.33	8.05	7.62	85.28
1980	Above Normal	7.42	6.77	6.16	8.32	9.35	11.94	5.97	6.28	7.13	6.79	7.63	7.22	90.98
1981	Dry	6.99	6.36	5.69	10.13	9.69	7.64	5.93	7.76	0.77	9.13	7.88	10.15	88.12
1982	Wet	7.97	7.33	6.13	4.12	4.38	12.10	7.71	7.33	8.23	7.77	8.75	8.29	90.11
1983	Wet	8.06	6.99	11.26	9.83	9.30	12.21	5.11	5.40	5.97	5.43	6.60	6.53	92.69
1984	Wet	6.49	5.90	11.26	9.03	9.57	12.22	6.55	7.12	7.99	7.53	8.32	7.90	99.88
1985	Dry	7.70	7.03	7.11	10.07	8.99	7.54	6.53	6.71	7.44	6.96	7.65	7.23	90.96
1986	Wet	7.05	6.43	5.85	8.53	7.93	7.67	7.21	7.29	8.21	7.75	8.64	8.15	90.71
1987	Dry	7.93	7.24	6.50	10.24	9.69	5.41	4.91	6.64	7.05	6.10	6.02	5.88	83.61
1988	Critical	3.75	2.97	2.51	1.29	1.85	1.75	3.38	4.51	4.63	4.02	3.93	3.82	38.41
1989	Dry	2.32	1.76	1.49	0.90	1.59	1.74	6.60	8.56	4.11	8.65	7.59	9.73	55.04
1990	Critical	7.60	6.95	5.72	1.46	2.04	2.22	4.41	5.94	6.10	5.26	5.17	5.04	57.91
1991	Critical	3.10	2.39	2.00	0.99	1.50	1.72	3.44	4.05	1.27	4.84	4.68	4.58	34.56
1992	Critical	2.73	1.78	1.90	0.90	1.43	1.60	3.39	4.52	4.63	0.22	0.22	1.60	24.92
1993	Above Normal	5.61	0.00	7.70	0.89	3.70	4.99	6.39	7.18	2.77	8.00	8.87	8.51	64.61
1994	Critical	7.61	6.95	6.09	6.09	5.86	4.21	5.41	6.90	4.66	6.87	0.27	6.49	67.41
1995	Wet	0.02	1.29	10.98	0.76	3.31	4.53	7.47	7.53	8.44	7.96	8.82	8.34	69.45
1996	Wet	8.12	7.42	6.64	5.36	5.67	6.16	6.98	7.01	7.89	7.42	8.18	7.74	84.59
1997	Wet	7.55	6.90	6.20	8.91	8.04	11.82	6.44	6.70	7.55	7.14	7.99	7.58	92.82
1998	Wet	7.36	6.71	6.03	10.13	9.77	9.05	6.37	6.47	6.79	6.44	7.81	7.39	90.32
1999	Wet	7.91	7.29	7.64	10.97	8.49	9.28	6.56	7.05	7.92	7.48	8.28	7.84	96.71
2000	Above Normal	7.65	6.99	6.34	9.56	8.70	6.41	6.48	8.07	8.63	8.31	9.24	8.93	95.31
2001	Dry	7.31	6.73	5.70	3.00	2.78	2.67	5.18	7.07	7.28	6.31	6.23	6.07	66.33
2002	Dry	3.77	2.96	2.46	1.47	2.68	3.46	5.14	7.15	7.49	7.04	7.69	7.23	60.54
2003	Above Normal	7.03	2.82	7.48	1.77	2.81	3.44	7.40	6.92	0.40	8.22	9.00	8.74	64.03
Average		6.42	5.96	6.25	5.48	5.69	6.36	6.07	6.74	5.85	7.05	7.30	7.30	76.47
Wet		6.77	6.49	6.67	7.14	7.51	9.27	6.70	6.87	7.45	7.27	8.15	7.74	88.02
Above Normal		7.09	5.13	6.85	5.54	6.12	6.29	6.29	6.97	5.48	7.82	8.76	8.40	80.74
Below Normal		6.50	6.73	6.35	5.63	5.54	6.84	6.50	6.67	4.69	8.18	9.06	8.71	81.39
Dry		5.75	5.62	6.31	4.56	4.47	4.27	5.94	7.30	5.73	7.37	7.14	7.60	72.06
Critical		5.94	5.24											

Difference in Energy generated (GWh) at Mojave Dam: Alternative1_2005 minus Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Average
1922	Above Normal	0.00	0.00	0.00	0.66	0.05	0.04	0.11	0.17	0.73	0.74	0.88	0.86	0.35
1923	Below Normal	0.83	0.80	0.71	0.08	1.72	2.77	2.15	(7.18)	(6.66)	2.23	2.26	2.17	0.16
1924	Critical	2.19	2.07	1.94	2.15	1.60	0.61	0.61	0.86	(2.73)	(4.49)	(4.41)	(4.35)	(0.33)
1925	Dry	(0.38)	4.73	9.24	0.29	0.48	(0.52)	(0.78)	(1.26)	(1.08)	(1.02)	(1.22)	(1.18)	0.61
1926	Dry	(0.93)	(0.84)	(0.65)	0.26	0.05	0.17	(0.07)	0.77	(1.35)	1.02	1.09	1.02	0.05
1927	Wet	(4.87)	2.77	2.16	0.13	(0.20)	(0.07)	(0.17)	(0.19)	(2.60)	0.59	0.57	0.57	(0.11)
1928	Above Normal	0.57	0.57	0.58	0.46	(0.07)	(0.12)	(0.12)	0.46	(7.07)	1.77	1.91	1.90	0.07
1929	Critical	1.30	1.24	0.96	(1.38)	(1.34)	(0.24)	0.75	0.61	0.62	(4.07)	(4.00)	(3.76)	(0.78)
1930	Dry	(2.52)	(1.95)	8.11	0.18	0.01	0.06	0.01	0.03	(6.71)	0.99	0.91	0.90	0.00
1931	Critical	0.51	0.38	0.32	0.12	0.05	0.07	(0.02)	(0.02)	(0.02)	(0.02)	(5.14)	(5.00)	(0.73)
1932	Dry	(3.02)	0.12	8.94	0.04	0.01	0.10	(0.04)	(0.09)	0.43	0.49	0.53	0.52	0.67
1933	Critical	0.60	0.62	0.60	0.64	0.03	(0.13)	(0.20)	0.04	0.14	0.03	(0.13)	(0.13)	0.18
1934	Critical	(0.30)	(0.22)	(0.19)	0.12	0.09	0.20	0.28	0.39	0.41	0.35	0.00	0.00	0.09
1935	Below Normal	0.34	0.43	0.34	0.08	0.05	0.11	0.16	0.23	(0.98)	1.53	1.61	1.60	0.46
1936	Below Normal	1.35	1.27	1.14	0.48	(0.11)	(1.58)	0.25	(0.02)	0.52	0.52	0.53	0.52	0.41
1937	Below Normal	0.52	0.52	0.52	(0.06)	0.09	1.06	(0.09)	(0.09)	0.44	0.45	0.45	0.45	0.36
1938	Wet	0.46	0.46	(0.07)	(1.66)	(2.07)	0.41	(0.11)	(0.77)	(0.77)	0.35	(0.23)	0.44	(0.30)
1939	Dry	0.44	0.45	0.45	0.35	(0.01)	(0.25)	(0.64)	0.10	0.52	0.53	0.34	0.51	0.23
1940	Above Normal	0.54	(1.81)	0.97	0.23	(0.25)	(0.06)	(0.01)	0.00	0.50	0.52	0.52	0.53	0.14
1941	Wet	0.52	0.52	0.24	0.00	0.00	(0.70)	0.00	0.00	0.54	0.54	0.54	0.53	0.23
1942	Wet	0.54	0.54	0.26	1.21	0.04	(0.08)	0.01	(0.02)	0.52	0.52	0.51	0.51	0.38
1943	Wet	0.51	0.51	0.53	0.08	0.16	0.24	0.17	0.00	0.54	0.54	0.52	0.52	0.36
1944	Dry	0.52	0.52	0.54	(0.37)	(0.81)	(0.27)	0.00	0.01	0.37	0.36	0.34	0.34	0.13
1945	Below Normal	0.33	0.32	0.32	0.34	0.00	(1.61)	0.01	0.01	0.55	0.55	0.55	0.55	0.16
1946	Below Normal	0.54	0.55	0.64	0.54	0.00	0.03	0.03	0.04	0.57	0.57	0.58	0.57	0.39
1947	Dry	0.57	0.57	0.56	0.60	0.01	0.00	(0.01)	0.03	0.24	0.25	0.25	0.25	0.28
1948	Below Normal	0.21	0.22	0.20	0.08	(0.12)	(0.05)	0.01	0.28	0.00	0.00	0.00	0.01	0.07
1949	Dry	0.01	0.00	0.00	(0.01)	0.00	0.00	0.00	0.01	0.02	0.02	0.02	0.02	0.01
1950	Below Normal	0.01	0.01	0.01	(0.07)	(0.08)	(0.02)	0.00	0.00	0.23	0.23	0.23	0.23	0.06
1951	Above Normal	0.23	0.23	0.00	0.00	1.74	0.00	0.00	0.00	0.54	0.54	0.54	0.54	0.36
1952	Wet	0.54	0.54	0.54	0.40	0.00	0.00	0.00	(0.23)	(0.24)	0.29	0.19	0.22	0.19
1953	Wet	0.25	0.27	1.29	1.71	(0.71)	(1.47)	(1.60)	(0.15)	0.43	0.43	0.39	0.38	0.10
1954	Above Normal	0.49	0.48	0.52	0.91	0.36	0.23	0.05	0.06	0.69	0.04	0.17	0.18	0.35
1955	Dry	0.18	0.18	0.17	0.15	0.00	(0.01)	(0.04)	(0.06)	0.00	0.01	0.00	0.00	0.05
1956	Wet	0.01	0.01	0.02	(2.32)	0.01	0.00	0.01	0.01	0.55	0.54	0.54	0.55	(0.01)
1957	Above Normal	0.55	0.54	0.54	0.54	0.00	(0.01)	0.00	0.04	0.53	0.52	0.52	0.52	0.36
1958	Wet	0.52	0.52	0.52	0.52	0.00	(0.02)	0.00	0.00	0.54	0.54	0.54	0.54	0.35
1959	Below Normal	0.53	0.53	0.54	0.52	(1.29)	(0.11)	(0.15)	(0.20)	0.28	0.30	0.25	0.26	0.12
1960	Dry	0.24	0.24	0.24	0.23	(0.03)	0.02	0.01	(0.02)	0.59	(0.15)	0.49	(0.30)	0.13
1961	Dry	(0.17)	(0.16)	(0.12)	0.15	0.13	0.05	0.01	0.02	0.02	0.01	0.15	(0.01)	0.01
1962	Below Normal	0.00	(0.01)	0.03	0.00	0.00	0.00	0.00	0.00	0.52	0.53	0.52	0.52	0.18
1963	Wet	0.52	0.52	0.52	0.52	0.00	0.00	0.00	0.00	0.53	0.54	0.53	0.54	0.35
1964	Dry	0.54	0.54	0.53	0.54	0.01	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.18
1965	Wet	0.00	0.00	0.01	0.04	0.01	(0.03)	0.00	0.02	0.29	0.58	0.58	0.58	0.17
1966	Below Normal	0.56	0.56	0.56	0.49	(0.05)	(0.02)	0.00	0.00	0.38	0.40	0.41	0.40	0.31
1967	Wet	0.40	0.40	0.40	0.39	0.00	0.00	0.01	0.00	(0.01)	0.53	0.53	0.52	0.26
1968	Below Normal	0.53	0.12	0.53	2.75	0.00	0.08	0.03	0.18	0.63	0.65	0.71	0.72	0.58
1969	Wet	0.52	0.53	0.46	(0.70)	(0.74)	0.00	(0.04)	(0.04)	(0.04)	0.50	0.50	0.50	0.12
1970	Wet	0.50	0.51	0.50	(0.22)	(0.18)	0.03	0.00	0.03	0.57	0.57	0.57	0.57	0.29
1971	Wet	0.57	0.57	0.56	0.52	(2.32)	0.04	(0.01)	(0.02)	0.15	0.33	0.33	0.33	0.09
1972	Below Normal	0.33	0.33	0.33	0.33	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.11
1973	Above Normal	0.01	0.00	0.00	0.01	0.00	0.02	(0.01)	0.00	0.53	0.54	0.54	0.54	0.18
1974	Wet	0.54	0.54	0.54	1.92	0.00	(0.03)	(0.03)	(0.06)	0.48	0.48	0.45	0.46	0.44
1975	Wet	0.46	0.48	0.50	0.28	(0.28)	(0.33)	0.07	0.08	0.62	0.62	0.62	0.62	0.31
1976	Critical	0.62	0.62	0.60	0.64	0.00	0.02	(0.03)	(0.04)	0.00	(0.05)	0.11	(0.09)	0.21
1977	Critical	(0.07)	(0.07)	(0.06)	0.00	0.00	0.00	0.44	0.00	0.01	0.00	(0.01)	0.00	0.02
1978	Above Normal	0.00	0.00	(0.18)	0.00	0.01	(0.10)	(0.01)	0.35	0.83	0.84	0.91	0.95	0.30
1979	Below Normal	0.61	0.61	0.49	(0.98)	(1.44)	0.45	0.28	0.06	0.61	0.59	0.59	0.58	0.20
1980	Above Normal	0.59	0.59	0.59	(0.18)	0.36	(0.27)	(0.31)	(0.26)	0.26	0.27	0.20	0.22	0.17
1981	Dry	0.23	0.26	0.32	0.44	(0.23)	1.06	0.14	0.20	0.54	0.48	(0.11)	0.63	0.33
1982	Wet	0.62	0.62	0.60	0.55	0.02	(0.01)	0.01	0.00	0.54	0.54	0.54	0.54	0.38
1983	Wet	0.44	0.09	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.54	0.54	0.13
1984	Wet	0.00	0.00	0.00	0.00	0.03	0.00	0.00	0.00	0.54	0.54	0.54	0.54	0.18
1985	Dry	0.54	0.53	0.54	0.54	0.00	0.00	0.00	0.00	0.37	0.36	0.37	0.37	0.30
1986	Wet	0.37	0.37	0.37	0.37	0.00	(4.16)	0.20	0.01	0.55	0.55	0.54	0.54	(0.02)
1987	Dry	0.55	0.54	0.54	0.54	0.00	0.01	(0.18)	(0.25)	(0.02)	0.02	0.02	0.03	0.15
1988	Critical	0.11	0.14	0.16	0.23	(0.02)	(0.01)	0.00	0.00	0.00	0.00	0.00	0.00	0.05
1989	Dry	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.01)	(0.09)	0.00	(0.51)	0.09	(0.04)
1990	Critical	0.06	0.06	0.05	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.02
1991	Critical	0.00	0.00	0.00	0.00	0.00	0.00	(0.01)	(0.17)	(0.01)	0.02	0.02	0.02	(0.01)
1992	Critical	0.01	(0.17)	0.12	0.00	0.00	(0.01)	0.00	0.00	0.00	0.00	0.00	(0.05)	(0.01)
1993	Above Normal	(0.08)	0.00	0.00	0.00	0.00	(0.01)	0.00	0.01	0.35	0.51	0.51	0.53	0.15
1994	Critical	0.53	0.50	0.51	0.49	(0.04)	(0.01)	0.00	0.00	0.03	0.00	0.05	0.01	0.17
1995	Wet	0.00	(0.21)	(0.09)	0.01	0.00	0.00	0.00	0.00	0.54	0.54	0.54	0.54	0.16
1996	Wet	0.53	0.54	0.48	(3.73)	(3.69)	(1.59)	(0.15)	(0.15)	0.37	0.39	0.38	0.39	(0.52)
1997	Wet	0.39	0.40	0.34	(0.65)	(0.06)	(0.01)	0.02	0.02	0.56	0.56	0.55	0.55	0.22
1998	Wet	0.56	0.55	0.55	0.56	2.51	(0.47)	0.00	(0.24)	(0.25)	(0.25)	0.18	0.21	0.33
1999	Wet	1.00	0.17	0.70	1.75	1.74	(0.90)	(0.03)	0.02	0.56	0.55	0.56	0.55	0.56
2000	Above Normal	0.56	0.56	0.55	0.58	0.05	(0.04)	(0.01)	0.06	0.57	0.58	0.59	0.59	0.39
2001	Dry	0.52	0.53	0.50	0.24	(0.27)	(0.06)	0.04	0.06	0.11	0.10	0.11	0.10	0.17
2002	Dry	0.09	0.08	0.07	0.06	0.00	(0.01)	(0.02)	(0.02)	(0.02)	(0.01)	(0.01)	(0.02)	0.02
2003	Above Normal	(0.02)	0.44	(0.44)	0.09	0.08	0.02	0.00	0.00	0.27	0.26	0.26	0.26	0.10
Average		0.23	0.39	0.69	0.20	(0.06)	(0.09)	0.01	(0.08)	(0.08)	0.28	0.21	0.23	0.16
Wet		0.23	0.47	0.46	0.06	(0.22)	(0.35)	(0.06)	(0.06)	0.21	0.46	0.46	0.49	0.18
Above Normal		0.29	0.13	0.26	0.28	0.19	(0.03)	(0.03)	0.07	(0.11)	0.59	0.63	0.64	0.24
Below Normal		0.48	0.45	0.45	0.33	(0.09)	0.08	0.19	(0.48)	(0.21)	0.61	0.62	0.61	0.26
Dry		(0.14)	0.35	1.67	0.24	(0.04)	0.02	(0.09)	(0.03)	(0.34)	0.19	0.15	0.18	0.18
Critical		0.46	0.43	0.42	0.25	0.04	0.04	0.15	0.14	(0.13)	(0.69)	(1.13)	(1.11)	(0.09)

Percent Difference in Energy generated (GWh) at Mojave Dam: Alternative1_2005 minus Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September
1922	Above Normal	0%	0%	0%	33%	1%	1%	2%	3%	11%	11%	12%	13%
1923	Below Normal	13%	13%	13%	1%	23%	31%	36%	-98%	-91%	32%	28%	28%
1924	Critical	34%	35%	40%	75%	49%	23%	15%	16%	-50%	-95%	-95%	-96%
1925	Dry	-14%	223%	519%	30%	32%	-17%	-13%	-15%	-13%	-13%	-14%	-14%
1926	Dry	-14%	-14%	-13%	18%	2%	6%	-1%	11%	-19%	15%	14%	14%
1927	Wet	-85%	53%	50%	8%	-6%	-1%	-2%	-3%	-34%	8%	7%	8%
1928	Above Normal	8%	9%	10%	6%	-1%	-2%	-2%	6%	-94%	25%	25%	26%
1929	Critical	19%	19%	17%	-18%	-18%	-6%	23%	13%	13%	-95%	-95%	-96%
1930	Dry	-99%	-100%	495%	20%	1%	3%	0%	0%	-97%	16%	14%	14%
1931	Critical	11%	10%	10%	10%	3%	3%	0%	0%	0%	0%	-96%	-97%
1932	Dry	-99%	5%	418%	4%	0%	4%	-1%	-1%	7%	8%	8%	8%
1933	Critical	12%	14%	16%	52%	2%	-5%	-4%	1%	2%	0%	-2%	-2%
1934	Critical	-7%	-7%	-7%	11%	6%	9%	6%	6%	6%	6%	0%	0%
1935	Below Normal	13%	5%	5%	8%	2%	4%	3%	3%	-58%	18%	17%	17%
1936	Below Normal	19%	19%	21%	32%	-4%	-22%	4%	0%	7%	7%	7%	7%
1937	Below Normal	7%	8%	8%	-1%	1%	11%	-1%	-1%	6%	6%	6%	6%
1938	Wet	6%	7%	-1%	-18%	-21%	3%	-2%	-11%	-10%	5%	-3%	6%
1939	Dry	6%	7%	8%	4%	0%	-2%	-9%	1%	274%	6%	8%	5%
1940	Above Normal	7%	-58%	12%	21%	-15%	-2%	0%	0%	9%	6%	6%	6%
1941	Wet	7%	8%	5%	0%	0%	-7%	0%	0%	9%	9%	8%	8%
1942	Wet	9%	10%	5%	17%	0%	-1%	0%	0%	8%	8%	7%	7%
1943	Wet	8%	8%	10%	1%	2%	3%	2%	0%	7%	7%	6%	7%
1944	Dry	7%	8%	9%	-5%	-11%	-6%	0%	0%	6%	6%	5%	5%
1945	Below Normal	7%	7%	9%	23%	0%	-13%	0%	0%	7%	8%	7%	7%
1946	Below Normal	8%	8%	10%	6%	0%	0%	0%	1%	8%	9%	8%	8%
1947	Dry	8%	9%	10%	7%	0%	0%	0%	0%	3%	3%	3%	3%
1948	Below Normal	3%	3%	4%	2%	-2%	-2%	0%	7%	0%	0%	0%	0%
1949	Dry	0%	0%	0%	-1%	0%	0%	0%	0%	0%	0%	0%	0%
1950	Below Normal	0%	0%	0%	-4%	-3%	-1%	0%	0%	135%	3%	2%	3%
1951	Above Normal	3%	4%	0%	0%	19%	0%	0%	0%	7%	8%	7%	7%
1952	Wet	8%	8%	9%	4%	0%	0%	0%	-4%	-4%	5%	3%	3%
1953	Wet	4%	5%	16%	19%	-7%	-13%	-19%	-2%	6%	7%	5%	5%
1954	Above Normal	8%	8%	10%	15%	6%	4%	1%	1%	9%	1%	2%	2%
1955	Dry	3%	3%	3%	8%	0%	0%	-1%	-1%	0%	0%	0%	0%
1956	Wet	0%	0%	0%	-24%	0%	0%	0%	0%	7%	7%	6%	7%
1957	Above Normal	7%	8%	9%	5%	0%	0%	0%	1%	265%	6%	6%	6%
1958	Wet	8%	9%	10%	27%	0%	0%	0%	0%	7%	7%	6%	7%
1959	Below Normal	7%	8%	9%	6%	-15%	-1%	-2%	-3%	147%	4%	3%	3%
1960	Dry	3%	4%	5%	16%	-2%	1%	0%	0%	19%	-2%	10%	-3%
1961	Dry	-2%	-2%	-2%	7%	5%	2%	0%	0%	0%	0%	3%	0%
1962	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	289%	6%	6%	6%
1963	Wet	7%	8%	10%	14%	0%	0%	0%	0%	8%	8%	7%	8%
1964	Dry	8%	9%	8%	7%	0%	0%	0%	0%	0%	0%	0%	0%
1965	Wet	0%	0%	0%	1%	0%	0%	0%	0%	5%	9%	8%	9%
1966	Below Normal	9%	9%	11%	6%	-1%	0%	0%	0%	6%	5%	5%	5%
1967	Wet	6%	7%	8%	16%	0%	0%	0%	0%	0%	8%	7%	7%
1968	Below Normal	7%	2%	9%	33%	0%	1%	0%	3%	9%	10%	9%	10%
1969	Wet	8%	9%	9%	-12%	-7%	0%	-1%	-1%	-1%	8%	7%	7%
1970	Wet	7%	8%	9%	-2%	-2%	0%	0%	0%	8%	8%	7%	8%
1971	Wet	8%	9%	10%	6%	-23%	1%	0%	0%	2%	5%	4%	4%
1972	Below Normal	5%	6%	7%	15%	0%	0%	0%	0%	0%	0%	0%	0%
1973	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	7%	8%	7%	7%
1974	Wet	7%	8%	9%	23%	0%	0%	0%	-1%	6%	7%	6%	6%
1975	Wet	6%	7%	9%	3%	-3%	-4%	1%	1%	8%	9%	8%	9%
1976	Critical	9%	10%	10%	8%	1%	0%	-1%	-1%	0%	-1%	2%	-1%
1977	Critical	-1%	-1%	-1%	0%	0%	0%	62%	0%	6%	0%	-4%	0%
1978	Above Normal	0%	0%	0%	0%	0%	-2%	0%	5%	12%	13%	13%	14%
1979	Below Normal	9%	10%	9%	-12%	-17%	7%	4%	1%	8%	9%	8%	8%
1980	Above Normal	9%	10%	11%	-2%	4%	-2%	-5%	-4%	4%	4%	3%	3%
1981	Dry	3%	4%	6%	5%	-2%	16%	2%	3%	235%	6%	-1%	7%
1982	Wet	9%	9%	11%	15%	0%	0%	0%	0%	7%	7%	7%	7%
1983	Wet	6%	1%	0%	0%	0%	0%	0%	0%	0%	0%	9%	9%
1984	Wet	0%	0%	0%	0%	0%	0%	0%	0%	7%	8%	7%	7%
1985	Dry	8%	8%	8%	6%	0%	0%	0%	0%	5%	5%	5%	5%
1986	Wet	6%	6%	7%	5%	0%	-35%	3%	0%	7%	8%	7%	7%
1987	Dry	7%	8%	9%	6%	0%	0%	-4%	-4%	0%	0%	0%	1%
1988	Critical	3%	5%	7%	22%	-1%	-1%	0%	0%	0%	0%	0%	0%
1989	Dry	0%	0%	0%	0%	0%	0%	0%	0%	-2%	0%	-6%	1%
1990	Critical	1%	1%	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1991	Critical	0%	0%	0%	0%	0%	0%	0%	-4%	-1%	0%	0%	0%
1992	Critical	0%	-9%	7%	0%	0%	-1%	0%	0%	0%	0%	0%	-3%
1993	Above Normal	-1%	0%	0%	0%	0%	0%	0%	0%	14%	7%	6%	7%
1994	Critical	7%	8%	9%	9%	-1%	0%	0%	0%	1%	0%	23%	0%
1995	Wet	0%	-14%	-1%	1%	0%	0%	0%	0%	7%	7%	7%	7%
1996	Wet	7%	8%	8%	-41%	-39%	-21%	-2%	-2%	5%	6%	5%	5%
1997	Wet	5%	6%	6%	-7%	-1%	0%	0%	0%	8%	9%	7%	8%
1998	Wet	8%	9%	10%	6%	35%	-5%	0%	-4%	-4%	2%	3%	3%
1999	Wet	14%	2%	10%	19%	26%	-9%	0%	0%	8%	8%	7%	8%
2000	Above Normal	8%	9%	9%	6%	1%	-1%	0%	1%	7%	8%	7%	7%
2001	Dry	8%	9%	10%	9%	-9%	-2%	1%	1%	2%	2%	2%	2%
2002	Dry	2%	3%	3%	4%	0%	0%	0%	0%	0%	0%	0%	0%
2003	Above Normal	0%	18%	-6%	5%	3%	1%	0%	0%	208%	3%	3%	3%
Average		2%	7%	24%	7%	0%	-1%	1%	-1%	17%	3%	2%	2%
Wet		3%	7%	8%	3%	-2%	-3%	-1%	-1%	3%	7%	6%	7%
Above Normal		4%	1%	4%	8%	1%	0%	0%	1%	38%	8%	8%	8%
Below Normal		8%	7%	8%	8%	-1%	1%	3%	-6%	34%	8%	7%	8%
Dry		-9%	10%	83%	8%	1%	0%	-1%	0%	23%	3%	3%	3%
Critical		7%	7%	9%	14%	3%	2%	8%	3%	-2%	-15%	-22%	-25%

Difference in Energy generated (GWh) at Oroville Dam: Alternative1_2005 minus Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Average
1922	Above Normal	0.00	0.00	0.00	0.18	(0.19)	0.00	0.00	0.00	0.00	0.97	1.03	0.21	0.18
1923	Below Normal	0.91	0.59	0.00	(0.03)	5.13	0.00	(0.08)	(0.11)	(0.10)	(1.31)	(1.09)	23.26	2.26
1924	Critical	35.84	(1.55)	59.05	(2.69)	(2.41)	(3.52)	(5.21)	(6.55)	(8.21)	(126.57)	(0.96)	0.23	(5.21)
1925	Dry	0.18	0.13	0.10	0.10	0.10	(0.16)	(0.11)	(0.19)	10.44	(1.09)	(4.68)	(0.25)	0.38
1926	Dry	(5.14)	(4.53)	(2.28)	(12.75)	0.25	0.49	0.37	0.26	2.42	(5.60)	37.52	(3.53)	0.62
1927	Wet	0.18	0.15	0.00	(0.02)	(0.43)	0.00	0.00	0.00	0.00	(0.07)	(0.27)	(0.02)	(0.04)
1928	Above Normal	(0.10)	(0.07)	(0.04)	(0.01)	0.01	0.74	(0.04)	(0.07)	0.40	(0.13)	0.40	0.28	0.11
1929	Critical	(0.86)	0.59	(0.05)	(0.58)	0.68	(2.07)	0.12	0.17	0.27	0.26	(0.73)	0.21	(0.17)
1930	Dry	0.17	0.11	0.12	0.06	0.05	0.00	0.02	0.02	0.10	0.17	2.41	(0.17)	0.25
1931	Critical	2.65	2.04	1.06	(0.04)	(0.06)	(0.05)	(0.46)	(0.30)	(0.92)	(6.87)	(0.13)	0.02	(0.26)
1932	Dry	0.01	0.01	0.01	0.02	0.01	0.00	0.01	0.02	0.02	(0.08)	60.25	(6.55)	4.48
1933	Critical	(40.77)	(4.84)	(8.70)	9.62	(0.16)	(0.99)	(0.76)	(0.89)	(1.22)	(12.90)	(0.07)	(0.08)	(5.15)
1934	Critical	(0.07)	(0.04)	0.01	0.03	0.03	(0.32)	(0.06)	(0.04)	0.07	0.07	0.16	0.11	0.00
1935	Below Normal	6.09	(0.04)	(0.06)	(0.13)	(0.08)	(0.05)	(0.09)	(0.11)	(0.07)	(0.55)	(0.59)	(0.54)	0.32
1936	Below Normal	8.34	7.29	(0.48)	(0.46)	(27.12)	0.00	0.00	(0.01)	0.00	0.31	(0.02)	16.58	0.37
1937	Below Normal	(0.72)	(0.49)	(1.54)	(0.32)	(0.27)	(0.27)	(0.33)	(0.38)	19.81	(0.97)	(7.79)	(1.09)	0.47
1938	Wet	(1.78)	(0.84)	(0.53)	(0.41)	(36.50)	0.00	0.00	0.00	0.00	8.26	(2.11)	29.51	(0.37)
1939	Dry	(1.02)	(0.61)	(10.10)	(0.31)	(0.27)	(0.28)	(0.80)	(3.19)	(1.23)	(2.49)	(2.83)	(5.73)	(2.41)
1940	Above Normal	(9.30)	(0.08)	(1.30)	(0.08)	(0.03)	(0.20)	0.00	0.00	(0.02)	0.00	0.03	0.03	(0.91)
1941	Wet	0.13	(0.01)	0.00	0.00	(0.21)	0.00	0.00	0.00	0.00	0.01	0.01	(0.01)	(0.01)
1942	Wet	0.00	0.00	(0.01)	0.00	0.00	0.00	0.00	0.00	0.00	(0.07)	(0.10)	15.13	1.25
1943	Wet	(0.60)	(0.32)	(0.18)	(16.20)	0.00	0.00	0.00	(0.04)	0.04	(0.51)	(0.07)	(0.05)	(1.49)
1944	Dry	(0.05)	0.04	0.33	0.09	0.08	0.10	0.00	0.00	(0.06)	(0.04)	0.28	2.36	0.26
1945	Below Normal	(0.09)	(0.07)	(0.10)	(0.06)	(0.04)	(0.07)	(0.07)	(0.07)	(0.08)	(0.60)	(0.31)	30.13	2.38
1946	Below Normal	(1.87)	(17.12)	(0.31)	(0.21)	4.28	(24.01)	0.01	(0.01)	6.14	(0.46)	(0.47)	(2.15)	(3.01)
1947	Dry	(0.14)	(0.08)	(0.05)	(0.07)	(0.04)	(0.05)	(0.06)	(0.08)	(0.09)	(0.28)	(1.16)	(2.24)	(0.36)
1948	Below Normal	0.00	0.00	0.00	0.00	(0.05)	0.00	0.00	0.00	0.01	0.01	1.79	0.10	0.16
1949	Dry	0.11	0.12	(0.01)	0.00	(0.01)	(0.01)	(0.02)	(0.02)	0.00	(0.02)	1.00	(0.15)	0.08
1950	Below Normal	(1.28)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(1.36)	0.11	0.05	(0.21)
1951	Above Normal	0.03	0.01	1.42	0.00	0.00	0.00	0.00	0.00	0.02	0.00	0.00	(0.01)	0.12
1952	Wet	0.00	0.00	0.00	0.00	(0.01)	0.00	0.00	0.00	0.00	0.00	(0.48)	12.57	1.01
1953	Wet	(1.08)	(0.68)	(10.88)	0.00	(0.01)	0.01	0.00	0.00	0.00	(0.05)	0.01	(0.06)	(1.06)
1954	Above Normal	0.04	0.03	(0.04)	0.01	0.00	0.06	0.00	0.02	0.03	0.02	0.02	0.02	0.02
1955	Dry	0.76	(0.01)	(0.01)	(0.02)	(0.01)	(0.03)	(0.04)	(0.04)	(0.07)	(0.14)	(0.06)	(5.02)	(0.39)
1956	Wet	0.09	0.11	0.12	0.32	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.91	0.13
1957	Above Normal	(0.03)	(0.02)	(0.05)	(0.01)	(0.02)	(0.98)	0.00	0.00	0.00	0.00	0.01	0.00	(0.09)
1958	Wet	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.06	0.00	0.07	0.01
1959	Below Normal	(0.01)	0.00	0.04	(0.01)	(0.18)	0.00	(0.02)	(0.02)	0.03	0.08	(0.04)	(0.77)	(0.07)
1960	Dry	(0.48)	(1.49)	(0.50)	0.06	0.05	0.04	0.12	0.11	0.17	0.37	1.64	0.31	0.03
1961	Dry	2.13	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.02)	0.00	0.18
1962	Below Normal	0.00	0.00	(0.02)	0.01	0.00	0.00	0.00	(0.01)	(0.01)	0.00	(0.01)	0.02	0.00
1963	Wet	0.00	0.00	0.00	(0.03)	0.00	0.00	0.00	0.00	0.01	2.26	0.01	0.00	0.19
1964	Dry	0.00	(0.53)	0.01	0.01	0.01	0.01	0.02	0.01	0.03	0.06	0.17	0.05	(0.01)
1965	Wet	0.29	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.15)	0.06	0.00	0.02
1966	Below Normal	0.00	(0.01)	0.00	0.00	0.00	0.00	0.01	0.05	0.10	(0.01)	(0.02)	(0.62)	(0.04)
1967	Wet	0.61	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.02)	1.30	0.16
1968	Below Normal	(0.06)	(0.03)	5.84	(7.27)	0.00	0.00	(0.01)	(0.03)	(1.23)	0.05	0.21	0.08	(0.20)
1969	Wet	(8.71)	0.17	0.18	11.84	0.00	0.00	0.00	0.00	0.00	6.65	(2.68)	(3.39)	0.34
1970	Wet	6.23	(0.10)	(7.29)	0.00	0.00	0.00	0.00	0.01	0.09	(0.06)	0.00	0.32	(0.07)
1971	Wet	(0.01)	0.00	(0.01)	(0.01)	0.00	(0.49)	0.00	0.00	0.00	0.00	0.03	(0.01)	(0.04)
1972	Below Normal	(0.05)	(0.01)	0.00	0.00	0.00	0.04	0.00	0.00	0.00	0.01	0.00	0.01	0.00
1973	Above Normal	0.00	0.00	0.00	0.00	(0.02)	0.00	0.00	0.00	0.00	(0.01)	0.00	(0.02)	0.00
1974	Wet	0.00	0.00	0.02	0.00	0.00	0.00	0.00	0.00	0.00	(0.13)	(0.12)	17.66	1.45
1975	Wet	(0.69)	(0.42)	(0.23)	(0.17)	(17.70)	0.00	0.01	(0.01)	0.00	0.03	0.04	0.02	(1.59)
1976	Critical	1.12	0.02	0.00	(0.02)	(0.02)	(0.02)	(0.03)	(0.03)	(0.04)	(1.11)	(0.13)	(0.05)	(0.03)
1977	Critical	0.02	(0.41)	0.00	0.01	0.00	0.01	0.03	0.02	0.03	0.01	0.02	0.02	(0.02)
1978	Above Normal	0.01	0.01	0.01	0.01	0.01	0.55	0.00	(0.07)	0.07	0.19	0.18	0.18	0.10
1979	Below Normal	(0.20)	(0.13)	0.89	(0.03)	(0.02)	(0.02)	(0.02)	(0.06)	(0.55)	(0.57)	(0.09)	30.57	2.48
1980	Above Normal	35.78	(1.44)	(1.35)	(77.02)	0.00	0.00	(0.21)	(0.23)	(0.33)	(44.76)	0.32	93.32	0.34
1981	Dry	(2.02)	(1.19)	(4.61)	(9.84)	(33.78)	0.00	0.02	0.05	0.15	0.14	0.17	(1.39)	(4.36)
1982	Wet	4.34	0.00	(4.55)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	(0.02)
1983	Wet	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1984	Wet	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.04	0.00
1985	Dry	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.01)	(0.01)	0.00	0.00
1986	Wet	(0.01)	(0.03)	0.03	0.00	0.00	0.00	0.00	0.00	0.00	0.01	40.30	(36.28)	0.33
1987	Dry	(0.28)	(0.15)	(0.03)	(0.11)	(0.10)	(0.09)	(0.15)	(0.32)	(0.47)	(4.81)	(0.03)	(0.05)	(0.55)
1988	Critical	(0.04)	(0.03)	(0.01)	0.00	0.01	0.01	0.01	(0.02)	0.00	0.26	(0.03)	0.00	0.01
1989	Dry	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(2.87)	0.21	(0.22)
1990	Critical	0.65	0.08	1.10	0.01	0.01	0.01	0.06	0.04	0.06	0.20	0.04	0.06	0.19
1991	Critical	0.03	0.01	0.02	0.05	0.01	0.03	0.03	0.03	0.07	1.25	(1.04)	0.05	0.05
1992	Critical	0.02	0.01	0.02	0.02	0.03	0.01	0.03	0.07	0.10	0.06	(0.02)	0.08	0.04
1993	Above Normal	0.03	0.02	0.01	0.02	0.01	1.57	0.00	0.00	0.00	(0.02)	(0.02)	0.01	0.14
1994	Critical	0.00	0.00	0.02	0.01	0.01	0.00	0.00	0.00	0.01	0.00	(0.01)	0.00	0.00
1995	Wet	0.00	0.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.10	0.01
1996	Wet	(0.11)	(0.10)	(0.10)	0.21	0.00	0.00	0.00	0.00	0.00	(0.03)	(0.04)	(0.02)	(0.02)
1997	Wet	(0.13)	(0.10)	0.38	0.00	0.00	0.00	0.00	0.00	(5.37)	2.03	0.17	0.96	(0.17)
1998	Wet	0.13	0.08	0.06	0.03	0.13	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.04
1999	Wet	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.01	(0.01)	0.01	0.03	(4.76)	(0.39)
2000	Above Normal	0.18	0.11	0.23	0.06	4.92	0.00	(0.01)	0.00	0.02	(0.03)	0.03	0.04	0.46
2001	Dry	(0.03)	(0.02)	(5.82)	0.14	0.11	0.12	0.21	0.37	0.50	6.01	0.01	0.01	0.13
2002	Dry	0.01	0.00	0.00	0.00	(0.01)	(0.01)	0.00	(0.01)	(0.01)	(0.01)	(2.06)	2.25	0.01
2003	Above Normal	(0.01)	(0.20)	(0.01)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	(0.02)
Average		0.36	(0.32)	0.12	(1.29)	(1.27)	(0.36)	(0.09)	(0.14)	0.26	(2.24)	1.41	2.49	(0.09)
Wet		(0.04)	(0.08)	(0.88)	(0.17)	(2.11)	(0.02)	0.00	(0.00)	(0.20)	0.70	1.34	1.31	(0.01)
Above Normal		2.22	(0.14)	(0.09)	(6.40)	0.39	0.14	(0.02)	(0.03)	0.02	(3.65)	0.17	7.84	0.04
Below Normal		0.79	(0.72)	0.30	(0.61)	(1.31)	(1.74)	(0.04)	(0.05)	1.72	(0.38)	(0.59)	6.83	0.35
Dry		(0.32)	(0.46)	(1.27)	(1.26)	(1.86)	0.01	(0.02)	(0.17)	0.66	(0.43)	4.99	(1.11)	(0.10)
Critical		(0.12)	(0.34)	4.38	0.54	(0.16)	(0.58)	(0.52)	(0.63)	(0.81)	(12.11)	(0.24)	0.0	

Percent Difference in Energy generated (GWh) at Oroville Dam: Alternative1_2005 minus Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September
1922	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1923	Below Normal	1%	1%	0%	0%	5%	0%	0%	0%	0%	0%	0%	20%
1924	Critical	41%	-2%	99%	-6%	-5%	-5%	-5%	-5%	-6%	-51%	-1%	1%
1925	Dry	1%	1%	0%	0%	1%	-1%	0%	0%	5%	0%	-3%	0%
1926	Dry	-8%	-14%	-5%	-41%	1%	1%	1%	0%	1%	-2%	20%	-4%
1927	Wet	1%	0%	0%	0%	-1%	0%	0%	0%	0%	0%	0%	0%
1928	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1929	Critical	-1%	2%	0%	-1%	2%	-5%	0%	0%	0%	0%	-1%	1%
1930	Dry	1%	1%	0%	0%	0%	0%	0%	0%	0%	0%	1%	0%
1931	Critical	5%	7%	5%	0%	0%	0%	0%	0%	-1%	-4%	0%	0%
1932	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	30%	-10%
1933	Critical	-62%	-14%	-29%	34%	-1%	-1%	-1%	-1%	-1%	-10%	0%	0%
1934	Critical	0%	0%	0%	0%	0%	-2%	0%	0%	0%	0%	0%	0%
1935	Below Normal	19%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1936	Below Normal	11%	12%	-1%	-1%	-15%	0%	0%	0%	0%	0%	0%	16%
1937	Below Normal	0%	-1%	-1%	-1%	-1%	-1%	0%	0%	6%	0%	-3%	-1%
1938	Wet	-2%	-2%	-1%	-1%	-9%	0%	0%	0%	0%	4%	-1%	9%
1939	Dry	-1%	-1%	-10%	-1%	-1%	-1%	0%	-2%	-1%	-1%	-1%	-3%
1940	Above Normal	-28%	0%	-4%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1941	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1942	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	4%
1943	Wet	0%	0%	0%	-3%	0%	0%	0%	0%	0%	0%	0%	0%
1944	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	4%
1945	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	29%
1946	Below Normal	-2%	-28%	-1%	0%	9%	-20%	0%	0%	3%	0%	0%	-1%
1947	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	-1%	-1%
1948	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	1%	0%
1949	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1950	Below Normal	-4%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1951	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1952	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	4%
1953	Wet	-1%	-1%	-5%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1954	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1955	Dry	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	-4%
1956	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1957	Above Normal	0%	0%	0%	0%	0%	-1%	0%	0%	0%	0%	0%	0%
1958	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1959	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	-1%
1960	Dry	-1%	-2%	-1%	0%	0%	0%	0%	0%	0%	0%	1%	0%
1961	Dry	7%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1962	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1963	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	1%	0%	0%
1964	Dry	0%	-1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1965	Wet	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1966	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1967	Wet	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1968	Below Normal	0%	0%	4%	-9%	0%	0%	0%	0%	-1%	0%	0%	0%
1969	Wet	-9%	0%	0%	4%	0%	0%	0%	0%	0%	4%	-2%	-1%
1970	Wet	5%	0%	-2%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1971	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1972	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1973	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1974	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	5%
1975	Wet	-1%	-1%	0%	0%	-7%	0%	0%	0%	0%	0%	0%	0%
1976	Critical	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1977	Critical	0%	-2%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1978	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1979	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	33%
1980	Above Normal	43%	-3%	-3%	-24%	0%	0%	0%	0%	0%	-16%	0%	104%
1981	Dry	-1%	-1%	-4%	-15%	-31%	0%	0%	0%	0%	0%	0%	-1%
1982	Wet	9%	0%	-1%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1983	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1984	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1985	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1986	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	23%	-11%
1987	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	-3%	0%	0%
1988	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1989	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	-1%	0%
1990	Critical	1%	0%	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1991	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	-2%	0%
1992	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1993	Above Normal	0%	0%	0%	0%	0%	1%	0%	0%	0%	0%	0%	0%
1994	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1995	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1996	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1997	Wet	0%	0%	0%	0%	0%	0%	0%	0%	-3%	1%	0%	0%
1998	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1999	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	-2%
2000	Above Normal	0%	0%	0%	0%	2%	0%	0%	0%	0%	0%	0%	0%
2001	Dry	0%	0%	-3%	0%	0%	0%	0%	0%	0%	3%	0%	0%
2002	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	-2%	1%
2003	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	Average	0%	-1%	0%	-1%	-1%	0%	0%	0%	0%	-1%	1%	2%
	Wet	0%	0%	0%	0%	-1%	0%	0%	0%	0%	0%	1%	0%
	Above Normal	1%	0%	-1%	-2%	0%	0%	0%	0%	0%	-1%	0%	9%
	Below Normal	2%	-1%	0%	-1%	0%	-1%	0%	0%	1%	0%	0%	7%
	Dry	0%	-1%	-1%	-3%	-2%	0%	0%	0%	0%	0%	3%	-1%
	Critical	-1%	-1%	6%	2%	0%	-1%	-1%	-1%	-1%	-5%	0%	0%

Energy generated (GWh) at SWP San Luis: Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Total
1922	Above Normal	0.00	6.00	0.00	0.00	0.00	0.00	44.96	46.73	0.00	0.00	0.00	0.00	97.69
1923	Below Normal	0.00	5.17	0.00	12.80	9.53	21.95	32.91	40.40	30.75	0.00	0.00	0.00	153.51
1924	Critical	0.00	0.00	0.00	0.00	0.00	18.31	22.34	20.98	29.41	0.00	24.72	10.35	126.11
1925	Dry	0.00	0.00	0.00	0.00	0.00	0.00	30.41	47.26	38.66	0.00	20.03	0.00	136.36
1926	Dry	0.00	0.00	0.00	0.00	0.00	20.75	16.57	34.30	21.53	0.00	10.38	0.00	103.53
1927	Wet	6.71	0.00	0.00	0.00	0.00	0.00	53.25	55.88	33.06	0.00	0.00	0.00	148.90
1928	Above Normal	1.14	9.00	0.00	4.46	25.83	0.00	50.43	50.93	26.69	0.00	0.00	0.00	168.48
1929	Critical	0.00	16.01	0.00	1.29	2.64	0.00	1.68	12.39	26.44	28.40	20.35	6.87	116.07
1930	Dry	0.00	0.00	0.00	0.00	0.00	0.00	17.54	27.07	30.74	0.00	6.76	0.00	82.11
1931	Critical	0.00	0.00	0.00	0.00	0.00	4.81	27.25	32.10	37.24	0.00	26.03	10.39	137.82
1932	Dry	0.00	0.00	0.00	0.00	0.00	0.00	38.41	39.94	55.12	0.00	0.00	5.56	139.03
1933	Critical	0.00	0.00	0.00	0.00	0.00	0.00	26.36	37.12	56.10	31.36	31.18	14.00	196.12
1934	Critical	2.69	0.00	0.00	0.00	0.00	0.00	30.32	29.00	43.95	28.68	10.52	0.00	145.16
1935	Below Normal	0.00	0.00	0.00	0.00	0.00	0.00	37.14	45.73	21.57	0.00	0.00	0.00	104.44
1936	Below Normal	0.00	0.00	0.00	0.00	0.00	0.00	47.70	64.56	46.42	0.00	0.00	0.00	158.68
1937	Below Normal	0.00	6.31	0.00	0.00	0.00	0.00	48.36	51.10	22.93	0.00	13.91	17.51	160.12
1938	Wet	0.00	0.00	0.00	0.00	0.00	0.00	15.79	0.00	0.00	0.00	0.00	0.00	15.79
1939	Dry	4.30	41.98	0.00	17.25	30.91	49.41	46.57	37.53	35.52	0.00	0.48	0.00	263.95
1940	Above Normal	7.62	6.75	0.00	0.00	0.00	0.00	29.08	37.21	25.40	0.00	0.00	0.00	106.06
1941	Wet	0.00	8.90	0.00	0.00	0.00	0.00	34.95	38.07	17.86	0.00	0.00	0.00	99.78
1942	Wet	9.46	30.52	0.00	0.00	0.00	1.75	53.63	46.98	20.94	0.00	0.00	0.00	163.28
1943	Wet	3.18	22.17	0.00	0.00	0.00	0.00	53.43	54.95	37.11	0.00	0.00	0.00	170.84
1944	Dry	9.93	28.35	0.00	0.00	0.00	0.00	21.43	23.72	23.59	0.00	0.00	1.99	109.01
1945	Below Normal	0.00	0.00	0.00	0.00	0.00	0.00	49.61	59.00	45.56	0.00	0.00	0.00	154.17
1946	Below Normal	0.00	0.00	0.00	0.12	7.67	2.63	51.63	54.80	41.22	0.00	0.00	0.00	158.07
1947	Dry	0.00	0.00	0.00	14.70	7.65	19.49	43.07	48.80	44.47	0.00	4.90	0.00	183.08
1948	Below Normal	0.00	0.00	0.58	2.66	17.10	0.00	11.35	23.25	0.00	0.00	0.00	0.00	54.94
1949	Dry	0.00	0.00	0.00	0.00	0.00	0.00	49.18	50.97	32.77	0.00	6.72	0.00	139.64
1950	Below Normal	10.42	6.62	1.89	0.00	0.00	0.00	27.37	34.55	1.59	0.00	0.00	0.00	82.44
1951	Above Normal	0.00	0.00	0.00	0.12	0.00	0.00	46.30	58.24	38.06	0.00	0.00	0.00	142.72
1952	Wet	1.82	0.00	0.00	0.00	12.16	0.00	23.04	23.23	0.00	0.00	0.00	0.00	60.25
1953	Wet	2.71	32.84	0.00	22.32	15.24	20.24	52.16	41.71	36.09	0.00	0.00	0.00	223.31
1954	Above Normal	5.19	16.30	0.00	11.18	9.11	0.00	36.37	35.26	28.09	0.00	0.00	0.00	141.50
1955	Dry	0.00	0.00	0.00	0.00	0.00	0.00	32.20	42.11	47.71	0.00	20.46	0.00	142.48
1956	Wet	1.40	0.00	0.00	0.00	0.00	0.00	54.15	61.03	27.00	0.00	0.00	0.00	143.58
1957	Above Normal	5.14	22.64	0.00	12.90	29.71	17.13	16.50	21.70	0.00	0.00	0.00	0.00	125.72
1958	Wet	0.00	0.00	0.00	0.00	0.00	0.00	33.04	52.56	16.84	0.00	0.00	0.00	102.44
1959	Below Normal	1.48	34.29	0.00	30.51	19.31	8.08	26.71	27.71	20.04	0.00	0.00	0.00	168.13
1960	Dry	0.00	0.00	0.00	0.00	0.00	0.00	43.54	32.00	31.88	0.00	0.03	0.00	107.45
1961	Dry	10.40	0.00	0.00	0.00	0.00	0.00	33.34	36.73	49.15	0.00	6.47	0.00	136.09
1962	Below Normal	0.00	0.00	0.00	0.00	0.00	0.00	26.71	27.86	7.96	0.00	0.00	0.00	62.53
1963	Wet	0.00	0.00	0.00	0.00	0.00	0.00	48.73	50.94	34.57	0.00	0.00	0.00	134.24
1964	Dry	0.00	0.00	0.00	0.12	0.00	4.18	53.32	52.70	46.48	0.00	18.14	0.00	174.94
1965	Wet	3.22	0.00	0.00	0.00	0.00	0.00	38.23	39.73	23.85	0.00	0.00	0.00	105.03
1966	Below Normal	9.61	0.00	0.00	1.27	8.85	5.44	37.92	40.37	36.86	0.00	0.00	0.00	140.32
1967	Wet	0.12	0.00	0.00	0.00	0.00	0.00	35.20	35.16	0.00	0.00	0.00	0.00	70.48
1968	Below Normal	0.00	38.26	0.00	17.12	37.74	17.97	39.84	36.93	37.68	0.00	0.00	0.00	225.54
1969	Wet	0.00	0.00	0.00	0.00	0.00	0.00	6.48	0.00	0.00	0.00	0.00	0.00	6.48
1970	Wet	0.00	39.91	0.00	0.00	0.00	0.00	51.78	57.73	45.80	0.00	0.00	6.18	201.40
1971	Wet	4.01	0.00	0.00	13.84	16.19	0.00	29.49	30.82	24.95	0.00	0.00	0.00	119.30
1972	Below Normal	0.00	19.54	0.00	0.00	3.98	7.72	31.40	39.90	39.47	0.00	0.00	0.00	142.01
1973	Above Normal	0.00	0.00	0.00	0.00	0.00	0.00	48.43	58.81	37.74	0.00	0.00	0.00	144.98
1974	Wet	0.00	0.00	0.00	0.53	15.47	0.00	56.65	62.10	32.39	0.00	0.00	0.00	167.14
1975	Wet	0.00	26.82	0.00	13.74	18.27	0.00	46.41	41.35	19.75	0.00	0.00	0.00	166.34
1976	Critical	0.00	23.65	0.00	11.73	26.37	0.00	28.86	38.93	30.55	0.00	2.87	0.00	162.96
1977	Critical	0.00	8.84	8.64	0.00	3.15	7.79	6.06	0.00	0.00	0.00	0.00	0.00	34.48
1978	Above Normal	0.00	0.00	0.00	0.00	0.00	0.00	18.88	14.45	0.00	0.00	0.00	0.00	33.33
1979	Below Normal	0.00	13.75	0.00	0.00	0.00	0.00	45.93	51.08	47.16	0.00	0.00	2.57	160.49
1980	Above Normal	0.00	0.00	0.00	0.00	0.00	0.00	35.24	48.06	18.21	0.00	3.92	29.23	134.66
1981	Dry	0.00	27.94	0.00	11.56	16.01	4.17	25.04	27.38	13.28	0.00	0.94	0.00	126.32
1982	Wet	0.00	0.00	0.00	0.00	0.00	0.00	0.00	43.05	24.85	0.00	0.00	0.00	67.90
1983	Wet	0.00	0.00	0.00	0.13	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.13
1984	Wet	0.00	0.00	0.00	0.12	0.00	0.00	46.00	58.80	45.08	0.00	0.00	0.00	150.00
1985	Dry	0.00	0.00	0.00	8.97	12.29	16.34	43.65	47.60	34.35	0.00	15.50	0.00	178.70
1986	Wet	0.00	0.00	0.00	21.05	0.00	0.00	42.01	54.48	25.50	0.00	27.00	0.00	170.04
1987	Dry	0.00	28.24	0.00	13.42	14.56	1.19	24.05	12.56	25.33	0.00	17.07	0.00	136.42
1988	Critical	3.88	0.03	0.00	0.00	4.36	0.00	5.71	7.06	20.79	0.00	16.42	1.87	60.12
1989	Dry	2.77	0.00	0.00	0.00	0.00	0.00	29.67	33.32	24.99	0.00	0.24	0.00	90.99
1990	Critical	0.00	2.13	0.00	0.00	0.00	3.34	18.78	13.12	28.80	0.00	19.99	0.94	87.10
1991	Critical	4.06	1.63	0.00	1.89	0.00	0.00	6.54	9.73	0.00	0.00	14.07	3.61	41.53
1992	Critical	0.09	0.21	0.00	0.00	0.00	0.00	9.78	11.12	6.45	1.32	0.00	0.00	28.97
1993	Above Normal	0.00	0.00	0.00	0.00	0.00	0.00	34.75	38.21	5.68	0.00	0.00	0.00	78.64
1994	Critical	0.00	23.85	0.00	0.00	0.00	0.00	26.81	28.23	39.21	0.00	2.34	0.00	120.44
1995	Wet	0.00	0.00	0.00	0.00	0.00	0.00	39.36	0.00	0.00	0.00	0.00	0.00	39.36
1996	Wet	17.64	20.99	0.00	15.52	0.00	0.00	48.21	46.85	20.36	0.00	0.00	0.00	169.57
1997	Wet	18.38	23.87	0.00	0.00	0.00	0.00	54.19	57.92	36.87	0.00	0.00	0.00	191.23
1998	Wet	6.09	23.23	0.00	14.86	0.00	0.00	35.62	41.69	0.00	0.00	0.00	0.00	121.49
1999	Wet	0.00	0.00	0.00	6.54	0.00	0.00	50.38	55.49	33.12	0.00	0.00	8.49	154.02
2000	Above Normal	11.88	28.65	0.00	20.78	0.00	0.00	40.74	45.31	34.64	0.00	0.00	0.00	182.00
2001	Dry	3.59	19.63	0.00	0.00	0.00	0.00	19.20	28.43	23.03	0.00	26.77	0.00	120.65
2002	Dry	8.21	0.00	0.00	0.00	0.00	0.00	50.61	47.97	44.01	0.00	26.95	0.00	177.75
2003	Above Normal	23.11	4.39	0.00	0.00	0.00	0.00	26.76	24.01	1.32	0.00	0.00	0.00	79.59
Average		2.44	8.16	0.14	3.70	4.44	3.08	33.82	37.03	25.76	1.09	4.82	1.46	125.96
Wet		2.87	8.82	0.00	4.18	2.97	0.85	38.55	40.40	21.38	0.00	1.04	0.56	121.63
Above Normal		4.51	7.81	0.00	4.12	5.39	1.43	35.70	39.91	17.99	0.00	0.33	2.44	119.61

Energy generated (GWh) at SWP San Luis: Alternative1_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Total
1922	Above Normal	0.00	6.00	0.00	0.00	0.00	0.00	47.91	49.58	0.25	0.00	0.00	0.00	103.74
1923	Below Normal	0.00	5.84	0.00	12.88	7.65	28.10	36.81	23.68	0.00	0.00	0.00	0.00	114.96
1924	Critical	0.00	0.00	0.00	0.00	2.37	20.03	21.85	19.40	26.34	0.00	0.00	0.00	89.99
1925	Dry	0.00	0.00	0.00	0.00	0.00	0.00	21.00	21.64	19.07	0.00	6.68	0.00	68.39
1926	Dry	0.00	0.00	0.00	0.00	0.00	19.43	14.97	25.99	22.49	0.00	1.22	0.35	84.45
1927	Wet	0.00	0.00	0.00	0.00	0.00	0.00	44.62	40.53	22.80	0.00	0.00	0.00	107.95
1928	Above Normal	1.07	8.42	0.00	3.18	20.97	0.00	41.68	37.56	11.98	0.00	0.00	0.00	124.86
1929	Critical	0.00	12.54	0.00	0.00	0.00	0.00	3.91	11.49	29.64	5.62	0.00	0.00	63.20
1930	Dry	0.00	0.00	0.00	0.00	0.00	0.00	15.44	22.94	12.06	0.00	10.54	0.00	60.98
1931	Critical	0.00	0.00	0.00	0.00	0.00	5.33	25.24	28.76	29.58	0.00	6.71	0.00	95.62
1932	Dry	0.00	0.00	0.00	0.00	0.00	0.00	36.80	37.45	47.99	0.00	0.00	0.00	122.24
1933	Critical	8.69	5.72	0.00	0.00	0.00	0.00	24.62	35.26	53.82	34.27	27.86	12.30	202.54
1934	Critical	0.52	0.00	0.00	0.00	0.00	0.00	31.90	30.97	45.60	42.45	2.22	0.00	153.66
1935	Below Normal	0.00	0.00	0.00	0.00	0.00	0.00	36.97	44.05	9.44	0.00	0.00	0.00	90.46
1936	Below Normal	0.00	0.00	0.00	0.00	0.00	0.00	52.45	63.24	44.02	0.00	0.00	0.00	159.71
1937	Below Normal	0.00	6.04	0.00	0.00	0.00	0.00	51.19	55.66	14.60	0.00	14.43	15.38	157.30
1938	Wet	0.00	0.00	0.00	0.00	0.00	0.00	19.54	28.90	0.00	0.00	0.00	0.00	48.44
1939	Dry	1.45	39.57	0.00	16.30	29.46	46.49	41.48	35.26	33.94	0.00	0.04	0.00	243.99
1940	Above Normal	9.82	4.29	0.00	0.00	0.00	0.00	29.60	37.63	24.95	0.00	0.00	0.00	106.29
1941	Wet	0.00	8.84	0.00	0.00	0.00	0.00	34.83	39.37	18.11	0.00	0.00	0.00	101.15
1942	Wet	9.03	30.34	0.00	0.00	0.00	1.38	53.00	45.90	19.82	0.00	0.00	0.00	159.47
1943	Wet	3.16	22.47	0.00	0.00	0.00	0.00	53.24	52.16	35.22	0.00	0.00	0.00	166.25
1944	Dry	8.33	25.13	0.00	0.00	0.00	0.00	21.26	23.53	23.50	0.00	0.00	1.89	103.64
1945	Below Normal	0.00	0.00	0.00	0.00	0.00	0.00	49.41	58.63	44.95	0.00	0.00	0.00	152.99
1946	Below Normal	0.00	0.00	0.00	0.12	5.08	2.83	51.76	54.89	41.22	0.00	0.00	0.00	155.90
1947	Dry	0.00	0.00	0.00	15.03	7.72	19.42	42.93	48.86	44.57	0.00	4.76	0.00	183.29
1948	Below Normal	0.00	0.00	0.46	2.11	16.62	0.00	11.39	23.75	0.00	0.00	0.00	0.00	54.33
1949	Dry	0.00	0.00	0.00	0.00	0.00	0.00	49.14	50.98	32.76	0.00	6.70	0.00	139.58
1950	Below Normal	10.69	6.54	1.84	0.00	0.00	0.00	27.35	34.53	1.57	0.00	0.00	0.00	82.52
1951	Above Normal	0.00	0.00	0.00	0.12	0.00	0.00	46.30	58.24	38.06	0.00	0.00	0.00	142.72
1952	Wet	1.82	0.00	0.00	0.00	11.99	0.00	25.16	26.06	0.00	0.00	0.00	0.00	65.03
1953	Wet	1.36	30.13	0.00	27.90	14.20	15.21	43.90	41.79	36.33	0.00	0.00	0.00	210.82
1954	Above Normal	5.13	18.22	0.00	13.59	11.33	0.00	37.05	36.69	29.59	0.00	0.00	0.00	151.60
1955	Dry	0.00	0.00	0.00	0.00	0.00	0.00	31.82	41.64	47.24	0.00	20.16	0.00	140.86
1956	Wet	1.16	0.00	0.00	0.00	0.00	0.00	54.19	61.07	27.02	0.00	0.00	0.00	143.44
1957	Above Normal	5.18	22.68	0.00	12.90	29.70	17.12	16.53	21.77	0.00	0.00	0.00	0.00	125.88
1958	Wet	0.00	0.00	0.00	0.00	0.00	0.00	35.97	56.35	19.60	0.00	0.00	0.00	111.92
1959	Below Normal	1.40	32.45	0.00	29.88	18.82	8.25	25.12	24.79	15.21	0.00	0.00	0.00	155.92
1960	Dry	0.00	0.00	0.00	0.00	0.00	0.00	43.88	32.31	32.93	0.00	0.07	0.00	109.19
1961	Dry	9.96	0.00	0.00	0.00	0.00	0.00	33.49	36.93	49.39	0.00	6.66	0.00	136.43
1962	Below Normal	0.00	0.00	0.00	0.00	0.00	0.00	26.71	27.87	7.96	0.00	0.00	0.00	62.54
1963	Wet	0.00	0.00	0.00	0.00	0.00	0.00	48.64	50.80	34.40	0.00	0.00	0.00	133.84
1964	Dry	0.00	0.00	0.00	0.12	0.00	4.29	53.32	52.71	46.53	0.00	18.11	0.00	175.08
1965	Wet	3.11	0.00	0.00	0.00	0.04	0.00	37.49	38.32	22.83	0.00	0.00	0.00	101.79
1966	Below Normal	9.66	0.00	0.00	0.97	8.57	5.30	37.89	40.00	36.54	0.00	0.00	0.00	138.93
1967	Wet	0.00	0.00	0.00	0.00	0.00	0.00	37.48	38.58	0.00	0.00	0.00	0.00	76.06
1968	Below Normal	0.00	35.51	0.00	16.77	37.09	17.70	38.48	35.56	36.76	0.00	0.00	0.00	217.87
1969	Wet	0.00	0.00	0.00	0.00	0.00	0.00	10.90	0.00	0.00	0.00	0.00	0.00	10.90
1970	Wet	0.00	39.77	0.00	0.00	0.00	0.00	50.34	58.09	46.19	0.00	0.00	6.23	200.62
1971	Wet	4.16	0.00	0.00	13.83	16.17	0.00	29.37	30.62	24.56	0.00	0.00	0.00	118.71
1972	Below Normal	0.00	19.54	0.00	0.00	4.01	7.73	31.41	39.91	39.48	0.00	0.00	0.00	142.08
1973	Above Normal	0.00	0.00	0.00	0.00	0.00	0.00	48.38	58.16	35.84	0.00	0.00	0.00	142.38
1974	Wet	0.00	0.00	0.00	3.73	15.16	0.00	54.83	58.64	28.42	0.00	0.00	0.00	160.78
1975	Wet	0.00	26.61	0.00	12.90	17.89	0.00	47.57	42.96	20.70	0.00	0.00	0.00	168.63
1976	Critical	0.00	24.13	0.00	12.25	26.75	0.00	28.60	38.60	30.32	0.00	2.88	0.00	163.53
1977	Critical	0.00	8.68	8.47	0.00	3.15	7.82	6.64	0.00	0.00	0.00	0.00	0.00	34.76
1978	Above Normal	0.00	0.00	0.00	0.00	0.00	0.00	21.53	17.47	6.76	0.00	0.00	0.00	45.76
1979	Below Normal	0.00	9.72	0.00	0.00	0.00	0.00	53.57	50.49	43.79	0.00	0.00	0.00	157.57
1980	Above Normal	0.00	0.00	0.00	0.00	0.00	0.00	32.80	45.64	16.99	0.00	14.99	9.02	119.44
1981	Dry	0.00	21.78	0.00	12.65	16.42	15.21	26.15	28.94	17.75	0.00	0.75	0.00	139.65
1982	Wet	0.00	0.00	0.00	0.00	0.00	0.00	49.23	32.51	0.00	0.00	0.00	0.00	81.74
1983	Wet	0.00	0.00	0.00	0.13	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.13
1984	Wet	0.00	0.00	0.00	0.12	0.00	0.00	46.00	58.80	45.08	0.00	0.00	0.00	150.00
1985	Dry	0.00	0.00	0.00	8.96	12.29	16.34	43.65	47.60	34.35	0.00	15.51	0.00	178.70
1986	Wet	0.00	0.00	0.00	21.05	0.00	0.00	47.07	58.14	26.34	0.00	10.40	0.00	163.00
1987	Dry	0.62	27.14	0.00	13.12	14.25	1.18	22.62	11.16	23.55	0.00	15.46	0.00	129.10
1988	Critical	3.47	0.00	0.00	0.00	4.21	0.00	5.70	7.06	20.81	0.00	16.44	1.87	59.56
1989	Dry	2.79	0.00	0.00	0.00	0.00	0.00	29.69	33.44	24.95	0.00	0.26	0.00	91.13
1990	Critical	0.00	2.32	0.00	0.00	0.00	3.34	18.75	13.08	28.74	0.00	19.95	0.94	87.12
1991	Critical	4.04	1.62	0.00	1.89	0.00	0.00	6.53	9.43	0.00	0.00	14.25	3.60	41.36
1992	Critical	0.08	0.12	0.00	0.00	0.00	0.00	9.76	11.08	6.38	1.20	0.00	0.00	28.62
1993	Above Normal	0.00	0.00	0.00	0.00	0.00	0.00	34.53	38.08	5.38	0.00	0.00	0.00	77.99
1994	Critical	0.00	23.81	0.00	0.00	0.00	0.00	26.79	28.26	39.28	0.00	2.34	0.00	120.48
1995	Wet	0.00	0.00	0.00	0.00	0.00	0.00	41.20	28.15	7.50	0.00	0.00	0.00	76.85
1996	Wet	15.98	20.42	0.00	0.00	0.00	0.00	43.75	41.06	25.27	0.00	0.00	0.00	146.48
1997	Wet	17.64	23.41	0.00	0.00	0.00	0.00	54.40	58.87	37.94	0.00	0.00	0.00	192.26
1998	Wet	6.13	23.10	0.00	14.80	0.00	0.00	37.29	40.41	0.00	0.00	0.00	0.00	121.73
1999	Wet	0.00	0.00	0.00	4.56	0.00	0.00	47.91	56.06	33.76	0.00	0.00	9.78	152.07
2000	Above Normal	11.92	28.62	0.00	20.85	0.00	0.00	40.19	44.83	34.48	0.00	0.00	0.00	180.89
2001	Dry	3.32	19.09	0.00	0.00	0.00	0.00	19.42	28.67	23.18	0.00	27.11	0.00	120.79
2002	Dry	8.26	0.00	0.00	0.00	0.00	0.00	50.32	47.63	43.71	0.00	27.12	0.00	177.04
2003	Above Normal	23.17	5.02	0.00	0.00	0.00	0.00	26.73	23.95	1.32	0.00	0.00	0.00	80.19
Average		2.36	7.87	0.13	3.57	4.29	3.20	33.66	36.69	24.34	1.02	3.58	0.75	121.46
Wet		2.44	8.66	0.00	3.81	2.90	0.64	38.41	42.34	21.71	0.00	0.40	0.62	121.93
Above Normal		4.69	7.77	0.00	4.22	5.17	1.43	35.27	39.13	17.13	0.00	1.25	0.75	116.81

Percent Difference in Energy generated (GWh) at SWP San Luis: Alternative1_2005 minus Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September
1922	Above Normal	0%	0%	0%	0%	0%	0%	7%	6%	-	0%	0%	0%
1923	Below Normal	0%	13%	0%	1%	-20%	28%	12%	-41%	-100%	0%	0%	0%
1924	Critical	0%	0%	0%	0%	0%	9%	-2%	-8%	-10%	0%	-100%	-100%
1925	Dry	0%	0%	0%	0%	0%	0%	-31%	-54%	-51%	0%	-67%	0%
1926	Dry	0%	0%	0%	0%	0%	-6%	-10%	-24%	4%	0%	-88%	-
1927	Wet	-100%	0%	0%	0%	0%	0%	-16%	-27%	-31%	0%	0%	0%
1928	Above Normal	-6%	-6%	0%	-29%	-19%	0%	-17%	-26%	-55%	0%	0%	0%
1929	Critical	0%	-22%	0%	-100%	-100%	0%	133%	-7%	12%	-80%	-100%	-100%
1930	Dry	0%	0%	0%	0%	0%	0%	-12%	-15%	-61%	0%	56%	0%
1931	Critical	0%	0%	0%	0%	0%	11%	-7%	-10%	-21%	0%	-74%	-100%
1932	Dry	0%	0%	0%	0%	0%	0%	-4%	-6%	-13%	0%	0%	-100%
1933	Critical	-	-	0%	0%	0%	0%	-7%	-5%	-4%	9%	-11%	-12%
1934	Critical	-81%	0%	0%	0%	0%	0%	5%	7%	4%	48%	-79%	0%
1935	Below Normal	0%	0%	0%	0%	0%	0%	0%	-4%	-56%	0%	0%	0%
1936	Below Normal	0%	0%	0%	0%	0%	0%	10%	-2%	-5%	0%	0%	0%
1937	Below Normal	0%	-4%	0%	0%	0%	0%	6%	9%	-36%	0%	4%	-12%
1938	Wet	0%	0%	0%	0%	0%	0%	24%	-	0%	0%	0%	0%
1939	Dry	-66%	-6%	0%	-6%	-5%	-6%	-11%	-6%	-4%	0%	-92%	0%
1940	Above Normal	29%	-36%	0%	0%	0%	0%	2%	1%	-2%	0%	0%	0%
1941	Wet	0%	-1%	0%	0%	0%	0%	0%	3%	1%	0%	0%	0%
1942	Wet	-5%	-1%	0%	0%	0%	-21%	-1%	-2%	-5%	0%	0%	0%
1943	Wet	-1%	1%	0%	0%	0%	0%	0%	-5%	-5%	0%	0%	0%
1944	Dry	-16%	-11%	0%	0%	0%	0%	-1%	-1%	0%	0%	0%	-5%
1945	Below Normal	0%	0%	0%	0%	0%	0%	0%	-1%	-1%	0%	0%	0%
1946	Below Normal	0%	0%	0%	0%	-34%	8%	0%	0%	0%	0%	0%	0%
1947	Dry	0%	0%	0%	2%	1%	0%	0%	0%	0%	0%	-3%	0%
1948	Below Normal	0%	0%	-21%	-21%	-3%	0%	0%	2%	0%	0%	0%	0%
1949	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1950	Below Normal	3%	-1%	-3%	0%	0%	0%	0%	0%	-1%	0%	0%	0%
1951	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1952	Wet	0%	0%	0%	0%	-1%	0%	9%	12%	0%	0%	0%	0%
1953	Wet	-50%	-8%	0%	25%	-7%	-25%	-16%	0%	1%	0%	0%	0%
1954	Above Normal	-1%	12%	0%	22%	24%	0%	2%	4%	5%	0%	0%	0%
1955	Dry	0%	0%	0%	0%	0%	0%	-1%	-1%	-1%	0%	-1%	0%
1956	Wet	-17%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1957	Above Normal	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1958	Wet	0%	0%	0%	0%	0%	0%	9%	7%	16%	0%	0%	0%
1959	Below Normal	-5%	-5%	0%	-2%	-3%	2%	-6%	-11%	-24%	0%	0%	0%
1960	Dry	0%	0%	0%	0%	0%	0%	1%	1%	3%	0%	133%	0%
1961	Dry	-4%	0%	0%	0%	0%	0%	0%	1%	0%	0%	3%	0%
1962	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1963	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1964	Dry	0%	0%	0%	0%	0%	3%	0%	0%	0%	0%	0%	0%
1965	Wet	-3%	0%	0%	0%	-	0%	-2%	-4%	-4%	0%	0%	0%
1966	Below Normal	1%	0%	0%	-24%	-3%	-3%	0%	-1%	-1%	0%	0%	0%
1967	Wet	-100%	0%	0%	0%	0%	0%	6%	10%	0%	0%	0%	0%
1968	Below Normal	0%	-7%	0%	-2%	-2%	-2%	-3%	-4%	-2%	0%	0%	0%
1969	Wet	0%	0%	0%	0%	0%	0%	68%	0%	0%	0%	0%	0%
1970	Wet	0%	0%	0%	0%	0%	0%	-3%	1%	1%	0%	0%	1%
1971	Wet	4%	0%	0%	0%	0%	0%	0%	-1%	-2%	0%	0%	0%
1972	Below Normal	0%	0%	0%	0%	1%	0%	0%	0%	0%	0%	0%	0%
1973	Above Normal	0%	0%	0%	0%	0%	0%	0%	-1%	-5%	0%	0%	0%
1974	Wet	0%	0%	0%	604%	-2%	0%	-3%	-6%	-12%	0%	0%	0%
1975	Wet	0%	-1%	0%	-6%	-2%	0%	2%	4%	5%	0%	0%	0%
1976	Critical	0%	2%	0%	4%	1%	0%	-1%	-1%	-1%	0%	0%	0%
1977	Critical	0%	-2%	-2%	0%	0%	0%	10%	0%	0%	0%	0%	0%
1978	Above Normal	0%	0%	0%	0%	0%	0%	14%	21%	-	0%	0%	0%
1979	Below Normal	0%	-29%	0%	0%	0%	0%	17%	-1%	-7%	0%	0%	-100%
1980	Above Normal	0%	0%	0%	0%	0%	0%	-7%	-5%	-7%	0%	282%	-69%
1981	Dry	0%	-22%	0%	9%	3%	265%	4%	6%	34%	0%	-20%	0%
1982	Wet	0%	0%	0%	0%	0%	0%	0%	14%	31%	0%	0%	0%
1983	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1984	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1985	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1986	Wet	0%	0%	0%	0%	0%	0%	12%	7%	3%	0%	-61%	0%
1987	Dry	-	-4%	0%	-2%	-2%	-1%	-6%	-11%	-7%	0%	-9%	0%
1988	Critical	-11%	-100%	0%	0%	-3%	0%	0%	0%	0%	0%	0%	0%
1989	Dry	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	8%	0%
1990	Critical	0%	9%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1991	Critical	0%	-1%	0%	0%	0%	0%	0%	-3%	0%	0%	1%	0%
1992	Critical	-11%	-43%	0%	0%	0%	0%	0%	0%	-1%	-9%	0%	0%
1993	Above Normal	0%	0%	0%	0%	0%	0%	-1%	0%	-5%	0%	0%	0%
1994	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1995	Wet	0%	0%	0%	0%	0%	0%	5%	-	-	0%	0%	0%
1996	Wet	-9%	-3%	0%	-100%	0%	0%	-9%	-12%	24%	0%	0%	0%
1997	Wet	-4%	-2%	0%	0%	0%	0%	0%	2%	3%	0%	0%	0%
1998	Wet	1%	-1%	0%	0%	0%	0%	5%	-3%	0%	0%	0%	0%
1999	Wet	0%	0%	0%	-30%	0%	0%	-5%	1%	2%	0%	0%	15%
2000	Above Normal	0%	0%	0%	0%	0%	0%	-1%	-1%	0%	0%	0%	0%
2001	Dry	-8%	-3%	0%	0%	0%	0%	1%	1%	1%	0%	1%	0%
2002	Dry	1%	0%	0%	0%	0%	0%	-1%	-1%	-1%	0%	1%	0%
2003	Above Normal	0%	14%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Average		-6%	-3%	0%	4%	-2%	3%	2%	-2%	-5%	0%	-3%	-7%
Wet		-11%	-1%	0%	19%	0%	-2%	3%	0%	1%	0%	-2%	1%
Above Normal		2%	-1%	0%	-1%	0%	0%	0%	0%	-6%	0%	24%	-6%
Below Normal		0%	-2%	-2%	-3%	-4%	2%	2%	-4%	-17%	0%	0%	-8%
Dry		-5%	-3%	0%	0%	0%	14%	-4%	-6%	-5%	0%	-4%	-6%
Critical		-9%	-13%	0%	-8%	-8%	2%	11%	-2%	-2%	-3%	-30%	-26%

Percent Difference in Energy generated (GWh) at Syst. Tot.: Alternative1_2005 minus Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September
1922	Above Normal	0%	0%	0%	23%	0%	0%	1%	1%	3%	3%	4%	3%
1923	Below Normal	6%	8%	6%	-3%	-4%	14%	23%	-34%	-58%	10%	11%	27%
1924	Critical	42%	26%	71%	38%	26%	6%	4%	4%	-14%	-64%	-60%	-69%
1925	Dry	84%	247%	395%	34%	17%	-37%	-5%	-16%	-8%	-5%	-11%	-7%
1926	Dry	-13%	-15%	-11%	-2%	2%	2%	3%	3%	-1%	4%	15%	8%
1927	Wet	-36%	42%	24%	13%	-5%	0%	-3%	-4%	-10%	2%	3%	3%
1928	Above Normal	5%	6%	6%	5%	-2%	-1%	-4%	-2%	-32%	7%	8%	8%
1929	Critical	9%	11%	10%	-11%	-13%	-4%	9%	4%	6%	-54%	-58%	-65%
1930	Dry	-34%	-17%	128%	44%	0%	0%	-2%	-2%	-28%	4%	7%	5%
1931	Critical	9%	9%	9%	8%	2%	2%	-1%	-1%	-3%	-2%	-55%	-71%
1932	Dry	-27%	72%	111%	16%	0%	1%	0%	-1%	2%	3%	22%	2%
1933	Critical	-10%	11%	9%	39%	1%	-2%	-3%	-2%	-1%	-4%	-4%	-4%
1934	Critical	-10%	-9%	-1%	0%	1%	4%	3%	3%	3%	8%	-9%	0%
1935	Below Normal	14%	5%	5%	4%	1%	2%	2%	1%	-33%	5%	7%	9%
1936	Below Normal	18%	19%	17%	11%	-12%	-13%	8%	0%	3%	2%	2%	10%
1937	Below Normal	4%	5%	4%	-1%	0%	4%	0%	0%	5%	2%	1%	3%
1938	Wet	3%	5%	-1%	2%	-9%	1%	1%	2%	-2%	4%	0%	8%
1939	Dry	2%	3%	0%	4%	-1%	-2%	-5%	-1%	10%	2%	2%	2%
1940	Above Normal	3%	-12%	12%	9%	-7%	0%	0%	0%	3%	2%	2%	2%
1941	Wet	5%	6%	4%	0%	0%	-1%	0%	0%	3%	3%	4%	2%
1942	Wet	4%	5%	2%	-1%	0%	0%	0%	0%	2%	3%	3%	5%
1943	Wet	4%	5%	7%	-2%	-1%	0%	1%	-1%	3%	2%	2%	2%
1944	Dry	4%	4%	5%	-1%	-7%	-3%	0%	0%	2%	2%	2%	5%
1945	Below Normal	5%	6%	6%	9%	0%	-6%	0%	0%	4%	2%	3%	16%
1946	Below Normal	4%	-2%	6%	5%	1%	-7%	0%	0%	5%	2%	3%	3%
1947	Dry	4%	6%	8%	6%	0%	0%	0%	0%	1%	1%	1%	1%
1948	Below Normal	2%	3%	3%	1%	-2%	-1%	0%	2%	0%	0%	0%	0%
1949	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1950	Below Normal	0%	0%	0%	-2%	-2%	-1%	0%	0%	4%	1%	1%	2%
1951	Above Normal	3%	3%	0%	0%	-1%	0%	0%	0%	3%	2%	2%	3%
1952	Wet	4%	6%	7%	5%	0%	0%	0%	0%	-1%	3%	2%	4%
1953	Wet	2%	2%	3%	3%	3%	-4%	-10%	-1%	2%	2%	3%	2%
1954	Above Normal	4%	6%	5%	9%	5%	2%	0%	1%	3%	0%	1%	1%
1955	Dry	2%	2%	3%	4%	0%	0%	-1%	-1%	0%	0%	0%	-2%
1956	Wet	0%	0%	0%	-3%	0%	0%	0%	0%	3%	2%	3%	3%
1957	Above Normal	4%	5%	4%	5%	0%	0%	0%	0%	9%	2%	2%	3%
1958	Wet	6%	6%	8%	15%	0%	0%	1%	0%	3%	3%	4%	2%
1959	Below Normal	4%	4%	4%	4%	1%	-2%	-2%	-2%	-11%	1%	1%	2%
1960	Dry	3%	2%	4%	8%	-1%	0%	0%	0%	2%	0%	2%	-1%
1961	Dry	0%	-1%	-1%	3%	3%	1%	0%	0%	0%	0%	1%	0%
1962	Below Normal	-4%	0%	1%	0%	0%	0%	0%	0%	7%	2%	2%	3%
1963	Wet	7%	7%	9%	8%	0%	0%	0%	0%	3%	2%	3%	2%
1964	Dry	5%	6%	5%	6%	0%	0%	0%	0%	0%	0%	0%	0%
1965	Wet	0%	0%	0%	0%	0%	0%	0%	0%	3%	2%	3%	3%
1966	Below Normal	4%	6%	8%	5%	0%	0%	0%	0%	2%	2%	2%	2%
1967	Wet	5%	5%	7%	10%	0%	0%	1%	0%	0%	4%	4%	2%
1968	Below Normal	4%	0%	3%	-1%	0%	0%	0%	0%	3%	3%	3%	4%
1969	Wet	1%	6%	6%	-7%	-3%	0%	1%	0%	0%	6%	3%	2%
1970	Wet	6%	5%	1%	0%	-1%	0%	-2%	0%	4%	2%	3%	3%
1971	Wet	5%	6%	7%	4%	3%	0%	0%	0%	1%	1%	2%	1%
1972	Below Normal	3%	4%	6%	9%	0%	0%	0%	0%	0%	0%	0%	0%
1973	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	3%	2%	3%	3%
1974	Wet	4%	6%	3%	1%	0%	0%	0%	-1%	2%	2%	4%	6%
1975	Wet	4%	4%	6%	4%	-4%	-1%	1%	1%	3%	3%	5%	3%
1976	Critical	6%	6%	5%	6%	1%	0%	0%	0%	0%	0%	0%	0%
1977	Critical	-1%	-1%	-1%	0%	0%	0%	5%	0%	0%	0%	0%	0%
1978	Above Normal	0%	13%	-2%	0%	0%	-1%	0%	3%	7%	4%	4%	4%
1979	Below Normal	4%	3%	3%	-7%	-25%	-7%	11%	0%	3%	3%	3%	17%
1980	Above Normal	21%	7%	7%	-17%	-1%	-1%	-3%	-2%	2%	-9%	6%	30%
1981	Dry	2%	0%	2%	0%	-13%	7%	2%	2%	21%	2%	1%	3%
1982	Wet	9%	8%	2%	4%	0%	0%	0%	1%	4%	3%	4%	4%
1983	Wet	0%	3%	0%	0%	0%	0%	0%	0%	0%	0%	5%	4%
1984	Wet	0%	0%	0%	0%	0%	0%	0%	0%	3%	2%	3%	3%
1985	Dry	4%	6%	6%	5%	0%	0%	0%	0%	2%	2%	2%	3%
1986	Wet	3%	4%	5%	4%	0%	-7%	6%	1%	4%	2%	10%	-5%
1987	Dry	4%	5%	4%	5%	0%	0%	-2%	-2%	0%	-1%	0%	1%
1988	Critical	4%	6%	7%	10%	0%	1%	0%	0%	0%	0%	0%	0%
1989	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	-2%	1%
1990	Critical	1%	1%	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1991	Critical	0%	0%	0%	0%	0%	0%	0%	-1%	0%	0%	0%	0%
1992	Critical	0%	-5%	3%	2%	0%	0%	0%	0%	0%	0%	0%	0%
1993	Above Normal	0%	0%	1%	0%	0%	0%	0%	0%	3%	2%	2%	3%
1994	Critical	5%	6%	6%	8%	-1%	0%	0%	0%	0%	0%	0%	0%
1995	Wet	2%	0%	0%	0%	0%	0%	0%	3%	3%	3%	3%	4%
1996	Wet	3%	4%	4%	-14%	-9%	-6%	-2%	-1%	3%	2%	2%	2%
1997	Wet	3%	3%	1%	0%	0%	0%	0%	0%	2%	3%	4%	3%
1998	Wet	5%	6%	7%	5%	-1%	0%	0%	-1%	-1%	-1%	2%	2%
1999	Wet	6%	1%	3%	2%	0%	-2%	-5%	0%	4%	2%	4%	2%
2000	Above Normal	4%	5%	4%	5%	1%	0%	0%	0%	3%	2%	2%	3%
2001	Dry	4%	5%	2%	6%	-5%	-1%	1%	1%	3%	3%	1%	1%
2002	Dry	1%	2%	2%	3%	0%	0%	0%	0%	0%	0%	-1%	1%
2003	Above Normal	0%	3%	-2%	3%	2%	0%	0%	0%	4%	1%	1%	1%
Average		3%	8%	12%	4%	-1%	-1%	0%	-1%	0%	0%	0%	1%
Wet		2%	6%	4%	2%	-1%	-1%	0%	0%	2%	2%	3%	3%
Above Normal		4%	3%	3%	3%	0%	0%	0%	0%	1%	2%	3%	5%
Below Normal		5%	4%	5%	3%	-3%	-1%	3%	-2%	-5%	2%	3%	7%
Dry		3%	18%	37%	8%	0%	-2%	-1%	-1%	0%	1%	2%	1%
Critical		5%	5%	10%	8%	1%	1%	1%	0%	-1%	-10%	-15%	-17%

Percent Difference in Energy generated (GWh) at Thermalito Dam: Alternative1_2005 minus Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September
1922	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1923	Below Normal	0%	0%	0%	0%	5%	0%	0%	0%	0%	0%	0%	31%
1924	Critical	53%	0%	106%	0%	0%	1%	0%	0%	0%	-55%	-3%	0%
1925	Dry	0%	0%	0%	0%	0%	0%	0%	0%	10%	0%	-3%	0%
1926	Dry	-22%	-30%	0%	0%	0%	-10%	0%	-1%	0%	-4%	26%	-7%
1927	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1928	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1929	Critical	0%	0%	0%	0%	0%	-4%	0%	0%	0%	0%	-4%	0%
1930	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	2%	0%
1931	Critical	7%	8%	5%	0%	0%	0%	0%	0%	-1%	-4%	0%	0%
1932	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	46%	0%
1933	Critical	-54%	-41%	0%	0%	0%	0%	0%	0%	0%	-16%	0%	0%
1934	Critical	0%	0%	0%	0%	0%	-1%	0%	0%	0%	0%	0%	0%
1935	Below Normal	20%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1936	Below Normal	13%	13%	0%	0%	-15%	0%	0%	0%	0%	0%	0%	34%
1937	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	10%	1%	-3%	0%
1938	Wet	0%	0%	0%	0%	-9%	0%	0%	0%	0%	7%	-1%	11%
1939	Dry	0%	0%	-10%	0%	0%	0%	0%	-2%	0%	0%	0%	-2%
1940	Above Normal	-23%	0%	-4%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1941	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	-2%	0%
1942	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	5%
1943	Wet	0%	0%	0%	-3%	0%	0%	0%	0%	0%	0%	0%	0%
1944	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	2%	0%
1945	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	59%
1946	Below Normal	0%	-26%	0%	0%	9%	-19%	0%	0%	7%	0%	0%	-2%
1947	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	-1%	-1%
1948	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	1%	0%
1949	Dry	0%	1%	0%	0%	0%	0%	0%	0%	0%	0%	1%	0%
1950	Below Normal	-4%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1951	Above Normal	0%	0%	0%	0%	0%	2%	0%	0%	0%	0%	0%	0%
1952	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	5%
1953	Wet	0%	0%	-5%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1954	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1955	Dry	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	-6%
1956	Wet	0%	0%	0%	0%	0%	2%	0%	0%	0%	0%	0%	0%
1957	Above Normal	0%	0%	0%	0%	0%	-1%	0%	0%	0%	0%	0%	0%
1958	Wet	0%	-1%	0%	0%	0%	0%	0%	0%	0%	0%	5%	0%
1959	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	-1%
1960	Dry	-1%	0%	-1%	0%	0%	0%	0%	0%	0%	0%	1%	0%
1961	Dry	7%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1962	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1963	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	1%	0%	0%
1964	Dry	0%	-1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1965	Wet	0%	0%	0%	0%	0%	1%	0%	0%	0%	0%	0%	0%
1966	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1967	Wet	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1968	Below Normal	0%	0%	4%	-8%	0%	0%	0%	0%	-1%	0%	0%	0%
1969	Wet	-10%	0%	0%	4%	0%	0%	0%	0%	0%	11%	-3%	-1%
1970	Wet	5%	0%	-1%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1971	Wet	0%	0%	0%	0%	0%	-1%	0%	0%	0%	0%	0%	0%
1972	Below Normal	0%	0%	0%	0%	0%	2%	0%	0%	0%	0%	0%	0%
1973	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1974	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	7%
1975	Wet	0%	0%	0%	0%	-7%	0%	0%	0%	0%	0%	0%	0%
1976	Critical	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1977	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1978	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1979	Below Normal	0%	0%	1%	0%	0%	0%	0%	0%	0%	0%	0%	80%
1980	Above Normal	44%	0%	0%	-23%	0%	0%	0%	0%	0%	-24%	0%	279%
1981	Dry	0%	0%	-3%	-14%	-29%	0%	0%	0%	0%	0%	0%	-1%
1982	Wet	7%	0%	-1%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1983	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	-1%	-4%	0%
1984	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1985	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1986	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	38%	-11%
1987	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	-3%	0%	0%
1988	Critical	0%	0%	0%	0%	0%	20%	0%	0%	0%	0%	0%	0%
1989	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	-2%	0%
1990	Critical	2%	0%	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1991	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	-2%	0%
1992	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1993	Above Normal	0%	0%	0%	0%	0%	1%	0%	0%	0%	0%	0%	0%
1994	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1995	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1996	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	1%	0%	0%
1997	Wet	0%	0%	0%	0%	0%	0%	0%	0%	-7%	1%	0%	0%
1998	Wet	0%	0%	0%	0%	1%	0%	0%	0%	0%	0%	1%	0%
1999	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	-3%
2000	Above Normal	0%	0%	0%	0%	2%	0%	0%	0%	0%	0%	0%	0%
2001	Dry	0%	0%	-3%	0%	0%	0%	0%	0%	0%	4%	0%	0%
2002	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	-5%	2%
2003	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Average		1%	-1%	1%	-1%	-1%	0%	0%	0%	0%	-1%	1%	6%
Wet		0%	0%	0%	0%	-1%	0%	0%	0%	0%	1%	1%	1%
Above Normal		2%	0%	0%	-2%	0%	0%	0%	0%	0%	-2%	0%	23%
Below Normal		2%	-1%	0%	-1%	0%	-1%	0%	0%	1%	0%	0%	14%
Dry		-1%	-2%	-1%	-1%	-2%	-1%	0%	0%	1%	0%	4%	-1%
Critical		1%	-3%	9%	0%	0%	1%	0%	0%	0%	-6%	-1%	0%

Percent Difference in Energy generated (GWh) at Warne: Alternative1_2005 minus Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September
1922	Above Normal	0%	0%	0%	64%	-1%	-1%	0%	0%	7%	7%	7%	7%
1923	Below Normal	8%	9%	11%	-10%	-29%	5%	36%	-10%	-89%	30%	32%	37%
1924	Critical	51%	53%	75%	63%	38%	12%	11%	13%	15%	-91%	-89%	-87%
1925	Dry	>1,000%	>1,000%	>1,000%	202%	20%	-58%	10%	-14%	-13%	-13%	-13%	-13%
1926	Dry	-15%	-16%	-18%	30%	3%	6%	12%	10%	12%	15%	15%	15%
1927	Wet	20%	61%	79%	38%	-15%	-1%	-2%	-2%	4%	7%	7%	8%
1928	Above Normal	9%	10%	11%	9%	-4%	-5%	-2%	1%	-49%	21%	17%	14%
1929	Critical	13%	13%	9%	-8%	-15%	-2%	15%	10%	12%	-90%	-87%	-86%
1930	Dry	405%	>1,000%	>1,000%	252%	-1%	-1%	-2%	-2%	-17%	13%	11%	10%
1931	Critical	13%	11%	21%	15%	2%	1%	0%	0%	0%	0%	-90%	-89%
1932	Dry	332%	>1,000%	>1,000%	53%	-2%	1%	2%	2%	11%	9%	11%	14%
1933	Critical	23%	26%	44%	42%	2%	-3%	-4%	-6%	-3%	-3%	-6%	-7%
1934	Critical	-28%	-39%	287%	-9%	3%	3%	4%	5%	6%	6%	0%	0%
1935	Below Normal	8%	7%	9%	8%	1%	2%	2%	2%	-80%	9%	18%	19%
1936	Below Normal	24%	25%	33%	20%	-1%	-27%	21%	0%	6%	6%	5%	6%
1937	Below Normal	7%	8%	9%	-1%	-1%	0%	-2%	-1%	5%	5%	5%	5%
1938	Wet	6%	7%	-2%	28%	5%	3%	6%	-2%	-2%	5%	5%	6%
1939	Dry	7%	7%	8%	10%	0%	0%	-8%	2%	35%	5%	6%	7%
1940	Above Normal	9%	10%	21%	20%	-9%	-2%	0%	0%	6%	5%	6%	7%
1941	Wet	10%	10%	8%	0%	0%	0%	0%	0%	8%	8%	8%	8%
1942	Wet	10%	11%	7%	-15%	-1%	0%	0%	0%	7%	7%	7%	7%
1943	Wet	9%	9%	11%	-3%	-6%	0%	3%	0%	7%	6%	6%	7%
1944	Dry	8%	9%	10%	3%	-6%	-2%	-1%	-1%	5%	4%	5%	6%
1945	Below Normal	9%	11%	21%	15%	0%	-1%	0%	0%	7%	6%	6%	7%
1946	Below Normal	8%	8%	6%	9%	0%	0%	0%	0%	7%	7%	7%	7%
1947	Dry	9%	9%	11%	9%	0%	-1%	0%	0%	3%	3%	2%	3%
1948	Below Normal	3%	3%	4%	4%	-2%	-1%	0%	0%	0%	0%	0%	0%
1949	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1950	Below Normal	0%	0%	0%	-2%	-2%	0%	0%	0%	75%	2%	2%	3%
1951	Above Normal	4%	4%	-4%	0%	-21%	0%	0%	0%	7%	6%	6%	7%
1952	Wet	8%	9%	10%	9%	0%	0%	0%	-2%	-2%	6%	6%	7%
1953	Wet	10%	10%	6%	-3%	23%	0%	-17%	-1%	7%	5%	6%	8%
1954	Above Normal	11%	11%	17%	15%	6%	5%	1%	1%	2%	1%	2%	2%
1955	Dry	3%	3%	5%	10%	0%	0%	-1%	-1%	0%	0%	0%	0%
1956	Wet	0%	0%	1%	0%	0%	0%	0%	0%	6%	6%	6%	6%
1957	Above Normal	7%	8%	9%	8%	0%	0%	0%	0%	151%	5%	6%	7%
1958	Wet	10%	10%	16%	69%	0%	0%	0%	0%	6%	6%	6%	6%
1959	Below Normal	7%	8%	10%	7%	21%	-4%	-2%	-2%	-43%	3%	4%	4%
1960	Dry	6%	6%	9%	13%	-1%	1%	0%	0%	0%	0%	0%	-1%
1961	Dry	-1%	-1%	0%	4%	3%	1%	0%	0%	0%	0%	0%	0%
1962	Below Normal	-11%	1%	2%	0%	0%	0%	0%	0%	162%	5%	5%	7%
1963	Wet	9%	10%	15%	13%	0%	0%	0%	0%	7%	6%	6%	7%
1964	Dry	8%	9%	6%	13%	0%	1%	0%	0%	0%	0%	0%	0%
1965	Wet	0%	0%	0%	0%	0%	-1%	0%	0%	7%	7%	7%	8%
1966	Below Normal	9%	10%	12%	6%	-1%	0%	0%	0%	5%	4%	5%	6%
1967	Wet	8%	9%	13%	27%	0%	0%	0%	0%	0%	6%	6%	7%
1968	Below Normal	8%	2%	-6%	-24%	0%	0%	0%	0%	7%	8%	7%	6%
1969	Wet	6%	7%	8%	-39%	-11%	0%	-1%	-1%	-1%	6%	6%	7%
1970	Wet	7%	11%	11%	4%	-6%	0%	-6%	0%	7%	7%	7%	7%
1971	Wet	8%	9%	11%	6%	40%	0%	0%	0%	4%	4%	4%	5%
1972	Below Normal	7%	8%	12%	38%	0%	0%	0%	0%	0%	0%	0%	0%
1973	Above Normal	0%	0%	0%	1%	0%	0%	0%	0%	6%	6%	6%	6%
1974	Wet	8%	8%	10%	-13%	0%	0%	0%	0%	6%	6%	6%	6%
1975	Wet	8%	8%	10%	10%	4%	-4%	1%	1%	8%	7%	7%	8%
1976	Critical	9%	10%	11%	10%	0%	0%	0%	0%	0%	-1%	-1%	-1%
1977	Critical	-1%	-1%	-1%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1978	Above Normal	0%	112%	0%	0%	0%	-3%	-1%	2%	8%	11%	9%	6%
1979	Below Normal	5%	6%	3%	-6%	-45%	-19%	26%	1%	8%	8%	8%	8%
1980	Above Normal	10%	11%	13%	-9%	-11%	0%	-3%	-3%	5%	4%	4%	5%
1981	Dry	6%	7%	9%	4%	-7%	8%	2%	2%	347%	4%	5%	7%
1982	Wet	9%	10%	16%	15%	0%	0%	0%	0%	7%	6%	6%	7%
1983	Wet	-8%	16%	0%	0%	0%	0%	0%	0%	0%	0%	12%	10%
1984	Wet	0%	0%	0%	0%	0%	0%	0%	0%	7%	6%	6%	7%
1985	Dry	8%	8%	6%	10%	0%	0%	0%	0%	5%	4%	4%	5%
1986	Wet	6%	6%	7%	7%	0%	-11%	16%	0%	7%	6%	6%	7%
1987	Dry	8%	9%	10%	8%	0%	0%	-3%	-3%	2%	1%	3%	5%
1988	Critical	31%	81%	769%	20%	0%	0%	0%	0%	0%	0%	0%	0%
1989	Dry	0%	0%	0%	-1%	0%	0%	0%	0%	0%	0%	0%	1%
1990	Critical	1%	1%	2%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1991	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	1%	1%	0%
1992	Critical	2%	0%	0%	13%	0%	0%	0%	0%	0%	0%	0%	0%
1993	Above Normal	2%	0%	5%	0%	0%	0%	0%	0%	7%	7%	7%	8%
1994	Critical	10%	11%	14%	11%	-1%	0%	0%	0%	0%	0%	-1%	0%
1995	Wet	8%	3%	0%	1%	0%	0%	0%	0%	6%	6%	6%	6%
1996	Wet	7%	8%	8%	-31%	-24%	-13%	-2%	-2%	4%	4%	4%	4%
1997	Wet	5%	6%	6%	8%	0%	0%	1%	0%	7%	7%	7%	8%
1998	Wet	9%	10%	12%	8%	-31%	5%	0%	-1%	-2%	-2%	5%	6%
1999	Wet	11%	2%	3%	-4%	-16%	0%	-12%	0%	7%	6%	6%	7%
2000	Above Normal	8%	9%	11%	9%	1%	-2%	0%	0%	7%	6%	6%	7%
2001	Dry	8%	9%	13%	14%	-6%	-1%	1%	1%	2%	2%	2%	3%
2002	Dry	10%	23%	217%	289%	1%	0%	0%	0%	0%	0%	0%	0%
2003	Above Normal	0%	0%		9%	4%	1%	0%	0%	96%	3%	3%	4%
Average		16%	10%	25%	17%	-1%	-1%	1%	0%	11%	2%	2%	2%
Wet		7%	10%	10%	5%	-2%	-1%	-1%	0%	5%	6%	6%	7%
Above Normal		5%	14%	7%	10%	-3%	-1%	-1%	0%	21%	7%	7%	7%
Below Normal		7%	8%	9%	5%	-4%	-3%	6%	-1%	5%	7%	7%	8%
Dry		44%	5%	16%	51%	0%	-3%	1%	0%	22%	3%	3%	3%
Critical		10%	14%	103%	13%	2%	1%	2%	2%	2%	-15%	-23%	-23%

Percent Difference in Energy Use (GWh) At Pumping Plant at Badger Hill: Alternative1_2005 minus Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September
1922	Above Normal	0%	0%	0%	23%	18%	16%	17%	20%	20%	20%	20%	19%
1923	Below Normal	20%	19%	20%	13%	14%	12%	-1%	-5%	-5%	-4%	-3%	-5%
1924	Critical	4%	1%	1%	70%	64%	26%	17%	16%	17%	17%	-89%	80%
1925	Dry	115%	110%	88%	45%	36%	-38%	-16%	-16%	-16%	-16%	-16%	-16%
1926	Dry	-16%	-15%	-17%	38%	11%	7%	13%	11%	11%	11%	11%	10%
1927	Wet	10%	11%	9%	-5%	-10%	-2%	-2%	-2%	-2%	-2%	-2%	-3%
1928	Above Normal	-3%	-2%	-2%	-3%	-3%	-3%	1%	7%	6%	7%	5%	6%
1929	Critical	-4%	-2%	-2%	-20%	-20%	-6%	24%	14%	13%	-7%	-10%	-32%
1930	Dry	95%	106%	92%	23%	0%	-2%	-3%	-4%	-1%	-1%	-1%	-3%
1931	Critical	-3%	-2%	0%	23%	8%	3%	0%	0%	0%	0%	0%	-1%
1932	Dry	0%	0%	0%	8%	0%	0%	2%	3%	1%	1%	0%	2%
1933	Critical	2%	2%	-2%	13%	0%	-6%	-5%	-12%	-4%	-4%	-3%	-10%
1934	Critical	-7%	-5%	-2%	9%	14%	8%	6%	5%	6%	6%	-16%	-37%
1935	Below Normal	56%	63%	55%	9%	3%	2%	3%	3%	3%	3%	3%	3%
1936	Below Normal	3%	2%	3%	-12%	-7%	-19%	1%	0%	0%	0%	0%	0%
1937	Below Normal	0%	-1%	0%	-1%	-2%	32%	0%	0%	0%	0%	0%	0%
1938	Wet	0%	0%	1%	-10%	7%	24%	0%	-6%	-5%	-5%	-5%	0%
1939	Dry	0%	0%	0%	0%	-1%	-1%	1%	0%	0%	0%	0%	0%
1940	Above Normal	1%	0%	0%	-16%	-16%	-1%	0%	0%	0%	0%	0%	0%
1941	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1942	Wet	0%	0%	0%	0%	0%	-1%	-1%	-1%	-2%	-1%	-1%	-1%
1943	Wet	-2%	-2%	-1%	-1%	-1%	-2%	-1%	-2%	-2%	-2%	-1%	-2%
1944	Dry	-2%	-2%	-2%	-20%	-20%	-11%	0%	-1%	0%	0%	0%	-1%
1945	Below Normal	-1%	0%	0%	0%	0%	-2%	0%	0%	0%	0%	0%	0%
1946	Below Normal	0%	0%	0%	0%	0%	0%	1%	0%	1%	1%	1%	1%
1947	Dry	1%	0%	0%	1%	0%	0%	0%	1%	0%	0%	0%	0%
1948	Below Normal	0%	0%	0%	-3%	-3%	-2%	0%	0%	0%	0%	0%	1%
1949	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1950	Below Normal	0%	0%	0%	-2%	-2%	0%	0%	0%	0%	0%	0%	0%
1951	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1952	Wet	0%	0%	0%	0%	0%	0%	0%	-6%	-5%	-5%	-6%	-6%
1953	Wet	-7%	-9%	-8%	-6%	-8%	-5%	0%	-2%	-1%	-2%	-1%	-2%
1954	Above Normal	2%	0%	1%	7%	6%	4%	1%	1%	1%	1%	1%	1%
1955	Dry	1%	0%	0%	-3%	0%	0%	-1%	-1%	-1%	-1%	-1%	-1%
1956	Wet	-1%	0%	-2%	-1%	0%	0%	0%	0%	0%	0%	0%	0%
1957	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	-21%	4%	4%	5%
1958	Wet	11%	12%	15%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1959	Below Normal	0%	0%	0%	0%	0%	-1%	-3%	-3%	-3%	-3%	-3%	-3%
1960	Dry	-3%	-4%	-3%	0%	0%	2%	0%	0%	0%	0%	0%	0%
1961	Dry	1%	0%	1%	9%	6%	2%	0%	0%	0%	0%	0%	0%
1962	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1963	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1964	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1965	Wet	0%	0%	0%	1%	0%	0%	0%	0%	0%	0%	0%	0%
1966	Below Normal	-1%	0%	0%	-1%	-1%	-1%	0%	0%	0%	0%	0%	0%
1967	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1968	Below Normal	0%	0%	0%	-1%	0%	-1%	1%	3%	3%	3%	2%	3%
1969	Wet	-2%	0%	-1%	-12%	34%	0%	0%	0%	0%	0%	0%	0%
1970	Wet	11%	-1%	0%	0%	10%	-2%	0%	0%	0%	1%	0%	1%
1971	Wet	1%	1%	0%	0%	1%	0%	-1%	0%	0%	0%	0%	0%
1972	Below Normal	-1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1973	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1974	Wet	0%	0%	0%	0%	0%	-1%	-3%	-4%	-4%	-4%	-4%	-4%
1975	Wet	-4%	-4%	-4%	-2%	-2%	0%	1%	1%	1%	1%	1%	1%
1976	Critical	1%	1%	1%	1%	1%	0%	-1%	0%	-1%	-1%	-1%	0%
1977	Critical	0%	-1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	-17%
1978	Above Normal	-39%	56%	57%	0%	0%	-2%	1%	4%	4%	4%	3%	4%
1979	Below Normal	-5%	-3%	-3%	-19%	-18%	1%	0%	-2%	-2%	-2%	-2%	-2%
1980	Above Normal	-2%	-2%	-2%	-3%	-1%	38%	-8%	-4%	-4%	-4%	-4%	-4%
1981	Dry	-5%	-7%	-6%	-6%	-7%	1%	3%	3%	3%	3%	3%	3%
1982	Wet	3%	3%	3%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1983	Wet	0%	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1984	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1985	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1986	Wet	0%	0%	0%	0%	0%	-1%	0%	0%	0%	0%	0%	0%
1987	Dry	0%	0%	0%	0%	0%	0%	-3%	-4%	-4%	-4%	-4%	-4%
1988	Critical	-3%	-4%	-4%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1989	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1990	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1991	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1992	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	-18%	0%	5%
1993	Above Normal	11%	15%	13%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1994	Critical	0%	-1%	-1%	-1%	-1%	-1%	0%	0%	0%	0%	0%	1%
1995	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1996	Wet	0%	0%	0%	-44%	-40%	-23%	-3%	-3%	-4%	-3%	-3%	-3%
1997	Wet	-3%	-3%	-4%	-1%	-1%	-1%	0%	0%	0%	0%	0%	0%
1998	Wet	0%	0%	0%	-1%	0%	0%	0%	-11%	-11%	-11%	-11%	-11%
1999	Wet	-2%	-11%	-11%	-7%	-6%	-13%	0%	0%	0%	1%	0%	1%
2000	Above Normal	1%	0%	1%	1%	1%	0%	0%	1%	1%	1%	0%	0%
2001	Dry	-2%	0%	0%	-11%	-12%	-4%	1%	1%	0%	1%	0%	1%
2002	Dry	2%	0%	0%	0%	0%	0%	-1%	0%	0%	0%	0%	0%
2003	Above Normal	-1%	-1%	-1%	3%	2%	2%	0%	0%	0%	0%	0%	0%
Average		3%	4%	3%	1%	1%	0%	0%	0%	0%	0%	-2%	0%
Wet		1%	0%	0%	-3%	-1%	-1%	0%	-1%	-1%	-1%	-1%	-1%
Above Normal		-2%	5%	6%	1%	1%	4%	1%	2%	1%	3%	2%	3%
Below Normal		5%	6%	5%	-1%	-1%	2%	0%	0%	0%	0%	0%	0%
Dry		10%	10%	9%	5%	1%	-3%	0%	0%	0%	0%	0%	0%
Critical		-1%	-1%	-1%	8%	6%	2%	3%	2%	3%	-1%	-10%	-1%

Percent Difference in Energy Use (GWh) At Pumping Plant at Buena Vista: Alternative1_2005 minus Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September
1922	Above Normal	0%	0%	0%	43%	1%	1%	2%	4%	11%	11%	11%	11%
1923	Below Normal	12%	13%	14%	1%	0%	18%	31%	-50%	-90%	29%	28%	30%
1924	Critical	38%	41%	48%	61%	43%	20%	13%	15%	-21%	-92%	-92%	-92%
1925	Dry	152%	377%	647%	74%	28%	-42%	-4%	-15%	-13%	-13%	-13%	-13%
1926	Dry	-14%	-14%	-14%	15%	1%	7%	5%	10%	-3%	15%	14%	14%
1927	Wet	-38%	52%	53%	17%	-5%	0%	-2%	-2%	-14%	7%	7%	8%
1928	Above Normal	8%	9%	11%	5%	-2%	-3%	-1%	4%	-62%	22%	21%	21%
1929	Critical	16%	17%	14%	-15%	-17%	-6%	20%	12%	12%	-91%	-91%	-91%
1930	Dry	3%	6%	686%	72%	3%	2%	-1%	-1%	-56%	12%	11%	11%
1931	Critical	10%	9%	10%	10%	3%	4%	0%	0%	0%	0%	-93%	-93%
1932	Dry	-11%	104%	471%	21%	1%	4%	1%	0%	8%	8%	9%	10%
1933	Critical	15%	18%	23%	38%	4%	-2%	-4%	-2%	0%	-1%	-3%	-3%
1934	Critical	-9%	-10%	-4%	-1%	4%	7%	5%	6%	6%	6%	-66%	0%
1935	Below Normal	22%	9%	9%	8%	4%	4%	2%	3%	-56%	14%	16%	17%
1936	Below Normal	20%	21%	24%	21%	-2%	-24%	11%	0%	6%	6%	6%	6%
1937	Below Normal	7%	8%	9%	-1%	0%	8%	-1%	-1%	5%	5%	5%	6%
1938	Wet	6%	7%	-2%	0%	0%	-2%	2%	-6%	-6%	4%	1%	6%
1939	Dry	7%	8%	9%	5%	0%	-1%	-8%	1%	30%	5%	6%	6%
1940	Above Normal	7%	-14%	15%	19%	-13%	-2%	0%	0%	7%	5%	5%	6%
1941	Wet	8%	9%	6%	0%	0%	-3%	0%	0%	8%	8%	7%	8%
1942	Wet	9%	10%	6%	0%	0%	0%	0%	0%	7%	7%	6%	7%
1943	Wet	8%	9%	11%	1%	0%	2%	2%	0%	6%	6%	6%	7%
1944	Dry	7%	8%	10%	-6%	-12%	-7%	0%	0%	5%	5%	5%	5%
1945	Below Normal	7%	8%	11%	16%	0%	-8%	0%	0%	7%	7%	6%	7%
1946	Below Normal	8%	9%	8%	6%	0%	0%	0%	0%	7%	7%	7%	8%
1947	Dry	9%	10%	11%	7%	0%	0%	0%	0%	3%	3%	3%	3%
1948	Below Normal	3%	4%	4%	2%	-2%	-1%	0%	3%	-3%	0%	0%	0%
1949	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1950	Below Normal	0%	0%	0%	-3%	-3%	-1%	0%	0%	75%	2%	2%	3%
1951	Above Normal	4%	4%	-1%	0%	0%	0%	0%	0%	7%	7%	6%	7%
1952	Wet	8%	9%	10%	5%	0%	0%	0%	-4%	-4%	4%	3%	4%
1953	Wet	6%	7%	11%	5%	0%	-7%	-17%	-2%	6%	5%	5%	6%
1954	Above Normal	9%	10%	12%	13%	6%	4%	1%	1%	5%	1%	2%	2%
1955	Dry	3%	3%	4%	7%	0%	0%	-1%	-1%	0%	0%	0%	0%
1956	Wet	0%	0%	1%	-14%	0%	0%	0%	0%	6%	6%	6%	7%
1957	Above Normal	7%	8%	9%	5%	0%	0%	0%	0%	154%	6%	6%	6%
1958	Wet	8%	10%	12%	28%	0%	0%	0%	0%	6%	6%	6%	7%
1959	Below Normal	7%	8%	9%	5%	0%	-2%	-2%	-2%	-26%	3%	3%	3%
1960	Dry	4%	4%	6%	10%	-1%	0%	0%	0%	4%	-1%	3%	-2%
1961	Dry	-1%	-2%	-1%	5%	4%	2%	0%	0%	0%	0%	1%	0%
1962	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	132%	5%	5%	6%
1963	Wet	8%	9%	11%	13%	0%	0%	0%	0%	7%	7%	7%	7%
1964	Dry	8%	9%	7%	7%	0%	0%	0%	0%	0%	0%	0%	0%
1965	Wet	0%	0%	0%	0%	0%	-1%	0%	0%	6%	8%	7%	8%
1966	Below Normal	9%	10%	12%	5%	-1%	0%	0%	0%	5%	5%	5%	5%
1967	Wet	7%	8%	10%	15%	0%	0%	0%	0%	0%	6%	6%	7%
1968	Below Normal	8%	2%	3%	5%	0%	0%	0%	2%	8%	9%	8%	9%
1969	Wet	8%	9%	10%	-24%	0%	0%	-1%	-1%	-1%	6%	6%	7%
1970	Wet	7%	10%	10%	0%	0%	0%	-3%	0%	7%	7%	7%	8%
1971	Wet	8%	9%	11%	5%	0%	0%	0%	0%	3%	4%	4%	4%
1972	Below Normal	6%	6%	8%	15%	0%	0%	0%	0%	0%	0%	0%	0%
1973	Above Normal	0%	0%	0%	1%	0%	0%	0%	0%	6%	6%	6%	7%
1974	Wet	8%	9%	10%	5%	0%	0%	-1%	-1%	6%	6%	5%	6%
1975	Wet	7%	8%	9%	4%	-1%	-4%	1%	1%	8%	8%	8%	8%
1976	Critical	9%	10%	11%	7%	1%	0%	-1%	-1%	0%	-1%	0%	-1%
1977	Critical	-1%	-1%	-1%	0%	0%	0%	10%	0%	2%	0%	-2%	0%
1978	Above Normal	0%	0%	0%	0%	0%	-2%	0%	4%	11%	12%	11%	11%
1979	Below Normal	9%	9%	8%	-10%	-26%	-3%	13%	1%	8%	7%	7%	8%
1980	Above Normal	9%	10%	12%	-4%	0%	3%	-5%	-4%	3%	3%	2%	4%
1981	Dry	4%	5%	7%	7%	0%	12%	2%	2%	107%	5%	2%	7%
1982	Wet	9%	10%	13%	14%	1%	0%	0%	0%	6%	6%	6%	7%
1983	Wet	0%	8%	0%	0%	0%	0%	0%	0%	0%	0%	9%	9%
1984	Wet	0%	0%	0%	0%	0%	0%	0%	0%	7%	7%	6%	7%
1985	Dry	8%	9%	7%	6%	0%	0%	0%	0%	5%	5%	5%	5%
1986	Wet	6%	6%	7%	4%	0%	-23%	8%	0%	6%	6%	6%	7%
1987	Dry	8%	9%	10%	5%	0%	0%	-3%	-3%	0%	0%	1%	2%
1988	Critical	5%	9%	13%	18%	-1%	0%	0%	0%	0%	0%	0%	0%
1989	Dry	0%	0%	0%	0%	0%	0%	0%	0%	-1%	0%	-3%	1%
1990	Critical	1%	1%	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1991	Critical	0%	0%	0%	0%	0%	0%	0%	-2%	0%	0%	0%	0%
1992	Critical	1%	-7%	5%	4%	0%	0%	0%	0%	0%	0%	0%	-1%
1993	Above Normal	-1%	-9%	2%	0%	0%	0%	0%	0%	8%	7%	6%	7%
1994	Critical	9%	9%	11%	8%	-1%	0%	0%	0%	0%	0%	0%	0%
1995	Wet	0%	0%	0%	1%	0%	0%	0%	0%	6%	6%	6%	7%
1996	Wet	7%	8%	8%	-42%	-39%	-20%	-2%	-2%	4%	4%	4%	5%
1997	Wet	5%	6%	6%	0%	0%	0%	1%	0%	7%	7%	7%	8%
1998	Wet	9%	10%	11%	6%	0%	0%	0%	-4%	-4%	-4%	2%	3%
1999	Wet	12%	2%	6%	5%	0%	-6%	-6%	0%	7%	7%	7%	7%
2000	Above Normal	8%	9%	10%	6%	1%	-1%	0%	1%	7%	7%	6%	7%
2001	Dry	8%	9%	11%	8%	-7%	-2%	1%	1%	2%	2%	2%	2%
2002	Dry	3%	4%	4%	5%	0%	0%	0%	0%	0%	0%	0%	0%
2003	Above Normal	0%	5%	-3%	6%	3%	1%	0%	0%	29%	3%	3%	3%
Average		7%	12%	30%	7%	0%	-1%	1%	0%	5%	2%	0%	2%
Wet		5%	9%	9%	2%	-2%	-2%	-1%	-1%	3%	6%	6%	7%
Above Normal		4%	3%	6%	8%	0%	0%	0%	1%	15%	7%	7%	8%
Below Normal		8%	8%	9%	5%	-2%	-1%	4%	-3%	6%	7%	7%	8%
Dry		11%	31%	104%	14%	1%	-1%	0%	0%	5%	3%	2%	3%
Critical		8%	8%	11%	11%	3%	2%	4%	2%	0%	-15%	-29%	-23%

Percent Difference in Energy Use (GWh) At Pumping Plant at Chrisman: Alternative1_2005 minus Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September
1922	Above Normal	0%	0%	0%	43%	1%	0%	2%	3%	11%	11%	11%	11%
1923	Below Normal	12%	13%	14%	1%	0%	18%	33%	-52%	-89%	30%	29%	31%
1924	Critical	39%	41%	48%	61%	43%	20%	13%	15%	-24%	-92%	-92%	-93%
1925	Dry	125%	375%	652%	75%	28%	-42%	-3%	-15%	-13%	-13%	-13%	-13%
1926	Dry	-14%	-14%	-14%	15%	1%	7%	5%	10%	-4%	15%	14%	14%
1927	Wet	-40%	53%	54%	17%	-5%	0%	-2%	-2%	-14%	7%	7%	8%
1928	Above Normal	9%	9%	11%	5%	-2%	-3%	-2%	4%	-66%	22%	21%	21%
1929	Critical	16%	17%	14%	-15%	-17%	-6%	19%	11%	12%	-92%	-91%	-92%
1930	Dry	-31%	-7%	692%	73%	3%	2%	-1%	-1%	-60%	13%	11%	11%
1931	Critical	10%	9%	10%	10%	3%	4%	0%	0%	0%	0%	-93%	-94%
1932	Dry	-28%	100%	477%	22%	1%	4%	1%	0%	9%	9%	9%	10%
1933	Critical	16%	18%	23%	39%	4%	-2%	-4%	-2%	0%	-1%	-4%	-4%
1934	Critical	-9%	-10%	-3%	-1%	4%	7%	5%	6%	6%	6%	-50%	0%
1935	Below Normal	15%	7%	8%	8%	4%	4%	2%	3%	-63%	15%	16%	17%
1936	Below Normal	20%	21%	24%	21%	-2%	-24%	11%	0%	6%	6%	6%	7%
1937	Below Normal	7%	8%	9%	-1%	0%	8%	-1%	-1%	6%	6%	5%	6%
1938	Wet	7%	7%	-2%	0%	0%	-2%	2%	-6%	-6%	5%	1%	6%
1939	Dry	7%	8%	9%	5%	0%	-1%	-8%	1%	35%	6%	7%	6%
1940	Above Normal	8%	-14%	15%	21%	-13%	-2%	0%	0%	8%	6%	6%	7%
1941	Wet	8%	9%	6%	0%	0%	-4%	0%	0%	8%	8%	8%	8%
1942	Wet	10%	11%	6%	0%	0%	0%	0%	0%	7%	7%	7%	8%
1943	Wet	8%	9%	11%	1%	0%	2%	2%	0%	7%	7%	6%	7%
1944	Dry	8%	8%	10%	-6%	-13%	-7%	0%	0%	5%	5%	5%	6%
1945	Below Normal	8%	9%	12%	16%	0%	-8%	0%	0%	7%	7%	7%	7%
1946	Below Normal	8%	9%	8%	6%	0%	0%	0%	0%	8%	8%	7%	8%
1947	Dry	9%	10%	11%	7%	0%	0%	0%	0%	3%	3%	3%	3%
1948	Below Normal	3%	4%	4%	2%	-2%	-1%	0%	3%	0%	0%	0%	0%
1949	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1950	Below Normal	0%	0%	0%	-3%	-3%	-1%	0%	0%	84%	2%	2%	3%
1951	Above Normal	4%	4%	-1%	0%	0%	0%	0%	0%	7%	7%	7%	7%
1952	Wet	8%	9%	10%	5%	0%	0%	0%	-4%	-4%	4%	3%	5%
1953	Wet	6%	7%	11%	5%	0%	-7%	-17%	-2%	6%	6%	6%	7%
1954	Above Normal	9%	10%	13%	14%	6%	4%	1%	1%	6%	1%	2%	2%
1955	Dry	3%	3%	4%	7%	0%	0%	-1%	-1%	0%	0%	0%	0%
1956	Wet	0%	0%	1%	-14%	0%	0%	0%	0%	7%	6%	6%	7%
1957	Above Normal	7%	8%	9%	5%	0%	0%	0%	0%	170%	6%	6%	7%
1958	Wet	9%	10%	12%	28%	0%	0%	0%	0%	6%	6%	6%	7%
1959	Below Normal	7%	8%	9%	5%	0%	-2%	-2%	-2%	-29%	3%	3%	3%
1960	Dry	4%	5%	6%	10%	-1%	0%	0%	0%	5%	-1%	3%	-2%
1961	Dry	-2%	-2%	-1%	5%	4%	2%	0%	0%	0%	0%	1%	0%
1962	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	182%	6%	5%	6%
1963	Wet	8%	9%	11%	13%	0%	0%	0%	0%	7%	7%	7%	8%
1964	Dry	8%	9%	7%	7%	0%	0%	0%	0%	0%	0%	0%	0%
1965	Wet	0%	0%	0%	0%	0%	-1%	0%	0%	6%	8%	8%	8%
1966	Below Normal	9%	10%	12%	5%	-1%	0%	0%	0%	5%	5%	5%	5%
1967	Wet	7%	8%	10%	15%	0%	0%	0%	0%	0%	7%	6%	7%
1968	Below Normal	8%	2%	3%	5%	0%	0%	0%	2%	8%	9%	8%	9%
1969	Wet	8%	9%	10%	-24%	0%	0%	-1%	-1%	-1%	7%	6%	7%
1970	Wet	7%	10%	10%	0%	0%	0%	-3%	0%	7%	7%	7%	8%
1971	Wet	9%	9%	11%	5%	0%	0%	0%	0%	3%	4%	4%	5%
1972	Below Normal	6%	7%	8%	16%	0%	0%	0%	0%	0%	0%	0%	0%
1973	Above Normal	0%	0%	0%	1%	0%	0%	0%	0%	7%	7%	6%	7%
1974	Wet	8%	9%	10%	5%	0%	0%	0%	-1%	6%	6%	6%	6%
1975	Wet	7%	8%	9%	4%	-1%	-4%	1%	1%	8%	8%	8%	8%
1976	Critical	9%	10%	11%	7%	1%	0%	-1%	-1%	0%	-1%	0%	-1%
1977	Critical	-1%	-1%	-1%	0%	0%	0%	11%	0%	2%	0%	-2%	0%
1978	Above Normal	0%	0%	0%	0%	0%	-3%	0%	3%	11%	12%	11%	11%
1979	Below Normal	8%	9%	8%	-10%	-27%	-3%	13%	1%	8%	8%	8%	8%
1980	Above Normal	9%	10%	12%	-4%	0%	3%	-5%	-4%	3%	3%	3%	4%
1981	Dry	4%	5%	7%	8%	0%	13%	2%	2%	150%	5%	2%	7%
1982	Wet	9%	10%	13%	15%	1%	0%	0%	0%	7%	6%	6%	7%
1983	Wet	0%	8%	0%	0%	0%	0%	0%	0%	0%	0%	9%	9%
1984	Wet	0%	0%	0%	0%	0%	0%	0%	0%	7%	7%	7%	7%
1985	Dry	8%	9%	7%	6%	0%	0%	0%	0%	5%	5%	5%	5%
1986	Wet	6%	6%	7%	5%	0%	-23%	8%	0%	7%	7%	6%	7%
1987	Dry	8%	9%	10%	5%	0%	0%	-3%	-3%	1%	1%	1%	2%
1988	Critical	6%	9%	13%	18%	-1%	0%	0%	0%	0%	0%	0%	0%
1989	Dry	0%	0%	0%	0%	0%	0%	0%	0%	-1%	0%	-3%	1%
1990	Critical	1%	1%	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1991	Critical	0%	0%	0%	0%	0%	0%	0%	-2%	0%	1%	0%	0%
1992	Critical	1%	-7%	5%	4%	0%	0%	0%	0%	0%	0%	0%	-1%
1993	Above Normal	-1%	-11%	2%	0%	0%	0%	0%	0%	9%	7%	7%	7%
1994	Critical	9%	9%	11%	8%	-1%	0%	0%	0%	0%	0%	0%	0%
1995	Wet	1%	0%	0%	1%	0%	0%	0%	0%	7%	7%	6%	7%
1996	Wet	8%	8%	8%	-43%	-39%	-20%	-2%	-2%	5%	5%	4%	5%
1997	Wet	6%	6%	6%	0%	0%	0%	1%	0%	8%	8%	7%	8%
1998	Wet	9%	10%	11%	6%	0%	0%	0%	-4%	-4%	-4%	2%	4%
1999	Wet	13%	2%	6%	5%	0%	-6%	-6%	0%	7%	7%	7%	8%
2000	Above Normal	8%	9%	10%	6%	1%	-1%	0%	0%	7%	7%	7%	7%
2001	Dry	8%	9%	11%	8%	-7%	-2%	1%	1%	2%	2%	2%	2%
2002	Dry	3%	4%	4%	6%	0%	0%	0%	0%	0%	0%	0%	0%
2003	Above Normal	0%	5%	-3%	6%	3%	1%	0%	0%	58%	3%	3%	3%
Average		6%	12%	30%	7%	0%	-1%	1%	0%	7%	3%	1%	2%
Wet		5%	9%	9%	2%	-2%	-3%	-1%	-1%	4%	6%	6%	7%
Above Normal		4%	3%	6%	8%	0%	0%	0%	1%	19%	8%	7%	8%
Below Normal		8%	8%	9%	5%	-2%	-1%	4%	-3%	10%	7%	7%	8%
Dry		7%	30%	105%	14%	1%	-1%	0%	0%	8%	3%	3%	3%
Critical		8%	8%	11%	11%	3%	2%	4%	2%	0%	-15%	-28%	-24%

Percent Difference in Energy Use (GWh) At Pumping Plant at Del Valle: Alternative1_2005 minus Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September
1922	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1923	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1924	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1925	Dry	0%	0%	0%	0%	0%	-28%	>1,000%	0%	0%	0%	0%	0%
1926	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1927	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1928	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1929	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1930	Dry	0%	0%	0%	0%	0%	22%	0%	0%	0%	0%	0%	0%
1931	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1932	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1933	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1934	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1935	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1936	Below Normal	0%	0%	0%	0%	0%	1%	0%	0%	0%	0%	0%	0%
1937	Below Normal	0%	0%	0%	0%	0%	-28%	290%	0%	0%	0%	0%	0%
1938	Wet	0%	0%	0%	0%	0%	37%	-100%	0%	0%	0%	0%	0%
1939	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1940	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1941	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1942	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1943	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1944	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1945	Below Normal	0%	0%	0%	0%	0%	0%	-6%	0%	0%	0%	0%	0%
1946	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1947	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1948	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1949	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1950	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1951	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1952	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1953	Wet	0%	0%	57%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1954	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1955	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1956	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1957	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1958	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1959	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1960	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1961	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1962	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1963	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1964	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1965	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1966	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1967	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1968	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1969	Wet	0%	0%	0%	-100%	-87%	>1,000%	0%	0%	0%	0%	0%	0%
1970	Wet	0%	0%	0%	0%	0%	8%	-16%	0%	0%	0%	0%	0%
1971	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1972	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1973	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1974	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1975	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1976	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1977	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1978	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1979	Below Normal	0%	0%	0%	0%	0%	-25%	160%	0%	0%	0%	0%	0%
1980	Above Normal	0%	0%	0%	0%	0%	-25%	144%	0%	0%	0%	0%	0%
1981	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1982	Wet	0%	0%	0%	0%	0%	-1%	0%	0%	0%	0%	0%	0%
1983	Wet	0%	950%	-	0%	0%	0%	0%	0%	0%	0%	0%	0%
1984	Wet	0%	0%	0%	0%	0%	11%	0%	0%	0%	0%	0%	0%
1985	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1986	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1987	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1988	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1989	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1990	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1991	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1992	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1993	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1994	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1995	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1996	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1997	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1998	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1999	Wet	0%	-	-100%	0%	0%	1%	-3%	0%	0%	0%	0%	0%
2000	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
2001	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
2002	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
2003	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	Average	0%	12%	-1%	-1%	-1%	0%	6%	0%	0%	0%	0%	0%
	Wet	0%	37%	-2%	-4%	-3%	2%	-5%	0%	0%	0%	0%	0%
	Above Normal	0%	0%	0%	0%	0%	-2%	12%	0%	0%	0%	0%	0%
	Below Normal	0%	0%	0%	0%	0%	-4%	32%	0%	0%	0%	0%	0%
	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%

Percent Difference in Energy Use (GWh) At Pumping Plant at Edmonston: Alternative1_2005 minus Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September
1922	Above Normal	0%	0%	0%	43%	1%	0%	2%	3%	11%	11%	11%	11%
1923	Below Normal	12%	13%	14%	1%	0%	18%	33%	-52%	-89%	30%	29%	31%
1924	Critical	39%	41%	48%	61%	43%	20%	13%	15%	-24%	-92%	-92%	-93%
1925	Dry	125%	375%	652%	75%	28%	-42%	-3%	-15%	-13%	-13%	-13%	-13%
1926	Dry	-14%	-14%	-14%	15%	1%	7%	5%	10%	-4%	15%	14%	14%
1927	Wet	-40%	53%	54%	17%	-5%	0%	-2%	-2%	-14%	7%	7%	8%
1928	Above Normal	9%	9%	11%	5%	-2%	-3%	-2%	4%	-66%	22%	21%	21%
1929	Critical	16%	17%	14%	-15%	-17%	-6%	19%	11%	12%	-92%	-91%	-92%
1930	Dry	-31%	-7%	692%	73%	3%	2%	-1%	-1%	-60%	13%	11%	11%
1931	Critical	10%	9%	10%	10%	3%	4%	0%	0%	0%	0%	-93%	-94%
1932	Dry	-28%	100%	477%	21%	1%	4%	1%	0%	9%	9%	9%	10%
1933	Critical	16%	18%	23%	39%	4%	-2%	-4%	-2%	0%	-1%	-4%	-4%
1934	Critical	-9%	-10%	-3%	-1%	4%	7%	5%	6%	6%	6%	-50%	0%
1935	Below Normal	15%	7%	8%	8%	4%	4%	2%	3%	-63%	15%	16%	17%
1936	Below Normal	20%	21%	24%	21%	-2%	-24%	11%	0%	6%	6%	6%	7%
1937	Below Normal	7%	8%	9%	-1%	0%	8%	-1%	-1%	6%	6%	5%	6%
1938	Wet	7%	7%	-2%	0%	0%	-2%	2%	-6%	-6%	5%	1%	6%
1939	Dry	7%	8%	9%	5%	0%	-1%	-8%	1%	35%	6%	7%	6%
1940	Above Normal	8%	-14%	15%	21%	-13%	-2%	0%	0%	8%	6%	6%	7%
1941	Wet	8%	9%	6%	0%	0%	-4%	0%	0%	8%	8%	8%	8%
1942	Wet	9%	11%	6%	0%	0%	0%	0%	0%	7%	7%	7%	8%
1943	Wet	8%	9%	11%	1%	0%	2%	2%	0%	7%	7%	6%	7%
1944	Dry	8%	8%	10%	-6%	-13%	-7%	0%	0%	5%	5%	5%	6%
1945	Below Normal	8%	9%	12%	16%	0%	-8%	0%	0%	7%	7%	7%	7%
1946	Below Normal	8%	9%	8%	6%	0%	0%	0%	0%	8%	8%	7%	8%
1947	Dry	9%	10%	11%	7%	0%	0%	0%	0%	3%	3%	3%	3%
1948	Below Normal	3%	4%	4%	2%	-2%	-1%	0%	3%	0%	0%	0%	0%
1949	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1950	Below Normal	0%	0%	0%	-3%	-3%	-1%	0%	0%	85%	2%	2%	3%
1951	Above Normal	4%	4%	-1%	0%	0%	0%	0%	0%	7%	7%	7%	7%
1952	Wet	8%	9%	10%	5%	0%	0%	0%	-4%	-4%	4%	3%	5%
1953	Wet	6%	7%	11%	5%	0%	-7%	-17%	-2%	6%	6%	6%	7%
1954	Above Normal	9%	10%	13%	14%	6%	4%	1%	1%	6%	1%	2%	2%
1955	Dry	3%	3%	4%	7%	0%	0%	-1%	-1%	0%	0%	0%	0%
1956	Wet	0%	0%	1%	-14%	0%	0%	0%	0%	7%	6%	6%	7%
1957	Above Normal	7%	8%	9%	5%	0%	0%	0%	0%	170%	6%	6%	7%
1958	Wet	9%	10%	12%	28%	0%	0%	0%	0%	6%	6%	6%	7%
1959	Below Normal	7%	8%	9%	5%	0%	-2%	-2%	-2%	-29%	3%	3%	3%
1960	Dry	4%	5%	6%	10%	-1%	0%	0%	0%	5%	-1%	3%	-2%
1961	Dry	-2%	-2%	-1%	5%	4%	2%	0%	0%	0%	0%	1%	0%
1962	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	182%	6%	5%	6%
1963	Wet	8%	9%	11%	13%	0%	0%	0%	0%	7%	7%	7%	8%
1964	Dry	8%	9%	7%	7%	0%	0%	0%	0%	0%	0%	0%	0%
1965	Wet	0%	0%	0%	0%	0%	-1%	0%	0%	6%	8%	8%	8%
1966	Below Normal	9%	10%	12%	5%	-1%	0%	0%	0%	5%	5%	5%	5%
1967	Wet	7%	8%	10%	15%	0%	0%	0%	0%	0%	7%	6%	7%
1968	Below Normal	8%	2%	3%	5%	0%	0%	0%	2%	8%	9%	8%	9%
1969	Wet	8%	9%	10%	-24%	0%	0%	-1%	-1%	-1%	7%	6%	7%
1970	Wet	7%	10%	10%	0%	0%	0%	-3%	0%	7%	7%	7%	8%
1971	Wet	9%	9%	11%	5%	0%	0%	0%	0%	3%	4%	4%	5%
1972	Below Normal	6%	7%	8%	16%	0%	0%	0%	0%	0%	0%	0%	0%
1973	Above Normal	0%	0%	0%	1%	0%	0%	0%	0%	7%	7%	6%	7%
1974	Wet	8%	9%	10%	5%	0%	0%	0%	-1%	6%	6%	6%	6%
1975	Wet	7%	8%	9%	4%	-1%	-4%	1%	1%	8%	8%	8%	8%
1976	Critical	9%	10%	11%	7%	1%	0%	-1%	-1%	0%	-1%	0%	-1%
1977	Critical	-1%	-1%	-1%	0%	0%	0%	11%	0%	2%	0%	-2%	0%
1978	Above Normal	0%	0%	0%	0%	0%	-3%	0%	3%	11%	12%	11%	11%
1979	Below Normal	8%	9%	8%	-10%	-27%	-3%	13%	1%	8%	8%	8%	8%
1980	Above Normal	9%	10%	12%	-4%	0%	3%	-5%	-4%	3%	3%	3%	4%
1981	Dry	4%	5%	7%	8%	0%	13%	2%	2%	150%	5%	2%	7%
1982	Wet	9%	10%	13%	15%	1%	0%	0%	0%	7%	7%	6%	7%
1983	Wet	0%	8%	0%	0%	0%	0%	0%	0%	0%	0%	9%	9%
1984	Wet	0%	0%	0%	0%	0%	0%	0%	0%	7%	7%	7%	7%
1985	Dry	8%	9%	7%	6%	0%	0%	0%	0%	5%	5%	5%	5%
1986	Wet	6%	6%	7%	5%	0%	-23%	8%	0%	7%	7%	6%	7%
1987	Dry	8%	9%	10%	5%	0%	0%	-3%	-3%	1%	1%	1%	2%
1988	Critical	6%	9%	13%	18%	-1%	0%	0%	0%	0%	0%	0%	0%
1989	Dry	0%	0%	0%	0%	0%	0%	0%	0%	-1%	0%	-3%	1%
1990	Critical	1%	1%	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1991	Critical	0%	0%	0%	0%	0%	0%	0%	-2%	0%	1%	0%	0%
1992	Critical	1%	-7%	5%	4%	0%	0%	0%	0%	0%	0%	0%	-1%
1993	Above Normal	-1%	-11%	2%	0%	0%	0%	0%	0%	9%	7%	7%	7%
1994	Critical	9%	9%	11%	8%	-1%	0%	0%	0%	0%	0%	0%	0%
1995	Wet	1%	0%	0%	1%	0%	0%	0%	0%	7%	7%	6%	7%
1996	Wet	8%	8%	8%	-43%	-39%	-20%	-2%	-2%	5%	5%	4%	5%
1997	Wet	6%	6%	6%	0%	0%	0%	1%	0%	8%	8%	7%	8%
1998	Wet	9%	10%	11%	6%	0%	0%	0%	-4%	-4%	-4%	2%	4%
1999	Wet	13%	2%	6%	5%	0%	-6%	-6%	0%	7%	7%	7%	8%
2000	Above Normal	8%	9%	10%	6%	1%	-1%	0%	0%	7%	7%	7%	7%
2001	Dry	8%	9%	11%	8%	-7%	-2%	1%	1%	2%	2%	2%	2%
2002	Dry	3%	4%	4%	6%	0%	0%	0%	0%	0%	0%	0%	0%
2003	Above Normal	0%	5%	-3%	6%	3%	1%	0%	0%	58%	3%	3%	3%
Average		6%	12%	30%	7%	0%	-1%	1%	0%	7%	3%	1%	2%
Wet		5%	9%	9%	2%	-2%	-3%	-1%	-1%	4%	6%	6%	7%
Above Normal		4%	3%	6%	8%	0%	0%	0%	1%	19%	8%	7%	8%
Below Normal		8%	8%	9%	5%	-2%	-1%	4%	-3%	10%	7%	7%	8%
Dry		7%	30%	105%	14%	1%	-1%	0%	0%	8%	3%	3%	3%
Critical		8%	8%	11%	11%	3%	2%	4%	2%	0%	-15%	-28%	-24%

Percent Difference in Energy Use (GWh) At Pumping Plant at Las Perillas: Alternative1_2005 minus Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September
1922	Above Normal	0%	0%	0%	26%	17%	15%	17%	19%	19%	20%	20%	20%
1923	Below Normal	19%	21%	21%	13%	13%	12%	0%	-5%	-4%	-5%	-4%	-5%
1924	Critical	5%	0%	0%	74%	67%	28%	19%	15%	16%	17%	-90%	79%
1925	Dry	117%	113%	88%	33%	33%	-37%	-17%	-16%	-16%	-16%	-16%	-15%
1926	Dry	-16%	-16%	-17%	44%	9%	10%	14%	11%	11%	10%	10%	11%
1927	Wet	11%	11%	12%	0%	-13%	-2%	-3%	-3%	-3%	-2%	-2%	-1%
1928	Above Normal	-2%	-3%	-3%	-3%	-3%	-3%	1%	6%	7%	7%	5%	7%
1929	Critical	-4%	-3%	0%	-21%	-20%	-7%	27%	17%	14%	-7%	-11%	-31%
1930	Dry	94%	100%	87%	25%	-9%	0%	-2%	-3%	-2%	-2%	-1%	-2%
1931	Critical	-3%	0%	0%	25%	11%	0%	0%	0%	0%	0%	0%	0%
1932	Dry	0%	0%	0%	0%	0%	0%	2%	4%	1%	1%	1%	3%
1933	Critical	0%	0%	0%	11%	0%	-6%	-3%	-13%	-4%	-4%	-4%	-9%
1934	Critical	-8%	-5%	0%	11%	13%	7%	6%	7%	6%	7%	-16%	-36%
1935	Below Normal	52%	63%	60%	11%	0%	5%	2%	3%	3%	3%	3%	2%
1936	Below Normal	2%	0%	3%	-10%	-6%	-19%	1%	0%	0%	0%	-1%	0%
1937	Below Normal	0%	0%	0%	-2%	-2%	32%	1%	0%	1%	0%	0%	1%
1938	Wet	0%	0%	0%	-9%	8%	24%	0%	-6%	-5%	-5%	-5%	0%
1939	Dry	-1%	0%	0%	0%	-1%	-2%	0%	0%	0%	0%	0%	0%
1940	Above Normal	2%	0%	0%	-17%	-17%	0%	0%	0%	0%	0%	0%	0%
1941	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1942	Wet	0%	0%	0%	0%	0%	0%	-1%	-2%	-2%	-2%	-1%	-1%
1943	Wet	-2%	-3%	-3%	0%	-2%	-2%	-1%	-2%	-2%	-1%	-2%	-1%
1944	Dry	-1%	-2%	0%	-20%	-20%	-13%	0%	-1%	-1%	0%	0%	-2%
1945	Below Normal	0%	0%	0%	0%	0%	0%	0%	1%	0%	0%	1%	0%
1946	Below Normal	0%	0%	0%	0%	0%	0%	2%	1%	1%	0%	0%	1%
1947	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	1%	0%	0%
1948	Below Normal	0%	0%	0%	-3%	-3%	0%	0%	0%	0%	1%	0%	0%
1949	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1950	Below Normal	0%	0%	0%	-5%	-6%	0%	0%	0%	0%	0%	0%	0%
1951	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1952	Wet	0%	0%	0%	0%	0%	0%	0%	-6%	-6%	-6%	-6%	-6%
1953	Wet	-7%	-11%	-8%	-6%	-8%	-3%	0%	-1%	-1%	-2%	-1%	-1%
1954	Above Normal	0%	0%	3%	7%	8%	5%	0%	1%	1%	1%	1%	1%
1955	Dry	2%	3%	0%	0%	0%	0%	0%	-1%	-1%	-1%	-1%	-1%
1956	Wet	0%	0%	0%	-3%	0%	0%	0%	0%	0%	0%	0%	0%
1957	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	-21%	4%	4%	6%
1958	Wet	11%	15%	13%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1959	Below Normal	0%	0%	0%	0%	-1%	-2%	-3%	-3%	-3%	-2%	-3%	-2%
1960	Dry	-2%	-3%	-4%	0%	0%	6%	0%	0%	0%	-1%	0%	0%
1961	Dry	0%	0%	0%	8%	7%	0%	0%	0%	0%	1%	0%	0%
1962	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1963	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1964	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1965	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	1%
1966	Below Normal	0%	0%	0%	-1%	0%	0%	0%	0%	1%	0%	0%	0%
1967	Wet	0%	0%	0%	0%	0%	0%	0%	-1%	0%	-1%	0%	0%
1968	Below Normal	0%	0%	0%	-1%	0%	-2%	0%	3%	3%	2%	2%	4%
1969	Wet	-2%	-3%	0%	-13%	32%	0%	0%	0%	0%	0%	-1%	0%
1970	Wet	10%	0%	0%	0%	10%	-3%	0%	1%	0%	1%	0%	0%
1971	Wet	2%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1972	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	-1%	0%	0%	0%
1973	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1974	Wet	0%	0%	0%	0%	0%	0%	-4%	-4%	-4%	-4%	-4%	-3%
1975	Wet	-3%	-5%	-5%	-4%	-3%	-2%	0%	1%	1%	1%	1%	0%
1976	Critical	0%	3%	0%	0%	0%	0%	0%	0%	-1%	-1%	0%	0%
1977	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	-16%
1978	Above Normal	-38%	58%	55%	0%	0%	-3%	2%	3%	4%	4%	2%	4%
1979	Below Normal	-4%	-3%	-3%	-20%	-18%	0%	0%	-2%	-2%	-2%	-2%	-2%
1980	Above Normal	-2%	-2%	-3%	-3%	0%	36%	-8%	-4%	-4%	-4%	-4%	-3%
1981	Dry	-4%	-6%	-7%	-7%	-6%	0%	3%	3%	2%	3%	3%	3%
1982	Wet	3%	3%	4%	0%	0%	-2%	0%	0%	0%	0%	0%	0%
1983	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1984	Wet	0%	0%	0%	0%	-1%	0%	0%	0%	0%	0%	0%	0%
1985	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1986	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	1%	0%
1987	Dry	0%	0%	0%	0%	0%	0%	-3%	-5%	-4%	-4%	-4%	-5%
1988	Critical	0%	-5%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1989	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1990	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1991	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1992	Critical	-6%	0%	0%	0%	0%	0%	0%	0%	0%	-18%	0%	6%
1993	Above Normal	8%	11%	11%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1994	Critical	0%	0%	0%	0%	-3%	0%	0%	0%	0%	0%	0%	0%
1995	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1996	Wet	0%	0%	0%	-45%	-40%	-23%	-3%	-3%	-3%	-4%	-4%	-4%
1997	Wet	-3%	-3%	-3%	-1%	-1%	0%	0%	0%	0%	0%	0%	0%
1998	Wet	0%	0%	0%	0%	0%	0%	0%	-12%	-11%	-12%	-11%	-12%
1999	Wet	-1%	-10%	-11%	-7%	-5%	-13%	0%	0%	1%	0%	0%	0%
2000	Above Normal	0%	0%	0%	0%	0%	0%	0%	1%	1%	1%	1%	0%
2001	Dry	0%	-3%	0%	-11%	-12%	0%	0%	0%	0%	1%	1%	0%
2002	Dry	0%	0%	0%	0%	-5%	0%	0%	0%	-1%	0%	0%	-1%
2003	Above Normal	0%	0%	0%	4%	0%	4%	0%	0%	0%	0%	0%	0%
Average		3%	4%	4%	1%	0%	0%	1%	0%	0%	0%	-2%	0%
Wet		1%	0%	0%	-3%	-1%	-1%	0%	-1%	-1%	-1%	-1%	-1%
Above Normal		-3%	5%	5%	1%	0%	5%	1%	2%	1%	3%	2%	3%
Below Normal		5%	6%	6%	-1%	-2%	2%	0%	0%	0%	0%	0%	0%
Dry		10%	10%	8%	4%	0%	-2%	0%	0%	-1%	0%	0%	-1%
Critical		-1%	-1%	0%	8%	6%	2%	4%	2%	3%	0%	-10%	-1%

Difference in Energy Use (GWh) At Pumping Plant at Oso: Alternative1_2005 minus Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Average
1922	Above Normal	0.00	0.00	0.00	2.83	(0.06)	(0.13)	(0.08)	0.04	1.34	1.37	1.36	1.30	0.66
1923	Below Normal	1.22	1.32	1.29	(2.11)	(7.04)	1.29	6.71	(1.78)	(15.72)	6.17	6.29	6.03	0.31
1924	Critical	6.19	5.82	5.49	4.08	2.20	0.89	1.03	1.15	1.28	(9.18)	(6.77)	(4.90)	0.61
1925	Dry	11.11	13.21	13.98	3.15	0.67	(10.00)	1.61	(2.79)	(2.48)	(3.04)	(2.75)	(2.18)	1.71
1926	Dry	(1.92)	(1.80)	(1.29)	1.37	0.14	0.51	1.47	1.74	1.95	3.01	2.77	2.29	0.85
1927	Wet	2.12	5.80	4.46	1.20	(0.83)	(0.24)	(0.51)	(0.49)	0.78	1.54	1.54	1.54	1.41
1928	Above Normal	1.56	1.52	1.50	1.25	(0.56)	(0.58)	(0.50)	0.19	(9.89)	4.50	3.77	2.73	0.46
1929	Critical	2.17	2.07	1.18	(1.06)	(1.72)	(0.19)	1.26	0.82	0.90	(8.31)	(6.13)	(4.43)	(1.12)
1930	Dry	1.70	3.32	16.66	2.97	(0.04)	(0.07)	(0.31)	(0.31)	(2.20)	1.97	1.48	1.08	2.19
1931	Critical	0.69	0.52	0.43	0.59	0.06	0.07	(0.02)	(0.02)	(0.02)	(0.03)	(7.87)	(5.69)	(0.94)
1932	Dry	3.66	7.95	10.23	1.44	(0.06)	0.11	0.28	0.28	1.54	1.60	1.76	1.74	2.54
1933	Critical	1.86	1.87	1.72	1.76	0.08	(0.20)	(0.47)	(0.71)	(0.39)	(0.45)	(0.67)	(0.61)	0.32
1934	Critical	(0.78)	(0.73)	0.21	(0.31)	0.10	0.21	0.47	0.53	0.59	0.71	0.00	0.00	0.08
1935	Below Normal	0.60	0.56	0.44	0.30	0.05	0.12	0.44	0.50	(15.50)	3.39	4.04	3.51	(0.13)
1936	Below Normal	3.33	3.17	2.71	0.94	(0.03)	(7.31)	3.93	(0.05)	1.24	1.23	1.23	1.24	0.97
1937	Below Normal	1.23	1.24	1.25	(0.11)	(0.21)	0.00	(0.31)	(0.29)	1.00	0.98	0.98	0.99	0.56
1938	Wet	0.98	1.00	(0.26)	4.93	1.08	0.73	0.93	(0.32)	(0.33)	0.95	0.95	0.96	0.97
1939	Dry	0.95	0.98	1.01	1.82	0.00	0.00	(1.73)	0.35	4.92	1.29	1.35	1.39	1.03
1940	Above Normal	1.44	1.42	3.34	0.84	(0.36)	(0.15)	0.00	(0.01)	1.26	1.27	1.26	1.27	0.97
1941	Wet	1.26	1.27	0.60	0.01	0.00	0.00	0.00	0.00	1.29	1.29	1.29	1.29	0.69
1942	Wet	1.29	1.29	0.63	(3.55)	(0.12)	0.00	0.06	(0.02)	1.27	1.27	1.27	1.28	0.39
1943	Wet	1.28	1.27	1.27	(0.45)	(1.22)	0.00	0.58	0.05	1.34	1.35	1.35	1.35	0.68
1944	Dry	1.36	1.34	1.34	0.45	(0.76)	(0.22)	(0.09)	(0.09)	0.76	0.74	0.71	0.71	0.52
1945	Below Normal	0.69	0.68	0.72	0.80	(0.01)	(0.26)	0.03	0.03	1.32	1.32	1.32	1.32	0.66
1946	Below Normal	1.33	1.32	1.31	1.29	0.00	0.07	0.08	0.08	1.37	1.39	1.38	1.38	0.92
1947	Dry	1.38	1.37	1.37	1.40	0.00	(0.08)	(0.04)	0.00	0.52	0.58	0.53	0.49	0.63
1948	Below Normal	0.44	0.46	0.41	0.34	(0.16)	(0.06)	0.01	0.05	0.00	(0.01)	0.00	(0.01)	0.12
1949	Dry	(0.01)	(0.01)	0.00	(0.01)	0.01	(0.02)	(0.01)	0.00	0.03	0.05	0.04	0.02	0.01
1950	Below Normal	0.01	0.01	0.00	(0.09)	(0.11)	(0.04)	0.00	(0.01)	0.56	0.55	0.55	0.56	0.17
1951	Above Normal	0.55	0.55	(0.47)	0.00	(5.14)	0.00	0.00	0.00	1.30	1.29	1.29	1.29	0.06
1952	Wet	1.29	1.29	1.29	1.71	0.00	(0.01)	0.00	(0.24)	(0.26)	1.00	1.00	1.08	0.68
1953	Wet	1.14	1.08	1.11	(0.59)	3.51	0.00	(4.48)	(0.24)	1.18	1.02	1.15	1.30	0.52
1954	Above Normal	1.42	1.39	1.52	1.75	0.69	0.81	0.11	0.13	0.47	0.34	0.38	0.38	0.78
1955	Dry	0.37	0.38	0.36	0.44	0.00	(0.03)	(0.12)	(0.12)	0.01	(0.02)	(0.01)	0.03	0.11
1956	Wet	0.03	0.04	0.06	(0.02)	0.00	0.00	0.01	0.02	1.31	1.31	1.31	1.31	0.45
1957	Above Normal	1.31	1.30	1.31	1.30	(0.01)	(0.01)	0.01	0.01	1.25	1.26	1.25	1.25	0.85
1958	Wet	1.25	1.25	1.25	1.25	0.00	0.00	0.00	0.00	1.30	1.29	1.29	1.29	0.85
1959	Below Normal	1.29	1.29	1.29	1.37	3.82	(1.01)	(0.39)	(0.43)	(7.20)	0.82	0.79	0.75	0.20
1960	Dry	0.75	0.72	0.69	0.57	(0.02)	0.03	0.05	0.00	0.01	(0.06)	(0.01)	(0.19)	0.21
1961	Dry	(0.14)	(0.12)	(0.04)	0.20	0.17	0.06	0.04	0.03	0.03	0.05	0.04	(0.02)	0.02
1962	Below Normal	(0.48)	0.17	0.20	0.00	0.00	0.00	0.00	0.00	1.25	1.25	1.25	1.25	0.41
1963	Wet	1.25	1.25	1.25	1.25	0.00	0.00	0.00	0.00	1.29	1.30	1.29	1.29	0.85
1964	Dry	1.29	1.29	1.29	1.29	(0.03)	0.09	(0.01)	(0.01)	0.01	0.01	0.01	0.01	0.44
1965	Wet	0.01	0.01	0.01	0.07	0.01	(0.22)	0.01	0.03	1.31	1.41	1.39	1.37	0.45
1966	Below Normal	1.35	1.35	1.32	1.20	(0.10)	(0.06)	0.00	0.00	0.96	0.97	0.97	0.97	0.74
1967	Wet	0.97	0.96	0.96	0.92	(0.01)	0.00	0.01	(0.01)	0.00	1.29	1.28	1.29	0.64
1968	Below Normal	1.29	0.32	(0.83)	(5.18)	0.04	0.00	(0.08)	0.07	1.24	1.55	1.31	1.03	0.06
1969	Wet	0.81	0.86	0.65	(7.33)	(2.66)	0.00	(0.13)	(0.12)	(0.12)	1.17	1.16	1.17	(0.38)
1970	Wet	1.17	1.18	1.19	0.65	(1.19)	0.00	(1.24)	0.08	1.38	1.38	1.39	1.38	0.61
1971	Wet	1.38	1.37	1.37	1.33	6.80	0.06	(0.03)	(0.03)	0.76	0.81	0.81	0.80	1.29
1972	Below Normal	0.81	0.80	0.80	0.82	0.03	0.01	(0.01)	(0.01)	0.02	0.01	0.02	0.01	0.28
1973	Above Normal	0.02	0.02	0.02	0.04	0.01	0.01	0.00	0.00	1.29	1.30	1.30	1.29	0.44
1974	Wet	1.29	1.30	1.29	(2.77)	0.00	0.00	0.00	(0.06)	1.23	1.22	1.22	1.24	0.50
1975	Wet	1.25	1.24	1.25	1.60	0.69	(0.96)	0.22	0.21	1.50	1.52	1.52	1.50	0.96
1976	Critical	1.51	1.49	1.48	1.45	0.06	(0.02)	(0.09)	(0.09)	(0.02)	(0.14)	(0.12)	(0.13)	0.45
1977	Critical	(0.13)	(0.12)	(0.09)	(0.01)	(0.01)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.03)
1978	Above Normal	0.00	0.56	0.00	0.00	0.00	(0.54)	(0.14)	0.29	1.53	2.13	1.66	1.12	0.55
1979	Below Normal	0.73	0.79	0.35	(0.86)	(8.95)	(5.03)	4.49	0.24	1.53	1.55	1.55	1.54	(0.17)
1980	Above Normal	1.56	1.53	1.51	(1.41)	(2.55)	0.00	(0.50)	(0.46)	0.81	0.78	0.77	0.84	0.24
1981	Dry	0.87	0.85	0.91	0.76	(1.20)	1.47	0.36	0.42	8.94	1.06	1.09	1.39	1.41
1982	Wet	1.37	1.37	1.36	1.30	0.03	0.00	0.01	0.00	1.29	1.29	1.30	1.30	0.89
1983	Wet	(1.51)	2.81	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.29	1.29	0.32
1984	Wet	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.01	1.29	1.29	1.29	1.29	0.43
1985	Dry	1.30	1.29	1.29	1.29	0.00	0.00	0.00	0.00	0.88	0.88	0.89	0.89	0.73
1986	Wet	0.89	0.89	0.88	0.88	0.00	(2.89)	2.88	0.00	1.29	1.30	1.30	1.30	0.73
1987	Dry	1.30	1.29	1.29	1.29	0.00	0.00	(0.30)	(0.34)	0.23	0.15	0.27	0.36	0.46
1988	Critical	0.46	0.48	0.60	0.51	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.17
1989	Dry	0.00	0.00	0.00	(0.01)	0.00	0.00	(0.02)	(0.02)	(0.02)	0.00	0.00	0.22	0.01
1990	Critical	0.20	0.18	0.14	0.00	0.00	0.00	0.01	0.00	0.00	0.01	0.00	0.00	0.05
1991	Critical	0.00	0.00	0.00	0.00	0.00	0.00	(0.01)	0.00	0.03	0.06	0.04	0.02	0.01
1992	Critical	0.01	0.00	0.00	0.20	0.00	(0.01)	0.00	0.00	0.00	0.00	0.00	(0.01)	0.02
1993	Above Normal	0.10	0.00	0.28	0.00	(0.01)	(0.08)	0.00	0.02	1.30	1.54	1.51	1.47	0.51
1994	Critical	1.45	1.44	1.40	1.23	(0.06)	(0.02)	0.00	0.00	0.02	0.02	(0.09)	0.03	0.45
1995	Wet	0.44	0.55	0.01	0.02	0.00	0.00	0.00	0.00	1.29	1.30	1.30	1.29	0.52
1996	Wet	1.29	1.30	1.14	(5.94)	(5.04)	(3.01)	(0.41)	(0.39)	0.88	0.86	0.86	0.89	(0.63)
1997	Wet	0.89	0.91	0.77	1.59	(0.09)	0.00	0.16	0.06	1.35	1.36	1.36	1.35	0.81
1998	Wet	1.35	1.35	1.34	1.31	(7.41)	1.34	0.00	(0.25)	(0.27)	(0.30)	0.99	1.06	0.04
1999	Wet	1.82	0.37	0.41	(0.65)	(3.68)	0.00	(2.50)	0.03	1.34	1.34	1.33	1.33	0.09
2000	Above Normal	1.33	1.33	1.33	1.34	0.08	(0.27)	(0.07)	0.02	1.28	1.38	1.29	1.19	0.85
2001	Dry	1.12	1.14	1.06	0.87	(0.35)	(0.08)	0.07	0.08	0.21	0.23	0.20	0.18	0.39
2002	Dry	0.16	0.16	0.13	0.13	0.04	(0.01)	(0.07)	(0.06)	(0.04)	(0.04)	(0.05)	(0.05)	0.03
2003	Above Normal	(0.05)	(0.04)	(0.11)	0.19	0.17	0.06	0.00	0.00	0.63	0.63	0.62	0.63	0.23
Average		1.06	1.24	1.32	0.41	(0.38)	(0.32)	0.15	(0.03)	0.20	0.73	0.70	0.74	0.49
Wet		0.97	1.23	0.93	(0.05)	(0.39)	(0.20)	(0.17)	(0.06)	0.91	1.14	1.24	1.25	0.57
Above Normal		0.77	0.80	0.85	0.68	(0.65)	(0.07)	(0.10)	0.02	0.21	1.48	1.37	1.23	0.55
Below Normal		0.99	0.96	0.80	(0.09)	(0.91)	(0.88)	1.06	(0.11)	(2.00)	1.51	1.55	1.47	0.36
Dry		1.40	1.85	2.79	1.08	(0.08)	(0.46)	0.07	(0.05)	0.85	0.47	0.46	0.46	0.74
Critical		1.14	1.09	1.05	0.70	0.06	0.06	0.18	0.14	0.20	(1.44)	(1.80)	(1.31)	0.01

Percent Difference in Energy Use (GWh) At Pumping Plant at Oso: Alternative1_2005 minus Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September
1922	Above Normal	0%	0%	0%	64%	-1%	-1%	0%	0%	7%	7%	7%	7%
1923	Below Normal	8%	10%	11%	-10%	-29%	5%	36%	-10%	-88%	30%	32%	37%
1924	Critical	51%	52%	75%	63%	37%	13%	11%	13%	15%	-90%	-88%	-87%
1925	Dry	>1,000%	>1,000%	>1,000%	198%	20%	-58%	10%	-14%	-13%	-13%	-13%	-13%
1926	Dry	-15%	-16%	-18%	30%	3%	6%	12%	10%	12%	15%	15%	15%
1927	Wet	20%	61%	78%	38%	-15%	-1%	-2%	-2%	4%	7%	7%	8%
1928	Above Normal	9%	10%	11%	9%	-4%	-5%	-2%	1%	-49%	21%	17%	14%
1929	Critical	13%	13%	9%	-8%	-15%	-2%	15%	10%	12%	-89%	-87%	-85%
1930	Dry	370%	>1,000%	>1,000%	245%	-1%	-1%	-2%	-2%	-16%	12%	11%	10%
1931	Critical	12%	11%	21%	15%	2%	1%	0%	0%	0%	0%	-89%	-88%
1932	Dry	318%	>1,000%	>1,000%	53%	-2%	1%	2%	2%	11%	9%	11%	14%
1933	Critical	23%	26%	44%	42%	2%	-3%	-4%	-6%	-3%	-3%	-6%	-7%
1934	Critical	-27%	-38%	210%	-9%	3%	3%	4%	5%	6%	6%	0%	0%
1935	Below Normal	8%	7%	9%	8%	1%	2%	2%	2%	-80%	14%	18%	19%
1936	Below Normal	24%	25%	33%	20%	-1%	-27%	21%	0%	6%	5%	5%	6%
1937	Below Normal	7%	7%	9%	-1%	-1%	0%	-2%	-1%	5%	5%	5%	5%
1938	Wet	6%	7%	-2%	28%	5%	3%	6%	-2%	-2%	5%	5%	6%
1939	Dry	7%	7%	8%	10%	0%	0%	-8%	2%	34%	5%	6%	7%
1940	Above Normal	9%	9%	21%	20%	-9%	-1%	0%	0%	6%	5%	6%	7%
1941	Wet	9%	10%	8%	0%	0%	0%	0%	0%	8%	8%	7%	8%
1942	Wet	10%	11%	7%	-15%	-1%	0%	0%	0%	7%	7%	7%	7%
1943	Wet	9%	9%	11%	-3%	-6%	0%	3%	0%	7%	6%	6%	7%
1944	Dry	8%	9%	10%	3%	-6%	-2%	-1%	-1%	5%	4%	5%	6%
1945	Below Normal	9%	10%	21%	15%	0%	-1%	0%	0%	7%	6%	6%	7%
1946	Below Normal	8%	8%	6%	9%	0%	0%	0%	0%	7%	7%	7%	7%
1947	Dry	9%	9%	11%	9%	0%	-1%	0%	0%	3%	3%	2%	3%
1948	Below Normal	3%	3%	4%	4%	-2%	-1%	0%	0%	0%	0%	0%	0%
1949	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1950	Below Normal	0%	0%	0%	-2%	-2%	-1%	0%	0%	69%	2%	2%	3%
1951	Above Normal	4%	4%	-4%	0%	-21%	0%	0%	0%	7%	6%	6%	7%
1952	Wet	8%	9%	10%	9%	0%	0%	0%	-2%	-2%	6%	6%	7%
1953	Wet	10%	10%	6%	-3%	23%	0%	-17%	-1%	7%	5%	6%	8%
1954	Above Normal	11%	11%	17%	15%	6%	5%	1%	1%	2%	1%	2%	2%
1955	Dry	3%	3%	5%	10%	0%	0%	-1%	-1%	0%	0%	0%	0%
1956	Wet	0%	0%	1%	0%	0%	0%	0%	0%	6%	6%	6%	6%
1957	Above Normal	7%	8%	9%	8%	0%	0%	0%	0%	140%	5%	6%	7%
1958	Wet	10%	10%	16%	68%	0%	0%	0%	0%	6%	6%	6%	6%
1959	Below Normal	7%	8%	10%	7%	21%	-4%	-2%	-2%	-42%	3%	4%	4%
1960	Dry	6%	6%	9%	13%	-1%	0%	0%	0%	0%	0%	0%	-1%
1961	Dry	-1%	-1%	0%	4%	3%	1%	0%	0%	0%	0%	0%	0%
1962	Below Normal	-11%	1%	2%	0%	0%	0%	0%	0%	149%	5%	5%	7%
1963	Wet	9%	10%	15%	13%	0%	0%	0%	0%	7%	7%	6%	7%
1964	Dry	8%	9%	6%	13%	0%	1%	0%	0%	0%	0%	0%	0%
1965	Wet	0%	0%	0%	0%	0%	-1%	0%	0%	7%	7%	7%	8%
1966	Below Normal	9%	10%	12%	6%	0%	0%	0%	0%	5%	4%	5%	6%
1967	Wet	8%	9%	13%	26%	0%	0%	0%	0%	0%	6%	6%	7%
1968	Below Normal	8%	2%	-6%	-24%	0%	0%	0%	0%	7%	8%	7%	6%
1969	Wet	6%	7%	8%	-39%	-11%	0%	-1%	-1%	-1%	6%	6%	7%
1970	Wet	7%	11%	11%	4%	-6%	0%	-6%	0%	7%	7%	7%	7%
1971	Wet	8%	9%	11%	6%	40%	0%	0%	0%	4%	4%	4%	5%
1972	Below Normal	7%	8%	12%	38%	0%	0%	0%	0%	0%	0%	0%	0%
1973	Above Normal	0%	0%	0%	1%	0%	0%	0%	0%	6%	6%	6%	6%
1974	Wet	7%	8%	10%	-13%	0%	0%	0%	0%	6%	6%	6%	6%
1975	Wet	8%	8%	10%	9%	4%	-4%	1%	1%	8%	7%	7%	8%
1976	Critical	9%	10%	12%	10%	0%	0%	0%	0%	0%	-1%	-1%	-1%
1977	Critical	-1%	-1%	-1%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1978	Above Normal	0%	108%	0%	0%	0%	-3%	-1%	2%	8%	11%	9%	6%
1979	Below Normal	5%	6%	3%	-6%	-44%	-19%	26%	1%	8%	8%	8%	8%
1980	Above Normal	10%	11%	13%	-9%	-11%	0%	-3%	-3%	5%	4%	4%	5%
1981	Dry	6%	7%	9%	4%	-7%	8%	2%	2%	339%	4%	5%	7%
1982	Wet	9%	10%	16%	15%	0%	0%	0%	0%	7%	6%	6%	7%
1983	Wet	-8%	16%	0%	0%	0%	0%	0%	0%	0%	0%	12%	9%
1984	Wet	0%	0%	0%	0%	0%	0%	0%	0%	6%	6%	6%	7%
1985	Dry	8%	8%	6%	10%	0%	0%	0%	0%	5%	4%	4%	5%
1986	Wet	6%	6%	7%	7%	0%	-11%	16%	0%	7%	6%	6%	7%
1987	Dry	8%	8%	10%	8%	0%	0%	-3%	-3%	2%	1%	3%	5%
1988	Critical	30%	76%	600%	20%	0%	0%	0%	0%	0%	0%	0%	0%
1989	Dry	0%	0%	0%	-1%	0%	0%	0%	0%	0%	0%	0%	1%
1990	Critical	1%	1%	2%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1991	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	1%	1%	0%
1992	Critical	1%	0%	0%	13%	0%	0%	0%	0%	0%	0%	0%	0%
1993	Above Normal	2%	0%	5%	0%	0%	0%	0%	0%	7%	7%	7%	8%
1994	Critical	10%	11%	14%	11%	-1%	0%	0%	0%	0%	0%	-1%	0%
1995	Wet	7%	3%	0%	1%	0%	0%	0%	0%	6%	6%	6%	6%
1996	Wet	7%	8%	8%	-31%	-24%	-13%	-2%	-2%	4%	4%	4%	4%
1997	Wet	5%	6%	6%	8%	0%	0%	1%	0%	7%	7%	7%	8%
1998	Wet	9%	10%	12%	8%	-31%	5%	0%	-1%	-2%	-2%	5%	6%
1999	Wet	11%	2%	3%	-4%	-16%	0%	-12%	0%	7%	6%	6%	7%
2000	Above Normal	8%	9%	11%	9%	1%	-2%	0%	0%	7%	6%	6%	7%
2001	Dry	8%	9%	13%	14%	-6%	-1%	1%	1%	2%	2%	2%	2%
2002	Dry	10%	23%	163%	186%	1%	0%	0%	0%	0%	0%	0%	0%
2003	Above Normal	0%	0%		9%	4%	1%	0%	0%	86%	3%	3%	4%
Average		15%	10%	21%	16%	-1%	-1%	1%	0%	10%	2%	2%	2%
Wet		7%	10%	10%	5%	-2%	-1%	-1%	0%	5%	6%	6%	7%
Above Normal		5%	14%	7%	10%	-3%	-1%	-1%	0%	19%	7%	7%	7%
Below Normal		7%	7%	9%	5%	-4%	-3%	6%	-1%	4%	7%	7%	8%
Dry		42%	5%	13%	45%	0%	-3%	1%	0%	21%	3%	3%	3%
Critical		10%	13%	82%	13%	2%	1%	2%	2%	2%	-15%	-23%	-22%

Energy Use (GWh) At Pumping Plant at Pearblossom: Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Total
1922	Above Normal	90.99	77.99	69.10	15.39	25.57	38.69	51.60	51.99	54.46	51.38	56.87	51.59	635.62
1923	Below Normal	50.11	45.48	40.86	73.02	64.11	69.94	46.53	56.74	57.25	55.19	62.90	58.98	681.11
1924	Critical	49.12	44.84	39.03	27.75	29.09	21.89	30.43	40.62	41.82	36.34	35.64	34.44	431.01
1925	Dry	21.84	17.00	14.80	9.06	12.65	23.93	47.66	62.31	62.92	60.49	67.74	64.18	464.58
1926	Dry	50.71	46.56	40.27	16.18	20.71	24.20	39.35	53.70	54.38	52.19	58.56	55.40	512.21
1927	Wet	43.77	40.04	34.68	17.14	28.60	46.52	55.35	56.70	59.38	55.86	61.11	55.50	554.65
1928	Above Normal	54.16	49.23	44.58	71.06	70.05	41.25	55.35	56.25	58.73	55.25	60.02	54.66	670.59
1929	Critical	52.78	48.12	43.72	66.46	63.77	32.34	25.06	36.91	37.89	33.11	32.49	30.04	502.69
1930	Dry	20.30	15.62	13.59	8.51	14.41	16.73	39.76	51.75	53.01	48.79	51.82	49.57	383.86
1931	Critical	35.75	31.04	27.06	12.05	16.16	15.66	35.14	47.10	48.22	41.98	41.28	39.31	390.75
1932	Dry	24.25	20.64	17.75	10.25	18.22	20.83	37.99	48.59	49.34	46.96	51.64	49.09	395.55
1933	Critical	37.56	33.91	29.51	13.18	17.45	20.30	39.64	53.43	54.87	48.70	49.36	47.63	445.54
1934	Critical	32.02	25.97	22.55	10.98	14.00	16.40	37.69	50.51	51.75	44.98	1.98	1.51	310.34
1935	Below Normal	21.58	63.37	49.96	10.03	16.82	20.26	48.85	62.55	15.25	66.43	73.56	69.93	518.59
1936	Below Normal	54.66	50.38	43.43	16.64	25.26	55.68	55.25	59.20	61.93	58.27	63.84	57.98	602.52
1937	Below Normal	56.57	51.48	46.56	75.14	74.71	69.15	54.62	56.55	59.18	56.02	61.74	55.60	717.32
1938	Wet	53.92	49.08	44.05	81.18	78.16	90.99	50.98	57.99	60.61	53.59	64.83	53.74	739.12
1939	Dry	52.00	47.12	41.45	75.02	58.73	90.99	55.94	59.65	4.18	65.38	33.89	76.53	660.88
1940	Above Normal	61.81	24.68	65.11	8.73	13.04	27.22	48.56	63.16	43.64	63.34	70.65	67.00	556.94
1941	Wet	52.86	48.50	41.88	27.10	32.87	78.43	45.86	48.62	50.81	48.54	54.80	49.04	579.31
1942	Wet	47.37	42.94	37.86	64.58	81.88	90.99	61.27	51.87	54.36	51.44	57.36	51.85	693.77
1943	Wet	50.48	45.74	40.87	70.76	79.55	62.45	58.62	58.70	61.19	58.04	64.48	58.34	709.22
1944	Dry	56.74	51.56	46.08	63.49	60.64	35.14	39.39	50.85	51.42	48.65	53.01	50.52	607.49
1945	Below Normal	38.06	33.93	29.54	15.22	19.99	90.99	55.12	56.69	59.43	55.92	61.15	55.56	571.60
1946	Below Normal	54.15	49.22	47.20	80.98	52.15	50.44	51.99	53.55	55.97	52.81	58.45	53.10	660.01
1947	Dry	51.73	46.98	42.29	71.66	73.96	41.52	53.41	61.07	62.62	59.54	65.51	61.19	691.48
1948	Below Normal	53.15	48.65	42.95	42.40	41.95	24.44	37.86	33.38	1.66	66.49	73.18	69.64	535.75
1949	Dry	54.43	50.02	43.26	16.65	21.19	22.56	53.55	60.07	61.98	58.76	64.51	60.07	567.05
1950	Below Normal	52.91	48.43	42.90	15.82	18.18	19.49	44.32	56.08	1.60	65.00	71.45	67.84	503.82
1951	Above Normal	53.01	48.72	42.24	90.68	69.27	86.37	51.24	55.35	57.95	54.52	60.33	54.86	724.54
1952	Wet	53.50	48.57	43.69	78.48	76.83	51.44	43.60	47.14	49.09	47.30	54.06	48.10	641.80
1953	Wet	46.31	41.81	59.92	80.03	81.39	90.99	64.70	52.68	53.65	51.24	57.40	53.03	733.15
1954	Above Normal	48.16	43.78	38.75	53.40	55.51	46.53	48.94	62.04	58.75	54.33	68.70	65.16	644.05
1955	Dry	51.50	47.19	40.78	19.14	25.17	25.85	40.81	51.92	52.36	50.54	56.38	53.42	515.06
1956	Wet	41.95	38.32	33.23	76.70	70.66	88.47	58.50	60.57	63.39	59.69	66.20	60.17	717.85
1957	Above Normal	58.72	53.39	47.86	86.44	82.18	48.20	40.48	25.76	1.86	62.14	67.86	64.63	639.52
1958	Wet	50.14	46.01	39.86	19.17	36.79	79.93	58.72	60.86	63.58	60.26	67.32	60.64	643.28
1959	Below Normal	59.06	53.59	47.67	75.66	74.87	77.72	46.69	58.90	4.01	64.09	71.08	67.52	700.86
1960	Dry	53.03	48.59	41.87	15.76	17.83	20.47	52.45	65.51	26.38	68.41	38.64	78.40	527.34
1961	Dry	62.31	57.17	49.26	21.41	24.32	20.40	43.99	55.60	56.45	54.18	41.86	17.79	504.74
1962	Below Normal	0.36	42.44	83.90	6.46	10.41	24.88	44.63	56.92	1.69	66.08	72.74	69.10	479.61
1963	Wet	53.99	49.61	43.01	33.79	37.83	43.77	51.17	53.10	55.47	52.36	57.93	52.68	584.71
1964	Dry	51.37	46.58	52.63	68.01	38.43	40.54	55.07	55.29	57.92	54.54	59.94	54.41	634.73
1965	Wet	53.20	48.24	43.58	62.76	65.16	49.20	50.19	51.66	50.51	51.12	56.54	51.56	633.72
1966	Below Normal	49.35	44.74	40.16	70.70	72.51	51.53	47.43	58.56	51.77	57.49	65.52	61.62	671.38
1967	Wet	50.23	45.89	39.79	24.03	41.78	46.13	55.18	56.61	59.15	56.00	62.20	56.24	593.23
1968	Below Normal	54.70	49.64	44.44	72.38	85.12	82.10	54.16	54.56	55.92	53.27	60.26	56.11	722.66
1969	Wet	48.73	44.39	38.91	49.48	82.18	90.99	51.54	53.65	56.07	53.40	60.49	54.27	684.10
1970	Wet	53.14	46.85	41.86	80.03	82.18	90.99	51.67	55.27	57.91	54.42	60.20	54.70	729.22
1971	Wet	53.40	48.43	43.58	72.75	82.18	61.26	45.41	58.20	57.57	56.57	64.50	60.86	704.71
1972	Below Normal	48.54	44.42	38.43	21.90	34.01	40.38	48.81	59.38	60.29	57.72	65.01	61.09	579.98
1973	Above Normal	50.38	46.10	40.12	29.45	47.35	50.63	54.00	57.08	59.86	56.10	61.71	56.05	608.83
1974	Wet	54.73	49.70	44.86	73.02	63.45	77.04	56.17	55.99	58.75	55.32	61.72	55.94	706.69
1975	Wet	54.47	49.33	44.05	83.37	82.18	68.44	55.22	55.66	58.39	54.75	59.87	54.50	720.23
1976	Critical	53.01	48.19	43.67	70.50	72.52	41.21	45.97	58.63	4.17	64.30	35.71	73.84	611.72
1977	Critical	57.48	52.68	45.23	15.42	17.64	15.28	6.21	1.33	1.51	2.46	2.13	1.55	218.92
1978	Above Normal	0.47	1.60	61.27	7.08	18.99	37.04	50.07	51.20	53.69	50.52	55.35	50.10	437.38
1979	Below Normal	48.83	44.18	39.96	70.44	70.99	49.83	51.85	54.09	56.76	53.38	58.71	53.21	652.23
1980	Above Normal	51.68	46.90	42.25	72.97	73.94	90.99	50.76	52.71	55.12	52.68	59.43	53.19	702.62
1981	Dry	51.46	46.58	41.03	81.39	82.18	52.44	44.73	57.91	4.17	66.65	61.83	71.85	662.22
1982	Wet	55.78	51.12	43.89	31.75	36.50	90.99	61.34	58.56	61.25	58.01	65.23	58.72	673.14
1983	Wet	57.82	52.50	84.64	85.54	72.94	90.99	42.10	44.29	48.49	52.16	49.27	45.66	726.40
1984	Wet	49.44	45.13	84.64	79.62	75.09	90.99	51.65	56.07	58.51	55.24	61.07	55.59	763.04
1985	Dry	54.13	49.22	49.69	80.39	75.60	59.40	51.28	52.75	55.46	52.06	57.11	51.81	688.90
1986	Wet	50.53	45.92	41.53	69.45	66.73	90.99	56.01	58.03	60.82	57.57	64.18	57.64	719.40
1987	Dry	56.02	50.95	45.38	83.51	82.18	44.15	39.93	52.46	53.89	46.62	46.02	44.58	644.79
1988	Critical	28.85	22.63	19.50	10.16	15.61	13.94	26.00	34.39	35.41	31.00	30.30	29.23	297.02
1989	Dry	18.46	14.16	12.41	8.45	13.00	13.67	50.96	65.55	33.83	66.95	62.98	72.90	433.32
1990	Critical	57.32	52.65	45.33	16.40	19.54	18.45	33.87	45.22	46.54	40.44	39.71	38.41	453.88
1991	Critical	24.60	19.16	16.60	9.45	12.64	13.60	26.49	32.29	10.68	36.89	35.70	34.70	272.80
1992	Critical	21.48	15.58	14.61	8.46	11.76	12.40	26.08	34.51	35.44	2.07	1.98	13.43	197.80
1993	Above Normal	43.90	1.30	59.15	8.29	28.64	37.61	50.01	55.76	20.92	58.57	65.02	60.31	489.48
1994	Critical	53.64	49.01	43.27	49.27	50.27	33.97	41.79	52.86	36.55	53.28	4.14	49.29	517.34
1995	Wet	1.42	12.48	84.64	6.39	25.44	34.30	59.11	59.59	62.31	58.96	65.25	59.00	528.89
1996	Wet	57.44	52.21	46.80	74.77	75.92	60.16	56.12	56.35	58.99	55.55	61.19	55.53	711.03
1997	Wet	54.15	49.23	44.40	80.12	68.33	90.99	51.23	53.18	55.50	52.63	58.89	53.21	711.86
1998	Wet	51.62	46.85	41.70	81.92	63.57	74.47	50.86	54.03	56.48	54.08	60.96	54.51	691.05
1999	Wet	52.61	54.16	52.71	80.78	61.07	78.01	52.02	55.38	57.83	54.77	60.60	55.03	714.97
2000	Above Normal	53.65	48.77	43.90	76.30	72.88	51.48	50.27	61.61	62.45	60.18	67.04	63.10	711.63
2001	Dry	51.70	47.42	41.30	26.78	27.59	22.07	39.44	53.33	54.66	47.65	46.99	45.47	504.40
2002	Dry	29.19	23.04	19.84	13.03	21.85	26.83	56.02	56.13					

Energy Use (GWh) At Pumping Plant at Pearblossom: Alternative1_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Total
1922	Above Normal	90.99	77.99	69.10	20.17	26.01	39.05	52.99	53.90	60.68	57.71	64.22	58.35	671.16
1923	Below Normal	56.73	51.84	46.50	75.40	78.47	90.99	62.73	3.84	5.66	72.62	80.50	75.42	700.70
1924	Critical	65.68	60.53	53.62	44.70	42.23	27.34	35.09	47.14	21.74	2.08	1.94	1.50	403.59
1925	Dry	20.33	53.12	84.64	11.63	16.93	20.56	41.56	52.66	54.58	52.57	58.34	55.33	522.25
1926	Dry	43.68	40.17	35.02	17.66	21.13	26.11	38.85	59.55	44.65	60.04	66.93	63.11	516.90
1927	Wet	7.87	60.70	50.95	18.62	28.17	46.92	53.96	55.23	40.27	60.35	65.48	59.93	548.45
1928	Above Normal	58.62	53.67	49.09	74.49	69.37	40.35	54.19	59.36	6.50	68.40	74.24	69.05	677.33
1929	Critical	62.64	57.62	51.61	55.63	53.15	30.38	30.77	41.49	42.60	2.08	2.00	1.50	431.47
1930	Dry	2.65	2.15	74.87	10.13	15.06	17.55	39.75	51.96	3.31	56.07	58.51	56.26	388.27
1931	Critical	39.56	33.94	29.42	12.89	16.98	16.84	35.04	46.97	48.09	41.86	2.01	1.45	325.05
1932	Dry	2.50	22.06	84.64	10.56	18.69	22.01	37.69	47.93	52.81	50.81	55.82	53.19	458.71
1933	Critical	42.17	38.74	34.23	18.31	18.36	20.10	38.07	53.66	55.88	48.80	48.26	46.69	463.27
1934	Critical	29.97	24.44	21.16	11.63	14.86	18.32	39.85	53.52	54.84	47.62	1.98	1.51	319.70
1935	Below Normal	24.25	66.68	52.58	10.85	17.73	21.56	50.10	64.26	8.21	78.04	85.78	82.01	562.05
1936	Below Normal	64.86	60.05	52.15	20.47	24.51	43.99	57.15	59.06	66.00	62.35	67.92	62.07	640.58
1937	Below Normal	60.67	55.59	50.68	74.64	75.36	78.18	53.93	55.86	62.68	59.60	65.32	59.21	751.72
1938	Wet	57.52	52.73	43.49	68.86	67.13	83.04	50.21	52.29	54.89	56.40	63.39	57.24	707.19
1939	Dry	55.49	50.67	45.03	77.91	58.71	89.20	51.18	60.39	8.30	69.51	36.63	80.54	683.56
1940	Above Normal	65.95	11.49	72.39	10.56	11.05	26.69	48.54	63.14	47.56	67.45	74.76	71.12	570.70
1941	Wet	56.98	52.61	43.83	27.11	32.86	73.21	45.86	48.62	55.02	52.76	59.02	53.26	601.14
1942	Wet	51.59	47.16	39.91	73.51	82.18	90.42	61.29	51.69	58.39	55.46	61.32	55.85	728.77
1943	Wet	54.50	49.77	44.96	72.11	81.41	64.51	59.78	58.64	65.35	62.19	68.51	62.42	744.15
1944	Dry	60.83	55.67	50.26	59.38	53.15	32.58	39.42	50.96	54.29	51.42	55.68	53.22	616.86
1945	Below Normal	40.63	36.44	32.09	17.90	19.97	79.00	55.19	56.76	63.73	60.21	65.44	59.85	587.21
1946	Below Normal	58.44	53.51	52.18	85.20	52.15	50.62	52.22	53.79	60.44	57.27	62.93	57.56	696.31
1947	Dry	56.18	51.42	46.70	76.35	74.06	41.58	53.34	61.28	64.49	61.44	67.46	63.17	717.47
1948	Below Normal	54.87	50.38	44.63	43.04	41.00	24.09	37.90	35.48	1.66	66.49	73.21	69.67	542.42
1949	Dry	54.46	50.05	43.29	16.65	21.19	22.53	53.54	60.14	62.13	58.92	64.69	60.25	567.84
1950	Below Normal	53.02	48.54	43.00	15.07	17.60	19.31	44.31	56.07	3.42	66.81	73.25	69.65	510.05
1951	Above Normal	54.82	50.52	42.23	90.68	82.18	86.37	51.24	55.35	62.17	58.74	64.55	59.08	757.93
1952	Wet	57.72	52.79	47.91	81.67	76.82	51.44	43.60	44.91	46.74	49.12	55.17	49.80	657.69
1953	Wet	48.19	43.88	69.52	91.62	74.98	79.72	52.84	51.58	57.10	54.62	60.53	56.06	740.64
1954	Above Normal	51.91	47.52	42.64	60.59	58.37	48.27	49.29	62.51	63.95	54.71	70.12	66.54	676.42
1955	Dry	52.88	48.56	42.12	20.36	25.19	25.78	40.48	51.49	52.39	50.58	56.38	53.44	519.65
1956	Wet	42.05	38.44	33.40	59.53	70.68	88.50	58.55	60.62	67.66	63.95	70.47	64.43	718.28
1957	Above Normal	62.98	57.64	52.11	90.64	82.18	48.17	40.49	26.00	5.94	66.23	71.95	68.72	673.05
1958	Wet	54.23	50.10	43.95	23.25	36.79	79.81	58.72	60.86	67.79	64.48	71.54	64.86	676.38
1959	Below Normal	63.28	57.81	51.89	79.73	65.30	76.89	45.51	57.40	6.08	66.30	72.98	69.54	712.71
1960	Dry	54.86	50.40	43.66	17.37	17.55	20.59	52.53	65.31	30.74	67.29	42.27	76.15	538.72
1961	Dry	61.02	55.99	48.37	22.55	25.35	20.80	44.09	55.73	56.58	54.31	42.95	17.71	505.45
1962	Below Normal	1.50	42.01	83.40	6.46	10.41	24.88	44.63	56.92	5.77	70.16	76.82	73.18	496.14
1963	Wet	58.07	53.69	47.09	37.87	37.83	43.77	51.17	53.10	59.69	56.58	62.15	56.90	617.91
1964	Dry	55.59	50.80	56.85	72.24	38.47	40.57	55.04	55.27	57.96	54.59	59.98	54.46	651.82
1965	Wet	53.24	48.29	43.63	63.04	65.32	49.00	50.20	51.79	52.90	55.62	61.06	56.09	650.18
1966	Below Normal	53.77	49.14	44.54	74.54	72.14	51.37	47.43	58.57	54.75	60.65	68.68	64.79	700.37
1967	Wet	53.37	49.03	42.93	27.10	41.74	46.13	55.20	56.55	59.09	60.15	66.33	60.39	618.01
1968	Below Normal	58.86	50.65	48.62	92.97	85.12	82.66	54.31	55.76	60.77	58.24	65.69	61.68	775.33
1969	Wet	52.87	48.57	42.88	43.89	82.18	90.99	51.25	53.36	55.76	57.34	64.42	58.22	701.73
1970	Wet	57.08	50.82	45.84	78.39	82.18	90.99	51.71	55.52	62.38	58.88	64.68	59.15	757.62
1971	Wet	57.85	52.87	48.00	76.83	65.05	61.53	45.33	58.08	58.81	59.18	67.09	63.45	714.07
1972	Below Normal	51.12	47.00	41.01	24.51	34.01	40.38	48.80	59.36	60.34	57.76	65.06	61.13	590.48
1973	Above Normal	50.44	46.16	40.18	29.58	47.40	50.78	53.87	57.09	64.09	60.32	65.93	60.28	626.12
1974	Wet	58.95	53.92	49.08	87.44	63.46	76.80	55.83	55.46	62.42	58.97	65.18	59.54	747.05
1975	Wet	58.11	53.02	47.88	85.30	79.84	65.91	55.82	56.28	63.25	59.57	64.76	59.32	749.06
1976	Critical	57.83	52.97	48.38	75.52	73.25	41.42	45.72	58.31	4.16	63.93	36.50	73.19	631.18
1977	Critical	56.94	52.18	44.79	15.36	17.59	15.26	9.41	1.33	1.61	2.46	2.04	1.55	220.52
1978	Above Normal	0.47	0.17	61.37	7.08	19.00	36.33	49.80	53.60	59.93	56.89	62.29	57.46	464.39
1979	Below Normal	53.67	49.07	44.32	62.67	59.67	55.50	53.91	54.50	61.40	57.95	63.23	57.76	673.65
1980	Above Normal	56.26	51.45	46.84	71.50	77.92	90.99	47.88	50.46	56.98	54.58	60.76	54.93	720.55
1981	Dry	53.31	48.63	43.54	86.78	82.18	60.91	45.82	59.39	8.46	70.54	61.36	76.77	697.69
1982	Wet	60.69	56.00	48.69	36.24	36.77	90.99	61.34	58.57	65.48	62.24	69.46	62.95	709.42
1983	Wet	61.34	53.21	84.64	85.54	72.94	90.99	42.10	44.29	48.49	52.16	53.49	49.88	739.07
1984	Wet	49.44	45.13	84.64	79.62	75.25	90.99	51.66	56.08	62.73	59.46	65.29	59.81	780.10
1985	Dry	58.35	53.44	53.92	84.61	75.60	59.40	51.28	52.75	58.35	54.95	60.00	54.70	717.35
1986	Wet	53.42	48.81	44.42	72.34	66.73	60.22	57.45	58.06	65.08	61.82	68.44	61.89	718.68
1987	Dry	60.27	55.20	49.62	87.73	82.18	44.17	37.65	50.53	53.87	46.90	46.29	44.90	659.31
1988	Critical	29.71	23.70	20.71	11.94	15.43	13.88	26.00	34.39	35.41	31.00	30.30	29.23	301.70
1989	Dry	18.46	14.16	12.41	8.44	12.99	13.65	50.91	65.49	33.22	66.94	59.19	73.57	429.43
1990	Critical	57.80	53.09	45.69	16.38	19.53	18.46	33.87	45.24	46.55	40.45	39.71	38.42	455.19
1991	Critical	24.61	19.17	16.60	9.45	12.64	13.60	26.48	31.04	10.60	37.09	35.87	34.88	272.03
1992	Critical	21.58	14.35	15.49	8.45	11.75	12.40	26.08	34.50	35.43	2.07	1.98	13.08	197.16
1993	Above Normal	43.31	0.71	59.70	8.29	28.61	37.51	50.00	55.85	23.70	62.59	69.05	64.48	503.80
1994	Critical	57.86	52.96	47.23	53.10	49.92	33.82	41.79	52.86	36.77	53.33	4.51	49.30	533.45
1995	Wet	0.40	11.24	84.71	6.46	25.44	34.30	59.11	59.59	66.53	63.18	69.47	63.22	543.65
1996	Wet	61.66	56.43	50.53	41.88	43.62	46.55	54.92	55.13	61.93	58.56	64.11	58.60	653.92
1997	Wet	57.25	52.41	47.13	75.64	68.13	90.99	51.37	53.31	59.86	56.97	63.24	57.55	733.85
1998	Wet	55.97	51.19	46.03	86.28	82.18	70.97	50.80	51.72	54.06	51.60	61.97	56.12	718.89
1999	Wet	60.04	55.45	57.85	92.64	72.74	70.20	51.78	55.51	62.19	59.12	64.97	59.39	761.88
2000	Above Normal	58.01	53.11	48.22	80.88	73.32	51.21	50.14	62.03	66.90	64.67	71.64	67.78	747.91
2001	Dry	55.82	51.55	45.36	28.59	25.52	21.49	39.75	53.77	55.53	48.45	47.79	46.26	519.88
2002	Dry	29.86	23.65	20.43	13.48	21.85	26.80	55.85	55.95	58.52	55			

Difference in Energy Use (GWh) At Pumping Plant at Pearblossom: Alternative1_2005 minus Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Average
1922	Above Normal	0.00	0.00	0.00	4.78	0.44	0.36	1.39	1.91	6.22	6.33	7.35	6.76	2.96
1923	Below Normal	6.62	6.36	5.64	2.38	14.36	21.05	16.20	(52.90)	(51.59)	17.43	17.60	16.44	1.63
1924	Critical	16.56	15.69	14.59	16.95	13.14	5.45	4.66	6.52	(20.08)	(34.26)	(33.70)	(32.94)	(2.29)
1925	Dry	(1.51)	36.12	69.84	2.57	4.28	(3.37)	(6.10)	(9.65)	(8.34)	(7.92)	(9.40)	(8.85)	4.81
1926	Dry	(7.03)	(6.39)	(5.25)	1.48	0.42	1.91	(0.50)	5.85	(9.73)	7.85	8.37	7.71	0.39
1927	Wet	(35.90)	20.66	16.27	1.48	(0.43)	0.40	(1.39)	(1.47)	(19.11)	4.49	4.37	4.43	(0.52)
1928	Above Normal	4.46	4.44	4.51	3.43	(0.68)	(0.90)	(1.16)	3.11	(52.23)	13.15	14.22	14.39	0.56
1929	Critical	9.86	9.50	7.89	(10.83)	(10.62)	(1.96)	5.71	4.58	4.71	(31.03)	(30.49)	(28.54)	(5.94)
1930	Dry	(17.65)	(13.47)	61.28	1.62	0.65	0.82	(0.01)	0.21	(49.70)	7.28	6.69	6.69	0.37
1931	Critical	3.81	2.90	2.36	0.84	0.82	1.18	(0.10)	(0.13)	(0.13)	(0.12)	(39.27)	(37.86)	(5.48)
1932	Dry	(21.75)	1.42	66.89	0.31	0.47	1.18	(0.30)	(0.66)	3.47	3.85	4.18	4.10	5.26
1933	Critical	4.61	4.83	4.72	5.13	0.91	(0.20)	(1.57)	0.23	1.01	0.10	(1.10)	(0.94)	1.48
1934	Critical	(2.05)	(1.53)	(1.39)	0.65	0.86	1.92	2.16	3.01	3.09	2.64	0.00	0.00	0.78
1935	Below Normal	2.67	3.31	2.62	0.82	0.91	1.30	1.25	1.71	(7.04)	11.61	12.22	12.08	3.62
1936	Below Normal	10.20	9.67	8.72	3.83	(0.75)	(11.69)	1.90	(0.14)	4.07	4.08	4.08	4.09	3.17
1937	Below Normal	4.10	4.11	4.12	(0.50)	0.65	9.03	(0.69)	(0.69)	3.50	3.58	3.58	3.61	2.87
1938	Wet	3.60	3.65	(0.56)	(12.32)	(11.03)	(7.95)	(0.77)	(5.70)	(5.72)	2.81	(1.44)	3.50	(2.66)
1939	Dry	3.49	3.55	3.58	2.89	(0.02)	(1.79)	(4.76)	0.74	4.12	4.13	2.74	4.01	1.89
1940	Above Normal	4.14	(13.19)	7.28	1.83	(1.99)	(0.53)	(0.02)	(0.02)	3.92	4.11	4.11	4.12	1.15
1941	Wet	4.12	4.11	1.95	0.01	(0.01)	(5.22)	0.00	0.00	4.21	4.22	4.22	4.22	1.82
1942	Wet	4.22	4.22	2.05	8.93	0.30	(0.57)	0.02	(0.18)	4.03	4.02	3.96	4.00	2.92
1943	Wet	4.02	4.03	4.09	1.35	1.86	2.06	1.16	(0.06)	4.16	4.15	4.03	4.08	2.91
1944	Dry	4.09	4.11	4.18	(4.11)	(7.49)	(2.56)	0.03	0.11	2.87	2.77	2.67	2.70	0.78
1945	Below Normal	2.57	2.51	2.55	2.68	(0.02)	(11.99)	0.07	0.07	4.30	4.29	4.29	4.29	1.30
1946	Below Normal	4.29	4.29	4.98	4.22	0.00	0.18	0.23	0.24	4.47	4.46	4.48	4.46	3.03
1947	Dry	4.45	4.44	4.41	4.69	0.10	0.06	(0.07)	0.21	1.87	1.90	1.95	1.98	2.17
1948	Below Normal	1.72	1.73	1.68	0.64	(0.95)	(0.35)	0.04	2.10	0.00	0.00	0.03	0.03	0.56
1949	Dry	0.03	0.03	0.03	0.00	0.00	(0.03)	(0.01)	0.07	0.15	0.16	0.18	0.18	0.07
1950	Below Normal	0.11	0.11	0.10	(0.55)	(0.58)	(0.18)	(0.01)	(0.01)	1.82	1.81	1.80	1.81	0.52
1951	Above Normal	1.81	1.80	(0.01)	0.00	12.91	0.00	0.00	0.00	4.22	4.22	4.22	4.22	2.78
1952	Wet	4.22	4.22	4.22	3.19	(0.01)	0.00	0.00	(2.23)	(2.35)	1.82	1.11	1.70	1.32
1953	Wet	1.88	2.07	9.60	11.59	(6.41)	(11.27)	(11.86)	(1.10)	3.45	3.38	3.13	3.03	0.62
1954	Above Normal	3.75	3.74	3.89	7.19	2.86	1.74	0.35	0.47	5.20	0.38	1.42	1.38	2.70
1955	Dry	1.38	1.37	1.34	1.22	0.02	(0.07)	(0.33)	(0.43)	0.03	0.04	0.00	0.02	0.38
1956	Wet	0.10	0.12	0.17	(17.17)	0.02	0.03	0.05	0.05	4.27	4.26	4.27	4.26	0.04
1957	Above Normal	4.26	4.25	4.25	4.20	0.00	(0.03)	0.01	0.24	4.08	4.09	4.09	4.09	2.79
1958	Wet	4.09	4.09	4.09	4.08	0.00	(0.12)	0.00	0.00	4.21	4.22	4.22	4.22	2.76
1959	Below Normal	4.22	4.22	4.22	4.07	(9.57)	(0.83)	(1.18)	(1.50)	2.07	2.21	1.90	2.02	0.99
1960	Dry	1.83	1.81	1.79	1.61	(0.28)	0.12	0.08	(0.20)	4.36	(1.12)	3.63	(2.25)	0.95
1961	Dry	(1.29)	(1.18)	(0.89)	1.14	1.03	0.40	0.10	0.13	0.13	0.13	1.09	(0.08)	0.06
1962	Below Normal	1.14	(0.43)	(0.50)	0.00	0.00	0.00	0.00	0.00	4.08	4.08	4.08	4.08	1.38
1963	Wet	4.08	4.08	4.08	4.08	0.00	0.00	0.00	0.00	4.22	4.22	4.22	4.22	2.77
1964	Dry	4.22	4.22	4.22	4.23	0.04	0.03	(0.03)	(0.02)	0.04	0.05	0.04	0.05	1.42
1965	Wet	0.04	0.05	0.05	0.28	0.16	(0.20)	0.01	0.13	2.39	4.50	4.52	4.53	1.37
1966	Below Normal	4.42	4.40	4.38	3.84	(0.37)	(0.16)	0.00	0.01	2.98	3.16	3.16	3.17	2.42
1967	Wet	3.14	3.14	3.14	3.07	(0.04)	0.00	0.02	(0.06)	(0.06)	4.15	4.13	4.15	2.07
1968	Below Normal	4.16	1.01	4.18	20.59	0.00	0.56	0.15	1.20	4.85	4.97	5.43	5.57	4.39
1969	Wet	4.14	4.18	3.97	(5.59)	0.00	0.00	(0.29)	(0.29)	(0.31)	3.94	3.93	3.95	1.47
1970	Wet	3.94	3.97	3.98	(1.64)	0.00	0.00	0.04	0.25	4.47	4.46	4.48	4.45	2.37
1971	Wet	4.45	4.44	4.42	4.08	(17.13)	0.27	(0.08)	(0.12)	1.24	2.61	2.59	2.59	0.78
1972	Below Normal	2.58	2.58	2.58	2.61	0.00	0.00	(0.01)	(0.02)	0.05	0.04	0.05	0.04	0.87
1973	Above Normal	0.06	0.06	0.06	0.13	0.05	0.15	(0.13)	0.01	4.23	4.22	4.22	4.23	1.44
1974	Wet	4.22	4.22	4.22	14.42	0.01	(0.24)	(0.34)	(0.53)	3.67	3.65	3.46	3.60	3.36
1975	Wet	3.64	3.69	3.83	1.93	(2.34)	(2.53)	0.80	0.62	4.86	4.82	4.89	4.82	2.40
1976	Critical	4.82	4.78	4.71	5.02	0.73	0.21	(0.25)	(0.32)	(0.01)	(0.37)	0.79	(0.65)	1.62
1977	Critical	(0.54)	(0.50)	(0.44)	(0.06)	(0.05)	(0.02)	3.20	0.00	0.10	0.00	(0.09)	0.00	0.13
1978	Above Normal	0.00	(1.43)	0.10	0.00	0.01	(0.71)	(0.27)	2.40	6.24	6.37	6.94	7.36	2.25
1979	Below Normal	4.84	4.89	4.36	(7.77)	(11.32)	5.67	2.06	0.41	4.64	4.57	4.52	4.55	1.79
1980	Above Normal	4.58	4.55	4.59	(1.47)	3.98	0.00	(2.88)	(2.25)	1.86	1.90	1.33	1.74	1.49
1981	Dry	1.85	2.05	2.51	5.39	0.00	8.47	1.09	1.48	4.29	3.89	(0.47)	4.92	2.96
1982	Wet	4.91	4.88	4.80	4.49	0.27	0.00	0.00	0.01	4.23	4.23	4.23	4.23	3.02
1983	Wet	3.52	0.71	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	4.22	4.22	1.06
1984	Wet	0.00	0.00	0.00	0.00	0.16	0.00	0.01	0.01	4.22	4.22	4.22	4.22	1.42
1985	Dry	4.22	4.22	4.23	4.22	0.00	0.00	0.00	0.00	2.89	2.89	2.89	2.89	2.37
1986	Wet	2.89	2.89	2.89	2.89	0.00	(30.77)	1.44	0.03	4.26	4.25	4.26	4.25	(0.06)
1987	Dry	4.25	4.25	4.24	4.22	0.00	0.02	(1.38)	(1.93)	(0.02)	0.28	0.27	0.32	1.21
1988	Critical	0.86	1.07	1.21	1.78	(0.18)	(0.06)	0.00	0.00	0.00	0.00	0.00	0.00	0.39
1989	Dry	0.00	0.00	0.00	(0.01)	(0.01)	(0.02)	(0.05)	(0.06)	(0.61)	(0.01)	(3.79)	0.67	(0.32)
1990	Critical	0.48	0.44	0.36	(0.02)	(0.01)	0.01	0.00	0.02	0.01	0.01	0.00	0.01	0.11
1991	Critical	0.01	0.01	0.00	0.00	0.00	0.00	(0.01)	(1.25)	(0.08)	0.20	0.17	0.18	(0.06)
1992	Critical	0.10	(1.23)	0.88	(0.01)	(0.01)	0.00	0.00	(0.01)	(0.01)	0.00	0.00	(0.35)	(0.05)
1993	Above Normal	(0.59)	(0.59)	0.55	0.00	(0.03)	(0.10)	(0.01)	0.09	2.78	4.02	4.03	4.17	1.19
1994	Critical	4.22	3.95	3.96	3.83	(0.35)	(0.15)	0.00	0.00	0.22	0.05	0.37	0.01	1.34
1995	Wet	(1.02)	(1.24)	0.07	0.07	0.00	0.00	0.00	0.00	4.22	4.22	4.22	4.22	1.23
1996	Wet	4.22	4.22	3.73	(32.89)	(32.30)	(13.61)	(1.20)	(1.22)	2.94	3.01	2.92	3.07	(4.76)
1997	Wet	3.10	3.18	2.73	(4.48)	(0.20)	0.00	0.14	0.13	4.36	4.34	4.35	4.34	1.83
1998	Wet	4.35	4.34	4.33	4.36	18.61	(3.50)	(0.06)	(2.31)	(2.42)	(2.48)	1.01	1.61	2.32
1999	Wet	7.43	1.29	5.14	11.86	11.67	(7.81)	(0.24)	0.13	4.36	4.35	4.37	4.36	3.91
2000	Above Normal	4.36	4.34	4.32	4.58	0.44	(0.27)	(0.13)	0.42	4.45	4.49	4.60	4.68	3.02
2001	Dry	4.12	4.13	4.06	1.81	(2.07)	(0.58)	0.31	0.44	0.87	0.80	0.80	0.79	1.29
2002	Dry	0.67	0.61	0.59	0.45	0.00	(0.03)	(0.17)	(0.18)	(0.13)	(0.11)	(0.13)	(0.12)	0.12
2003	Above Normal	(0.12)	3.24	(3.23)	0.69	0.57	0.21	(0.01)	(0.01)	2.05	2.05	2.04	2.05	0.79
Average		1.90	3.00	5.31	1.55	(0.29)	(0.70)	0.07	(0.59)	(0.48)	2.17	1.68	1.83	1.29
Wet		1.82	3.66	3.59	0.31	(1.42)	(3.12)	(0.49)	(0.54)	1.68	3.53	3.61	3.86	1.38
Above Normal		2.23	0.93	2.19	2.11	1.55	(0.01)	(0.24)	0.53	(0.58)	4.61	4.88	4.93	1.93
Below Normal		3.83	3.48	3.55	2.63	(0.55)	0.90	1.43	(3.54)	(1.56)	4.74	4.80	4.73	2.04
Dry		(0.81)	2.85	12.61	1.87	(0.16)	0.25	(0.67)	(0.22)	(2.41)	1.49	1.21	1.43	1.45
Critical		3.56	3.33	3.24	1.94	0.44	0.53	1.15	1.05					

Percent Difference in Energy Use (GWh) At Pumping Plant at Pearblossom: Alternative1_2005 minus Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September
1922	Above Normal	0%	0%	0%	31%	2%	1%	3%	4%	11%	12%	13%	13%
1923	Below Normal	13%	14%	14%	3%	22%	30%	35%	-93%	-90%	32%	28%	28%
1924	Critical	34%	35%	37%	61%	45%	25%	15%	16%	-48%	-94%	-95%	-96%
1925	Dry	-7%	212%	472%	28%	34%	-14%	-13%	-15%	-13%	-13%	-14%	-14%
1926	Dry	-14%	-14%	-13%	9%	2%	8%	-1%	11%	-18%	15%	14%	14%
1927	Wet	-82%	52%	47%	9%	-2%	1%	-3%	-3%	-32%	8%	7%	8%
1928	Above Normal	8%	9%	10%	5%	-1%	-2%	-2%	6%	-89%	24%	24%	26%
1929	Critical	19%	20%	18%	-16%	-17%	-6%	23%	12%	12%	-94%	-94%	-95%
1930	Dry	-87%	-86%	451%	19%	5%	5%	0%	0%	-94%	15%	13%	13%
1931	Critical	11%	9%	9%	7%	5%	8%	0%	0%	0%	0%	-95%	-96%
1932	Dry	-90%	7%	377%	3%	3%	6%	-1%	-1%	7%	8%	8%	8%
1933	Critical	12%	14%	16%	39%	5%	-1%	-4%	0%	2%	0%	-2%	-2%
1934	Critical	-6%	-6%	-6%	6%	6%	12%	6%	6%	6%	6%	0%	0%
1935	Below Normal	12%	5%	5%	8%	5%	6%	3%	3%	-46%	17%	17%	17%
1936	Below Normal	19%	19%	20%	23%	-3%	-21%	3%	0%	7%	7%	6%	7%
1937	Below Normal	7%	8%	9%	-1%	1%	13%	-1%	-1%	6%	6%	6%	6%
1938	Wet	7%	7%	-1%	-15%	-14%	-9%	-2%	-10%	-9%	5%	-2%	7%
1939	Dry	7%	8%	9%	4%	0%	-2%	-9%	1%	99%	6%	8%	5%
1940	Above Normal	7%	-53%	11%	21%	-15%	-2%	0%	0%	9%	6%	6%	6%
1941	Wet	8%	8%	5%	0%	0%	-7%	0%	0%	8%	9%	8%	9%
1942	Wet	9%	10%	5%	14%	0%	-1%	0%	0%	7%	8%	7%	8%
1943	Wet	8%	9%	10%	2%	2%	3%	2%	0%	7%	7%	6%	7%
1944	Dry	7%	8%	9%	-6%	-12%	-7%	0%	0%	6%	6%	5%	5%
1945	Below Normal	7%	7%	9%	18%	0%	-13%	0%	0%	7%	8%	7%	8%
1946	Below Normal	8%	9%	11%	5%	0%	0%	0%	0%	8%	8%	8%	8%
1947	Dry	9%	9%	10%	7%	0%	0%	0%	0%	3%	3%	3%	3%
1948	Below Normal	3%	4%	4%	2%	-2%	-1%	0%	6%	0%	0%	0%	0%
1949	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1950	Below Normal	0%	0%	0%	-4%	-3%	-1%	0%	0%	114%	3%	3%	3%
1951	Above Normal	3%	4%	0%	0%	19%	0%	0%	0%	7%	8%	7%	8%
1952	Wet	8%	9%	10%	4%	0%	0%	0%	-5%	-5%	4%	2%	4%
1953	Wet	4%	5%	16%	14%	-8%	-12%	-18%	-2%	6%	7%	5%	6%
1954	Above Normal	8%	9%	10%	13%	5%	4%	1%	1%	9%	1%	2%	2%
1955	Dry	3%	3%	3%	6%	0%	0%	-1%	-1%	0%	0%	0%	0%
1956	Wet	0%	0%	1%	-22%	0%	0%	0%	0%	7%	7%	6%	7%
1957	Above Normal	7%	8%	9%	5%	0%	0%	0%	1%	219%	7%	6%	6%
1958	Wet	8%	9%	10%	21%	0%	0%	0%	0%	7%	7%	6%	7%
1959	Below Normal	7%	8%	9%	5%	-13%	-1%	-3%	-3%	52%	3%	3%	3%
1960	Dry	3%	4%	4%	10%	-2%	1%	0%	0%	17%	-2%	9%	-3%
1961	Dry	-2%	-2%	-2%	5%	4%	2%	0%	0%	0%	0%	3%	0%
1962	Below Normal	317%	-1%	-1%	0%	0%	0%	0%	0%	241%	6%	6%	6%
1963	Wet	8%	8%	9%	12%	0%	0%	0%	0%	8%	8%	7%	8%
1964	Dry	8%	9%	8%	6%	0%	0%	0%	0%	0%	0%	0%	0%
1965	Wet	0%	0%	0%	0%	0%	0%	0%	0%	5%	9%	8%	9%
1966	Below Normal	9%	10%	11%	5%	-1%	0%	0%	0%	6%	5%	5%	5%
1967	Wet	6%	7%	8%	13%	0%	0%	0%	0%	0%	7%	7%	7%
1968	Below Normal	8%	2%	9%	28%	0%	1%	0%	2%	9%	9%	9%	10%
1969	Wet	8%	9%	10%	-11%	0%	0%	-1%	-1%	-1%	7%	6%	7%
1970	Wet	7%	8%	10%	-2%	0%	0%	0%	0%	8%	8%	7%	8%
1971	Wet	8%	9%	10%	6%	-21%	0%	0%	0%	2%	5%	4%	4%
1972	Below Normal	5%	6%	7%	12%	0%	0%	0%	0%	0%	0%	0%	0%
1973	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	7%	8%	7%	8%
1974	Wet	8%	8%	9%	20%	0%	0%	-1%	-1%	6%	7%	6%	6%
1975	Wet	7%	7%	9%	2%	-3%	-4%	1%	1%	8%	9%	8%	9%
1976	Critical	9%	10%	11%	7%	1%	1%	-1%	-1%	0%	-1%	2%	-1%
1977	Critical	-1%	-1%	-1%	0%	0%	0%	52%	0%	7%	0%	-4%	0%
1978	Above Normal	0%	-89%	0%	0%	0%	-2%	-1%	5%	12%	13%	13%	15%
1979	Below Normal	10%	11%	11%	-11%	-16%	11%	4%	1%	8%	9%	8%	9%
1980	Above Normal	9%	10%	11%	-2%	5%	0%	-6%	-4%	3%	4%	2%	3%
1981	Dry	4%	4%	6%	7%	0%	16%	2%	3%	103%	6%	-1%	7%
1982	Wet	9%	10%	11%	14%	1%	0%	0%	0%	7%	6%	6%	7%
1983	Wet	6%	1%	0%	0%	0%	0%	0%	0%	0%	0%	9%	9%
1984	Wet	0%	0%	0%	0%	0%	0%	0%	0%	7%	8%	7%	8%
1985	Dry	8%	9%	9%	5%	0%	0%	0%	0%	5%	6%	5%	6%
1986	Wet	6%	6%	7%	4%	0%	-34%	3%	0%	7%	7%	7%	7%
1987	Dry	8%	8%	9%	5%	0%	0%	-4%	-4%	0%	1%	1%	1%
1988	Critical	3%	5%	6%	18%	-1%	0%	0%	0%	0%	0%	0%	0%
1989	Dry	0%	0%	0%	0%	0%	0%	0%	0%	-2%	0%	-6%	1%
1990	Critical	1%	1%	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1991	Critical	0%	0%	0%	0%	0%	0%	0%	-4%	-1%	1%	0%	1%
1992	Critical	0%	-8%	6%	0%	0%	0%	0%	0%	0%	0%	0%	-3%
1993	Above Normal	-1%	-45%	1%	0%	0%	0%	0%	0%	13%	7%	6%	7%
1994	Critical	8%	8%	9%	8%	-1%	0%	0%	0%	1%	0%	9%	0%
1995	Wet	-72%	-10%	0%	1%	0%	0%	0%	0%	7%	7%	6%	7%
1996	Wet	7%	8%	8%	-44%	-43%	-23%	-2%	-2%	5%	5%	5%	6%
1997	Wet	6%	6%	6%	-6%	0%	0%	0%	0%	8%	8%	7%	8%
1998	Wet	8%	9%	10%	5%	29%	-5%	0%	-4%	-4%	-5%	2%	3%
1999	Wet	14%	2%	10%	15%	19%	-10%	0%	0%	8%	8%	7%	8%
2000	Above Normal	8%	9%	10%	6%	1%	-1%	0%	1%	7%	7%	7%	7%
2001	Dry	8%	9%	10%	7%	-8%	-3%	1%	1%	2%	2%	2%	2%
2002	Dry	2%	3%	3%	3%	0%	0%	0%	0%	0%	0%	0%	0%
2003	Above Normal	0%	17%	-5%	5%	3%	1%	0%	0%	153%	3%	3%	3%
Average		5%	6%	23%	6%	0%	0%	1%	-1%	10%	3%	2%	2%
Wet		0%	8%	8%	2%	-1%	-4%	-1%	-1%	3%	6%	6%	7%
Above Normal		4%	-10%	5%	7%	2%	0%	0%	1%	30%	8%	8%	9%
Below Normal		30%	7%	8%	7%	-1%	2%	3%	-6%	23%	8%	7%	8%
Dry		-7%	11%	76%	7%	1%	1%	-1%	0%	6%	3%	3%	3%
Critical		7%	7%	9%	11%	4%	3%	8%	3%	-2%	-15%	-23%	-24%

Energy Use (GWh) At Pumping Plant at South Bay: Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Total
1922	Above Normal	14.70	7.57	9.06	1.02	1.68	11.46	9.47	9.50	12.65	13.29	12.77	11.66	114.83
1923	Below Normal	1.49	1.30	5.61	14.70	13.28	14.70	14.23	14.70	14.23	14.70	14.70	13.71	137.35
1924	Critical	1.64	2.54	5.31	10.10	9.10	12.59	7.04	4.95	5.84	6.45	6.37	5.93	77.86
1925	Dry	1.00	0.74	0.37	0.93	0.52	14.70	6.27	9.31	11.59	13.35	12.79	11.50	83.07
1926	Dry	1.76	2.73	5.27	7.04	6.57	11.97	8.04	8.13	10.12	11.59	11.08	9.95	94.25
1927	Wet	1.44	0.84	4.51	6.26	6.19	12.52	9.35	9.40	12.55	13.20	12.66	11.50	100.42
1928	Above Normal	1.48	1.29	5.59	14.70	13.75	14.70	14.23	14.70	14.23	13.76	11.96	10.87	131.26
1929	Critical	1.40	0.99	4.79	14.70	13.28	14.70	14.23	7.79	5.33	5.91	5.85	5.39	94.36
1930	Dry	0.89	0.66	0.33	0.83	0.45	8.91	8.50	6.88	8.49	9.59	9.34	8.48	63.35
1931	Critical	1.32	0.80	1.35	4.55	4.11	10.58	7.53	5.70	6.63	7.45	7.29	6.72	64.03
1932	Dry	1.14	0.85	0.42	1.06	1.76	10.84	8.72	7.17	8.87	10.15	9.79	8.90	69.67
1933	Critical	1.29	0.68	2.46	5.29	4.88	11.32	7.92	6.50	7.83	8.85	8.66	7.97	73.65
1934	Critical	1.33	0.93	0.49	3.02	3.10	10.56	7.76	6.02	7.08	7.83	0.84	3.56	52.52
1935	Below Normal	1.70	3.87	5.46	3.03	2.85	10.80	10.20	9.31	11.61	13.28	12.81	11.55	96.47
1936	Below Normal	1.76	2.72	5.27	7.10	6.79	14.70	7.52	9.77	12.99	13.67	13.17	11.96	107.42
1937	Below Normal	1.52	1.80	5.81	14.70	13.28	14.70	7.18	10.96	14.23	14.70	14.70	13.78	127.36
1938	Wet	2.69	3.06	6.78	14.70	13.28	14.70	8.47	14.70	14.23	14.70	14.70	14.23	136.24
1939	Dry	7.01	5.60	9.67	14.70	13.28	14.70	14.23	14.70	12.99	14.70	14.70	14.23	150.51
1940	Above Normal	9.82	5.54	9.34	1.02	1.46	11.34	10.23	9.49	11.79	13.44	12.96	11.71	108.14
1941	Wet	1.92	2.82	5.34	7.88	7.86	14.70	9.60	11.28	14.23	14.70	14.70	14.23	119.26
1942	Wet	3.48	3.56	7.32	14.70	13.28	14.70	14.23	14.70	14.23	14.70	14.70	14.23	143.83
1943	Wet	8.93	9.55	5.95	14.70	13.28	14.70	14.23	14.70	14.23	14.70	14.70	14.23	153.90
1944	Dry	7.81	3.75	7.46	13.96	12.81	14.46	8.68	7.22	8.80	10.08	9.77	8.92	113.72
1945	Below Normal	1.31	0.73	2.28	5.26	4.91	14.70	6.91	9.36	12.59	13.20	12.67	11.56	95.48
1946	Below Normal	1.47	1.29	14.70	14.70	2.65	13.10	9.27	9.23	12.29	12.95	12.46	11.33	115.44
1947	Dry	1.47	1.06	5.38	14.70	13.28	14.70	14.23	14.70	14.23	14.70	14.70	11.56	134.71
1948	Below Normal	1.56	2.06	5.40	13.73	12.39	13.95	7.64	8.22	10.25	11.77	11.29	10.19	108.45
1949	Dry	1.47	1.06	4.61	6.22	5.84	11.60	9.83	9.28	12.00	13.08	12.57	11.45	99.01
1950	Below Normal	1.54	1.87	5.38	2.08	2.32	10.73	9.66	8.39	5.24	13.09	12.61	11.39	84.30
1951	Above Normal	1.60	2.63	14.70	14.70	6.75	8.39	5.40	9.60	12.76	13.36	12.89	11.75	114.53
1952	Wet	1.52	1.47	5.67	14.70	13.75	14.70	14.23	14.70	14.23	14.70	14.70	14.23	138.60
1953	Wet	6.97	5.56	14.70	14.70	13.28	14.70	14.23	14.70	14.23	14.70	14.70	14.23	156.70
1954	Above Normal	6.63	1.88	5.17	14.70	13.28	14.70	14.23	9.54	11.79	13.62	13.00	11.79	130.33
1955	Dry	1.99	2.87	5.36	7.49	6.95	12.16	9.20	7.93	9.79	11.26	10.86	9.82	95.68
1956	Wet	1.39	0.70	4.25	14.70	11.33	8.90	6.23	10.79	14.23	14.70	14.63	13.35	115.20
1957	Above Normal	2.26	2.83	6.50	14.70	13.28	14.70	14.23	14.70	9.80	14.70	14.70	13.57	135.97
1958	Wet	1.37	0.69	4.04	6.38	6.51	14.70	9.42	12.47	14.23	14.70	14.70	14.23	113.44
1959	Below Normal	7.55	5.87	9.99	14.70	13.28	14.70	14.23	14.70	14.23	14.70	14.70	14.23	152.88
1960	Dry	9.24	6.54	5.08	6.92	6.22	11.72	10.48	9.74	12.27	13.88	13.31	12.05	117.45
1961	Dry	2.13	2.96	5.54	8.54	7.81	12.06	9.59	8.25	2.85	13.56	13.12	11.76	98.17
1962	Below Normal	1.81	2.85	5.38	1.28	1.68	10.99	9.75	8.54	10.64	12.23	11.76	10.60	87.51
1963	Wet	1.51	1.66	4.82	7.59	6.89	12.54	9.12	9.16	12.23	12.81	12.38	11.26	101.97
1964	Dry	1.46	1.05	14.70	14.70	11.14	0.24	8.49	9.23	12.33	12.97	12.51	11.35	110.17
1965	Wet	1.46	1.11	5.52	14.65	13.28	14.70	9.16	8.77	11.52	12.26	11.84	10.65	114.92
1966	Below Normal	1.40	0.97	4.64	14.70	13.28	14.70	14.23	14.70	14.23	13.49	12.99	11.73	131.06
1967	Wet	1.84	2.76	5.35	8.85	8.90	13.67	9.81	10.71	14.23	14.70	14.59	13.28	118.69
1968	Below Normal	2.20	2.78	6.45	14.70	13.75	14.70	14.23	14.70	14.23	14.70	14.70	14.23	141.37
1969	Wet	2.94	2.25	5.26	14.70	13.27	4.11	7.19	12.40	14.23	14.70	14.70	14.23	119.98
1970	Wet	6.85	6.02	9.68	14.70	13.28	14.70	9.22	9.53	12.65	13.28	12.75	11.61	134.27
1971	Wet	1.50	1.33	5.62	14.70	13.28	14.70	14.23	14.70	14.23	14.70	14.70	13.56	137.25
1972	Below Normal	1.73	2.71	5.21	7.62	7.25	12.58	10.19	9.48	11.89	13.44	12.94	11.67	106.71
1973	Above Normal	1.73	2.66	5.37	10.16	9.89	14.70	8.73	9.67	12.86	13.42	12.92	11.74	113.85
1974	Wet	1.51	1.52	5.70	14.70	13.28	14.70	14.23	14.70	14.23	14.70	14.70	14.23	138.20
1975	Wet	8.98	2.77	6.45	14.70	13.28	14.70	14.23	14.70	14.23	14.70	14.70	14.23	147.67
1976	Critical	4.50	1.76	5.48	14.70	13.75	14.70	14.23	14.70	13.02	14.70	11.98	10.86	134.38
1977	Critical	1.55	1.96	4.92	6.66	6.00	11.56	6.55	3.95	0.82	0.89	1.61	4.31	50.78
1978	Above Normal	0.00	3.51	5.44	1.18	2.09	11.53	9.38	8.87	11.80	12.39	11.94	10.82	88.95
1979	Below Normal	1.38	1.00	4.72	14.70	13.28	14.70	6.80	9.81	13.05	13.66	13.13	12.01	118.24
1980	Above Normal	1.52	1.79	5.82	14.70	13.75	14.70	8.62	12.38	14.23	14.70	14.70	14.23	131.14
1981	Dry	7.32	5.77	9.86	14.70	13.28	14.70	14.23	14.70	14.23	14.70	14.70	14.23	152.42
1982	Wet	1.59	2.06	4.91	7.60	7.14	14.70	14.23	12.39	14.23	14.70	14.70	14.23	122.48
1983	Wet	14.70	10.09	9.76	14.70	13.28	11.38	7.09	12.30	14.23	14.70	14.70	14.23	151.16
1984	Wet	14.70	14.23	14.38	14.70	13.75	14.70	5.37	9.66	12.76	13.43	12.90	11.79	152.37
1985	Dry	1.52	1.40	14.70	11.00	13.28	14.70	14.23	14.70	14.23	13.88	11.97	10.86	136.47
1986	Wet	1.40	1.01	4.76	14.70	13.28	14.70	10.87	11.82	14.23	14.70	14.70	14.23	130.40
1987	Dry	5.32	4.60	8.53	14.70	13.28	14.70	14.23	14.70	14.23	13.45	7.97	7.45	133.16
1988	Critical	1.26	0.93	0.46	1.32	2.77	10.37	6.66	4.25	5.08	5.72	5.56	5.16	49.54
1989	Dry	0.85	0.63	0.31	0.80	0.42	8.05	10.49	9.64	12.05	13.84	13.29	12.00	82.37
1990	Critical	2.17	3.02	5.50	7.23	6.61	12.17	7.43	5.42	6.43	7.16	7.06	6.58	76.78
1991	Critical	1.11	0.82	0.41	1.02	0.94	10.21	6.67	4.33	5.15	5.79	5.64	5.30	47.39
1992	Critical	0.87	0.64	0.32	0.81	0.43	7.86	6.69	4.37	5.06	3.31	0.87	7.88	39.11
1993	Above Normal	1.02	0.76	0.38	0.98	2.64	11.32	9.70	9.19	11.88	12.94	12.47	11.31	84.59
1994	Critical	1.51	1.67	5.31	14.70	13.28	14.70	9.56	8.06	9.99	11.47	11.03	9.97	111.25
1995	Wet	1.41	0.73	4.49	1.29	2.45	11.63	10.49	11.15	14.23	14.70	14.70	14.23	101.50
1996	Wet	3.25	3.41	7.15	14.70	13.75	14.70	14.23	14.70	14.23	13.54	13.04	11.81	138.51
1997	Wet	1.52	1.60	5.73	14.70	13.28	14.70	10.30	10.84	14.23	14.70	14.55	13.30	129.45
1998	Wet	2.18	2.79	6.45	14.70	13.28	14.70	14.23	14.70	14.23	14.70	14.70	14.23	140.89
1999	Wet	14.70	14.23	14.70	12.49	13.28	14.70	9.39	9.55	12.67	13.22	12.81	11.68	153.42
2000	Above Normal	1.50	1.43	5.64	14.70	13.75	14.70	14.23	14.70	14.23	14.70	14.70	13.73	138.01
2001	Dry	1.77	2.67	5.40	9.91	8.86	12.63	7.87	6.46	7.53	8.24	8.17	7.64	87.15
2002	Dry	1.30	0.96	0.48	1.87	3.16	11.69	9.25	8.98	12.03	12.60	12.10	11.03	85.45
2003	Above Normal	1.41	1.01	4.97	1.49	2.03	11.21	9.31	8.08	10.04	11.59	11.08	10.04	82.26
Average		3.16	2.75	5.90	9.81	8.90	12.84	10.27	10.48	11.65	12.61	12.12	11.38	111.87
Wet		4.30	3.76	6.90	12.42	11.45	13.62	10.90	12.28	13.81</				

Energy Use (GWh) At Pumping Plant at South Bay: Alternative1_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Total
1922	Above Normal	14.70	7.57	9.06	1.36	1.97	12.00	10.35	11.23	14.23	14.70	14.70	14.23	126.10
1923	Below Normal	3.30	3.43	7.21	14.70	13.28	14.70	14.23	14.70	11.64	14.70	14.70	14.23	140.82
1924	Critical	9.13	6.43	5.25	13.02	12.31	14.35	7.49	5.68	6.69	4.20	2.33	0.59	87.47
1925	Dry	2.97	4.95	6.14	3.07	3.48	11.40	9.32	7.94	9.90	11.42	10.91	9.78	91.28
1926	Dry	1.41	0.70	4.31	6.23	6.29	12.72	8.38	8.96	11.15	12.77	12.23	11.00	96.15
1927	Wet	1.59	2.22	5.02	6.88	7.12	13.52	9.22	9.16	12.24	12.87	12.35	11.22	103.41
1928	Above Normal	1.44	1.03	5.37	14.70	13.75	14.70	14.23	14.70	14.23	14.70	13.47	11.26	133.58
1929	Critical	1.50	1.45	5.34	14.70	13.28	14.70	11.01	5.02	5.95	3.66	1.45	4.08	82.14
1930	Dry	1.03	2.55	4.81	2.69	3.08	10.99	8.44	6.82	8.39	9.46	9.23	8.39	75.88
1931	Critical	1.32	0.83	1.09	4.49	4.63	11.37	7.53	5.71	6.63	7.45	0.85	0.54	52.44
1932	Dry	2.38	4.23	5.60	2.95	3.46	11.45	8.78	7.22	8.96	10.28	9.89	8.97	84.17
1933	Critical	1.28	0.66	2.70	5.50	5.56	12.06	7.75	6.30	7.54	8.47	8.32	7.70	73.84
1934	Critical	1.32	0.96	0.48	2.02	3.56	11.29	7.97	6.35	7.47	8.27	3.27	0.61	53.57
1935	Below Normal	2.62	4.59	5.93	3.25	3.75	11.49	10.36	9.56	11.92	13.64	13.16	11.87	102.14
1936	Below Normal	2.03	2.91	5.42	7.24	6.89	14.70	7.50	9.73	12.94	13.62	13.11	11.91	108.00
1937	Below Normal	1.51	1.74	5.78	14.70	13.28	14.70	10.36	10.98	14.23	14.70	14.70	13.83	130.51
1938	Wet	2.73	3.08	6.81	14.70	13.28	14.70	4.55	12.34	14.23	14.70	14.70	14.23	130.05
1939	Dry	6.98	5.66	9.71	14.70	13.28	14.70	14.23	14.70	12.99	14.70	14.70	14.23	150.58
1940	Above Normal	9.09	4.90	10.35	0.65	1.15	11.24	10.23	9.48	11.78	13.44	12.95	11.70	106.96
1941	Wet	1.92	2.82	5.34	7.87	7.85	14.70	9.59	11.28	14.23	14.70	14.70	14.23	119.23
1942	Wet	3.51	3.59	7.28	14.70	13.28	14.70	14.23	14.70	14.23	14.70	14.70	14.23	143.85
1943	Wet	8.99	8.37	5.87	14.70	13.28	14.70	14.23	14.70	14.23	14.70	14.70	14.23	152.70
1944	Dry	9.70	3.41	7.13	9.48	8.77	12.97	8.66	7.20	8.77	10.04	9.73	8.89	104.75
1945	Below Normal	1.31	0.74	2.21	5.21	4.86	14.70	6.85	9.37	12.60	13.21	12.68	11.57	95.31
1946	Below Normal	1.47	1.30	14.70	14.70	2.65	13.11	9.29	9.27	12.34	13.01	12.51	11.38	115.73
1947	Dry	1.47	1.06	5.46	14.70	13.28	14.70	14.23	14.70	14.23	14.70	14.70	11.59	134.82
1948	Below Normal	1.57	2.12	5.40	13.47	12.15	13.86	7.64	8.24	10.28	11.81	11.33	10.22	108.09
1949	Dry	1.47	1.11	4.63	6.24	5.86	11.60	9.84	9.29	12.00	13.09	12.58	11.46	99.17
1950	Below Normal	1.54	1.89	5.38	1.97	2.23	10.70	9.66	8.39	5.24	13.09	12.60	11.39	84.08
1951	Above Normal	1.60	2.63	14.70	14.70	6.75	8.39	5.40	9.60	12.76	13.36	12.89	11.75	114.53
1952	Wet	1.52	1.47	5.67	14.70	13.75	14.70	14.23	14.70	14.23	14.70	14.70	14.23	138.60
1953	Wet	2.38	2.87	14.70	12.59	13.28	14.70	14.23	14.70	14.23	14.70	14.70	12.31	145.39
1954	Above Normal	1.46	0.95	5.09	14.70	13.28	14.70	14.23	11.34	11.90	13.74	13.13	11.90	126.42
1955	Dry	2.08	2.94	5.42	7.55	7.01	12.17	9.16	7.87	9.72	11.17	10.78	9.74	95.61
1956	Wet	1.38	0.69	4.12	14.70	11.26	8.90	6.23	10.79	14.23	14.70	14.63	13.35	114.98
1957	Above Normal	2.26	2.83	6.51	14.70	13.28	14.70	14.23	14.70	9.80	14.70	14.70	13.55	135.96
1958	Wet	1.37	0.69	4.05	6.38	6.52	14.70	9.42	12.47	14.23	14.70	14.70	14.23	113.46
1959	Below Normal	7.55	5.88	9.99	14.70	13.28	14.70	14.23	14.70	14.23	14.70	14.70	14.23	152.89
1960	Dry	9.25	4.38	4.93	6.73	6.05	11.69	10.45	9.72	12.27	13.85	13.28	12.02	114.62
1961	Dry	2.09	2.93	5.54	8.82	8.06	12.18	9.60	8.27	2.86	13.59	13.16	11.81	98.91
1962	Below Normal	1.85	2.86	5.33	1.28	1.68	10.99	9.75	8.54	10.64	12.23	11.76	10.60	87.51
1963	Wet	1.51	1.66	4.82	7.59	6.89	12.54	9.12	9.16	12.23	12.81	12.38	11.26	101.97
1964	Dry	1.46	1.05	14.70	14.70	11.14	0.24	8.49	9.23	12.33	12.97	12.51	11.35	110.17
1965	Wet	1.46	1.11	5.52	14.70	13.28	14.70	9.17	8.78	11.52	12.27	11.85	10.66	115.02
1966	Below Normal	1.40	0.97	4.67	14.70	13.28	14.70	14.23	14.70	14.10	13.43	13.00	11.73	130.91
1967	Wet	1.84	2.76	5.35	8.83	8.89	13.66	9.81	10.66	14.18	14.70	14.51	13.20	118.39
1968	Below Normal	2.14	2.74	6.41	14.70	13.75	14.70	14.23	14.70	14.23	14.70	14.70	14.23	141.23
1969	Wet	4.18	2.46	5.30	12.09	13.28	14.65	7.19	12.40	14.23	14.70	14.70	14.23	129.41
1970	Wet	7.26	5.84	9.46	14.70	13.28	14.70	8.57	9.56	12.69	13.33	12.79	11.64	133.82
1971	Wet	1.51	1.37	5.64	14.70	13.28	14.70	14.23	14.70	14.23	14.70	14.70	13.57	137.33
1972	Below Normal	1.71	2.69	5.20	7.61	7.24	12.57	10.19	9.48	11.89	13.44	12.94	11.66	106.62
1973	Above Normal	1.72	2.65	5.37	10.18	9.90	14.70	8.73	9.67	12.86	13.42	12.92	11.74	113.86
1974	Wet	1.51	1.52	5.70	14.70	13.28	14.70	14.23	14.70	14.23	14.70	14.70	14.23	138.20
1975	Wet	6.27	2.48	6.16	14.70	13.28	14.70	14.23	14.70	14.23	14.70	14.70	14.23	144.38
1976	Critical	2.78	1.82	5.54	14.70	13.75	14.70	14.23	14.70	13.02	14.70	11.91	10.80	132.65
1977	Critical	1.55	1.88	4.90	6.62	5.97	11.55	6.55	3.95	0.82	0.89	1.72	4.36	50.76
1978	Above Normal	0.00	3.46	5.34	1.18	2.09	11.56	9.64	9.00	11.77	12.62	12.17	11.01	89.84
1979	Below Normal	1.45	1.05	5.25	14.70	13.28	14.70	14.23	11.48	12.82	13.42	12.90	11.80	127.08
1980	Above Normal	1.50	1.54	5.71	14.70	13.75	14.70	10.26	11.28	14.23	14.70	14.70	14.23	131.30
1981	Dry	3.60	3.61	7.39	14.70	13.28	14.70	14.23	14.70	14.23	14.70	14.70	14.23	144.07
1982	Wet	7.08	2.49	5.05	7.79	7.31	14.70	14.23	12.39	14.23	14.70	14.70	14.23	128.90
1983	Wet	7.54	14.23	12.77	14.70	13.28	11.38	7.09	12.30	14.23	14.70	14.70	14.23	151.15
1984	Wet	14.70	14.23	14.38	14.70	13.75	14.70	5.37	9.66	12.76	13.43	12.90	11.79	152.37
1985	Dry	1.52	1.40	14.70	11.00	13.28	14.70	14.23	14.70	14.23	13.88	11.97	10.86	136.47
1986	Wet	1.40	1.01	4.76	14.70	13.28	14.70	14.23	14.70	14.23	14.70	14.70	14.23	136.64
1987	Dry	10.26	8.82	8.49	14.70	13.28	14.70	14.23	14.70	14.23	12.61	7.71	7.20	140.93
1988	Critical	1.21	0.90	0.45	1.11	2.44	10.34	6.66	4.25	5.08	5.72	5.56	5.16	48.88
1989	Dry	0.85	0.63	0.31	0.80	0.42	8.04	10.48	9.63	12.04	13.82	13.28	11.99	82.29
1990	Critical	2.16	3.01	5.49	7.22	6.60	12.17	7.43	5.42	6.43	7.16	7.06	6.58	76.73
1991	Critical	1.11	0.82	0.41	1.02	0.94	10.21	6.67	4.33	5.15	5.79	5.64	5.30	47.39
1992	Critical	0.87	0.64	0.32	0.81	0.43	7.85	6.69	4.37	5.06	3.31	2.06	7.48	39.89
1993	Above Normal	0.84	0.62	0.31	0.79	2.41	11.33	9.71	9.19	11.88	12.95	12.48	11.32	83.83
1994	Critical	1.52	1.69	5.31	14.70	13.28	14.70	9.41	8.06	9.99	11.47	11.03	9.97	111.13
1995	Wet	1.41	0.73	4.49	1.29	2.45	11.63	10.49	11.15	14.23	14.70	14.70	14.23	101.50
1996	Wet	3.25	3.41	7.15	5.30	5.35	12.58	9.49	9.38	12.50	13.14	12.66	11.45	105.66
1997	Wet	1.47	1.19	5.55	14.70	13.28	14.70	10.30	10.83	14.23	14.70	14.54	13.29	128.78
1998	Wet	2.18	2.78	6.45	14.70	13.28	14.70	14.23	14.70	14.23	14.70	14.70	14.23	140.88
1999	Wet	14.70	14.23	11.54	8.81	13.28	14.70	9.31	9.59	12.73	13.29	12.87	11.73	146.78
2000	Above Normal	1.51	1.49	5.66	14.70	13.75	14.70	14.23	14.70	14.23	14.70	14.70	14.23	138.60
2001	Dry	1.87	2.73	5.41	9.33	8.35	12.42	7.90	6.51	7.59	8.31	8.23	7.70	86.35
2002	Dry	1.31	0.96	0.48	1.97	3.18	11.69	9.24	8.96	11.99	12.56	12.07	11.00	85.41
2003	Above Normal	1.40	1.01	4.91	1.61	2.13	11.24	9.31	8.08	10.04	11.59	11.08	10.04	82.44
Average		3.18	2.92	6.08	9.62	8.91	13.00	10.36	10.44	11.63	12.56	12.00	11.19	111.90
Wet		4.03	3.82	6.88	11.77	11.17	13.98	10.66	12.08					

Difference in Energy Use (GWh) At Pumping Plant at South Bay: Alternative1_2005 minus Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Average
1922	Above Normal	0.00	0.00	0.00	0.34	0.29	0.54	0.88	1.73	1.58	1.41	1.93	2.57	0.94
1923	Below Normal	1.81	2.13	1.60	0.00	0.00	0.00	0.00	0.00	(2.59)	0.00	0.00	0.52	0.29
1924	Critical	7.49	3.89	(0.06)	2.92	3.21	1.76	0.45	0.73	0.85	(2.25)	(4.04)	(5.34)	0.80
1925	Dry	1.97	4.21	5.77	2.14	2.96	(3.30)	3.05	(1.37)	(1.69)	(1.93)	(1.88)	(1.72)	0.68
1926	Dry	(0.35)	(2.03)	(0.96)	(0.81)	(0.28)	0.75	0.34	0.83	1.03	1.18	1.15	1.05	0.16
1927	Wet	0.15	1.38	0.51	0.62	0.93	1.00	(0.13)	(0.24)	(0.31)	(0.33)	(0.31)	(0.28)	0.25
1928	Above Normal	(0.04)	(0.26)	(0.22)	0.00	0.00	0.00	0.00	0.00	0.00	0.94	1.51	0.39	0.19
1929	Critical	0.10	0.46	0.55	0.00	0.00	0.00	(3.22)	(2.77)	0.62	(2.25)	(4.40)	(1.31)	(1.02)
1930	Dry	0.14	1.89	4.48	1.86	2.63	2.08	(0.06)	(0.06)	(0.10)	(0.13)	(0.11)	(0.09)	1.04
1931	Critical	0.00	0.03	(0.26)	(0.06)	0.52	0.79	0.00	0.01	0.00	0.00	(6.44)	(6.18)	(0.97)
1932	Dry	1.24	3.38	5.18	1.89	1.70	0.61	0.06	0.05	0.09	0.13	0.10	0.07	1.21
1933	Critical	(0.01)	(0.02)	0.24	0.21	0.68	0.74	(0.17)	(0.20)	(0.29)	(0.38)	(0.34)	(0.27)	0.02
1934	Critical	(0.01)	0.03	(0.01)	(1.00)	0.46	0.73	0.21	0.33	0.39	0.44	2.43	(2.95)	0.09
1935	Below Normal	0.92	0.72	0.47	0.22	0.90	0.69	0.16	0.25	0.31	0.36	0.35	0.32	0.47
1936	Below Normal	0.27	0.19	0.15	0.14	0.10	0.00	(0.02)	(0.04)	(0.05)	(0.05)	(0.06)	(0.05)	0.05
1937	Below Normal	(0.01)	(0.06)	(0.03)	0.00	0.00	0.00	3.18	0.02	0.00	0.00	0.00	0.05	0.26
1938	Wet	0.04	0.02	0.03	0.00	0.00	0.00	(3.92)	(2.36)	0.00	0.00	0.00	0.00	(0.52)
1939	Dry	(0.03)	0.06	0.04	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01
1940	Above Normal	(0.73)	(0.64)	1.01	(0.37)	(0.31)	(0.10)	0.00	(0.01)	(0.01)	0.00	(0.01)	(0.01)	(0.10)
1941	Wet	0.00	0.00	0.00	(0.01)	(0.01)	0.00	(0.01)	0.00	0.00	0.00	0.00	0.00	0.00
1942	Wet	0.03	0.03	(0.04)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1943	Wet	0.06	(1.18)	(0.08)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.10)
1944	Dry	1.89	(0.34)	(0.33)	(4.48)	(4.04)	(1.49)	(0.02)	(0.02)	(0.03)	(0.04)	(0.04)	(0.03)	(0.75)
1945	Below Normal	0.00	0.01	(0.07)	(0.05)	(0.05)	0.00	(0.06)	0.01	0.01	0.01	0.01	0.01	(0.01)
1946	Below Normal	0.00	0.01	0.00	0.00	0.00	0.01	0.02	0.04	0.05	0.06	0.05	0.05	0.02
1947	Dry	0.00	0.00	0.08	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.03	0.01
1948	Below Normal	0.01	0.06	0.00	(0.26)	(0.24)	(0.09)	0.00	0.02	0.03	0.04	0.04	0.03	(0.03)
1949	Dry	0.00	0.05	0.02	0.02	0.02	0.00	0.01	0.01	0.00	0.01	0.01	0.01	0.01
1950	Below Normal	0.00	0.02	0.00	(0.11)	(0.09)	(0.03)	0.00	0.00	0.00	0.00	(0.01)	0.00	(0.02)
1951	Above Normal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1952	Wet	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1953	Wet	(4.59)	(2.69)	0.00	(2.11)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(1.92)	(0.94)
1954	Above Normal	(5.17)	(0.93)	(0.08)	0.00	0.00	0.00	0.00	1.80	0.11	0.12	0.13	0.11	(0.33)
1955	Dry	0.09	0.07	0.06	0.06	0.06	0.01	(0.04)	(0.06)	(0.07)	(0.09)	(0.08)	(0.08)	(0.01)
1956	Wet	(0.01)	(0.01)	(0.13)	0.00	(0.07)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.02)
1957	Above Normal	0.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.02)	0.00
1958	Wet	0.00	0.00	0.01	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1959	Below Normal	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1960	Dry	0.01	(2.16)	(0.15)	(0.19)	(0.17)	(0.03)	(0.03)	(0.02)	0.00	(0.03)	(0.03)	(0.03)	(0.24)
1961	Dry	(0.04)	(0.03)	0.00	0.28	0.25	0.12	0.01	0.02	0.01	0.03	0.04	0.05	0.06
1962	Below Normal	0.04	0.01	(0.05)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1963	Wet	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1964	Dry	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1965	Wet	0.00	0.00	0.00	0.05	0.00	0.00	0.01	0.01	0.00	0.01	0.01	0.01	0.01
1966	Below Normal	0.00	0.00	0.03	0.00	0.00	0.00	0.00	0.00	(0.13)	(0.06)	0.01	0.00	(0.01)
1967	Wet	0.00	0.00	0.00	(0.02)	(0.01)	(0.01)	0.00	(0.05)	(0.05)	0.00	(0.08)	(0.08)	(0.03)
1968	Below Normal	(0.06)	(0.04)	(0.04)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.01)
1969	Wet	1.24	0.21	0.04	(2.61)	0.01	10.54	0.00	0.00	0.00	0.00	0.00	0.00	0.79
1970	Wet	0.41	(0.18)	(0.22)	0.00	0.00	0.00	(0.65)	0.03	0.04	0.05	0.04	0.03	(0.04)
1971	Wet	0.01	0.04	0.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.01
1972	Below Normal	(0.02)	(0.02)	(0.01)	(0.01)	(0.01)	(0.01)	0.00	0.00	0.00	0.00	0.00	(0.01)	(0.01)
1973	Above Normal	(0.01)	(0.01)	0.00	0.02	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1974	Wet	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1975	Wet	(2.71)	(0.29)	(0.29)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.27)
1976	Critical	(1.72)	0.06	0.06	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.07)	(0.06)	(0.14)
1977	Critical	0.00	(0.08)	(0.02)	(0.04)	(0.03)	(0.01)	0.00	0.00	0.00	0.00	0.11	0.05	0.00
1978	Above Normal	0.00	(0.05)	(0.10)	0.00	0.00	0.03	0.26	0.13	(0.03)	0.23	0.23	0.19	0.07
1979	Below Normal	0.07	0.05	0.53	0.00	0.00	0.00	7.43	1.67	(0.23)	(0.24)	(0.23)	(0.21)	0.74
1980	Above Normal	(0.02)	(0.25)	(0.11)	0.00	0.00	0.00	1.64	(1.10)	0.00	0.00	0.00	0.00	0.01
1981	Dry	(3.72)	(2.16)	(2.47)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.70)
1982	Wet	5.49	0.43	0.14	0.19	0.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.54
1983	Wet	(7.16)	4.14	3.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1984	Wet	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1985	Dry	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1986	Wet	0.00	0.00	0.00	0.00	0.00	0.00	3.36	2.88	0.00	0.00	0.00	0.00	0.52
1987	Dry	4.94	4.22	(0.04)	0.00	0.00	0.00	0.00	0.00	0.00	(0.84)	(0.26)	(0.25)	0.65
1988	Critical	(0.05)	(0.03)	(0.01)	(0.21)	(0.33)	(0.03)	0.00	0.00	0.00	0.00	0.00	0.00	(0.06)
1989	Dry	0.00	0.00	0.00	0.00	0.00	(0.01)	(0.01)	(0.01)	(0.01)	(0.02)	(0.01)	(0.01)	(0.01)
1990	Critical	(0.01)	(0.01)	(0.01)	(0.01)	(0.01)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1991	Critical	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1992	Critical	0.00	0.00	0.00	0.00	0.00	(0.01)	0.00	0.00	0.00	0.00	1.19	(0.40)	0.07
1993	Above Normal	(0.18)	(0.14)	(0.07)	(0.19)	(0.23)	0.01	0.01	0.00	0.00	0.01	0.01	0.01	(0.06)
1994	Critical	0.01	0.02	0.00	0.00	0.00	0.00	(0.15)	0.00	0.00	0.00	0.00	0.00	(0.01)
1995	Wet	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1996	Wet	0.00	0.00	0.00	(9.40)	(8.40)	(2.12)	(4.74)	(5.32)	(1.73)	(0.40)	(0.38)	(0.36)	(2.74)
1997	Wet	(0.05)	(0.41)	(0.18)	0.00	0.00	0.00	0.00	(0.01)	0.00	0.00	(0.01)	(0.01)	(0.06)
1998	Wet	0.00	(0.01)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1999	Wet	0.00	0.00	(3.16)	(3.68)	0.00	0.00	(0.08)	0.04	0.06	0.07	0.06	0.05	(0.55)
2000	Above Normal	0.01	0.06	0.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.50	0.05
2001	Dry	0.10	0.06	0.01	(0.58)	(0.51)	(0.21)	0.03	0.05	0.06	0.07	0.06	0.06	(0.07)
2002	Dry	0.01	0.00	0.00	0.10	0.02	0.00	(0.01)	(0.02)	(0.04)	(0.04)	(0.03)	(0.03)	0.00
2003	Above Normal	(0.01)	0.00	(0.06)	0.12	0.10	0.03	0.00	0.00	0.00	0.00	0.00	0.00	0.02
Average		0.02	0.17	0.18	(0.18)	0.00	0.16	0.10	(0.04)	(0.03)	(0.05)	(0.11)	(0.19)	0.00
Wet		(0.27)	0.06	(0.01)	(0.65)	(0.28)	0.36	(0.24)	(0.19)	(0.08)	(0.02)	(0.03)	(0.10)	(0.12)
Above Normal		(0.51)	(0.19)	0.03	(0.01)	(0.01)	0.04	0.23	0.21	0.14	0.23	0.32	0.31	0.07
Below Normal		0.22	0.22	0.18	(0.00)	0.04	0.04	0.77	0.14	(0.19)	0.01	0.01	0.05	0.12
Dry		0.35	0.40	0.65	0.02	0.15	(0.08)	0.19	(0.03)	(0.04)	(0.09)	(0.06)	(0.05)	0.11
Critical		0.48	0.36	0.04	0.15	0.38	0.33	(0.24)	(0.16)	0.13	(0.37)	(0.96)	(1.37)	(0.10)

Percent Difference in Energy Use (GWh) At Pumping Plant at South Bay: Alternative1_2005 minus Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September
1922	Above Normal	0%	0%	0%	33%	17%	5%	9%	18%	12%	11%	15%	22%
1923	Below Normal	121%	164%	29%	0%	0%	0%	0%	0%	-18%	0%	0%	4%
1924	Critical	457%	153%	-1%	29%	35%	14%	6%	15%	15%	-35%	-63%	-90%
1925	Dry	197%	569%	>1,000%	230%	569%	-22%	49%	-15%	-15%	-14%	-15%	-15%
1926	Dry	-20%	-74%	-18%	-12%	-4%	6%	4%	10%	10%	10%	10%	11%
1927	Wet	10%	164%	11%	10%	15%	8%	-1%	-3%	-2%	-3%	-2%	-2%
1928	Above Normal	-3%	-20%	-4%	0%	0%	0%	0%	0%	0%	7%	13%	4%
1929	Critical	7%	46%	11%	0%	0%	0%	-23%	-36%	12%	-38%	-75%	-24%
1930	Dry	16%	286%	>1,000%	224%	584%	23%	-1%	-1%	-1%	-1%	-1%	-1%
1931	Critical	0%	4%	-19%	-1%	13%	7%	0%	0%	0%	0%	-88%	-92%
1932	Dry	109%	398%	>1,000%	178%	97%	6%	1%	1%	1%	1%	1%	1%
1933	Critical	-1%	-3%	10%	4%	14%	7%	-2%	-3%	-4%	-4%	-4%	-3%
1934	Critical	-1%	3%	-2%	-33%	15%	7%	3%	5%	6%	6%	289%	-83%
1935	Below Normal	54%	19%	9%	7%	32%	6%	2%	3%	3%	3%	3%	3%
1936	Below Normal	15%	7%	3%	2%	1%	0%	0%	0%	0%	0%	0%	0%
1937	Below Normal	-1%	-3%	-1%	0%	0%	0%	44%	0%	0%	0%	0%	0%
1938	Wet	1%	1%	0%	0%	0%	0%	-46%	-16%	0%	0%	0%	0%
1939	Dry	0%	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1940	Above Normal	-7%	-12%	11%	-36%	-21%	-1%	0%	0%	0%	0%	0%	0%
1941	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1942	Wet	1%	1%	-1%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1943	Wet	1%	-12%	-1%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1944	Dry	24%	-9%	-4%	-32%	-32%	-10%	0%	0%	0%	0%	0%	0%
1945	Below Normal	0%	1%	-3%	-1%	-1%	0%	-1%	0%	0%	0%	0%	0%
1946	Below Normal	0%	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1947	Dry	0%	0%	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1948	Below Normal	1%	3%	0%	-2%	-2%	-1%	0%	0%	0%	0%	0%	0%
1949	Dry	0%	5%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1950	Below Normal	0%	1%	0%	-5%	-4%	0%	0%	0%	0%	0%	0%	0%
1951	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1952	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1953	Wet	-66%	-48%	0%	-14%	0%	0%	0%	0%	0%	0%	0%	-13%
1954	Above Normal	-78%	-49%	-2%	0%	0%	0%	0%	19%	1%	1%	1%	1%
1955	Dry	5%	2%	1%	1%	1%	0%	0%	-1%	-1%	-1%	-1%	-1%
1956	Wet	-1%	-1%	-3%	0%	-1%	0%	0%	0%	0%	0%	0%	0%
1957	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1958	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1959	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1960	Dry	0%	-33%	-3%	-3%	-3%	0%	0%	0%	0%	0%	0%	0%
1961	Dry	-2%	-1%	0%	3%	3%	1%	0%	0%	0%	0%	0%	0%
1962	Below Normal	2%	0%	-1%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1963	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1964	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1965	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1966	Below Normal	0%	0%	1%	0%	0%	0%	0%	0%	-1%	0%	0%	0%
1967	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	-1%	-1%
1968	Below Normal	-3%	-1%	-1%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1969	Wet	42%	9%	1%	-18%	0%	256%	0%	0%	0%	0%	0%	0%
1970	Wet	6%	-3%	-2%	0%	0%	0%	-7%	0%	0%	0%	0%	0%
1971	Wet	1%	3%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1972	Below Normal	-1%	-1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1973	Above Normal	-1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1974	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1975	Wet	-30%	-10%	-4%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1976	Critical	-38%	3%	1%	0%	0%	0%	0%	0%	0%	0%	-1%	-1%
1977	Critical	0%	-4%	0%	-1%	-1%	0%	0%	0%	0%	0%	7%	1%
1978	Above Normal	0%	-1%	-2%	0%	0%	0%	3%	1%	0%	2%	2%	2%
1979	Below Normal	5%	5%	11%	0%	0%	0%	109%	17%	-2%	-2%	-2%	-2%
1980	Above Normal	-1%	-14%	-2%	0%	0%	0%	19%	-9%	0%	0%	0%	0%
1981	Dry	-51%	-37%	-25%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1982	Wet	345%	21%	3%	3%	2%	0%	0%	0%	0%	0%	0%	0%
1983	Wet	-49%	41%	31%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1984	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1985	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1986	Wet	0%	0%	0%	0%	0%	0%	31%	24%	0%	0%	0%	0%
1987	Dry	93%	92%	0%	0%	0%	0%	0%	0%	0%	-6%	-3%	-3%
1988	Critical	-4%	-3%	-2%	-16%	-12%	0%	0%	0%	0%	0%	0%	0%
1989	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1990	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1991	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1992	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	137%	-5%
1993	Above Normal	-18%	-18%	-18%	-19%	-9%	0%	0%	0%	0%	0%	0%	0%
1994	Critical	1%	1%	0%	0%	0%	0%	-2%	0%	0%	0%	0%	0%
1995	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1996	Wet	0%	0%	0%	-64%	-61%	-14%	-33%	-36%	-12%	-3%	-3%	-3%
1997	Wet	-3%	-26%	-3%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1998	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1999	Wet	0%	0%	-21%	-29%	0%	0%	-1%	0%	0%	1%	0%	0%
2000	Above Normal	1%	4%	0%	0%	0%	0%	0%	0%	0%	0%	0%	4%
2001	Dry	6%	2%	0%	-6%	-6%	-2%	0%	1%	1%	1%	1%	1%
2002	Dry	1%	0%	0%	5%	1%	0%	0%	0%	0%	0%	0%	0%
2003	Above Normal	-1%	0%	-1%	8%	5%	0%	0%	0%	0%	0%	0%	0%
Average		14%	20%	0%	5%	15%	4%	2%	0%	0%	-1%	3%	-3%
Wet		10%	5%	0%	-4%	-2%	10%	-2%	-1%	-1%	0%	0%	-1%
Above Normal		-9%	-9%	-1%	-1%	-1%	0%	3%	2%	1%	2%	3%	3%
Below Normal		14%	14%	3%	0%	2%	0%	11%	1%	-1%	0%	0%	0%
Dry		21%	67%	-3%	33%	67%	0%	3%	0%	0%	-1%	0%	0%
Critical		35%	17%	0%	-2%	5%	3%	-1%	-2%	2%	-6%	17%	-25%

Energy Use (GWh) At Pumping Plant at SWP Banks: Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Total
1922	Above Normal	90.57	60.97	131.24	65.00	53.04	82.37	18.03	17.24	109.40	121.99	121.99	118.05	989.89
1923	Below Normal	67.79	42.23	77.98	65.23	67.96	51.10	17.96	12.78	46.44	121.99	121.99	118.05	811.50
1924	Critical	63.18	55.29	51.48	55.50	37.15	5.48	5.30	11.98	5.30	108.32	5.48	10.15	414.61
1925	Dry	41.41	51.04	72.97	58.37	39.28	78.33	19.09	17.51	35.44	121.99	63.19	118.05	716.67
1926	Dry	54.72	47.93	50.32	58.68	29.28	5.48	20.05	15.81	42.24	121.99	61.50	62.26	570.26
1927	Wet	27.25	118.05	67.89	42.81	65.34	67.69	14.27	12.78	50.72	121.99	121.99	118.05	828.83
1928	Above Normal	59.07	38.49	129.71	62.82	37.28	78.31	15.25	12.78	45.21	111.99	121.99	118.05	830.95
1929	Critical	65.48	24.98	85.50	60.23	54.71	49.90	28.37	20.75	5.30	5.48	5.48	11.95	418.13
1930	Dry	20.61	16.97	60.61	43.46	41.21	46.14	24.64	22.21	28.52	121.99	49.78	118.05	594.19
1931	Critical	34.94	28.67	24.65	58.15	33.49	15.68	5.30	5.48	5.30	66.54	5.48	7.95	291.63
1932	Dry	18.13	26.96	131.02	62.50	69.87	74.11	5.30	12.78	5.30	121.99	78.02	42.13	648.11
1933	Critical	39.75	33.69	39.70	48.79	80.20	29.84	13.30	12.78	5.30	28.48	5.48	11.17	348.48
1934	Critical	19.08	20.63	73.80	109.04	69.89	25.44	5.30	14.12	5.30	5.48	5.48	9.08	362.64
1935	Below Normal	26.48	56.99	68.95	64.12	46.82	45.65	15.01	12.78	40.84	121.99	121.99	118.05	739.67
1936	Below Normal	57.68	49.54	56.06	40.46	144.14	131.51	18.13	12.78	48.80	121.99	121.99	95.97	899.05
1937	Below Normal	84.01	48.46	118.48	91.46	140.20	114.03	19.95	22.24	77.16	121.99	86.14	55.35	979.47
1938	Wet	90.73	118.05	111.21	139.11	113.11	120.18	42.07	112.80	118.05	117.76	118.74	81.63	1,283.44
1939	Dry	58.61	5.30	108.67	62.05	45.06	32.39	9.04	16.83	5.30	121.99	84.58	118.05	667.87
1940	Above Normal	36.85	18.36	61.90	47.29	56.83	103.88	20.21	12.78	48.47	115.60	121.99	118.05	762.21
1941	Wet	56.68	24.14	77.58	72.93	140.20	138.07	24.83	25.74	69.81	121.99	121.99	109.59	983.55
1942	Wet	42.43	5.30	76.87	90.91	85.25	90.18	21.00	21.13	68.30	121.99	121.99	100.95	846.30
1943	Wet	53.03	5.30	71.96	107.65	99.71	138.07	22.05	14.83	48.67	121.70	121.99	113.96	918.92
1944	Dry	49.89	5.30	129.82	62.08	63.07	45.04	15.43	12.78	33.01	121.99	82.56	46.04	667.01
1945	Below Normal	37.68	118.05	72.40	62.25	67.77	120.22	15.38	12.78	34.84	121.99	121.99	98.62	883.97
1946	Below Normal	98.41	115.64	103.02	75.52	48.88	62.01	13.46	12.78	34.88	121.99	121.99	101.40	909.98
1947	Dry	88.22	86.20	78.99	51.84	58.29	24.49	17.81	12.78	30.25	121.99	76.13	118.05	765.04
1948	Below Normal	77.32	62.33	41.44	36.92	5.13	46.20	12.37	12.78	47.38	121.99	121.99	118.05	703.90
1949	Dry	55.97	47.40	78.03	58.70	54.82	35.44	12.37	12.78	30.64	121.99	64.30	118.05	690.49
1950	Below Normal	30.17	33.82	40.14	40.76	42.71	62.92	12.37	12.78	37.12	121.80	121.99	118.05	674.63
1951	Above Normal	89.21	118.05	140.22	114.64	104.13	116.90	14.09	12.78	47.63	107.63	121.99	105.58	1,092.85
1952	Wet	56.21	68.28	71.83	83.97	67.50	138.07	27.85	41.83	102.10	121.99	121.99	102.37	1,003.99
1953	Wet	52.16	5.30	129.74	57.86	64.06	67.72	14.97	13.29	34.24	121.99	121.99	118.05	801.37
1954	Above Normal	39.96	5.30	128.12	37.58	41.46	63.11	12.59	12.78	46.31	106.23	121.99	118.05	733.48
1955	Dry	55.69	53.27	128.33	65.11	49.77	43.86	15.05	12.78	5.30	121.99	42.29	87.72	681.16
1956	Wet	35.55	68.57	109.49	155.23	109.94	118.40	15.06	16.98	75.00	121.99	121.99	100.26	1,048.46
1957	Above Normal	54.24	5.30	128.53	60.18	31.46	23.92	14.91	12.78	30.63	121.75	121.99	118.05	723.74
1958	Wet	121.99	46.38	67.70	46.22	67.57	138.07	42.33	36.32	93.26	121.99	121.99	118.05	1,021.87
1959	Below Normal	68.81	5.30	129.25	39.60	50.64	70.19	19.05	15.65	29.41	121.99	121.99	118.05	789.93
1960	Dry	58.77	48.77	42.88	58.16	38.27	44.41	5.30	22.32	26.90	121.99	91.01	118.05	676.83
1961	Dry	26.23	73.59	127.64	60.11	33.80	60.30	13.40	14.64	1.51	121.99	37.97	43.94	615.12
1962	Below Normal	15.57	47.35	53.46	45.35	51.70	70.00	16.57	12.78	30.25	118.28	121.99	118.05	701.35
1963	Wet	121.99	118.05	64.59	43.91	47.88	65.05	13.37	12.78	40.22	121.99	121.99	118.05	889.87
1964	Dry	72.67	118.05	91.21	62.09	46.76	39.76	12.37	12.78	5.30	121.99	55.34	118.05	756.37
1965	Wet	53.44	53.21	71.32	100.67	72.02	77.08	18.80	12.78	50.05	121.66	121.99	115.96	868.98
1966	Below Normal	35.39	66.46	137.04	71.27	65.83	55.00	12.37	12.78	29.58	119.51	121.99	118.05	845.27
1967	Wet	45.87	66.87	69.51	68.02	59.74	81.86	35.34	35.25	118.05	121.99	121.99	118.05	942.54
1968	Below Normal	74.69	5.30	126.38	61.79	38.98	64.43	17.11	15.85	29.35	121.69	121.99	118.05	795.61
1969	Wet	74.05	70.97	128.68	80.99	62.20	70.34	47.92	79.37	95.08	97.14	111.87	78.96	997.57
1970	Wet	62.85	5.30	75.09	138.07	110.11	121.44	12.37	12.78	32.60	121.99	121.99	64.15	878.74
1971	Wet	48.53	93.73	72.11	60.36	55.28	73.80	15.52	12.78	46.78	121.99	121.99	118.05	840.92
1972	Below Normal	52.46	5.30	128.55	58.73	30.92	42.62	21.00	13.00	29.05	121.99	121.99	118.05	743.66
1973	Above Normal	66.70	118.05	67.22	52.83	72.16	75.08	14.71	12.78	50.27	121.67	121.99	88.76	862.22
1974	Wet	98.82	118.05	80.60	80.82	64.82	109.87	17.00	12.78	60.65	121.99	121.99	108.42	995.81
1975	Wet	79.87	5.30	130.26	61.86	53.26	102.72	15.65	12.78	66.37	121.99	121.99	118.05	890.10
1976	Critical	110.14	5.30	128.74	52.67	34.07	51.90	22.86	20.21	5.30	115.53	75.63	118.05	740.40
1977	Critical	58.91	25.80	21.44	32.37	11.50	5.48	5.30	10.18	4.62	5.48	5.48	24.23	210.79
1978	Above Normal	5.48	29.86	53.35	52.59	77.62	90.47	29.84	26.59	94.48	121.99	121.99	118.05	822.31
1979	Below Normal	57.89	27.87	129.85	71.62	88.12	88.66	15.27	20.39	34.56	121.99	121.99	68.26	846.47
1980	Above Normal	84.23	53.21	129.13	111.30	82.22	78.00	15.54	16.53	78.64	121.99	91.94	6.01	868.74
1981	Dry	68.65	6.62	128.82	61.92	55.99	53.38	20.04	16.41	29.13	121.99	86.22	118.05	767.22
1982	Wet	57.73	118.05	66.88	70.27	131.21	132.07	108.25	44.20	92.12	121.99	121.99	118.05	1,182.81
1983	Wet	112.24	65.11	85.32	74.11	64.93	63.18	40.64	37.00	57.12	55.67	94.44	65.00	814.76
1984	Wet	117.81	107.79	123.45	122.72	115.94	119.30	14.79	12.78	35.88	121.70	121.99	102.82	1,116.97
1985	Dry	71.57	118.05	128.44	61.82	58.34	53.45	19.52	16.35	29.57	121.99	60.35	118.05	857.50
1986	Wet	83.40	96.26	78.05	38.95	139.19	120.53	26.97	26.20	69.02	121.99	74.79	118.05	993.40
1987	Dry	65.66	5.30	129.24	60.19	55.42	42.94	9.71	32.76	28.82	73.80	13.75	38.52	556.11
1988	Critical	8.42	15.00	60.60	42.64	5.13	30.14	17.99	17.75	5.30	90.42	5.48	22.30	321.17
1989	Dry	5.48	51.97	56.18	57.92	13.50	22.04	19.97	14.89	41.62	121.99	97.00	118.05	620.61
1990	Critical	60.59	40.73	59.22	56.26	35.64	18.67	5.30	16.70	4.25	121.99	5.48	32.23	457.06
1991	Critical	6.85	8.92	23.51	5.48	20.98	23.30	18.05	15.64	37.06	113.99	5.48	10.87	290.13
1992	Critical	13.03	9.29	25.30	24.58	28.97	43.69	12.37	12.78	25.54	5.48	5.48	37.69	244.20
1993	Above Normal	35.15	8.73	62.56	57.30	68.22	71.88	12.37	12.78	70.04	121.99	121.99	118.05	761.06
1994	Critical	64.29	5.30	127.55	58.43	54.59	42.35	16.33	18.73	4.31	121.99	21.58	57.38	592.83
1995	Wet	16.94	34.52	63.01	54.64	59.88	138.07	28.89	112.80	118.05	121.99	121.99	118.05	988.83
1996	Wet	39.79	22.06	68.92	51.39	133.97	126.07	17.77	17.06	59.25	121.99	121.99	118.05	898.31
1997	Wet	27.54	9.80	140.22	155.23	140.20	132.03	12.37	13.86	50.76	110.14	121.99	118.05	1,032.19
1998	Wet	37.76	13.74	128.71	54.90	140.20	138.07	32.29	38.03	118.05	121.99	121.99	118.05	1,063.78
1999	Wet	121.99	118.05	73.81	74.66	119.47	90.59	15.02	12.78	50.64	121.99	121.99	56.96	977.95
2000	Above Normal	40.78	5.30	127.64	40.53	88.19	104.07	14.61	12.78	44.23	113.87	121.99	118.05	832.

Energy Use (GWh) At Pumping Plant at SWP Banks: Alternative1_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Total
1922	Above Normal	90.57	60.97	131.24	65.00	53.10	82.49	18.03	17.24	109.40	121.99	121.99	118.05	990.07
1923	Below Normal	68.15	42.33	77.98	64.32	70.61	51.18	17.96	12.78	49.28	121.99	121.99	118.05	816.62
1924	Critical	86.75	55.64	91.28	47.48	37.15	5.51	5.30	11.98	5.30	25.96	5.48	10.14	387.97
1925	Dry	41.50	51.13	73.00	58.37	39.28	78.28	19.09	17.51	41.30	121.99	60.82	118.05	720.32
1926	Dry	45.86	39.49	50.32	58.68	29.28	5.48	20.05	15.21	42.25	121.99	84.02	60.08	572.71
1927	Wet	27.39	118.05	67.89	42.81	65.34	67.69	14.27	12.78	50.72	121.99	121.99	118.05	828.97
1928	Above Normal	59.05	38.47	129.71	62.82	37.28	78.31	15.25	12.78	45.21	111.72	121.99	118.05	830.64
1929	Critical	65.22	24.89	85.48	60.23	54.71	50.71	28.37	20.75	5.30	5.48	15.56	11.82	428.52
1930	Dry	20.73	16.39	60.61	43.46	41.21	46.14	24.64	22.21	28.52	121.99	49.74	118.05	593.69
1931	Critical	36.85	30.17	25.46	58.15	33.51	15.65	5.30	5.48	5.30	62.11	5.48	7.95	291.41
1932	Dry	18.16	26.51	131.02	62.50	70.23	74.12	5.30	12.78	5.30	121.99	121.99	50.91	700.81
1933	Critical	20.42	20.32	39.69	71.25	90.18	29.84	13.30	12.78	5.30	19.93	5.48	10.88	339.37
1934	Critical	20.52	18.16	73.00	109.32	70.20	25.44	5.30	14.12	5.30	5.48	5.48	9.16	361.48
1935	Below Normal	37.75	57.14	68.91	64.12	46.82	45.65	15.01	12.78	40.86	121.99	121.99	118.05	751.07
1936	Below Normal	63.02	54.42	56.06	40.46	143.70	129.63	18.13	12.78	48.80	121.99	121.99	102.95	913.93
1937	Below Normal	84.07	48.38	118.46	70.04	140.20	115.60	17.48	16.13	85.72	121.99	83.27	55.35	956.69
1938	Wet	90.73	118.05	91.80	120.75	121.14	122.16	37.24	45.57	118.05	121.99	121.99	97.78	1,207.25
1939	Dry	61.00	5.30	104.20	62.05	45.08	32.39	9.25	15.71	5.30	121.99	84.52	118.05	664.84
1940	Above Normal	30.37	18.19	61.09	47.40	56.83	103.88	20.21	12.78	48.48	115.58	121.99	118.05	754.85
1941	Wet	56.67	24.22	77.58	72.92	137.84	138.07	24.83	23.98	69.20	121.99	121.99	109.59	978.88
1942	Wet	42.95	5.30	76.87	85.20	83.61	90.18	21.00	21.13	68.30	121.99	121.99	109.39	847.91
1943	Wet	52.99	5.30	71.96	87.75	98.70	138.07	21.64	14.41	42.52	121.70	121.99	113.23	890.26
1944	Dry	51.12	5.30	129.82	62.08	63.07	45.04	15.43	12.78	33.01	121.99	84.58	46.11	670.33
1945	Below Normal	37.68	118.05	72.40	62.25	61.17	113.90	15.37	12.78	34.83	121.99	121.99	99.58	871.99
1946	Below Normal	98.77	118.05	103.02	75.52	49.18	62.01	13.46	12.78	34.88	121.99	121.99	100.62	912.27
1947	Dry	88.24	86.21	78.93	51.84	58.28	24.49	17.81	12.78	30.25	121.99	76.32	118.05	765.19
1948	Below Normal	77.40	62.33	41.40	36.92	5.13	46.20	12.37	12.78	47.38	121.99	121.99	118.05	703.94
1949	Dry	56.04	47.47	78.01	58.70	54.82	35.44	12.37	12.78	30.64	121.99	64.22	118.05	690.53
1950	Below Normal	29.26	33.82	40.14	40.76	42.71	62.92	12.37	12.78	37.10	121.80	121.99	118.05	673.70
1951	Above Normal	89.21	118.05	139.69	114.63	104.13	116.90	14.09	12.78	47.63	107.63	121.99	105.58	1,092.31
1952	Wet	56.21	68.28	71.83	83.34	67.68	138.07	25.20	35.25	88.50	121.99	121.99	112.05	990.39
1953	Wet	49.93	5.30	129.74	49.62	64.06	67.71	14.97	13.28	34.24	121.99	121.99	118.05	790.88
1954	Above Normal	40.02	5.30	128.12	37.58	41.46	63.11	12.60	12.78	46.31	106.23	121.99	118.05	733.55
1955	Dry	56.03	53.26	128.33	65.11	49.76	43.86	15.05	12.78	5.30	121.99	42.33	85.40	679.20
1956	Wet	35.63	68.55	93.82	155.23	109.92	118.41	15.06	16.98	75.00	121.99	121.99	100.77	1,033.35
1957	Above Normal	54.21	5.30	128.53	60.18	31.46	23.92	14.91	12.78	30.63	121.75	121.99	118.05	723.71
1958	Wet	121.99	46.37	67.70	46.22	67.57	138.07	39.13	31.17	89.17	121.99	121.99	118.05	1,009.42
1959	Below Normal	68.81	5.30	129.25	39.60	50.64	67.71	19.06	15.65	29.41	121.99	121.99	118.05	787.46
1960	Dry	58.44	47.69	42.47	58.16	38.27	44.41	5.30	22.32	26.90	121.99	91.78	118.05	675.78
1961	Dry	27.74	73.52	127.64	60.11	33.80	60.30	13.40	14.64	1.51	121.99	37.96	43.94	616.55
1962	Below Normal	15.58	47.37	53.46	45.36	51.70	70.00	16.57	12.78	30.25	118.28	121.99	118.05	701.39
1963	Wet	121.99	118.05	64.59	43.91	47.88	65.05	13.37	12.78	40.22	121.99	121.99	118.05	889.87
1964	Dry	72.68	118.05	91.20	62.09	46.76	39.76	12.37	12.78	5.30	121.99	55.41	118.05	756.44
1965	Wet	53.65	53.21	71.32	99.48	72.02	77.08	18.80	12.78	50.04	121.66	121.99	115.98	868.01
1966	Below Normal	35.41	66.44	137.04	71.27	65.83	55.00	12.37	12.78	29.58	119.51	121.99	118.05	845.27
1967	Wet	46.31	66.87	69.51	68.02	59.74	81.85	32.57	29.97	110.88	121.99	121.99	118.05	927.75
1968	Below Normal	73.59	5.30	128.63	61.79	38.98	64.43	17.11	15.85	29.35	121.69	121.99	118.05	796.76
1969	Wet	68.23	71.50	128.68	71.58	76.30	74.23	43.04	83.59	94.66	96.72	111.45	78.64	998.62
1970	Wet	62.71	5.30	75.09	137.41	113.33	121.38	12.37	12.78	32.60	121.99	121.99	64.36	881.31
1971	Wet	48.53	93.72	72.11	60.36	55.28	73.80	15.52	12.78	46.78	121.99	121.99	118.05	840.91
1972	Below Normal	52.43	5.30	128.55	58.73	30.92	42.62	21.00	13.00	29.05	121.99	121.99	118.05	743.63
1973	Above Normal	66.69	118.05	67.22	52.83	72.16	75.08	14.71	12.78	50.27	121.67	121.99	88.74	862.19
1974	Wet	98.37	118.05	80.60	77.29	64.82	92.42	16.96	12.78	60.63	121.99	121.99	118.05	983.95
1975	Wet	79.82	5.30	130.26	61.86	53.26	102.04	15.65	12.78	66.37	121.99	121.99	118.05	889.37
1976	Critical	110.72	5.30	128.74	52.67	34.06	51.90	22.86	20.21	5.30	114.94	75.57	118.05	740.32
1977	Critical	58.62	25.81	21.50	32.21	11.49	5.48	5.30	10.21	4.66	5.48	5.48	24.24	210.48
1978	Above Normal	5.48	29.82	53.33	52.59	71.47	81.08	24.02	20.48	73.22	121.99	121.99	118.05	773.52
1979	Below Normal	57.69	27.78	129.85	71.62	87.35	87.09	15.27	20.39	34.56	121.99	121.99	83.64	859.22
1980	Above Normal	98.75	55.94	129.13	77.56	88.65	81.93	15.54	16.53	77.64	98.94	69.06	55.44	865.11
1981	Dry	67.51	6.75	128.82	61.92	55.99	45.14	20.04	16.40	29.13	121.99	86.25	118.05	757.99
1982	Wet	60.62	118.05	66.88	70.27	130.19	135.31	108.25	37.51	83.05	121.99	121.99	118.05	1,172.16
1983	Wet	121.99	69.93	86.45	74.11	64.93	63.18	40.64	37.00	57.12	55.67	94.44	65.00	830.46
1984	Wet	117.81	107.79	123.45	122.72	115.92	119.30	14.79	12.78	35.88	121.70	121.99	102.84	1,116.97
1985	Dry	71.57	118.05	128.44	61.82	58.34	53.45	19.52	16.35	29.57	121.99	60.34	118.05	857.49
1986	Wet	83.40	96.26	78.05	38.95	105.40	138.07	26.55	22.76	67.49	121.99	97.67	98.19	974.78
1987	Dry	65.75	5.30	129.24	60.19	55.42	42.94	9.73	32.75	28.82	70.76	13.77	38.53	553.20
1988	Critical	8.40	14.99	60.60	42.64	5.14	30.18	17.99	17.75	5.30	90.61	5.48	22.31	321.39
1989	Dry	5.48	51.97	56.10	57.92	13.50	22.04	19.97	14.89	41.62	121.99	95.29	118.05	618.82
1990	Critical	60.98	40.71	59.88	56.26	35.63	18.67	5.30	16.70	4.25	121.99	5.48	32.23	458.08
1991	Critical	6.84	8.92	23.50	5.48	20.97	23.30	18.05	15.64	37.06	114.45	5.48	10.84	290.53
1992	Critical	12.97	9.25	25.31	24.39	28.97	43.69	12.37	12.78	25.54	5.48	5.48	37.68	243.91
1993	Above Normal	35.15	8.69	62.53	57.30	68.20	71.88	12.37	12.78	70.04	121.99	121.99	118.05	760.97
1994	Critical	64.27	5.30	127.55	58.43	54.59	42.35	16.33	18.73	4.31	121.99	21.58	57.37	592.80
1995	Wet	16.94	34.53	63.00	54.61	59.88	138.07	25.00	47.19	101.23	121.99	121.99	118.05	902.48
1996	Wet	39.73	22.00	68.92	51.39	133.90	119.30	17.77	16.99	59.25	121.99	121.99	118.05	891.28
1997	Wet	27.49	9.44	140.22	155.23	140.20	131.32	12.37	12.78	48.92	110.62	121.99	118.05	1,028.63
1998	Wet	37.73	13.75	128.71	54.85	140.20	138.07	29.73	32.99	118.05	121.99	121.99	118.05	1,056.11
1999	Wet	121.99	118.05	73.80	74.66	116.70	90.59	15.02	12.78	50.64	121.99	121.99	54.31	972.52
2000	Above Normal	40.80	5.30	127.64	40.53	87.15	103.25	14.61	12.78	44.23	113.86	121.99	118.05	830.19

Difference in Energy Use (GWh) At Pumping Plant at SWP Banks: Alternative1_2005 minus Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Average
1922	Above Normal	0.00	0.00	0.00	0.00	0.06	0.12	0.00	0.00	0.00	0.00	0.00	0.00	0.01
1923	Below Normal	0.36	0.10	0.00	(0.91)	2.65	0.08	0.00	0.00	2.84	0.00	0.00	0.00	0.43
1924	Critical	23.57	0.35	39.80	(8.02)	0.00	0.03	0.00	0.00	0.00	(82.36)	0.00	(0.01)	(2.22)
1925	Dry	0.09	0.09	0.03	0.00	0.00	(0.05)	0.00	0.00	5.86	0.00	(2.37)	0.00	0.30
1926	Dry	(8.86)	(8.44)	0.00	0.00	0.00	0.00	0.00	(0.60)	0.01	0.00	22.52	(2.18)	0.20
1927	Wet	0.14	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01
1928	Above Normal	(0.02)	(0.02)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.27)	0.00	0.00	(0.03)
1929	Critical	(0.26)	(0.09)	(0.02)	0.00	0.00	0.81	0.00	0.00	0.00	0.00	10.08	(0.13)	0.87
1930	Dry	0.12	(0.58)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.04)	0.00	(0.04)
1931	Critical	1.91	1.50	0.81	0.00	0.02	(0.03)	0.00	0.00	0.00	(4.43)	0.00	0.00	(0.02)
1932	Dry	0.03	(0.45)	0.00	0.00	0.36	0.01	0.00	0.00	0.00	0.00	43.97	8.78	4.39
1933	Critical	(19.33)	(13.37)	(0.01)	22.46	9.98	0.00	0.00	0.00	0.00	(8.55)	0.00	(0.29)	(0.76)
1934	Critical	1.44	(2.47)	(0.80)	0.28	0.31	0.00	0.00	0.00	0.00	0.00	0.00	0.08	(0.10)
1935	Below Normal	11.27	0.15	(0.04)	0.00	0.00	0.00	0.00	0.00	0.02	0.00	0.00	0.00	0.95
1936	Below Normal	5.34	4.88	0.00	0.00	(0.44)	(1.88)	0.00	0.00	0.00	0.00	0.00	6.98	1.24
1937	Below Normal	0.06	(0.08)	(0.02)	(21.42)	0.00	1.57	(2.47)	(6.11)	8.56	0.00	(2.87)	0.00	(1.90)
1938	Wet	0.00	0.00	(19.41)	(18.36)	8.03	1.98	(4.83)	(67.23)	0.00	4.23	3.25	16.15	(6.35)
1939	Dry	2.39	0.00	(4.47)	0.00	0.02	0.00	0.21	(1.12)	0.00	0.00	(0.06)	0.00	(0.25)
1940	Above Normal	(6.48)	(0.17)	(0.81)	0.11	0.00	0.00	0.00	0.00	0.01	(0.02)	0.00	0.00	(0.61)
1941	Wet	(0.01)	0.08	0.00	(0.01)	(2.36)	0.00	0.00	(1.76)	(0.61)	0.00	0.00	0.00	(0.39)
1942	Wet	0.52	0.00	0.00	(5.71)	(1.64)	0.00	0.00	0.00	0.00	0.00	0.00	8.44	0.13
1943	Wet	(0.04)	0.00	0.00	(19.90)	(1.01)	0.00	(0.41)	(0.42)	(6.15)	0.00	0.00	(0.73)	(2.39)
1944	Dry	1.23	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	2.02	0.07	0.28
1945	Below Normal	0.00	0.00	0.00	0.00	(6.60)	(6.32)	(0.01)	0.00	(0.01)	0.00	0.00	0.96	(1.00)
1946	Below Normal	0.36	2.41	0.00	0.00	0.30	0.00	0.00	0.00	0.00	0.00	0.00	(0.78)	0.19
1947	Dry	0.02	0.01	(0.06)	0.00	(0.01)	0.00	0.00	0.00	0.00	0.00	0.19	0.00	0.01
1948	Below Normal	0.08	0.00	(0.04)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1949	Dry	0.07	0.07	(0.02)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.08)	0.00	0.00
1950	Below Normal	(0.91)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.02)	0.00	0.00	0.00	(0.08)
1951	Above Normal	0.00	0.00	(0.53)	(0.01)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.05)
1952	Wet	0.00	0.00	0.00	(0.63)	0.18	0.00	(2.65)	(6.58)	(13.60)	0.00	0.00	9.68	(1.13)
1953	Wet	(2.23)	0.00	0.00	(8.24)	0.00	(0.01)	0.00	(0.01)	0.00	0.00	0.00	0.00	(0.87)
1954	Above Normal	0.06	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.01
1955	Dry	0.34	(0.01)	0.00	0.00	(0.01)	0.00	0.00	0.00	0.00	0.00	0.04	(2.32)	(0.16)
1956	Wet	0.08	(0.02)	(15.67)	0.00	(0.02)	0.01	0.00	0.00	0.00	0.00	0.00	0.51	(1.26)
1957	Above Normal	(0.03)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1958	Wet	0.00	(0.01)	0.00	0.00	0.00	0.00	(3.20)	(5.15)	(4.09)	0.00	0.00	0.00	(1.04)
1959	Below Normal	0.00	0.00	0.00	0.00	0.00	(2.48)	0.01	0.00	0.00	0.00	0.00	0.00	(0.21)
1960	Dry	(0.33)	(1.08)	(0.41)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.77	0.00	(0.09)
1961	Dry	1.51	(0.07)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.01)	0.00	0.12
1962	Below Normal	0.01	0.02	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1963	Wet	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1964	Dry	0.01	0.00	(0.01)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.07	0.00	0.01
1965	Wet	0.21	0.00	0.00	(1.19)	0.00	0.00	0.00	0.00	(0.01)	0.00	0.00	0.02	(0.08)
1966	Below Normal	0.02	(0.02)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1967	Wet	0.44	0.00	0.00	0.00	0.00	(0.01)	(2.77)	(5.28)	(7.17)	0.00	0.00	0.00	(1.23)
1968	Below Normal	(1.10)	0.00	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.10
1969	Wet	(5.82)	0.53	0.00	(9.41)	14.10	3.89	(4.88)	4.22	(0.42)	(0.42)	(0.42)	(0.32)	0.09
1970	Wet	(0.14)	0.00	0.00	(0.66)	3.22	(0.06)	0.00	0.00	0.00	0.00	0.00	0.21	0.21
1971	Wet	0.00	(0.01)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1972	Below Normal	(0.03)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1973	Above Normal	(0.01)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.02)	0.00
1974	Wet	(0.45)	0.00	0.00	(3.53)	0.00	(17.45)	(0.04)	0.00	(0.02)	0.00	0.00	9.63	(0.99)
1975	Wet	(0.05)	0.00	0.00	0.00	0.00	(0.68)	0.00	0.00	0.00	0.00	0.00	0.00	(0.06)
1976	Critical	0.58	0.00	0.00	0.00	(0.01)	0.00	0.00	0.00	0.00	(0.59)	(0.06)	0.00	(0.01)
1977	Critical	(0.29)	0.01	0.06	(0.16)	(0.01)	0.00	0.00	0.03	0.04	0.00	0.00	0.01	(0.03)
1978	Above Normal	0.00	(0.04)	(0.02)	0.00	(6.15)	(9.39)	(5.82)	(6.11)	(21.26)	0.00	0.00	0.00	(4.07)
1979	Below Normal	(0.20)	(0.09)	0.00	0.00	(0.77)	(1.57)	0.00	0.00	0.00	0.00	0.00	15.38	1.06
1980	Above Normal	14.52	2.73	0.00	(33.74)	6.43	3.93	0.00	0.00	(1.00)	(23.05)	(22.88)	49.43	(0.30)
1981	Dry	(1.14)	0.13	0.00	0.00	0.00	(8.24)	0.00	(0.01)	0.00	0.00	0.03	0.00	(0.77)
1982	Wet	2.89	0.00	0.00	0.00	(1.02)	3.24	0.00	(6.69)	(9.07)	0.00	0.00	0.00	(0.89)
1983	Wet	9.75	4.82	1.13	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.31
1984	Wet	0.00	0.00	0.00	0.00	(0.02)	0.00	0.00	0.00	0.00	0.00	0.00	0.02	0.00
1985	Dry	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.01)	0.00	0.00
1986	Wet	0.00	0.00	0.00	0.00	(33.79)	17.54	(0.42)	(3.44)	(1.53)	0.00	22.88	(19.86)	(1.55)
1987	Dry	0.09	0.00	0.00	0.00	0.00	0.00	0.02	(0.01)	0.00	(3.04)	0.02	0.01	(0.24)
1988	Critical	(0.02)	(0.01)	0.00	0.00	0.01	0.04	0.00	0.00	0.00	0.19	0.00	0.01	0.02
1989	Dry	0.00	0.00	(0.08)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(1.71)	0.00	(0.15)
1990	Critical	0.39	(0.02)	0.66	0.00	(0.01)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.09
1991	Critical	(0.01)	0.00	(0.01)	0.00	(0.01)	0.00	0.00	0.00	0.00	0.46	0.00	(0.03)	0.03
1992	Critical	(0.06)	(0.04)	0.01	(0.19)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.01)	(0.02)
1993	Above Normal	0.00	(0.04)	(0.03)	0.00	(0.02)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.01)
1994	Critical	(0.02)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.01)	0.00
1995	Wet	0.00	0.01	(0.01)	(0.03)	0.00	0.00	(3.89)	(65.61)	(16.82)	0.00	0.00	0.00	(7.20)
1996	Wet	(0.06)	(0.06)	0.00	0.00	(0.07)	(6.77)	0.00	(0.07)	0.00	0.00	0.00	0.00	(0.59)
1997	Wet	(0.05)	(0.36)	0.00	0.00	0.00	(0.71)	0.00	(1.08)	(1.84)	0.48	0.00	0.00	(0.30)
1998	Wet	(0.03)	0.01	0.00	(0.05)	0.00	0.00	(2.56)	(5.04)	0.00	0.00	0.00	0.00	(0.64)
1999	Wet	0.00	0.00	(0.01)	0.00	(2.77)	0.00	0.00	0.00	0.00	0.00	0.00	(2.65)	(0.45)
2000	Above Normal	0.02	0.00	0.00	0.00	(1.04)	(0.82)	0.00	0.00	0.00	(0.01)	0.00	0.00	(0.15)
2001	Dry	(0.05)	0.00	(5.31)	0.00	0.00	0.00	0.00	0.00	0.00	3.84	(0.12)	0.02	(0.13)
2002	Dry	0.00	(0.01)	0.00	0.00	(0.01)	0.00	0.00	0.00	0.00	0.00	0.00	1.36	0.11
2003	Above Normal	0.00	(0.18)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.02)
Average		0.39	(0.12)	(0.04)	(1.33)	(0.15)	(0.28)	(0.41)	(2.17)	(0.81)	(1.38)	0.92	1.20	(0.35)
Wet		0.20	0.19	(1.31)	(2.60)	(0.66)	0.04	(0.99)	(6.31)	(2.36)	0.17	0.99	0.81	(0.99)
Above Normal		0.67	0.19	(0.12)	(2.80)	(0.06)	(0.51)	(0.48)	(0.51)	(1.85)	(1.95)	(1.91)	4.12	(0.44)
Below Normal		1.09	0.53	0.15	(1.59)	(0.35)	(0.76)	(0.18)	(0.44)	0.81	0.00	(0.21)	1.61	0.06
Dry		(0.25)	(0.57)	(0.57)	0.00	0.02	(0.46)	0.01	(0.10)	0.33	0.04	3.62	0.32	0.20
Critical		0.66	(1.18)	3.38	1.20	0.86	0.07	0.00	0.00	0.00	(7.94)	0.84	(0.	

Percent Difference in Energy Use (GWh) At Pumping Plant at SWP Banks: Alternative1_2005 minus Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September
1922	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1923	Below Normal	1%	0%	0%	-1%	4%	0%	0%	0%	6%	0%	0%	0%
1924	Critical	37%	1%	77%	-14%	0%	1%	0%	0%	0%	-76%	0%	0%
1925	Dry	0%	0%	0%	0%	0%	0%	0%	0%	17%	0%	-4%	0%
1926	Dry	-16%	-18%	0%	0%	0%	0%	0%	-4%	0%	0%	37%	-4%
1927	Wet	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1928	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1929	Critical	0%	0%	0%	0%	0%	2%	0%	0%	0%	0%	184%	-1%
1930	Dry	1%	-3%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1931	Critical	5%	5%	3%	0%	0%	0%	0%	0%	0%	-7%	0%	0%
1932	Dry	0%	-2%	0%	0%	1%	0%	0%	0%	0%	0%	56%	21%
1933	Critical	-49%	-40%	0%	46%	12%	0%	0%	0%	0%	-30%	0%	-3%
1934	Critical	8%	-12%	-1%	0%	0%	0%	0%	0%	0%	0%	0%	1%
1935	Below Normal	43%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1936	Below Normal	9%	10%	0%	0%	0%	-1%	0%	0%	0%	0%	0%	7%
1937	Below Normal	0%	0%	0%	-23%	0%	1%	-12%	-27%	11%	0%	-3%	0%
1938	Wet	0%	0%	-17%	-13%	7%	2%	-11%	-60%	0%	4%	3%	20%
1939	Dry	4%	0%	-4%	0%	0%	0%	2%	-7%	0%	0%	0%	0%
1940	Above Normal	-18%	-1%	-1%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1941	Wet	0%	0%	0%	0%	-2%	0%	0%	-7%	-1%	0%	0%	0%
1942	Wet	1%	0%	0%	-6%	-2%	0%	0%	0%	0%	0%	0%	8%
1943	Wet	0%	0%	0%	-18%	-1%	0%	-2%	-3%	-13%	0%	0%	-1%
1944	Dry	2%	0%	0%	0%	0%	0%	0%	0%	0%	0%	2%	0%
1945	Below Normal	0%	0%	0%	0%	-10%	-5%	0%	0%	0%	0%	0%	1%
1946	Below Normal	0%	2%	0%	0%	1%	0%	0%	0%	0%	0%	0%	-1%
1947	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1948	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1949	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1950	Below Normal	-3%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1951	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1952	Wet	0%	0%	0%	-1%	0%	0%	-10%	-16%	-13%	0%	0%	9%
1953	Wet	-4%	0%	0%	-14%	0%	0%	0%	0%	0%	0%	0%	0%
1954	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1955	Dry	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	-3%
1956	Wet	0%	0%	-14%	0%	0%	0%	0%	0%	0%	0%	0%	1%
1957	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1958	Wet	0%	0%	0%	0%	0%	0%	-8%	-14%	-4%	0%	0%	0%
1959	Below Normal	0%	0%	0%	0%	0%	-4%	0%	0%	0%	0%	0%	0%
1960	Dry	-1%	-2%	0%	0%	0%	0%	0%	0%	0%	0%	1%	0%
1961	Dry	6%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1962	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1963	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1964	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1965	Wet	0%	0%	0%	-1%	0%	0%	0%	0%	0%	0%	0%	0%
1966	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1967	Wet	1%	0%	0%	0%	0%	0%	-8%	-15%	-6%	0%	0%	0%
1968	Below Normal	-1%	0%	2%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1969	Wet	-8%	1%	0%	-12%	23%	6%	-10%	5%	0%	0%	0%	0%
1970	Wet	0%	0%	0%	0%	3%	0%	0%	0%	0%	0%	0%	0%
1971	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1972	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1973	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1974	Wet	0%	0%	0%	-4%	0%	-16%	0%	0%	0%	0%	0%	9%
1975	Wet	0%	0%	0%	0%	0%	-1%	0%	0%	0%	0%	0%	0%
1976	Critical	1%	0%	0%	0%	0%	0%	0%	0%	0%	-1%	0%	0%
1977	Critical	0%	0%	0%	0%	0%	0%	0%	0%	1%	0%	0%	0%
1978	Above Normal	0%	0%	0%	0%	-8%	-10%	-20%	-23%	0%	0%	0%	0%
1979	Below Normal	0%	0%	0%	0%	-1%	-2%	0%	0%	0%	0%	0%	23%
1980	Above Normal	17%	5%	0%	-30%	8%	5%	0%	0%	-1%	-19%	-25%	822%
1981	Dry	-2%	2%	0%	0%	0%	-15%	0%	0%	0%	0%	0%	0%
1982	Wet	5%	0%	0%	0%	-1%	2%	0%	-15%	-10%	0%	0%	0%
1983	Wet	9%	7%	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1984	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1985	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1986	Wet	0%	0%	0%	0%	-24%	15%	-2%	-13%	-2%	0%	31%	-17%
1987	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	-4%	0%	0%
1988	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1989	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	-2%	0%
1990	Critical	1%	0%	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1991	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1992	Critical	0%	0%	0%	-1%	0%	0%	0%	0%	0%	0%	0%	0%
1993	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1994	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1995	Wet	0%	0%	0%	0%	0%	0%	-13%	-58%	-14%	0%	0%	0%
1996	Wet	0%	0%	0%	0%	0%	-5%	0%	0%	0%	0%	0%	0%
1997	Wet	0%	-4%	0%	0%	0%	-1%	0%	-8%	-4%	0%	0%	0%
1998	Wet	0%	0%	0%	0%	0%	0%	-8%	-13%	0%	0%	0%	0%
1999	Wet	0%	0%	0%	0%	-2%	0%	0%	0%	0%	0%	0%	-5%
2000	Above Normal	0%	0%	0%	0%	-1%	-1%	0%	0%	0%	0%	0%	0%
2001	Dry	0%	0%	-4%	0%	0%	0%	0%	0%	0%	5%	-1%	0%
2002	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	1%
2003	Above Normal	0%	-1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Average		1%	-1%	0%	-1%	0%	0%	-1%	-3%	-1%	-2%	3%	11%
Wet		0%	0%	-1%	-3%	0%	0%	-3%	-8%	-3%	0%	1%	1%
Above Normal		0%	0%	0%	-3%	0%	0%	-2%	-2%	-2%	-2%	69%	
Below Normal		3%	1%	0%	-2%	0%	-1%	-1%	-2%	1%	0%	0%	2%
Dry		0%	-1%	-1%	0%	0%	-1%	0%	-1%	1%	0%	5%	1%
Critical		0%	-4%	7%	3%	1%	0%	0%	0%	0%	-9%	15%	0%

Energy Use (GWh) At Pumping Plant at SWP Dos Amigos: Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Total
1922	Above Normal	39.20	49.47	27.00	7.25	13.46	22.05	30.16	34.24	43.51	43.87	44.42	31.55	386.18
1923	Below Normal	29.11	35.32	21.37	34.85	34.36	33.65	24.76	32.29	42.86	47.34	43.54	28.72	408.17
1924	Critical	29.35	18.38	15.72	11.27	11.41	10.06	13.65	17.60	23.72	28.21	20.70	13.54	213.61
1925	Dry	7.05	5.33	4.80	3.47	5.38	20.51	23.37	33.71	45.02	50.52	52.14	29.62	280.92
1926	Dry	21.08	18.26	15.27	6.87	8.24	11.83	17.48	29.26	38.85	43.51	42.92	25.70	279.27
1927	Wet	18.09	15.60	12.96	6.64	11.29	25.30	31.70	36.26	45.64	45.97	46.49	33.45	329.39
1928	Above Normal	28.17	34.19	23.07	28.94	28.84	17.97	31.34	35.42	44.37	44.85	45.09	32.58	394.83
1929	Critical	27.30	32.60	22.29	26.16	24.63	13.92	11.51	16.21	21.54	22.94	18.82	12.26	250.18
1930	Dry	6.53	5.02	4.54	3.14	6.13	8.31	19.34	25.22	33.87	37.14	36.91	21.09	207.24
1931	Critical	13.41	11.05	9.13	5.39	6.60	7.80	15.51	20.12	27.20	31.63	23.79	15.36	186.99
1932	Dry	8.06	6.32	5.60	4.35	7.21	10.33	19.81	25.77	34.40	38.41	38.26	22.27	220.79
1933	Critical	15.10	12.84	10.59	5.88	7.13	9.59	17.41	23.61	32.11	36.43	28.94	18.80	218.43
1934	Critical	10.95	8.43	6.92	4.95	5.73	8.15	16.53	21.46	29.13	34.28	12.91	3.39	162.83
1935	Below Normal	11.83	19.27	14.94	4.71	6.88	9.85	25.64	33.84	35.80	52.72	47.43	31.50	294.41
1936	Below Normal	27.70	19.63	16.37	7.14	9.55	36.01	30.03	37.69	47.41	47.77	48.33	42.65	370.28
1937	Below Normal	29.38	26.08	24.07	29.42	46.60	49.96	31.16	34.32	45.48	49.98	56.49	35.20	458.14
1938	Wet	29.19	25.79	23.89	48.65	50.02	52.87	25.39	40.85	50.88	54.97	56.70	34.69	493.89
1939	Dry	34.21	33.19	23.57	34.95	34.34	38.58	28.83	33.37	31.14	51.85	46.24	34.41	424.68
1940	Above Normal	25.66	16.23	25.08	5.04	6.13	13.54	25.50	34.17	41.73	52.06	46.76	30.71	322.61
1941	Wet	23.52	25.17	15.93	11.31	15.60	34.98	26.73	30.10	40.27	44.83	45.47	31.32	345.23
1942	Wet	35.14	26.67	20.37	35.63	35.51	40.02	34.51	34.86	44.68	45.11	45.71	32.09	430.30
1943	Wet	33.76	31.44	21.63	29.47	34.86	33.52	34.62	35.32	46.66	51.20	51.86	36.28	440.62
1944	Dry	38.13	33.71	24.72	25.03	23.50	15.09	20.00	26.17	34.73	38.60	38.76	22.41	340.85
1945	Below Normal	14.95	12.62	10.46	7.10	8.12	46.91	29.98	36.25	45.64	45.99	46.49	42.49	347.00
1946	Below Normal	30.13	24.98	30.99	32.44	26.00	27.62	29.95	34.55	43.58	43.95	44.55	39.66	408.40
1947	Dry	29.77	23.69	21.80	29.11	28.56	18.75	29.28	35.51	45.95	49.07	54.57	31.89	397.95
1948	Below Normal	24.77	21.75	19.14	16.90	16.31	10.89	16.58	25.71	19.65	49.71	45.05	30.91	297.37
1949	Dry	26.35	19.46	16.11	7.69	8.55	10.94	29.54	35.39	45.71	48.44	56.85	31.91	336.94
1950	Below Normal	25.05	22.03	19.52	8.03	8.34	9.48	23.35	30.47	17.60	50.72	45.74	30.85	291.18
1951	Above Normal	28.58	18.30	17.71	50.62	47.00	52.39	28.01	35.70	45.12	45.44	46.06	32.99	447.92
1952	Wet	30.82	32.28	22.16	34.81	35.48	27.39	21.73	29.09	38.70	43.35	44.10	30.44	390.35
1953	Wet	28.79	35.09	35.80	36.02	35.42	39.50	33.51	32.20	41.23	43.38	42.04	29.09	432.07
1954	Above Normal	26.34	24.31	18.05	21.67	22.41	22.64	25.73	33.76	44.47	49.76	46.02	30.06	365.22
1955	Dry	23.81	23.16	15.50	7.65	9.49	12.58	21.69	28.42	37.76	42.42	46.06	24.91	293.45
1956	Wet	17.42	15.02	12.48	38.11	48.91	53.00	32.22	39.38	50.11	50.50	51.20	36.38	444.73
1957	Above Normal	36.32	35.70	25.05	33.52	32.24	21.90	21.53	23.10	11.91	50.23	44.91	29.64	366.05
1958	Wet	21.02	22.41	15.07	6.65	17.69	43.15	33.74	41.72	50.01	54.57	55.31	38.26	399.60
1959	Below Normal	31.81	45.61	25.91	34.11	33.48	35.14	24.60	32.12	31.49	50.78	45.67	30.35	421.07
1960	Dry	27.62	18.87	15.70	6.66	7.11	9.62	27.65	35.76	39.68	54.49	48.36	35.34	326.86
1961	Dry	26.04	22.77	19.13	8.80	9.58	9.50	23.19	30.24	40.28	45.12	44.86	19.32	298.83
1962	Below Normal	6.80	21.69	24.18	4.07	4.96	12.43	23.53	30.98	19.60	51.20	46.19	31.21	276.84
1963	Wet	22.42	19.47	16.20	14.93	17.85	23.89	29.58	34.31	43.27	43.62	44.23	31.71	341.48
1964	Dry	26.51	23.50	41.07	26.22	19.59	20.33	31.52	35.41	44.58	44.92	53.45	32.70	399.80
1965	Wet	27.51	24.37	22.48	28.55	30.96	25.36	28.71	32.77	40.81	42.56	42.42	30.20	376.70
1966	Below Normal	36.20	24.44	20.06	31.15	33.10	25.84	25.11	32.64	42.19	50.03	44.45	29.11	394.32
1967	Wet	28.46	18.29	9.25	8.84	14.06	19.50	32.37	33.64	44.34	48.84	49.47	34.76	341.82
1968	Below Normal	28.95	43.25	24.67	35.05	36.05	37.25	28.80	32.17	42.23	45.45	42.83	28.90	425.60
1969	Wet	28.21	19.29	16.84	24.64	26.41	31.53	23.86	30.10	40.27	52.21	52.38	33.43	379.17
1970	Wet	32.46	22.66	19.94	53.81	48.62	53.39	29.25	35.55	44.88	45.20	45.81	36.81	468.38
1971	Wet	33.13	25.93	22.49	34.79	34.14	28.04	23.98	31.98	42.78	48.40	43.51	28.19	397.36
1972	Below Normal	25.69	17.67	14.44	7.56	15.17	21.73	26.18	33.37	44.28	48.82	44.73	29.58	329.22
1973	Above Normal	29.00	18.93	16.15	10.91	21.99	28.85	29.16	36.50	46.03	46.28	46.87	33.66	364.33
1974	Wet	28.34	25.13	23.18	35.11	35.21	37.05	32.97	37.45	48.09	48.46	49.13	34.49	434.61
1975	Wet	28.69	40.93	23.40	34.09	33.04	34.62	31.64	35.60	44.82	45.08	45.59	32.84	430.34
1976	Critical	27.57	35.37	22.58	28.68	28.37	18.53	24.23	31.81	29.60	52.26	38.72	32.43	370.15
1977	Critical	23.43	20.45	16.94	6.59	7.08	7.41	7.77	3.84	1.44	3.75	1.52	10.31	110.53
1978	Above Normal	2.36	13.35	24.00	3.97	7.58	20.44	22.77	19.88	36.82	42.49	42.95	30.68	267.29
1979	Below Normal	31.64	33.07	20.83	28.08	30.98	38.20	28.61	35.67	45.36	45.68	46.19	42.48	426.79
1980	Above Normal	27.29	24.13	22.29	30.25	35.59	33.26	22.60	30.58	44.38	43.31	60.78	34.26	408.72
1981	Dry	27.09	23.76	21.78	33.42	33.75	24.73	23.63	31.50	23.85	51.13	50.96	31.73	377.33
1982	Wet	22.81	19.90	16.49	13.83	17.43	52.92	47.06	39.39	52.83	53.38	54.11	37.24	427.39
1983	Wet	36.82	41.74	38.19	31.79	27.65	26.95	16.95	14.19	22.78	39.16	39.62	26.94	362.78
1984	Wet	48.18	47.68	55.09	54.35	51.25	52.37	28.18	35.98	45.33	45.74	46.36	33.29	543.80
1985	Dry	27.93	24.80	31.84	31.31	30.92	30.43	29.49	33.95	42.80	43.06	51.97	31.31	409.81
1986	Wet	26.21	23.25	21.40	27.27	25.77	37.98	30.72	37.95	47.76	48.46	61.26	34.98	423.01
1987	Dry	29.26	25.82	23.74	33.53	32.16	17.96	17.04	22.29	30.20	36.79	26.31	17.24	312.34
1988	Critical	9.47	7.08	6.22	4.20	6.39	6.98	11.89	15.26	20.31	21.82	17.74	11.81	139.17
1989	Dry	6.01	4.66	4.23	2.93	5.59	6.96	26.60	35.29	40.70	54.12	52.50	32.92	272.51
1990	Critical	23.73	20.64	17.20	6.89	7.74	8.69	15.01	19.50	26.33	28.03	22.95	15.08	211.79
1991	Critical	8.05	6.00	5.40	3.78	5.31	6.81	12.07	14.90	15.74	27.47	19.47	13.16	138.16
1992	Critical	6.73	4.87	4.59	3.31	5.10	6.58	11.91	15.19	20.09	13.02	1.66	15.93	108.98
1993	Above Normal	15.76	4.02	18.12	4.23	14.21	20.88	27.84	33.40	36.04	47.09	45.24	31.47	298.30
1994	Critical	28.41	28.31	19.39	20.06	19.55	16.01	22.17	28.83	35.17	43.98	33.38	26.34	321.60
1995	Wet	7.44	16.02	28.66	4.03	12.45	16.67	34.28	39.76	50.66	51.43	52.08	36.59	350.07
1996	Wet	36.10	38.26	25.03	32.58	33.89	31.18	32.24	36.29	45.83	46.18	46.77	33.50	437.85
1997	Wet	40.67	24.95	23.02	34.95	34.85	47.51	30.31	36.33	46.79	47.27	47.92	33.34	447.91
1998	Wet	31.31	34.60	22.40	33.10	35.04	35.91	30.80	38.62	50.50	51.20	51.89	35.33	450.70
1999	Wet	29.90	52.43	31.99	35.79	49.62	39.12	30.47	35.64	44.94	45.40	46.04	38.66	480.00
2000	Above Normal	30.29	25.48	22.62	30.29	29.91	24.16	26.89	34.49	45.64	50.43	46.18	30.63	397.01
2001	Dry	26.70	24.75	16.80	10.83	10.80	10.12	17.22	22.66	30.77	39.88	26.93	17.59	255.05
2002	Dry	9.62	7.24	6.32	3.93	8.24	12.99	31.93	35.67	44.65	45.06	51.87	32.95	290.47
2003	Above Normal	27												

Energy Use (GWh) At Pumping Plant at SWP Dos Amigos: Alternative1_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Total
1922	Above Normal	39.20	49.47	27.00	10.40	14.10	22.85	31.91	37.25	49.86	50.35	51.01	35.75	419.15
1923	Below Normal	33.40	37.67	24.51	35.64	35.10	39.26	32.14	21.39	21.88	53.57	50.88	36.16	421.60
1924	Critical	36.61	25.37	22.27	18.08	16.39	12.07	15.52	20.18	22.20	17.19	1.62	4.41	211.91
1925	Dry	18.61	22.99	29.32	5.78	6.90	9.76	22.05	28.80	38.79	43.46	44.88	25.70	297.04
1926	Dry	18.12	15.72	13.15	7.99	8.43	12.63	18.47	32.29	40.04	49.07	48.59	29.06	293.56
1927	Wet	12.51	22.79	18.67	7.58	10.55	25.16	30.95	35.37	41.79	47.13	47.64	34.91	335.05
1928	Above Normal	29.72	35.55	24.63	30.13	28.24	17.35	30.09	35.61	29.84	51.43	49.99	35.99	398.57
1929	Critical	29.43	34.57	23.52	22.20	20.56	13.21	13.80	18.06	24.27	7.03	6.25	5.95	218.85
1930	Dry	9.34	7.37	27.59	5.08	6.24	8.44	19.11	24.94	22.82	39.27	38.70	22.82	231.72
1931	Critical	14.44	11.85	9.75	5.96	6.83	8.09	15.48	20.09	27.19	31.62	9.61	3.42	164.33
1932	Dry	7.86	11.68	24.68	5.16	7.29	10.66	19.94	25.93	36.12	40.28	36.12	28.28	254.00
1933	Critical	17.07	14.83	12.51	7.96	7.38	9.36	16.70	22.87	31.49	35.31	27.70	18.03	221.21
1934	Critical	10.02	7.70	6.65	4.95	5.99	8.73	17.39	22.65	30.86	36.01	4.18	3.93	159.06
1935	Below Normal	16.90	23.01	18.11	5.09	7.12	10.21	26.27	34.73	27.52	57.52	52.52	35.91	314.91
1936	Below Normal	31.46	23.26	19.60	8.41	9.29	24.07	32.41	37.58	48.81	49.16	49.73	43.27	377.05
1937	Below Normal	31.71	27.56	25.56	29.22	38.77	50.69	30.87	34.06	46.78	51.28	57.81	36.51	460.82
1938	Below Normal	30.48	27.11	23.65	35.22	50.12	53.78	25.65	33.39	45.22	51.34	52.04	35.88	463.88
1939	Dry	34.48	38.85	24.84	36.30	34.09	37.94	27.16	33.80	34.59	53.44	46.86	36.12	438.47
1940	Above Normal	27.39	14.55	28.38	5.62	5.29	13.27	25.49	34.16	43.21	53.58	48.28	32.24	331.46
1941	Wet	25.10	27.15	16.65	11.32	15.60	33.95	26.73	30.10	41.84	46.40	47.03	32.89	354.76
1942	Wet	36.59	28.08	21.14	35.62	35.48	39.84	34.42	34.62	45.87	46.30	46.89	33.45	438.30
1943	Wet	35.18	32.81	23.07	29.64	34.75	33.88	34.98	35.10	47.83	52.37	53.01	37.65	450.27
1944	Dry	39.28	35.36	26.18	23.61	20.81	14.18	19.94	26.10	35.67	39.50	39.48	23.32	343.43
1945	Below Normal	15.84	13.50	11.37	8.08	8.10	42.12	30.02	36.29	47.26	47.60	48.10	43.65	351.93
1946	Below Normal	31.82	26.58	32.86	34.01	26.00	27.71	30.07	34.70	45.34	45.71	46.31	41.73	422.84
1947	Dry	30.83	25.37	23.47	30.84	28.59	18.72	29.19	35.52	46.65	49.88	55.33	32.50	406.89
1948	Below Normal	25.30	22.28	19.65	17.13	15.94	10.76	16.60	26.17	19.64	49.80	45.13	30.95	299.35
1949	Dry	26.34	19.47	16.13	7.69	8.56	10.92	29.52	35.39	45.77	48.53	56.93	31.94	337.19
1950	Below Normal	25.06	22.04	19.52	7.79	8.10	9.40	23.34	30.46	18.25	51.39	46.42	31.52	293.29
1951	Above Normal	29.24	18.97	17.48	50.62	47.00	52.39	28.01	35.70	46.68	47.00	47.63	34.55	455.27
1952	Wet	32.39	33.85	23.73	36.38	35.48	27.39	21.73	27.92	37.47	43.64	44.26	30.86	395.10
1953	Wet	30.03	35.16	39.42	37.21	34.99	36.92	28.97	32.01	42.52	44.31	43.34	30.64	435.52
1954	Above Normal	28.09	25.69	19.89	24.41	23.65	23.65	25.91	34.01	45.94	50.26	46.70	30.61	378.81
1955	Dry	24.26	23.83	16.00	8.14	9.49	12.55	21.53	28.20	37.63	42.25	45.90	24.89	294.67
1956	Wet	17.44	15.06	12.54	31.33	48.91	53.00	32.24	39.40	51.70	52.09	52.79	37.97	444.47
1957	Above Normal	37.92	37.27	26.64	35.09	32.23	21.88	21.54	23.16	13.42	51.64	46.36	31.20	378.35
1958	Wet	22.59	23.98	16.64	8.17	17.69	43.10	33.74	41.72	51.58	56.14	56.88	39.83	412.06
1959	Below Normal	33.37	46.64	27.48	35.67	33.45	34.21	24.01	31.33	27.81	50.97	45.94	30.96	421.84
1960	Dry	28.23	19.55	16.36	7.28	7.02	9.68	27.76	35.77	40.51	54.13	49.09	34.88	330.26
1961	Dry	25.80	22.56	19.01	9.24	9.97	9.66	23.24	30.30	40.37	45.22	45.13	19.32	299.82
1962	Below Normal	6.79	21.70	24.18	4.07	4.96	12.43	23.53	30.98	21.11	52.72	47.71	32.73	282.91
1963	Wet	23.94	20.98	17.72	16.44	17.85	23.89	29.58	34.31	44.83	45.19	45.80	33.27	353.80
1964	Dry	28.08	25.06	42.54	27.78	19.59	20.38	31.51	35.39	44.59	44.92	53.48	32.71	406.03
1965	Wet	27.52	24.39	22.49	28.67	31.01	25.17	28.69	32.80	42.05	44.31	44.11	31.84	383.05
1966	Below Normal	37.80	25.38	21.65	32.55	32.93	25.76	25.11	32.65	43.33	51.22	45.63	30.27	404.28
1967	Wet	29.45	19.45	10.41	9.97	14.05	19.50	32.38	33.56	44.21	50.27	50.90	36.25	350.40
1968	Below Normal	30.46	43.60	25.15	36.54	35.98	37.26	28.44	32.19	44.07	47.97	44.63	30.21	436.50
1969	Wet	29.08	20.18	17.60	19.24	27.21	31.52	23.72	29.94	40.07	53.78	53.95	34.84	381.13
1970	Wet	33.92	24.10	21.39	53.82	50.11	53.36	28.65	35.68	46.62	46.94	47.55	38.46	480.60
1971	Wet	34.77	27.70	24.16	36.36	34.15	28.11	23.93	31.92	43.42	49.32	44.43	29.15	407.42
1972	Below Normal	26.66	18.61	15.40	8.53	15.19	21.74	26.18	33.36	44.29	48.83	44.74	29.60	333.13
1973	Above Normal	29.03	18.96	16.18	10.96	22.01	28.89	29.13	36.51	47.60	47.85	48.44	35.24	370.80
1974	Wet	29.91	26.70	24.75	36.67	35.19	36.97	32.56	36.76	48.58	48.93	49.58	35.45	442.05
1975	Wet	29.80	41.64	24.59	35.11	32.70	33.61	31.97	35.98	46.88	47.13	47.65	34.76	441.82
1976	Critical	29.46	37.32	24.42	30.55	28.60	18.57	24.11	31.64	29.47	52.26	38.42	32.20	377.02
1977	Critical	23.24	20.28	16.79	6.58	7.07	7.40	8.40	3.86	1.45	3.75	1.50	10.31	110.63
1978	Above Normal	2.36	13.34	24.01	3.97	7.58	19.87	22.14	19.95	39.07	45.94	45.10	32.00	275.33
1979	Below Normal	32.27	32.71	21.12	24.97	23.23	28.90	31.23	35.61	46.71	47.00	47.51	44.04	415.30
1980	Above Normal	28.91	25.76	23.92	29.10	35.55	35.08	21.12	29.42	44.67	54.27	51.94	33.27	413.01
1981	Dry	27.62	24.45	22.59	35.27	33.47	27.63	24.17	32.28	29.77	53.20	51.67	33.67	395.79
1982	Wet	24.66	21.71	18.28	15.47	17.50	52.90	47.06	39.40	54.41	54.96	55.69	38.81	440.85
1983	Wet	32.36	47.78	38.19	31.79	27.65	26.95	16.95	14.19	22.78	39.16	41.18	28.51	367.49
1984	Wet	44.71	47.68	55.09	54.35	51.25	52.37	28.18	35.98	46.90	47.31	47.93	34.85	546.60
1985	Dry	29.49	26.37	33.41	32.87	30.92	30.43	29.49	33.95	43.87	44.13	53.05	32.38	420.36
1986	Wet	27.29	24.32	22.47	28.34	25.77	30.43	32.43	37.97	49.35	50.05	62.11	36.57	427.10
1987	Dry	30.85	28.20	25.32	35.10	32.17	17.97	16.49	21.53	29.86	36.33	26.10	17.39	317.31
1988	Critical	9.82	7.51	6.73	4.84	6.35	6.96	11.89	15.26	20.31	21.76	17.74	11.81	140.98
1989	Dry	6.01	4.66	4.23	2.93	5.58	6.95	26.57	35.26	40.54	54.10	51.72	33.15	271.70
1990	Critical	23.91	20.82	17.33	6.89	7.73	8.69	15.01	19.50	26.34	28.04	22.95	15.09	212.30
1991	Critical	8.06	6.01	5.41	3.78	5.31	6.81	12.07	14.66	15.74	27.33	19.72	13.21	138.11
1992	Critical	6.76	4.63	4.77	3.41	5.10	6.58	11.90	15.19	20.09	12.67	1.45	15.99	108.54
1993	Above Normal	15.79	4.02	18.55	4.23	14.19	20.80	27.82	33.41	37.34	48.78	46.89	33.10	304.92
1994	Critical	30.04	29.80	20.94	21.48	19.42	15.96	22.17	28.83	35.23	44.00	33.42	26.37	327.66
1995	Wet	7.46	16.05	28.68	4.05	12.45	16.67	34.28	39.76	52.23	52.99	53.65	38.15	356.42
1996	Wet	37.68	38.84	26.42	20.33	22.73	25.91	31.48	35.39	46.16	46.50	47.09	34.25	412.78
1997	Wet	40.93	25.90	23.79	34.87	34.79	49.05	30.42	36.38	48.41	48.88	49.53	34.96	457.91
1998	Wet	32.93	36.22	24.01	34.70	35.02	35.85	30.73	36.13	46.86	47.46	49.64	34.70	444.25
1999	Wet	42.30	54.00	33.28	36.96	49.37	39.12	29.17	35.75	46.67	47.12	47.77	40.94	502.45
2000	Above Normal	32.34	26.23	24.26	31.99	30.09	23.90	26.71	34.48	47.28	52.31	47.81	32.09	409.49
2001	Dry	27.99	26.07	18.07	11.47	10.00	9.90	17.35	22.83	31.17	40.32	27.30	17.88	260.35
2002	Dry	9.86	7.46	6.52	4.09	8.26	12.97	31.84	35.56	44.54	44.95	51.75	32.87	290.67
2003	Above Normal	27												

Difference in Energy Use (GWh) At Pumping Plant at SWP Dos Amigos: Alternative1_2005 minus Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Average
1922	Above Normal	0.00	0.00	0.00	3.15	0.64	0.80	1.75	3.01	6.35	6.48	6.59	4.20	2.75
1923	Below Normal	4.29	2.35	3.14	0.79	0.74	5.61	7.38	(10.90)	(20.98)	6.23	7.34	7.44	1.12
1924	Critical	7.26	6.99	6.55	6.81	4.98	2.01	1.87	2.58	(1.52)	(11.02)	(19.08)	(9.13)	(0.14)
1925	Dry	11.56	17.66	24.52	2.31	1.52	(10.75)	(1.32)	(4.91)	(6.23)	(7.06)	(7.26)	(3.92)	1.34
1926	Dry	(2.96)	(2.54)	(2.12)	1.12	0.19	0.80	0.99	3.03	1.19	5.56	5.67	3.36	1.19
1927	Wet	(5.58)	7.19	5.71	0.94	(0.74)	(0.14)	(0.75)	(0.89)	(3.85)	1.16	1.15	1.46	0.47
1928	Above Normal	1.55	1.36	1.56	1.19	(0.60)	(0.62)	(1.25)	0.19	(14.53)	6.58	4.90	3.41	0.31
1929	Critical	2.13	1.97	1.23	(3.96)	(4.07)	(0.71)	2.29	1.85	2.73	(15.91)	(12.57)	(6.31)	(2.61)
1930	Dry	2.81	2.35	23.05	1.94	0.11	0.13	(0.23)	(0.28)	(11.05)	2.13	1.79	1.73	2.04
1931	Critical	1.03	0.80	0.62	0.57	0.23	0.29	(0.03)	(0.03)	(0.01)	(0.01)	(14.18)	(11.94)	(1.89)
1932	Dry	(0.20)	5.36	19.08	0.81	0.08	0.33	0.13	0.16	1.72	1.87	(2.14)	6.01	2.77
1933	Critical	1.97	1.99	1.92	2.08	0.25	(0.23)	(0.71)	(0.74)	(0.62)	(1.12)	(1.24)	(0.77)	0.23
1934	Critical	(0.93)	(0.73)	(0.27)	0.00	0.26	0.58	0.86	1.19	1.73	1.73	(8.73)	0.54	(0.31)
1935	Below Normal	5.07	3.74	3.17	0.38	0.24	0.36	0.63	0.89	(8.28)	4.80	5.09	4.41	1.71
1936	Below Normal	3.76	3.63	3.23	1.27	(0.26)	(11.94)	2.38	(0.11)	1.40	1.39	1.40	0.62	0.56
1937	Below Normal	2.33	1.48	1.49	(0.20)	(7.83)	0.73	(0.29)	(0.26)	1.30	1.30	1.32	1.31	0.22
1938	Wet	1.29	1.32	(0.24)	(13.43)	0.10	0.91	0.26	(7.46)	(5.66)	(3.63)	(4.66)	1.19	(2.50)
1939	Dry	0.27	5.66	1.27	1.35	(0.25)	(0.64)	(1.67)	0.43	3.45	1.59	0.62	1.71	1.15
1940	Above Normal	1.73	(1.68)	3.30	0.58	(0.84)	(0.27)	(0.01)	(0.01)	1.48	1.52	1.52	1.53	0.74
1941	Wet	1.58	1.98	0.72	0.01	0.00	(1.03)	0.00	0.00	1.57	1.57	1.56	1.57	0.79
1942	Wet	1.45	1.41	0.77	(0.01)	(0.03)	(0.18)	(0.09)	(0.24)	1.19	1.19	1.18	1.36	0.67
1943	Wet	1.42	1.37	1.44	0.17	(0.11)	0.36	0.36	(0.22)	1.17	1.17	1.15	1.37	0.80
1944	Dry	1.15	1.65	1.46	(1.42)	(2.69)	(0.91)	(0.06)	(0.07)	0.94	0.90	0.72	0.91	0.22
1945	Below Normal	0.89	0.88	0.91	0.98	(0.02)	(4.79)	0.04	0.04	1.62	1.61	1.61	1.16	0.41
1946	Below Normal	1.69	1.60	1.87	1.57	0.00	0.09	0.12	0.15	1.76	1.76	1.76	2.07	1.20
1947	Dry	1.06	1.68	1.67	1.73	0.03	(0.03)	(0.09)	0.01	0.70	0.81	0.76	0.61	0.75
1948	Below Normal	0.53	0.53	0.51	0.23	(0.37)	(0.13)	0.02	0.46	(0.01)	0.09	0.08	0.04	0.17
1949	Dry	(0.01)	0.01	0.02	0.00	0.01	(0.02)	(0.02)	0.00	0.06	0.09	0.08	0.03	0.02
1950	Below Normal	0.01	0.01	0.00	(0.24)	(0.24)	(0.08)	(0.01)	(0.01)	0.65	0.67	0.68	0.67	0.18
1951	Above Normal	0.66	0.67	(0.23)	0.00	0.00	0.00	0.00	0.00	1.56	1.56	1.57	1.56	0.61
1952	Wet	1.57	1.57	1.57	1.57	0.00	0.00	0.00	(1.17)	(1.23)	0.29	0.16	0.42	0.40
1953	Wet	1.24	0.07	3.62	1.19	(0.43)	(2.58)	(4.54)	(0.19)	1.29	0.93	1.30	1.55	0.29
1954	Above Normal	1.75	1.38	1.84	2.74	1.24	1.01	0.18	0.25	1.47	0.50	0.68	0.55	1.13
1955	Dry	0.45	0.67	0.50	0.49	0.00	(0.03)	(0.16)	(0.22)	(0.13)	(0.17)	(0.16)	(0.02)	0.10
1956	Wet	0.02	0.04	0.06	(6.78)	0.00	0.00	0.02	0.02	1.59	1.59	1.59	1.59	(0.02)
1957	Above Normal	1.60	1.57	1.59	1.57	(0.01)	(0.02)	0.01	0.06	1.51	1.41	1.45	1.56	1.03
1958	Wet	1.57	1.57	1.57	1.52	0.00	(0.05)	0.00	0.00	1.57	1.57	1.57	1.57	1.04
1959	Below Normal	1.56	1.03	1.57	1.56	(0.03)	(0.93)	(0.59)	(0.79)	(3.68)	0.19	0.27	0.61	0.06
1960	Dry	0.61	0.68	0.66	0.62	(0.09)	0.06	0.11	0.01	0.83	(0.36)	0.73	(0.46)	0.28
1961	Dry	(0.24)	(0.21)	(0.12)	0.44	0.39	0.16	0.05	0.06	0.09	0.10	0.27	0.00	0.08
1962	Below Normal	(0.01)	0.01	0.00	0.00	0.00	0.00	0.00	0.00	1.51	1.52	1.52	1.52	0.51
1963	Wet	1.52	1.51	1.52	1.51	0.00	0.00	0.00	0.00	1.56	1.57	1.57	1.56	1.03
1964	Dry	1.57	1.56	1.47	1.56	0.00	0.05	(0.01)	(0.02)	0.01	0.00	0.03	0.01	0.52
1965	Wet	0.01	0.02	0.01	0.12	0.05	(0.19)	(0.02)	0.03	1.24	1.75	1.69	1.64	0.53
1966	Below Normal	1.60	0.94	1.59	1.40	(0.17)	(0.08)	0.00	0.01	1.14	1.19	1.18	1.16	0.83
1967	Wet	0.99	1.16	1.16	1.13	(0.01)	0.00	0.01	(0.08)	(0.13)	1.43	1.43	1.49	0.72
1968	Below Normal	1.51	0.35	0.48	1.49	(0.07)	0.01	(0.36)	0.02	1.84	2.52	1.80	1.31	0.91
1969	Wet	0.87	0.89	0.76	(5.40)	0.80	(0.01)	(0.14)	(0.16)	(0.20)	1.57	1.57	1.41	0.16
1970	Wet	1.46	1.44	1.45	0.01	1.49	(0.03)	(0.60)	0.13	1.74	1.74	1.74	1.65	1.02
1971	Wet	1.64	1.77	1.67	1.57	0.01	0.07	(0.05)	(0.06)	0.64	0.92	0.92	0.96	0.84
1972	Below Normal	0.97	0.94	0.96	0.97	0.02	0.01	0.00	(0.01)	0.01	0.01	0.01	0.02	0.33
1973	Above Normal	0.03	0.03	0.03	0.05	0.02	0.04	(0.03)	0.01	1.57	1.57	1.57	1.58	0.54
1974	Wet	1.57	1.57	1.57	1.56	(0.02)	(0.08)	(0.41)	(0.69)	0.49	0.47	0.45	0.96	0.62
1975	Wet	1.11	0.71	1.19	1.02	(0.34)	(1.01)	0.33	0.38	2.06	2.05	2.06	1.92	0.96
1976	Critical	1.89	1.95	1.84	1.87	0.23	0.04	(0.12)	(0.17)	(0.13)	0.00	(0.30)	(0.23)	0.57
1977	Critical	(0.19)	(0.17)	(0.15)	(0.01)	(0.01)	(0.01)	0.63	0.02	0.01	0.00	(0.02)	0.00	0.01
1978	Above Normal	0.00	(0.01)	0.01	0.00	0.00	(0.57)	(0.63)	0.07	2.25	3.45	2.15	1.32	0.67
1979	Below Normal	0.63	(0.36)	0.29	(3.11)	(7.75)	(9.30)	2.62	(0.06)	1.35	1.32	1.32	1.56	(0.96)
1980	Above Normal	1.62	1.63	1.63	(1.15)	(0.04)	1.82	(1.48)	(1.16)	0.29	10.96	(8.84)	(0.99)	0.36
1981	Dry	0.53	0.69	0.81	1.85	(0.28)	2.90	0.54	0.78	5.92	2.07	0.71	1.94	1.54
1982	Wet	1.85	1.81	1.79	1.64	0.07	(0.02)	0.00	0.01	1.58	1.58	1.58	1.57	1.12
1983	Wet	(4.46)	6.04	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.56	1.57	0.39
1984	Wet	(3.47)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.57	1.57	1.57	1.56	0.23
1985	Dry	1.56	1.57	1.57	1.56	0.00	0.00	0.00	0.00	1.07	1.07	1.08	1.07	0.88
1986	Wet	1.08	1.07	1.07	1.07	0.00	(7.55)	1.71	0.02	1.59	1.59	0.85	1.59	0.34
1987	Dry	1.59	2.38	1.58	1.57	0.01	0.01	(0.55)	(0.76)	(0.34)	(0.46)	(0.21)	0.15	0.41
1988	Critical	0.35	0.43	0.51	0.64	(0.04)	(0.02)	0.00	0.00	0.00	(0.06)	0.00	0.00	0.15
1989	Dry	0.00	0.00	0.00	0.00	(0.01)	(0.01)	(0.03)	(0.03)	(0.16)	(0.02)	(0.78)	0.23	(0.07)
1990	Critical	0.18	0.18	0.13	0.00	(0.01)	0.00	0.00	0.00	0.01	0.01	0.00	0.01	0.04
1991	Critical	0.01	0.01	0.01	0.00	0.00	0.00	0.00	(0.24)	0.00	(0.14)	0.25	0.05	0.00
1992	Critical	0.03	(0.24)	0.18	0.10	0.00	0.00	(0.01)	0.00	0.00	(0.35)	(0.21)	0.06	(0.04)
1993	Above Normal	0.03	0.00	0.43	0.00	(0.02)	(0.08)	(0.02)	0.01	1.30	1.69	1.65	1.63	0.55
1994	Critical	1.63	1.49	1.55	1.42	(0.13)	(0.05)	0.00	0.00	0.06	0.02	0.04	0.03	0.51
1995	Wet	0.02	0.03	0.02	0.02	0.00	0.00	0.00	0.00	1.57	1.56	1.57	1.56	0.53
1996	Wet	1.58	0.58	1.39	(12.25)	(11.16)	(5.27)	(0.76)	(0.90)	0.33	0.32	0.32	0.75	(2.09)
1997	Wet	0.26	0.95	0.77	(0.08)	(0.06)	1.54	0.11	0.05	1.62	1.61	1.61	1.62	0.83
1998	Wet	1.62	1.62	1.61	1.60	(0.02)	(0.06)	(0.07)	(2.49)	(3.64)	(3.74)	(2.25)	(0.63)	(0.54)
1999	Wet	12.40	1.57	1.29	1.17	(0.25)	0.00	(1.30)	0.11	1.73	1.72	1.73	2.28	1.87
2000	Above Normal	2.05	0.75	1.64	1.70	0.18	(0.26)	(0.18)	(0.01)	1.64	1.88	1.63	1.46	1.04
2001	Dry	1.29	1.32	1.27	0.64	(0.80)	(0.22)	0.13	0.17	0.40	0.44	0.37	0.29	0.44
2002	Dry	0.24	0.22	0.20	0.16	0.02	(0.02)	(0.09)	(0.11)	(0.11)	(0.11)	(0.12)	(0.08)	0.02
2003	Above Normal	(0.07)	0.60	(0.71)	0.33	0.28	0.11	0.00	(0.01)	0.76	0.76	0.76	0.76	0.30
Average		1.18	1.44	1.88	0.29	(0.31)	(0.49)	0.08	(0.23)	(0.03)	0.83	0.15	0.78	0.46
Wet		0.95	1.51	1.25	(0.77)	(0.41)	(0.59)	(0.23)	(0.53)	0.44	0.91	0.96	1.37	0.40
Above Normal		0.91	0.53	0.92	0.85	0.07	0.16	(0.14)	0.20	0.47	3.20	1.30	1.55	0.84
Below Normal		1.77	1.22	1.37	0.51	(1.12)	(1.46)	0.85	(0.76)	(1.46)	1.76	1.81	1.71	0.52
Dry		1.18	2.26	4.27	0.93	(0.10)	(0.46)	(0.13)	(0.10)	(0.09)	0.47	0.12	0.75	0.76
Critical		1.28	1.22	1.18	0.79	0.14	0.16	0.40	0.37	0.19	(2.24)	(4.67)	(2.31)	(0.

Percent Difference in Energy Use (GWh) At Pumping Plant at SWP Dos Amigos: Alternative1_2005 minus Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September
1922	Above Normal	0%	0%	0%	43%	5%	4%	6%	9%	15%	15%	15%	13%
1923	Below Normal	15%	7%	15%	2%	2%	17%	30%	-34%	-49%	13%	17%	26%
1924	Critical	25%	38%	42%	60%	44%	20%	14%	15%	-6%	-39%	-92%	-67%
1925	Dry	164%	331%	511%	67%	26%	-52%	-6%	-15%	-14%	-14%	-14%	-13%
1926	Dry	-14%	-14%	-14%	16%	2%	7%	6%	10%	3%	13%	13%	13%
1927	Wet	-31%	46%	44%	14%	-7%	-1%	-2%	-2%	-8%	3%	2%	4%
1928	Above Normal	6%	4%	7%	4%	-2%	-3%	-4%	1%	-33%	15%	11%	10%
1929	Critical	8%	6%	6%	-15%	-17%	-5%	20%	11%	13%	-69%	-67%	-51%
1930	Dry	43%	47%	508%	62%	2%	2%	-1%	-1%	-33%	6%	5%	8%
1931	Critical	8%	7%	7%	11%	3%	4%	0%	0%	0%	0%	-60%	-78%
1932	Dry	-2%	85%	341%	19%	1%	3%	1%	1%	5%	5%	-6%	27%
1933	Critical	13%	15%	18%	35%	4%	-2%	-4%	-3%	-2%	-3%	-4%	-4%
1934	Critical	-8%	-9%	-4%	0%	5%	7%	5%	6%	6%	5%	-68%	16%
1935	Below Normal	43%	19%	21%	8%	3%	4%	2%	3%	-23%	9%	11%	14%
1936	Below Normal	14%	18%	20%	18%	-3%	-33%	8%	0%	3%	3%	3%	1%
1937	Below Normal	8%	6%	6%	-1%	-17%	1%	-1%	-1%	3%	3%	2%	4%
1938	Wet	4%	5%	-1%	-28%	0%	2%	1%	-18%	-11%	-7%	-8%	3%
1939	Dry	1%	17%	5%	4%	-1%	-2%	-6%	1%	11%	3%	1%	5%
1940	Above Normal	7%	-10%	13%	12%	-14%	-2%	0%	0%	4%	3%	3%	5%
1941	Wet	7%	8%	5%	0%	0%	-3%	0%	0%	4%	4%	3%	5%
1942	Wet	4%	5%	4%	0%	0%	0%	0%	-1%	3%	3%	3%	4%
1943	Wet	4%	4%	7%	1%	0%	1%	1%	-1%	3%	2%	2%	4%
1944	Dry	3%	5%	6%	-6%	-11%	-6%	0%	0%	3%	2%	2%	4%
1945	Below Normal	6%	7%	9%	14%	0%	-10%	0%	0%	4%	4%	3%	3%
1946	Below Normal	6%	6%	6%	5%	0%	0%	0%	0%	4%	4%	4%	5%
1947	Dry	4%	7%	8%	6%	0%	0%	0%	0%	2%	2%	1%	2%
1948	Below Normal	2%	2%	3%	1%	-2%	-1%	0%	2%	0%	0%	0%	0%
1949	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1950	Below Normal	0%	0%	0%	-3%	-3%	-1%	0%	0%	4%	1%	1%	2%
1951	Above Normal	2%	4%	-1%	0%	0%	0%	0%	0%	3%	3%	3%	5%
1952	Wet	5%	5%	7%	5%	0%	0%	0%	-4%	-3%	1%	0%	1%
1953	Wet	4%	0%	10%	3%	-1%	-7%	-14%	-1%	3%	2%	3%	5%
1954	Above Normal	7%	6%	10%	13%	6%	4%	1%	1%	3%	1%	1%	2%
1955	Dry	2%	3%	3%	6%	0%	0%	-1%	-1%	0%	0%	0%	0%
1956	Wet	0%	0%	0%	-18%	0%	0%	0%	0%	3%	3%	3%	4%
1957	Above Normal	4%	4%	6%	5%	0%	0%	0%	0%	13%	3%	3%	5%
1958	Wet	7%	7%	10%	23%	0%	0%	0%	0%	3%	3%	3%	4%
1959	Below Normal	5%	2%	6%	5%	0%	-3%	-2%	-2%	-12%	0%	1%	2%
1960	Dry	2%	4%	4%	9%	-1%	1%	0%	0%	2%	-1%	2%	-1%
1961	Dry	-1%	-1%	-1%	5%	4%	2%	0%	0%	0%	0%	1%	0%
1962	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	8%	3%	3%	5%
1963	Wet	7%	8%	9%	10%	0%	0%	0%	0%	4%	4%	4%	5%
1964	Dry	6%	7%	4%	6%	0%	0%	0%	0%	0%	0%	0%	0%
1965	Wet	0%	0%	0%	0%	0%	-1%	0%	0%	3%	4%	4%	5%
1966	Below Normal	4%	4%	8%	4%	-1%	0%	0%	0%	3%	2%	3%	4%
1967	Wet	3%	6%	13%	13%	0%	0%	0%	0%	0%	3%	3%	4%
1968	Below Normal	5%	1%	2%	4%	0%	0%	-1%	0%	4%	6%	4%	5%
1969	Wet	3%	5%	5%	-22%	3%	0%	-1%	-1%	0%	3%	3%	4%
1970	Wet	4%	6%	7%	0%	3%	0%	-2%	0%	4%	4%	4%	4%
1971	Wet	5%	7%	7%	5%	0%	0%	0%	0%	1%	2%	2%	3%
1972	Below Normal	4%	5%	7%	13%	0%	0%	0%	0%	0%	0%	0%	0%
1973	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	3%	3%	3%	5%
1974	Wet	6%	6%	7%	4%	0%	0%	-1%	-2%	1%	1%	1%	3%
1975	Wet	4%	2%	5%	3%	-1%	-3%	1%	1%	5%	5%	5%	6%
1976	Critical	7%	6%	8%	7%	1%	0%	0%	-1%	0%	0%	-1%	-1%
1977	Critical	-1%	-1%	-1%	0%	0%	0%	8%	1%	1%	0%	-1%	0%
1978	Above Normal	0%	0%	0%	0%	0%	-3%	-3%	0%	6%	8%	5%	4%
1979	Below Normal	2%	-1%	1%	-11%	-25%	-24%	9%	0%	3%	3%	3%	4%
1980	Above Normal	6%	7%	7%	-4%	0%	5%	-7%	-4%	1%	25%	-15%	-3%
1981	Dry	2%	3%	4%	6%	-1%	12%	2%	2%	25%	4%	1%	6%
1982	Wet	8%	9%	11%	12%	0%	0%	0%	0%	3%	3%	3%	4%
1983	Wet	-12%	14%	0%	0%	0%	0%	0%	0%	0%	0%	4%	6%
1984	Wet	-7%	0%	0%	0%	0%	0%	0%	0%	3%	3%	3%	5%
1985	Dry	6%	6%	5%	5%	0%	0%	0%	0%	3%	2%	2%	3%
1986	Wet	4%	5%	5%	4%	0%	-20%	6%	0%	3%	3%	1%	5%
1987	Dry	5%	9%	7%	5%	0%	0%	-3%	-3%	-1%	-1%	-1%	1%
1988	Critical	4%	6%	8%	15%	-1%	0%	0%	0%	0%	0%	0%	0%
1989	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	-1%	1%
1990	Critical	1%	1%	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1991	Critical	0%	0%	0%	0%	0%	0%	0%	-2%	0%	-1%	1%	0%
1992	Critical	0%	-5%	4%	3%	0%	0%	0%	0%	0%	-3%	-13%	0%
1993	Above Normal	0%	0%	2%	0%	0%	0%	0%	0%	4%	4%	4%	5%
1994	Critical	6%	5%	8%	7%	-1%	0%	0%	0%	0%	0%	0%	0%
1995	Wet	0%	0%	0%	0%	0%	0%	0%	0%	3%	3%	3%	4%
1996	Wet	4%	2%	6%	-38%	-33%	-17%	-2%	-2%	1%	1%	1%	2%
1997	Wet	1%	4%	3%	0%	0%	3%	0%	0%	3%	3%	3%	5%
1998	Wet	5%	5%	7%	5%	0%	0%	0%	-6%	-7%	-7%	-4%	-2%
1999	Wet	41%	3%	4%	3%	-1%	0%	-4%	0%	4%	4%	4%	6%
2000	Above Normal	7%	3%	7%	6%	1%	-1%	-1%	0%	4%	4%	4%	5%
2001	Dry	5%	5%	8%	6%	-7%	-2%	1%	1%	1%	1%	1%	2%
2002	Dry	2%	3%	3%	4%	0%	0%	0%	0%	0%	0%	0%	0%
2003	Above Normal	0%	3%	-2%	6%	3%	1%	0%	0%	4%	2%	2%	3%
Average		6%	10%	22%	6%	0%	-1%	1%	0%	0%	1%	-2%	1%
Wet		3%	6%	7%	0%	-1%	-2%	-1%	-1%	1%	2%	2%	4%
Above Normal		3%	2%	4%	7%	0%	0%	-1%	1%	2%	7%	3%	5%
Below Normal		8%	6%	7%	4%	-3%	-4%	3%	-2%	-3%	4%	4%	5%
Dry		13%	29%	78%	12%	1%	-2%	0%	0%	0%	1%	0%	3%
Critical		5%	6%	8%	10%	3%	2%	4%	2%	1%	-9%	-25%	-15%

Energy Use (GWh) At Pumping Plant at SWP San Luis: Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Total
1922	Above Normal	0.48	0.00	61.88	47.07	23.57	32.54	0.00	0.00	9.43	23.77	25.16	39.35	263.25
1923	Below Normal	9.58	0.00	29.02	0.00	0.00	0.00	0.00	0.00	0.00	11.86	18.74	34.87	104.07
1924	Critical	15.54	13.57	15.38	27.55	9.44	0.00	0.00	0.00	0.00	49.07	0.00	0.00	130.55
1925	Dry	16.11	28.65	54.99	48.79	28.52	31.08	0.00	0.00	0.00	13.96	0.00	38.27	260.37
1926	Dry	7.44	7.11	14.83	40.54	9.13	0.00	0.00	0.00	0.00	19.49	0.00	2.27	100.81
1927	Wet	0.00	71.98	36.59	26.25	41.86	9.48	0.00	0.00	0.00	19.41	21.34	35.83	262.74
1928	Above Normal	0.00	0.00	74.05	0.00	0.00	35.90	0.00	0.00	0.00	11.04	12.88	30.15	164.02
1929	Critical	4.89	0.00	31.31	0.00	0.00	16.16	0.00	0.00	0.00	0.00	0.00	0.00	52.36
1930	Dry	3.99	4.47	43.99	33.41	27.16	25.43	0.00	0.00	0.00	35.80	0.00	59.05	233.30
1931	Critical	4.93	4.53	4.72	44.04	18.58	0.00	0.00	0.00	0.00	5.17	0.00	0.00	81.97
1932	Dry	0.17	7.78	101.14	50.84	57.80	55.56	0.00	0.00	0.00	35.81	9.21	0.00	318.31
1933	Critical	6.03	5.66	16.05	36.30	73.34	5.65	0.00	0.00	0.00	0.00	0.00	0.00	143.03
1934	Critical	0.00	2.13	54.40	98.47	61.85	6.96	0.00	0.00	0.00	0.00	0.00	0.33	224.14
1935	Below Normal	0.19	8.53	26.99	47.36	29.95	20.66	0.00	0.00	0.00	6.29	15.69	33.37	189.03
1936	Below Normal	8.40	5.98	18.22	22.13	132.31	58.16	0.00	0.00	0.00	17.35	19.13	16.50	298.18
1937	Below Normal	19.08	0.00	69.40	26.04	42.11	0.72	0.00	0.00	0.00	13.63	0.00	0.00	170.98
1938	Wet	25.04	62.22	65.55	34.87	0.10	0.57	0.00	23.88	3.17	3.48	2.82	2.04	223.74
1939	Dry	0.00	0.00	58.50	0.00	0.00	0.00	0.00	0.00	0.00	3.55	0.00	22.34	84.39
1940	Above Normal	0.00	0.00	2.91	23.61	36.36	64.61	0.00	0.00	0.00	1.47	8.46	26.69	164.11
1941	Wet	5.19	0.00	31.34	40.64	105.42	66.48	0.00	0.00	0.00	22.70	23.82	33.42	329.01
1942	Wet	0.00	0.00	29.72	8.71	3.82	0.00	0.00	0.00	0.00	20.38	18.67	20.01	101.31
1943	Wet	0.00	0.00	20.63	35.87	19.47	66.10	0.00	0.00	0.00	5.51	8.15	19.37	175.10
1944	Dry	0.00	0.00	62.21	2.38	6.72	6.33	0.00	0.00	0.00	21.88	7.82	0.00	107.34
1945	Below Normal	2.89	66.17	45.15	44.88	53.55	16.11	0.00	0.00	0.00	17.64	19.02	18.92	284.33
1946	Below Normal	32.36	60.46	32.83	0.00	0.00	0.00	0.00	0.00	0.00	19.05	18.08	24.11	186.89
1947	Dry	26.29	32.70	30.96	0.00	0.00	0.00	0.00	0.00	0.00	8.20	0.00	24.63	122.78
1948	Below Normal	13.74	10.39	0.00	0.00	0.00	14.53	0.00	0.00	0.42	8.33	15.80	28.73	91.94
1949	Dry	6.32	4.80	38.58	39.70	36.91	8.16	0.00	0.00	0.00	9.48	0.00	24.75	168.70
1950	Below Normal	0.00	0.00	0.00	18.89	20.36	34.32	0.00	0.00	0.00	7.31	15.29	29.32	125.49
1951	Above Normal	35.37	71.17	103.02	0.00	0.11	0.71	0.00	0.00	0.00	5.73	12.34	23.56	252.01
1952	Wet	0.00	13.37	20.78	3.15	0.00	81.11	0.00	0.00	13.42	22.02	28.24	30.23	212.32
1953	Wet	0.00	0.00	48.22	0.00	0.00	0.00	0.00	0.00	0.00	16.74	21.14	36.40	122.50
1954	Above Normal	0.00	0.00	78.04	0.00	0.00	8.24	0.00	0.00	0.00	0.52	12.61	27.21	126.62
1955	Dry	5.36	11.90	83.27	45.83	28.80	13.48	0.00	0.00	0.00	21.43	0.00	19.40	229.47
1956	Wet	0.00	30.79	75.94	72.57	0.09	0.71	0.00	0.00	0.00	10.86	11.12	13.05	215.13
1957	Above Normal	0.00	0.00	63.89	0.00	0.00	0.00	0.00	0.00	0.47	3.83	15.06	28.18	111.43
1958	Wet	57.23	12.98	32.82	30.14	29.56	46.94	0.00	0.00	0.00	3.59	4.89	26.59	244.74
1959	Below Normal	0.00	0.00	64.93	0.00	0.00	0.00	0.00	0.00	0.00	5.76	11.79	29.50	111.98
1960	Dry	6.46	4.34	6.58	36.63	19.24	18.49	0.00	0.00	0.00	1.49	0.00	22.58	115.81
1961	Dry	0.00	13.76	71.67	35.06	9.76	35.51	0.00	0.00	0.00	14.15	0.00	0.28	180.19
1962	Below Normal	0.18	0.05	0.00	25.50	34.72	35.59	0.00	0.00	0.00	8.35	13.37	27.12	144.88
1963	Wet	54.15	68.91	28.54	9.16	7.14	9.63	0.00	0.00	0.00	23.70	25.61	39.35	266.19
1964	Dry	13.24	63.20	17.81	0.00	0.10	0.00	0.00	0.00	0.00	14.33	0.00	25.18	133.86
1965	Wet	0.00	0.50	16.67	29.74	0.05	16.76	0.00	0.00	0.00	16.84	18.83	27.82	127.21
1966	Below Normal	0.00	13.32	82.99	0.00	0.00	0.00	0.00	0.00	0.00	6.82	13.62	32.13	148.88
1967	Wet	0.00	20.44	42.50	43.76	26.86	38.18	0.00	0.00	16.54	15.09	17.00	35.89	256.26
1968	Below Normal	11.14	0.00	73.43	0.00	0.00	0.00	0.00	0.00	0.00	12.19	16.20	35.56	148.52
1969	Wet	21.33	25.46	88.80	24.61	0.08	0.65	0.00	12.49	3.12	3.66	3.19	2.21	185.60
1970	Wet	1.16	0.00	31.22	19.08	0.14	0.74	0.00	0.00	0.00	21.03	17.50	0.00	90.87
1971	Wet	0.00	34.42	19.43	0.00	0.00	7.04	0.00	0.00	0.00	9.43	17.35	32.62	120.29
1972	Below Normal	6.38	0.00	83.97	38.56	0.00	0.00	0.00	0.00	0.00	8.34	16.15	34.77	188.17
1973	Above Normal	19.82	67.76	30.26	26.46	23.23	8.39	0.00	0.00	0.00	15.64	16.62	10.38	218.56
1974	Wet	32.39	60.23	30.49	0.00	0.00	29.41	0.00	0.00	0.00	14.30	13.27	21.68	201.77
1975	Wet	12.54	0.00	71.26	0.00	0.00	22.28	0.00	0.00	0.00	13.78	14.94	25.77	160.57
1976	Critical	37.97	0.00	70.87	0.00	0.00	6.27	0.00	0.00	0.00	5.35	0.00	27.36	147.82
1977	Critical	4.55	0.00	0.00	11.30	0.00	0.00	0.00	0.34	0.49	0.48	0.44	0.29	17.89
1978	Above Normal	0.19	0.05	0.01	27.99	52.40	40.45	0.00	0.00	9.28	26.98	28.55	41.89	227.79
1979	Below Normal	2.11	0.00	81.15	5.71	17.93	0.65	0.00	0.00	0.00	19.94	21.90	0.00	149.39
1980	Above Normal	21.75	0.95	77.73	44.92	0.13	0.65	0.00	0.00	0.00	26.18	0.00	0.00	172.31
1981	Dry	5.25	0.00	69.05	0.00	0.00	0.00	0.00	0.00	0.00	5.39	0.00	26.50	106.19
1982	Wet	4.75	58.69	27.28	36.66	100.77	14.95	1.33	0.00	0.00	6.48	7.70	30.73	289.34
1983	Wet	36.83	0.22	0.02	0.00	0.12	0.67	1.24	2.54	2.78	3.50	3.35	2.48	53.75
1984	Wet	1.48	0.35	0.04	0.00	0.10	0.84	0.00	0.00	0.00	14.68	15.85	22.71	56.05
1985	Dry	9.35	58.32	55.62	0.00	0.00	0.00	0.00	0.00	0.00	17.89	0.00	29.79	170.97
1986	Wet	20.15	40.85	29.75	0.00	84.28	39.35	0.00	0.00	0.00	18.74	0.00	33.63	266.75
1987	Dry	0.65	0.00	67.10	0.00	0.00	0.00	0.00	0.00	0.00	3.96	0.00	0.63	72.34
1988	Critical	0.00	0.00	33.06	28.33	0.00	9.52	0.00	0.00	0.00	23.89	0.00	0.00	94.80
1989	Dry	0.00	24.95	37.37	45.99	5.61	3.56	0.00	0.00	0.00	1.94	0.00	27.73	147.15
1990	Critical	5.00	0.00	14.66	33.29	14.70	0.00	0.00	0.00	0.00	36.38	0.00	0.00	104.03
1991	Critical	0.00	0.00	7.76	0.00	6.59	3.55	0.00	0.00	0.42	36.29	0.00	0.00	54.61
1992	Critical	0.00	0.00	8.70	10.09	11.51	19.63	0.00	0.00	0.00	0.00	0.46	0.33	50.72
1993	Above Normal	0.20	0.05	13.19	32.28	31.48	20.58	0.00	0.00	0.00	11.34	15.30	26.52	150.94
1994	Critical	6.55	0.00	72.45	8.85	7.01	2.01	0.00	0.00	0.00	14.72	0.00	0.31	111.90
1995	Wet	0.18	0.03	0.00	30.77	27.27	91.90	0.00	22.33	2.97	4.38	11.27	30.67	221.77
1996	Wet	0.00	0.00	11.28	0.00	51.13	53.87	0.00	0.00	0.00	13.94	14.59	26.53	171.34
1997	Wet	0.00	0.00	76.40	72.50	66.39	28.80	0.00	0.00	0.00	1.40	12.44	29.97	287.90
1998	Wet	0.00	0.00	67.23	0.00	56.46	58.11	0.00	0.00	3.25	7.51	11.46	32.60	236.62
1999	Wet	48.47	0.29	0.00	0.00	8.12	0.56	0.00	0.00	0.00	20.57	22.30	0.00	100.31
2000	Above Normal	0.00	0.00	67.06	0.00	17.07	46.59	0.00	0.00	0.00	3.85	12.35	27.31	174.23
2001	Dry	0.00	0.00	77.48	33.40	23.09	28.26	0.00	0.00	0.00	9.38	0.00	11.64	183.25
2002	Dry	0.00	29.85	51.27	37.23	45.48	15.86	0.00	0.00	0.00	14.51	0.00	24.69	218.89
2003	Above Normal	0.00	0.00	3.76	23.89	30.09	26.40	0.00	0.00	0.00	11.49	19.19	31.89	146.71
Average		8.42	13.71	40.95	21.00	20.44	17.83	0.03	0.75	0.80	12.96	9.49	20.22	166.61
Wet		12.34	19.30	34.71	19.94	24.20	26.35	0.10	2.36	1.74	12.84	14.11	23.52	191.51
Above Normal		6.48	11.67											

Energy Use (GWh) At Pumping Plant at SWP San Luis: Alternative1_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Total
1922	Above Normal	0.48	0.00	61.88	40.25	21.91	30.24	0.00	0.00	0.00	12.08	11.58	25.87	204.29
1923	Below Normal	4.76	0.00	23.56	0.00	0.00	0.00	0.00	0.00	0.42	5.30	10.21	22.11	66.36
1924	Critical	17.67	2.09	40.17	6.45	0.00	0.00	0.00	0.00	0.00	0.50	0.42	0.31	67.61
1925	Dry	0.16	0.04	4.42	30.12	19.50	46.97	0.00	0.00	0.00	18.62	0.00	33.73	153.56
1926	Dry	4.52	4.80	18.78	36.19	8.06	0.00	0.00	0.00	0.00	8.30	0.00	0.00	80.65
1927	Wet	0.19	40.88	22.71	21.45	37.60	8.15	0.00	0.00	0.00	13.70	14.98	25.29	184.95
1928	Above Normal	0.00	0.00	67.42	0.00	0.00	33.55	0.00	0.00	0.00	2.30	6.16	21.10	130.53
1929	Critical	1.81	0.00	22.73	7.17	4.53	15.74	0.00	0.00	0.00	0.00	0.48	0.34	52.80
1930	Dry	0.22	0.06	0.01	27.22	24.22	22.62	0.00	0.00	0.00	27.92	0.00	44.79	147.06
1931	Critical	4.48	4.14	4.09	40.45	16.81	0.00	0.00	0.00	0.00	1.12	0.00	0.28	71.37
1932	Dry	0.17	0.05	56.71	45.75	53.78	51.01	0.00	0.00	0.00	33.55	44.25	0.30	285.57
1933	Critical	0.00	0.00	15.03	58.23	82.78	5.82	0.00	0.00	0.00	0.00	0.00	0.00	161.86
1934	Critical	0.00	1.81	54.41	99.27	61.12	4.96	0.00	0.00	0.00	0.00	0.00	0.33	221.90
1935	Below Normal	0.19	3.57	19.84	45.58	28.40	19.07	0.00	0.00	0.00	0.86	9.79	26.14	153.44
1936	Below Normal	8.37	6.03	14.25	21.86	128.52	85.86	0.00	0.00	0.00	17.27	19.03	21.45	322.64
1937	Below Normal	20.16	0.00	68.28	1.54	62.07	0.72	0.00	0.00	0.00	13.69	0.00	0.00	166.46
1938	Wet	24.72	60.50	42.49	46.69	9.76	0.57	51.50	0.00	16.45	15.20	16.27	18.93	251.58
1939	Dry	0.00	0.00	52.72	0.00	0.00	0.00	0.00	0.00	0.00	3.46	0.00	22.14	78.32
1940	Above Normal	0.00	0.00	0.01	25.53	38.23	65.81	0.00	0.00	0.00	1.46	8.42	26.62	166.08
1941	Wet	5.21	0.00	31.03	40.52	102.45	68.60	0.00	0.00	0.00	22.56	23.71	33.29	327.37
1942	Wet	0.00	0.00	29.68	2.79	2.08	0.00	0.00	0.00	0.00	19.73	18.80	26.53	99.61
1943	Wet	0.00	0.00	20.99	16.86	18.35	63.72	0.00	0.00	0.00	5.39	8.01	17.65	150.97
1944	Dry	0.00	0.00	54.12	9.42	13.24	8.63	0.00	0.00	0.00	22.03	9.17	0.00	116.61
1945	Below Normal	3.05	67.00	45.50	45.11	45.89	20.63	0.00	0.00	0.00	17.53	18.86	19.66	283.23
1946	Below Normal	32.57	60.16	32.01	0.00	0.00	0.00	0.00	0.00	0.00	18.63	17.77	23.20	184.34
1947	Dry	26.07	32.49	30.65	0.00	0.00	0.00	0.00	0.00	0.00	7.97	0.00	24.60	121.78
1948	Below Normal	13.85	10.44	0.00	0.00	0.00	14.80	0.00	0.00	0.42	8.22	15.69	28.66	92.08
1949	Dry	6.32	4.81	38.52	39.71	36.89	8.22	0.00	0.00	0.00	9.40	0.00	24.73	168.60
1950	Below Normal	0.00	0.00	0.00	19.40	20.82	34.47	0.00	0.00	0.00	7.31	15.29	29.33	126.62
1951	Above Normal	35.37	71.18	103.01	0.00	0.11	0.71	52.00	0.00	0.00	5.74	12.34	23.56	252.02
1952	Wet	0.00	13.36	20.78	2.53	0.00	80.56	0.00	0.00	1.96	23.67	29.92	40.45	213.23
1953	Wet	0.00	0.00	43.87	0.00	0.00	0.00	0.00	0.00	0.00	17.76	22.01	38.75	122.39
1954	Above Normal	0.00	0.00	78.16	0.00	0.00	6.17	0.00	0.00	0.00	0.39	12.29	26.99	124.00
1955	Dry	5.39	11.71	83.00	45.59	28.71	13.53	0.00	0.00	0.00	22.01	0.00	18.23	228.17
1956	Wet	0.00	30.99	60.99	87.20	0.08	0.71	0.00	0.00	0.00	10.82	11.07	13.40	215.26
1957	Above Normal	0.00	0.00	63.86	0.00	0.00	0.00	0.00	0.00	0.47	3.95	15.13	28.14	111.55
1958	Wet	57.18	12.87	32.70	30.14	29.56	47.06	0.00	0.00	0.00	3.52	4.82	26.26	244.11
1959	Below Normal	0.00	0.00	64.20	0.00	0.00	0.00	0.00	0.00	0.00	6.36	12.33	29.74	112.63
1960	Dry	6.37	4.22	6.40	36.93	19.51	18.42	0.00	0.00	0.00	1.90	0.00	23.13	116.88
1961	Dry	0.00	14.09	72.06	34.18	8.85	35.18	0.00	0.00	0.00	14.04	0.00	0.28	178.68
1962	Below Normal	0.18	0.05	0.00	25.50	34.72	35.59	0.00	0.00	0.00	8.35	13.37	27.12	144.88
1963	Wet	54.15	68.91	28.54	9.16	7.13	9.61	0.00	0.00	0.00	23.69	25.61	39.34	266.14
1964	Dry	13.25	63.21	17.80	0.00	0.10	0.00	0.00	0.00	0.00	14.36	0.00	25.21	133.93
1965	Wet	0.00	0.52	16.72	28.42	0.00	16.94	0.00	0.00	0.00	16.53	18.64	27.72	125.49
1966	Below Normal	0.00	13.25	82.93	0.00	0.00	0.00	0.00	0.00	0.00	6.80	13.60	32.11	148.69
1967	Wet	0.14	20.44	42.51	43.85	26.89	38.10	0.00	0.00	9.46	14.72	16.45	34.32	246.88
1968	Below Normal	9.70	0.00	74.75	0.00	0.00	0.00	0.00	0.00	0.00	10.69	15.35	34.33	144.82
1969	Wet	15.10	26.55	88.82	27.60	14.78	0.65	0.00	18.02	3.12	3.66	3.19	2.21	203.70
1970	Wet	1.17	0.00	31.72	18.39	0.14	0.74	0.00	0.00	0.00	21.94	17.24	0.00	91.34
1971	Wet	0.00	34.20	19.22	0.00	0.00	6.90	0.00	0.00	0.00	9.48	17.40	32.64	119.84
1972	Below Normal	6.38	0.00	84.00	38.53	0.00	0.00	0.00	0.00	0.00	8.36	16.16	34.80	188.23
1973	Above Normal	19.83	67.77	30.26	26.40	23.17	8.29	0.00	0.00	0.00	15.40	16.38	10.29	217.79
1974	Wet	31.83	59.47	30.07	0.00	0.00	8.19	0.00	0.00	0.00	14.39	14.18	29.10	187.23
1975	Wet	14.21	0.00	72.30	0.00	0.00	23.98	0.00	0.00	0.00	13.28	14.40	25.40	163.57
1976	Critical	38.58	0.00	70.37	0.00	0.00	6.17	0.00	0.00	0.00	5.35	0.00	27.69	148.16
1977	Critical	4.62	0.00	0.00	11.27	0.00	0.00	0.00	0.34	0.49	0.48	0.44	0.29	17.93
1978	Above Normal	0.19	0.05	0.01	27.96	46.73	31.84	0.00	0.00	0.00	20.01	20.91	33.94	181.64
1979	Below Normal	3.58	0.00	79.89	15.74	34.67	22.01	0.00	0.00	0.00	20.16	20.69	8.70	205.44
1980	Above Normal	34.30	3.40	78.50	10.06	7.89	0.65	42.13	0.00	7.33	0.00	0.00	0.00	142.13
1981	Dry	8.61	0.00	72.91	0.00	0.00	0.00	0.00	0.00	0.00	4.79	0.00	26.05	112.36
1982	Wet	4.86	57.81	26.75	36.39	98.74	18.95	1.33	0.00	0.00	6.30	7.51	30.06	288.60
1983	Wet	51.10	0.21	0.02	0.00	0.12	0.67	1.24	2.54	2.78	3.50	3.35	2.48	68.01
1984	Wet	1.48	0.35	0.04	0.00	0.10	0.84	0.00	0.00	0.00	14.68	15.85	22.73	56.07
1985	Dry	9.35	58.31	55.61	0.00	0.00	0.00	0.00	0.00	0.00	17.89	0.00	29.79	170.95
1986	Wet	20.14	40.85	29.75	0.00	46.97	78.10	0.00	0.00	0.00	18.38	0.00	15.84	250.03
1987	Dry	0.00	0.00	66.41	0.00	0.00	0.00	0.00	0.00	0.00	3.73	0.00	1.37	71.51
1988	Critical	0.00	0.33	33.21	28.54	0.00	9.58	0.00	0.00	0.00	24.01	0.00	0.00	95.67
1989	Dry	0.00	24.99	37.43	46.02	5.63	3.58	0.00	0.00	0.00	1.97	0.00	27.46	147.08
1990	Critical	4.99	0.00	14.88	33.28	14.69	0.00	0.00	0.00	0.00	36.33	0.00	0.00	104.17
1991	Critical	0.00	0.00	7.74	0.00	6.57	3.54	0.00	0.00	0.42	36.47	0.00	0.00	54.74
1992	Critical	0.00	0.00	8.50	9.84	11.47	19.55	0.00	0.00	0.00	0.00	0.46	0.33	50.15
1993	Above Normal	0.20	0.05	12.67	32.23	31.53	20.69	0.00	0.00	0.00	11.17	15.20	26.42	150.16
1994	Critical	6.44	0.00	72.45	9.14	7.28	2.12	0.00	0.00	0.00	14.73	0.00	0.31	112.47
1995	Wet	0.18	0.03	0.00	30.74	27.21	90.94	0.00	0.00	0.00	3.95	8.83	24.13	186.01
1996	Wet	0.00	0.00	9.19	7.35	73.64	57.86	0.00	0.00	0.00	14.94	15.95	27.67	206.60
1997	Wet	0.00	0.00	77.66	72.81	66.78	24.00	0.00	0.00	0.00	1.66	12.23	29.53	284.67
1998	Wet	0.00	0.00	66.98	0.00	56.08	57.52	0.00	0.00	10.59	14.91	18.91	37.35	262.34
1999	Wet	27.03	0.29	0.00	0.00	5.65	0.56	0.00	0.00	0.00	20.30	22.02	0.00	75.85
2000	Above Normal	0.00	0.00	66.82	0.00	15.72	46.11	0.00	0.00	0.00	3.38	12.17	27.04	171.24
2001	Dry	0.00	0.00	74.41	35.25	24.92	28.79	0.00	0.00	0.00	11.89	0.00	11.44	186.70
2002	Dry	0.00	29.56	51.11	37.11	45.34	15.86	0.00	0.00	0.00	14.66	0.00	26.31	219.95
2003	Above Normal	0.00	0.00	4.80	23.29	29.52	26.17	0.00	0.00	0.00	11.49	19.20	31.90	146.37
Average		8.06	12.54	38.28	20.11	20.59	18.63	0.03	0.25	0.57	11.59	9.57	19.63	159.84
Wet		11.87	18.01	32.52	20.11	24.00	27.07	0.10	0.79	1.71	13.41	14.67	23.89	188.15
Above Normal		7.53	11.87	47.28	15									

Difference in Energy Use (GWh) At Pumping Plant at SWP San Luis: Alternative1_2005 minus Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Average
1922	Above Normal	0.00	0.00	0.00	(6.82)	(1.66)	(2.30)	0.00	0.00	(9.43)	(11.69)	(13.58)	(13.48)	(4.91)
1923	Below Normal	(4.82)	0.00	(5.46)	0.00	0.00	0.00	0.00	0.00	0.42	(6.56)	(8.53)	(12.76)	(3.14)
1924	Critical	2.13	(11.48)	24.79	(21.10)	(9.44)	0.00	0.00	0.00	0.00	(48.57)	0.42	0.31	(5.25)
1925	Dry	(15.95)	(28.61)	(50.57)	(18.67)	(9.02)	15.89	0.00	0.00	0.00	4.66	0.00	(4.54)	(8.90)
1926	Dry	(2.92)	(2.31)	3.95	(4.35)	(1.07)	0.00	0.00	0.00	0.00	(11.19)	0.00	(2.27)	(1.68)
1927	Wet	0.19	(31.10)	(13.88)	(4.80)	(4.26)	(1.33)	0.00	0.00	0.00	(5.71)	(6.36)	(10.54)	(6.48)
1928	Above Normal	0.00	0.00	(6.63)	0.00	0.00	(2.35)	0.00	0.00	0.00	(8.74)	(6.72)	(9.05)	(2.79)
1929	Critical	(3.08)	0.00	(8.58)	7.17	4.53	(0.42)	0.00	0.00	0.00	0.00	0.48	0.34	0.04
1930	Dry	(3.77)	(4.41)	(43.98)	(6.19)	(2.94)	(2.81)	0.00	0.00	0.00	(7.88)	0.00	(14.26)	(7.19)
1931	Critical	(0.45)	(0.39)	(0.63)	(3.59)	(1.77)	0.00	0.00	0.00	0.00	(4.05)	0.00	0.28	(0.88)
1932	Dry	0.00	(7.73)	(44.43)	(5.09)	(4.02)	(4.55)	0.00	0.00	0.00	(2.26)	35.04	0.30	(2.73)
1933	Critical	(6.03)	(5.66)	(1.02)	21.93	9.44	0.17	0.00	0.00	0.00	0.00	0.00	0.00	1.57
1934	Critical	0.00	(0.32)	0.01	0.80	(0.73)	(2.00)	0.00	0.00	0.00	0.00	0.00	0.00	(0.19)
1935	Below Normal	0.00	(4.96)	(7.15)	(1.78)	(1.55)	(1.59)	0.00	0.00	0.00	(5.43)	(5.90)	(7.23)	(2.97)
1936	Below Normal	(0.03)	0.05	(3.97)	(0.27)	(3.79)	27.70	0.00	0.00	0.00	(0.08)	(0.10)	4.95	2.04
1937	Below Normal	1.08	0.00	(1.12)	(24.50)	19.96	0.00	0.00	0.00	0.00	0.06	0.00	0.00	(0.38)
1938	Wet	(0.32)	(1.72)	(23.06)	11.82	9.66	0.00	0.00	(23.88)	13.28	11.72	13.45	16.89	2.32
1939	Dry	0.00	0.00	(5.78)	0.00	0.00	0.00	0.00	0.00	0.00	(0.09)	0.00	(0.20)	(0.51)
1940	Above Normal	0.00	0.00	(2.90)	1.92	1.87	1.20	0.00	0.00	0.00	(0.01)	(0.04)	(0.07)	0.16
1941	Wet	0.02	0.00	(0.31)	(0.12)	(2.97)	2.12	0.00	0.00	0.00	(0.14)	(0.11)	(0.13)	(0.14)
1942	Wet	0.00	0.00	(0.04)	(5.92)	(1.74)	0.00	0.00	0.00	0.00	(0.65)	0.13	6.52	(0.14)
1943	Wet	0.00	0.00	0.36	(19.01)	(1.12)	(2.38)	0.00	0.00	0.00	(0.12)	(0.14)	(1.72)	(2.01)
1944	Dry	0.00	0.00	(8.09)	7.04	6.52	2.30	0.00	0.00	0.00	0.15	1.35	0.00	0.77
1945	Below Normal	0.16	0.83	0.35	0.23	(7.66)	4.52	0.00	0.00	0.00	(0.11)	(0.16)	0.74	(0.09)
1946	Below Normal	0.21	(0.30)	(0.82)	0.00	0.00	0.00	0.00	0.00	0.00	(0.42)	(0.31)	(0.91)	(0.21)
1947	Dry	(0.22)	(0.21)	(0.31)	0.00	0.00	0.00	0.00	0.00	0.00	(0.23)	0.00	(0.03)	(0.08)
1948	Below Normal	0.11	0.05	0.00	0.00	0.00	0.27	0.00	0.00	0.00	(0.11)	(0.11)	(0.07)	0.01
1949	Dry	0.00	0.01	(0.06)	0.01	(0.02)	0.06	0.00	0.00	0.00	(0.08)	0.00	(0.02)	(0.01)
1950	Below Normal	0.00	0.00	0.00	0.51	0.46	0.15	0.00	0.00	0.00	0.00	0.00	0.01	0.09
1951	Above Normal	0.00	0.01	(0.01)	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.00
1952	Wet	0.00	(0.01)	0.00	(0.62)	0.00	(0.55)	0.00	0.00	(11.46)	1.65	1.68	10.22	0.08
1953	Wet	0.00	0.00	(4.35)	0.00	0.00	0.00	0.00	0.00	0.00	1.02	0.87	2.35	(0.01)
1954	Above Normal	0.00	0.00	0.12	0.00	0.00	(2.07)	0.00	0.00	0.00	(0.13)	(0.32)	(0.22)	(0.22)
1955	Dry	0.03	(0.19)	(0.27)	(0.24)	(0.09)	0.05	0.00	0.00	0.00	0.58	0.00	(1.17)	(0.11)
1956	Wet	0.00	0.20	(14.95)	14.63	(0.01)	0.00	0.00	0.00	0.00	(0.04)	(0.05)	0.35	0.01
1957	Above Normal	0.00	0.00	(0.03)	0.00	0.00	0.00	0.00	0.00	0.00	0.12	0.07	(0.04)	0.01
1958	Wet	(0.05)	(0.11)	(0.12)	0.00	0.00	0.12	0.00	0.00	0.00	(0.07)	(0.07)	(0.33)	(0.05)
1959	Below Normal	0.00	0.00	0.73	0.00	0.00	0.00	0.00	0.00	0.00	0.60	0.54	0.24	0.05
1960	Dry	(0.09)	(0.12)	(0.18)	0.30	0.27	(0.07)	0.00	0.00	0.00	0.41	0.00	0.55	0.09
1961	Dry	0.00	0.33	0.39	(0.88)	(0.91)	(0.33)	0.00	0.00	0.00	(0.11)	0.00	0.00	(0.13)
1962	Below Normal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1963	Wet	0.00	0.00	0.00	0.00	(0.01)	(0.02)	0.00	0.00	0.00	(0.01)	0.00	(0.01)	0.00
1964	Dry	0.01	0.01	(0.01)	0.00	0.00	0.00	0.00	0.00	0.00	0.03	0.00	0.03	0.01
1965	Wet	0.00	0.02	0.05	(1.32)	(0.05)	0.18	0.00	0.00	0.00	(0.31)	(0.19)	(0.10)	(0.14)
1966	Below Normal	0.00	(0.07)	(0.06)	0.00	0.00	0.00	0.00	0.00	0.00	(0.02)	(0.02)	(0.02)	(0.02)
1967	Wet	0.14	0.00	0.01	0.09	0.03	(0.08)	0.00	0.00	(7.08)	(0.37)	(0.55)	(1.57)	(0.78)
1968	Below Normal	(1.44)	0.00	1.32	0.00	0.00	0.00	0.00	0.00	0.00	(1.50)	(0.85)	(1.23)	(0.31)
1969	Wet	(6.23)	1.09	0.02	2.99	14.70	0.00	0.00	5.53	0.00	0.00	0.00	0.00	1.51
1970	Wet	0.01	0.00	0.50	(0.69)	0.00	0.00	0.00	0.00	0.00	0.91	(0.26)	0.00	0.04
1971	Wet	0.00	(0.22)	(0.21)	0.00	0.00	(0.14)	0.00	0.00	0.00	0.05	0.05	0.02	(0.04)
1972	Below Normal	0.00	0.00	0.03	(0.03)	0.00	0.00	0.00	0.00	0.00	0.02	0.01	0.03	0.00
1973	Above Normal	0.01	0.01	0.00	(0.06)	(0.06)	(0.10)	0.00	0.00	0.00	(0.24)	(0.24)	(0.09)	(0.06)
1974	Wet	(0.56)	(0.76)	(0.42)	0.00	0.00	(21.22)	0.00	0.00	0.00	0.09	0.91	7.42	(1.21)
1975	Wet	1.67	0.00	1.04	0.00	0.00	1.70	0.00	0.00	0.00	(0.50)	(0.54)	(0.37)	0.25
1976	Critical	0.61	0.00	(0.50)	0.00	0.00	(0.10)	0.00	0.00	0.00	0.00	0.00	0.33	0.03
1977	Critical	0.07	0.00	0.00	(0.03)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1978	Above Normal	0.00	0.00	0.00	(0.03)	(5.67)	(8.61)	0.00	0.00	(9.28)	(6.97)	(7.64)	(7.95)	(3.85)
1979	Below Normal	1.47	0.00	(1.26)	10.03	16.74	21.36	0.00	0.00	0.00	0.22	(1.21)	8.70	4.67
1980	Above Normal	12.55	2.45	0.77	(34.86)	7.76	0.00	0.00	0.00	0.00	(18.85)	0.00	0.00	(2.52)
1981	Dry	3.36	0.00	3.86	0.00	0.00	0.00	0.00	0.00	0.00	(0.60)	0.00	(0.45)	0.51
1982	Wet	0.11	(0.88)	(0.53)	(0.27)	(2.03)	3.90	0.00	0.00	0.00	(0.18)	(0.19)	(0.67)	(0.06)
1983	Wet	14.27	(0.01)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.19
1984	Wet	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.02	0.00
1985	Dry	0.00	(0.01)	(0.01)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1986	Wet	(0.01)	0.00	0.00	0.00	(37.31)	38.75	0.00	0.00	0.00	(0.36)	0.00	(17.79)	(1.39)
1987	Dry	(0.65)	0.00	(0.69)	0.00	0.00	0.00	0.00	0.00	0.00	(0.23)	0.00	0.74	(0.07)
1988	Critical	0.00	0.33	0.15	0.21	0.00	0.06	0.00	0.00	0.00	0.12	0.00	0.00	0.07
1989	Dry	0.00	0.04	0.06	0.03	0.02	0.02	0.00	0.00	0.00	0.03	0.00	(0.27)	(0.01)
1990	Critical	(0.01)	0.00	0.22	(0.01)	(0.01)	0.00	0.00	0.00	0.00	(0.05)	0.00	0.00	0.01
1991	Critical	0.00	0.00	(0.02)	0.00	(0.02)	(0.01)	0.00	0.00	0.00	0.18	0.00	0.00	0.01
1992	Critical	0.00	0.00	(0.20)	(0.25)	(0.04)	(0.08)	0.00	0.00	0.00	0.00	0.00	0.00	(0.05)
1993	Above Normal	0.00	0.00	(0.52)	(0.05)	0.05	0.11	0.00	0.00	0.00	(0.17)	(0.10)	(0.10)	(0.06)
1994	Critical	(0.11)	0.00	0.00	0.29	0.27	0.11	0.00	0.00	0.00	0.01	0.00	0.00	0.05
1995	Wet	0.00	0.00	0.00	(0.03)	(0.06)	(0.96)	0.00	(22.33)	(2.97)	(0.43)	(2.44)	(6.54)	(2.98)
1996	Wet	0.00	0.00	(2.09)	7.35	22.51	3.99	0.00	0.00	0.00	1.00	1.36	1.14	2.94
1997	Wet	0.00	0.00	1.26	0.31	0.39	(4.80)	0.00	0.00	0.00	0.26	(0.21)	(0.44)	(0.27)
1998	Wet	0.00	0.00	(0.25)	0.00	(0.38)	(0.59)	0.00	0.00	7.34	7.40	7.45	4.75	2.14
1999	Wet	(21.44)	0.00	0.00	0.00	(2.47)	0.00	0.00	0.00	0.00	(0.27)	(0.28)	0.00	(2.04)
2000	Above Normal	0.00	0.00	(0.24)	0.00	(1.35)	(0.48)	0.00	0.00	0.00	(0.47)	(0.18)	(0.27)	(0.25)
2001	Dry	0.00	0.00	(3.07)	1.85	1.83	0.53	0.00	0.00	0.00	2.51	0.00	(0.20)	0.29
2002	Dry	0.00	(0.29)	(0.16)	(0.12)	(0.14)	0.00	0.00	0.00	0.00	0.15	0.00	1.62	0.09
2003	Above Normal	0.00	0.00	1.04	(0.60)	(0.57)	(0.23)	0.00	0.00	0.00	0.00	0.01	0.01	(0.03)
Average		(0.37)	(1.18)	(2.68)	(0.89)	0.15	0.79	0.00	(0.50)	(0.23)	(1.37)	0.08	(0.59)	(0.56)
Wet		(0.47)	(1.29)	(2.19)	0.17	(0.20)	0.72	0.00	(1.56)	(0.03)	0.57	0.56	0.36	(0.28)
Above Normal		1.05	0.21	(0.70)	(3.38)	0.03	(1.24)	0.00	0.00	(1.56)	(3.93)	(2.40)	(2.61)	(1.21)
Below Normal		(0.23)	(0.31)	(1.35)	(1.13)	1.73	3.74	0.00	0.00	0.03	(0.95)	(1.19)	(0.54)	(0.02)
Dry		(1.12)	(2.42)	(8.30)	(1.46)	(0.53)	0.62	0.00	0.00	0.00	(0.79)	2.02	(1.12)	(1.09)
Critical		(0.57)	(1.46)	1.19	0.45	0.19	(0.19)	0.00	0.00	0.00	(			

Percent Difference in Energy Use (GWh) At Pumping Plant at SWP San Luis: Alternative1_2005 minus Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September
1922	Above Normal	0%	0%	0%	-14%	-7%	-7%	0%	0%	-100%	-49%	-54%	-34%
1923	Below Normal	-50%	0%	-19%	0%	0%	0%	0%	0%	-	-55%	-46%	-37%
1924	Critical	14%	-85%	161%	-77%	-100%	0%	0%	0%	0%	-99%	0%	-12%
1925	Dry	-99%	-100%	-92%	-38%	-32%	51%	0%	0%	0%	33%	0%	-100%
1926	Dry	-39%	-32%	27%	-11%	-12%	0%	0%	0%	0%	-57%	0%	-29%
1927	Wet	-	-43%	-38%	-18%	-10%	-14%	0%	0%	0%	-29%	-30%	-30%
1928	Above Normal	0%	0%	-9%	0%	0%	-7%	0%	0%	0%	-79%	-52%	-
1929	Critical	-63%	0%	-27%	-	-	-3%	0%	0%	0%	0%	-	-
1930	Dry	-94%	-99%	-100%	-19%	-11%	-11%	0%	0%	0%	-22%	0%	-24%
1931	Critical	-9%	-9%	-13%	-8%	-10%	0%	0%	0%	0%	-78%	0%	-
1932	Dry	0%	-99%	-44%	-10%	-7%	-8%	0%	0%	0%	-6%	380%	-
1933	Critical	-100%	-100%	-6%	60%	13%	3%	0%	0%	0%	0%	0%	0%
1934	Critical	0%	-15%	0%	1%	-1%	-29%	0%	0%	0%	0%	0%	0%
1935	Below Normal	0%	-58%	-26%	-4%	-5%	-8%	0%	0%	0%	-86%	-38%	-22%
1936	Below Normal	0%	1%	-22%	-1%	-3%	48%	0%	0%	0%	0%	-1%	30%
1937	Below Normal	6%	0%	-2%	-94%	47%	0%	0%	0%	0%	0%	0%	0%
1938	Wet	-1%	-3%	-35%	34%	>1,000%	0%	0%	-100%	419%	337%	477%	828%
1939	Dry	0%	0%	-10%	0%	0%	0%	0%	0%	0%	-3%	0%	-1%
1940	Above Normal	0%	0%	-100%	8%	5%	2%	0%	0%	0%	-1%	0%	0%
1941	Wet	0%	0%	-1%	0%	-3%	3%	0%	0%	0%	-1%	0%	0%
1942	Wet	0%	0%	0%	-68%	-46%	0%	0%	0%	0%	-3%	1%	33%
1943	Wet	0%	0%	2%	-53%	-6%	-4%	0%	0%	0%	-2%	-2%	-9%
1944	Dry	0%	0%	-13%	296%	97%	36%	0%	0%	0%	1%	17%	0%
1945	Below Normal	6%	1%	1%	1%	-14%	28%	0%	0%	0%	-1%	-1%	4%
1946	Below Normal	1%	0%	-2%	0%	0%	0%	0%	0%	0%	-2%	-2%	-4%
1947	Dry	-1%	-1%	-1%	0%	0%	0%	0%	0%	0%	-3%	0%	0%
1948	Below Normal	1%	0%	0%	0%	0%	2%	0%	0%	0%	-1%	-1%	0%
1949	Dry	0%	0%	0%	0%	0%	1%	0%	0%	0%	-1%	0%	0%
1950	Below Normal	0%	0%	0%	3%	2%	0%	0%	0%	0%	0%	0%	0%
1951	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1952	Wet	0%	0%	0%	-20%	0%	-1%	0%	0%	-85%	7%	6%	34%
1953	Wet	0%	0%	-9%	0%	0%	0%	0%	0%	0%	6%	4%	6%
1954	Above Normal	0%	0%	0%	0%	0%	-25%	0%	0%	0%	-25%	-3%	-1%
1955	Dry	1%	-2%	0%	-1%	0%	0%	0%	0%	0%	3%	0%	-6%
1956	Wet	0%	1%	-20%	20%	-11%	0%	0%	0%	0%	0%	0%	3%
1957	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	3%	0%	0%
1958	Wet	0%	-1%	0%	0%	0%	0%	0%	0%	0%	-2%	-1%	-1%
1959	Below Normal	0%	0%	-1%	0%	0%	0%	0%	0%	0%	10%	5%	1%
1960	Dry	-1%	-3%	-3%	1%	1%	0%	0%	0%	0%	28%	0%	2%
1961	Dry	0%	2%	1%	-3%	-9%	-1%	0%	0%	0%	-1%	0%	0%
1962	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1963	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1964	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1965	Wet	0%	4%	0%	-4%	-100%	1%	0%	0%	0%	-2%	-1%	0%
1966	Below Normal	0%	-1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1967	Wet	-	0%	0%	0%	0%	0%	0%	0%	-43%	-2%	-3%	-4%
1968	Below Normal	-13%	0%	2%	0%	0%	0%	0%	0%	0%	-12%	-5%	-3%
1969	Wet	-29%	4%	0%	12%	>1,000%	0%	0%	44%	0%	0%	0%	0%
1970	Wet	1%	0%	2%	-4%	0%	0%	0%	0%	0%	4%	-1%	0%
1971	Wet	0%	-1%	-1%	0%	0%	-2%	0%	0%	0%	1%	0%	0%
1972	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1973	Above Normal	0%	0%	0%	0%	0%	-1%	0%	0%	0%	-2%	-1%	-1%
1974	Wet	-2%	-1%	-1%	0%	0%	-72%	0%	0%	0%	1%	7%	34%
1975	Wet	13%	0%	1%	0%	0%	8%	0%	0%	0%	-4%	-4%	-1%
1976	Critical	2%	0%	-1%	0%	0%	-2%	0%	0%	0%	0%	0%	1%
1977	Critical	2%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1978	Above Normal	0%	0%	0%	0%	-11%	-21%	0%	0%	-100%	-26%	-27%	-19%
1979	Below Normal	70%	0%	-2%	176%	93%	>1,000%	0%	0%	0%	1%	-6%	-
1980	Above Normal	58%	258%	1%	-78%	>1,000%	0%	0%	0%	0%	-72%	0%	0%
1981	Dry	64%	0%	6%	0%	0%	0%	0%	0%	0%	-11%	0%	-2%
1982	Wet	2%	-1%	-2%	-1%	-2%	26%	0%	0%	0%	-3%	-2%	-2%
1983	Wet	39%	-5%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1984	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1985	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1986	Wet	0%	0%	0%	0%	-44%	98%	0%	0%	0%	-2%	0%	-53%
1987	Dry	-100%	0%	-1%	0%	0%	0%	0%	0%	0%	-6%	0%	117%
1988	Critical	0%	-	0%	1%	0%	1%	0%	0%	0%	1%	0%	0%
1989	Dry	0%	0%	0%	0%	0%	1%	0%	0%	0%	2%	0%	-1%
1990	Critical	0%	0%	2%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1991	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1992	Critical	0%	0%	-2%	-2%	0%	0%	0%	0%	0%	0%	0%	0%
1993	Above Normal	0%	0%	-4%	0%	0%	1%	0%	0%	0%	-1%	-1%	0%
1994	Critical	-2%	0%	0%	3%	4%	5%	0%	0%	0%	0%	0%	0%
1995	Wet	0%	0%	0%	0%	0%	-1%	0%	-100%	-100%	-10%	-22%	-21%
1996	Wet	0%	0%	-19%	-	44%	7%	0%	0%	0%	7%	9%	4%
1997	Wet	0%	0%	2%	0%	1%	-17%	0%	0%	0%	19%	-2%	-1%
1998	Wet	0%	0%	0%	0%	-1%	-1%	0%	0%	226%	99%	65%	15%
1999	Wet	-44%	0%	0%	0%	-30%	0%	0%	0%	0%	-1%	-1%	0%
2000	Above Normal	0%	0%	0%	0%	-8%	-1%	0%	0%	0%	-12%	-1%	-1%
2001	Dry	0%	0%	-4%	6%	8%	2%	0%	0%	0%	27%	0%	-2%
2002	Dry	0%	-1%	0%	0%	0%	0%	0%	0%	0%	1%	0%	7%
2003	Above Normal	0%	0%	28%	-3%	-2%	-1%	0%	0%	0%	0%	0%	0%
Average		-5%	-5%	-5%	1%	-2%	1%	0%	-2%	3%	-2%	8%	9%
Wet		-1%	-2%	-5%	-4%	-8%	1%	0%	-6%	16%	16%	19%	32%
Above Normal		5%	21%	-7%	-7%	-2%	-5%	0%	0%	-17%	-22%	-12%	-7%
Below Normal		1%	-4%	-5%	6%	9%	5%	0%	0%	0%	-10%	-7%	-2%
Dry		-15%	-19%	-13%	12%	2%	4%	0%	0%	0%	-1%	22%	-1%
Critical		-13%	-17%	9%	-2%	-8%	-2%	0%	0%	0%	-15%	0%	0%

Energy Use (GWh) At Pumping Plant at System Total: Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Total
1922	Above Normal	1,086.48	905.48	858.83	275.77	377.66	621.50	662.96	649.71	774.11	803.41	836.53	768.90	8,621.34
1923	Below Normal	624.09	544.11	538.68	933.53	902.10	889.84	607.77	679.71	721.02	848.85	875.77	795.13	8,960.60
1924	Critical	586.56	517.98	429.61	385.59	345.62	267.46	344.64	413.66	417.80	568.76	371.22	326.79	4,975.69
1925	Dry	217.89	199.33	229.71	191.95	198.09	528.68	566.24	732.78	764.07	913.89	856.29	841.93	6,240.85
1926	Dry	578.63	520.82	433.95	285.85	251.89	304.21	451.99	636.00	672.95	813.78	745.27	657.10	6,352.44
1927	Wet	468.12	584.02	415.06	242.26	384.06	673.05	704.96	700.49	763.59	855.56	888.08	816.94	7,496.19
1928	Above Normal	656.56	586.68	682.03	812.85	777.11	576.88	712.02	699.72	751.19	830.39	867.84	801.56	8,754.83
1929	Critical	654.82	561.06	583.78	747.33	696.34	431.25	322.70	391.41	379.65	378.19	339.61	293.04	5,779.18
1930	Dry	171.37	131.54	198.47	152.56	215.57	281.15	495.73	573.29	594.54	742.19	617.67	666.94	4,841.02
1931	Critical	360.76	303.66	237.97	245.28	219.14	216.84	390.56	466.60	478.99	545.35	426.94	368.85	4,260.94
1932	Dry	202.69	180.25	353.45	221.65	301.03	388.54	483.36	564.27	565.59	751.30	682.69	557.73	5,252.55
1933	Critical	411.90	361.54	306.05	242.18	335.11	280.58	443.74	546.08	556.70	585.40	516.27	454.44	5,039.99
1934	Critical	278.15	223.55	280.76	336.19	275.52	241.49	415.32	506.17	512.82	511.84	75.65	38.80	3,696.26
1935	Below Normal	294.87	588.32	491.35	233.24	245.47	314.05	630.51	730.93	483.12	969.07	984.25	892.12	8,857.30
1936	Below Normal	630.03	561.29	475.20	255.95	517.73	943.34	655.49	729.05	791.15	883.28	917.61	811.56	8,171.68
1937	Below Normal	727.63	613.01	688.69	889.01	1,035.54	958.02	646.28	705.18	786.96	853.53	843.40	717.06	9,464.31
1938	Wet	705.86	713.95	647.48	1,060.57	974.40	1,085.41	618.31	820.60	827.39	810.97	877.60	710.54	9,853.08
1939	Dry	620.63	513.75	619.33	930.26	874.74	1,026.96	708.55	714.59	311.37	954.95	697.73	953.20	8,926.06
1940	Above Normal	679.79	402.00	709.65	188.65	235.12	501.67	632.21	737.84	665.82	929.34	950.39	860.21	7,492.69
1941	Wet	604.65	518.32	495.99	394.25	607.78	1,087.87	548.70	614.65	679.65	765.83	803.00	716.99	7,837.68
1942	Wet	553.41	461.22	498.64	962.71	934.36	1,083.62	786.22	657.36	724.81	802.55	835.46	735.27	9,035.63
1943	Wet	611.80	511.08	522.70	890.56	964.39	1,012.57	752.15	725.45	781.36	869.16	910.08	823.15	9,374.45
1944	Dry	681.00	571.56	684.79	703.93	665.94	437.06	499.62	576.25	603.75	746.08	689.66	564.59	7,424.23
1945	Below Normal	401.48	497.69	361.94	292.59	325.11	1,062.81	650.50	700.01	747.87	854.27	885.77	789.82	7,569.86
1946	Below Normal	728.82	714.63	772.50	876.38	640.55	707.75	663.93	663.12	707.21	816.18	848.24	763.02	8,903.33
1947	Dry	681.24	626.84	558.21	807.62	796.80	504.13	692.62	736.52	768.99	895.15	865.90	830.59	8,764.61
1948	Below Normal	656.18	583.01	468.63	486.93	433.07	347.61	423.35	517.44	109.94	973.53	984.35	889.12	6,873.16
1949	Dry	628.16	557.97	518.48	301.76	308.86	320.25	684.32	722.36	761.41	885.09	845.39	823.47	7,357.52
1950	Below Normal	595.56	544.50	470.98	244.02	253.98	333.90	574.12	659.10	86.69	960.44	970.23	875.43	6,568.95
1951	Above Normal	679.78	683.06	718.68	1,013.90	893.54	1,055.47	601.71	684.09	809.95	865.10	779.42	792.58	9,528.07
1952	Wet	643.08	615.74	556.91	958.56	933.93	857.60	574.35	613.77	701.90	744.95	790.26	687.84	8,678.89
1953	Wet	540.43	452.65	836.41	930.17	908.42	1,061.96	814.13	648.65	675.64	800.47	829.53	761.32	9,259.78
1954	Above Normal	555.61	465.45	592.36	607.65	614.29	629.37	633.36	726.72	748.96	850.02	933.20	842.22	8,199.21
1955	Dry	589.44	543.58	586.50	314.28	319.41	374.12	536.65	614.25	613.99	794.98	708.35	680.82	6,676.37
1956	Wet	459.44	477.64	483.26	984.07	926.88	1,072.05	687.81	749.46	836.12	895.18	934.01	825.02	9,330.94
1957	Above Normal	702.60	595.20	705.69	935.17	863.52	593.81	537.46	459.22	81.92	924.60	934.93	844.35	8,168.47
1958	Wet	699.27	530.30	470.25	245.27	509.03	1,048.62	717.26	773.48	854.17	895.03	938.33	858.35	8,539.36
1959	Below Normal	714.61	604.47	706.50	907.78	889.43	976.61	613.98	700.49	370.55	941.27	953.08	865.21	9,243.98
1960	Dry	618.35	543.45	434.14	276.20	243.98	310.70	662.92	775.51	555.56	990.09	747.09	974.72	7,132.71
1961	Dry	672.85	672.27	668.08	333.32	293.82	342.45	571.25	655.58	647.98	834.86	638.47	434.13	6,765.06
1962	Below Normal	114.86	612.31	703.72	169.42	204.14	412.48	582.16	668.75	89.15	970.14	981.62	885.30	6,394.05
1963	Wet	735.14	690.40	493.79	418.32	477.52	636.96	654.10	657.75	706.65	814.47	849.51	782.02	7,916.63
1964	Dry	645.06	684.42	770.31	733.85	489.42	493.70	698.05	683.33	700.20	832.89	791.58	791.09	8,313.90
1965	Wet	638.88	578.84	553.33	838.94	818.56	704.46	648.64	637.89	673.85	792.93	823.84	749.51	8,457.67
1966	Below Normal	580.00	561.17	637.40	861.09	885.40	684.76	612.99	696.53	678.17	870.19	896.15	812.58	8,776.43
1967	Wet	562.40	545.01	471.33	344.34	546.12	702.23	722.10	717.79	842.88	853.87	892.19	819.26	8,019.52
1968	Below Normal	680.98	560.20	701.58	929.19	914.26	999.20	696.57	665.09	692.32	823.58	849.85	778.89	9,291.71
1969	Wet	606.44	549.12	591.29	735.09	904.95	1,008.59	626.80	735.56	764.19	784.62	839.70	711.92	8,858.27
1970	Wet	669.76	467.31	543.49	1,047.28	972.42	1,105.32	638.08	683.04	727.43	838.77	868.58	716.57	9,278.05
1971	Wet	636.77	654.49	555.28	928.37	899.96	796.93	593.24	690.03	726.43	865.99	888.43	802.30	9,037.82
1972	Below Normal	553.34	445.13	559.55	291.45	397.26	560.36	635.78	703.35	734.26	875.32	898.27	816.73	7,470.80
1973	Above Normal	610.80	651.56	473.06	363.48	625.69	778.35	634.77	704.36	768.10	853.85	888.00	765.97	8,117.99
1974	Wet	732.15	720.30	591.29	949.38	899.58	1,042.87	719.36	696.32	768.14	844.71	881.31	790.89	9,636.30
1975	Wet	689.22	552.77	668.86	935.24	896.69	966.31	709.93	694.01	769.34	837.84	869.54	797.94	9,387.69
1976	Critical	735.78	544.10	667.42	796.78	766.79	532.28	609.47	701.37	305.83	937.16	678.17	924.45	8,199.60
1977	Critical	654.67	559.02	443.70	222.49	196.64	200.82	178.05	56.72	31.15	41.28	36.66	64.45	2,685.65
1978	Above Normal	17.94	125.93	494.08	178.96	308.36	610.41	653.13	636.10	743.48	795.12	824.71	757.79	6,146.01
1979	Below Normal	599.64	517.19	633.61	812.13	913.52	808.25	611.03	677.75	717.27	825.10	857.88	710.96	8,684.33
1980	Above Normal	670.51	562.93	656.61	936.35	952.00	1,029.54	585.27	650.17	738.15	814.06	813.93	626.65	9,036.17
1981	Dry	623.72	500.68	628.37	916.34	901.51	679.32	592.83	690.38	173.22	970.03	869.23	907.54	8,453.17
1982	Wet	636.32	694.51	503.64	449.24	638.53	1,125.97	826.83	734.35	829.53	870.02	913.26	836.74	9,059.94
1983	Wet	822.70	682.67	1,003.85	945.29	901.36	1,004.61	523.57	544.73	656.17	680.73	634.34	590.60	8,990.62
1984	Wet	678.72	623.28	1,066.79	1,013.32	1,004.63	1,091.94	607.80	692.61	738.42	842.31	877.74	784.76	10,022.32
1985	Dry	672.79	710.74	832.21	839.15	846.76	789.11	667.29	663.74	698.10	807.34	763.97	766.09	9,057.29
1986	Wet	657.36	636.09	548.35	754.72	894.24	1,144.02	673.87	726.72	795.81	870.71	856.57	829.27	9,387.73
1987	Dry	674.61	554.76	679.17	932.97	891.57	518.92	438.74	550.90	563.47	607.65	481.18	444.68	7,338.62
1988	Critical	228.24	176.83	226.73	176.87	162.68	220.90	314.33	362.31	356.35	465.10	318.58	293.26	3,302.18
1989	Dry	138.63	177.56	179.66	173.46	153.29	203.32	659.39	765.26	610.43	979.82	896.18	921.61	5,858.61
1990	Critical	656.01	574.14	496.57	277.46	252.45	245.66	378.15	460.37	462.01	612.07	411.47	384.06	5,210.42
1991	Critical	190.89	143.15	144.89	99.43	157.46	203.58	318.69	349.82	243.31	560.63	365.71	325.17	3,102.73
1992	Critical	169.15	118.65	133.55	114.91	163.55	230.63	309.58	358.64	376.56	51.52	35.06	297.71	2,359.51
1993	Above Normal	400.23	41.89	531.30	195.76	425.08	582.83	640.59	674.13	528.31	874.22	901.19	819.25	6,614.78
1994	Critical	638.55	520.45	629.38	596.35	569.45	451.96	549.45	630.43	523.03	821.96	248.06	669.01	6,848.08
1995	Wet	139.26	426.55	842.63	182.99</									

Energy Use (GWh) At Pumping Plant at System Total: Alternative1_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Total
1922	Above Normal	1,086.48	905.48	858.83	338.58	380.07	622.84	677.53	672.85	836.68	865.29	902.74	826.59	8,973.96
1923	Below Normal	687.26	608.83	593.40	937.84	913.31	1,042.18	796.24	333.09	152.75	1,040.30	1,068.66	971.67	9,145.53
1924	Critical	811.08	691.04	663.20	537.75	464.74	320.35	390.13	473.66	320.44	78.69	36.09	38.44	4,825.61
1925	Dry	393.63	602.49	822.32	235.78	228.85	373.30	549.33	626.92	674.08	815.73	746.44	746.03	6,814.90
1926	Dry	493.33	442.17	385.37	307.87	253.35	323.96	471.66	700.49	648.86	900.55	865.43	736.48	6,529.52
1927	Wet	284.02	760.97	563.29	264.85	367.43	671.98	688.64	683.43	659.48	898.82	930.09	855.63	7,628.63
1928	Above Normal	706.65	636.00	725.19	850.34	762.70	559.76	699.27	724.38	306.47	972.36	1,007.10	923.12	8,873.34
1929	Critical	744.73	649.45	641.10	655.74	595.22	411.61	374.62	430.53	425.50	46.27	52.00	43.89	5,070.66
1930	Dry	125.01	116.81	777.60	199.83	219.05	285.23	490.98	569.65	263.08	804.51	677.61	707.35	5,236.71
1931	Critical	394.39	329.27	257.72	254.85	223.52	225.70	389.72	465.55	478.00	535.95	45.01	34.11	3,633.79
1932	Dry	147.90	307.92	871.05	240.22	301.26	393.77	485.86	564.68	610.86	797.52	810.04	622.69	6,153.77
1933	Critical	442.78	400.10	360.21	345.46	362.29	277.35	426.75	535.89	555.82	569.09	498.60	438.73	5,213.07
1934	Critical	255.84	201.39	274.30	335.55	281.40	254.90	436.36	533.93	542.64	540.91	41.51	36.00	3,734.73
1935	Below Normal	352.00	624.61	517.16	241.24	251.38	323.18	645.39	749.86	233.36	1,085.46	1,112.53	1,010.25	7,146.42
1936	Below Normal	746.25	671.47	564.35	294.60	508.47	788.51	721.10	727.18	834.99	927.05	961.36	866.78	8,612.11
1937	Below Normal	773.82	657.21	731.97	838.01	1,048.06	1,025.97	638.86	691.04	833.02	891.32	878.28	755.21	9,762.77
1938	Wet	743.44	750.76	598.11	1,032.87	982.48	1,066.58	617.46	678.49	793.49	851.06	892.46	780.51	9,787.71
1939	Dry	658.75	555.71	647.17	874.64	874.64	1,016.25	656.31	722.47	405.84	999.63	733.96	998.46	9,244.43
1940	Above Normal	719.61	343.36	799.26	213.92	218.19	497.01	631.97	737.55	709.25	974.03	995.05	904.86	7,744.06
1941	Wet	649.43	563.58	516.87	394.22	602.41	1,058.36	548.68	612.90	724.89	811.54	848.75	762.72	8,094.35
1942	Wet	599.69	506.95	520.82	956.45	931.12	1,079.96	786.74	655.32	768.36	845.35	878.67	794.01	9,323.44
1943	Wet	655.87	554.03	567.52	860.59	962.72	1,024.49	766.09	724.53	820.33	913.96	954.25	865.79	9,670.17
1944	Dry	729.28	616.91	722.29	671.84	596.02	413.11	498.43	575.50	633.00	774.60	720.15	592.22	7,543.35
1945	Below Normal	428.15	524.69	389.14	321.54	310.31	982.39	651.34	700.91	794.65	900.93	932.40	837.80	7,774.25
1946	Below Normal	777.20	763.40	822.61	922.23	640.84	709.93	666.63	665.95	756.07	864.59	896.92	810.35	9,296.72
1947	Dry	728.99	675.01	606.03	858.10	797.82	503.37	691.75	738.16	788.92	915.89	886.75	850.62	9,041.41
1948	Below Normal	674.14	600.93	485.55	494.73	423.46	344.36	423.80	531.01	109.75	973.75	984.72	889.36	6,935.56
1949	Dry	628.48	558.33	518.64	301.63	308.99	319.79	684.18	722.92	762.98	886.88	847.09	825.03	7,364.94
1950	Below Normal	595.60	545.47	471.67	239.46	248.98	332.32	574.01	658.96	106.42	980.06	989.85	895.07	6,637.87
1951	Above Normal	699.42	702.74	711.67	1,013.90	901.31	1,055.47	601.71	684.09	789.21	855.80	919.95	825.26	9,751.53
1952	Wet	688.93	661.58	602.76	1,002.54	934.06	857.02	571.61	584.79	653.09	767.40	808.50	730.93	8,863.21
1953	Wet	560.13	476.39	906.90	970.46	904.77	988.88	681.05	637.99	713.87	836.49	866.17	799.23	9,342.33
1954	Above Normal	594.40	508.00	638.95	682.63	645.69	650.67	637.33	733.64	788.45	858.57	948.29	856.84	8,543.46
1955	Dry	604.33	557.93	600.31	328.23	319.55	373.38	532.77	609.51	614.01	795.26	707.99	677.63	6,720.90
1956	Wet	460.64	479.26	454.58	891.23	926.90	1,072.26	688.30	749.93	882.46	941.47	980.32	872.19	9,399.54
1957	Above Normal	748.89	641.46	751.90	981.01	863.33	583.47	537.68	460.82	125.45	969.18	979.52	988.89	8,531.60
1958	Wet	743.82	574.78	514.71	289.62	509.04	1,047.98	714.07	768.33	895.94	940.81	984.11	903.86	8,887.07
1959	Below Normal	760.46	649.79	751.61	953.58	883.63	955.40	600.36	684.07	283.85	965.42	975.12	887.83	9,351.12
1960	Dry	639.41	561.49	454.32	294.51	241.71	311.80	663.97	774.11	581.61	982.40	769.26	958.66	7,233.25
1961	Dry	664.52	663.58	662.49	343.99	303.26	346.15	572.40	656.98	649.43	836.30	645.81	433.56	6,778.47
1962	Below Normal	115.25	612.14	703.43	169.43	204.14	412.48	582.17	668.75	133.49	1,014.48	1,025.96	929.64	6,571.36
1963	Wet	779.48	734.74	538.13	462.66	477.51	636.94	654.10	657.74	752.49	860.31	895.35	827.86	8,277.31
1964	Dry	690.92	730.26	816.08	779.67	489.19	495.12	697.77	683.04	700.60	833.33	792.09	791.56	8,499.63
1965	Wet	637.53	579.31	553.85	839.65	819.97	700.64	648.83	639.16	709.12	842.07	872.92	798.31	8,641.36
1966	Below Normal	627.95	608.20	684.56	902.57	881.12	682.77	613.02	696.68	711.22	904.47	930.47	846.84	9,089.87
1967	Wet	596.93	579.13	505.39	377.52	545.69	702.05	719.53	711.77	827.80	898.52	936.46	862.78	8,263.57
1968	Below Normal	723.64	571.23	721.59	984.81	914.20	1,002.20	696.93	674.59	743.39	879.08	904.62	829.87	9,646.15
1969	Wet	635.37	590.81	626.77	582.07	931.63	1,023.95	618.42	741.91	760.19	826.74	881.76	754.11	8,973.73
1970	Wet	712.77	509.86	586.71	1,044.96	976.27	1,103.19	620.57	685.88	776.28	888.50	917.26	765.37	9,587.62
1971	Wet	685.33	702.77	603.24	974.13	889.64	799.20	592.27	688.79	745.78	893.95	916.64	830.56	9,322.30
1972	Below Normal	581.45	473.26	587.69	319.95	397.58	560.46	635.70	703.11	734.75	875.77	898.77	817.27	7,585.76
1973	Above Normal	611.49	652.25	473.79	364.83	626.20	779.34	633.98	704.44	814.03	899.54	933.70	811.80	8,305.39
1974	Wet	777.07	765.46	636.78	997.83	899.56	1,002.66	715.88	690.34	807.23	883.59	919.98	847.76	9,944.14
1975	Wet	728.75	593.04	711.64	967.61	888.67	937.77	716.95	701.09	822.68	890.63	922.70	850.43	9,731.96
1976	Critical	788.05	596.48	718.57	850.74	773.09	533.44	606.56	697.84	305.09	932.36	680.46	918.68	8,401.36
1977	Critical	649.32	554.19	439.72	221.78	196.17	200.65	197.43	56.77	31.75	41.27	36.21	63.87	2,689.13
1978	Above Normal	17.37	125.39	495.13	178.93	296.63	580.71	644.75	650.45	777.57	863.62	888.08	815.48	6,334.11
1979	Below Normal	644.37	559.64	666.56	748.77	723.08	802.41	692.59	684.21	767.62	875.32	906.42	785.40	8,856.39
1980	Above Normal	748.67	618.53	707.89	837.55	967.54	1,056.32	557.70	625.23	757.82	802.80	798.55	696.10	9,174.70
1981	Dry	645.34	523.41	658.04	978.64	899.69	748.57	605.30	706.44	325.97	1,012.26	885.56	959.83	8,949.05
1982	Wet	696.87	745.65	554.05	497.17	638.00	1,133.17	826.93	727.77	866.42	915.82	959.04	882.02	9,442.91
1983	Wet	838.44	739.19	1,008.27	945.29	901.36	1,004.61	523.57	544.73	656.17	680.73	680.19	636.45	9,159.00
1984	Wet	675.25	623.28	1,066.79	1,013.32	1,004.74	1,092.01	607.84	692.64	784.29	888.18	923.62	830.68	10,202.64
1985	Dry	718.67	756.61	878.11	884.98	846.75	789.08	667.30	663.75	729.50	838.74	795.36	797.49	9,366.34
1986	Wet	688.76	667.49	579.74	786.11	823.12	974.03	724.90	726.48	840.46	916.55	924.94	837.76	9,490.34
1987	Dry	725.10	605.88	724.51	978.82	891.62	519.13	425.45	533.40	566.11	606.58	485.87	452.25	7,514.72
1988	Critical	240.12	190.89	243.21	195.62	161.05	220.56	314.34	362.32	356.37	465.36	318.59	293.28	3,361.71
1989	Dry	138.64	177.61	179.64	173.38	153.17	203.15	658.84	764.57	606.39	979.77	871.47	928.19	5,834.82
1990	Critical	661.93	579.18	501.45	277.30	252.39	245.67	378.22	460.47	462.12	612.13	411.57	384.14	5,226.57
1991	Critical	190.93	143.18	144.89	99.43	157.42	203.54	318.62	342.22	243.35	563.00	367.47	326.57	3,100.62
1992	Critical	169.90	111.20	138.69	117.18	163.50	230.54	309.55	358.60	376.51	50.80	36.05	295.39	2,357.91
1993	Above Normal	398.11	38.37	538.05	195.52	424.50	581.36	640.52	674.91	565.69	922.26	948.99	867.28	6,795.56
1994	Critical	686.59	566.70	675.18	638.68	566.40	450.64	549.32	630.45	524.70	822.52	248.97	669.57	7,029.72
1995	Wet	139.26	426.64	84										

Difference in Energy Use (GWh) At Pumping Plant at System Total: Alternative1_2005 minus Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Average
1922	Above Normal	0.00	0.00	0.00	62.81	2.41	1.34	14.57	23.14	62.57	61.88	66.21	57.69	29.39
1923	Below Normal	63.17	64.72	54.72	4.31	11.21	152.34	188.47	(346.62)	(568.27)	191.45	192.89	176.54	15.41
1924	Critical	224.52	173.06	233.59	152.16	119.12	52.89	45.49	60.00	(97.36)	(490.07)	(335.13)	(288.35)	(12.51)
1925	Dry	175.74	403.16	592.61	43.83	30.76	(155.38)	(16.91)	(105.86)	(89.99)	(98.16)	(109.85)	(95.90)	47.84
1926	Dry	(85.30)	(78.65)	(48.58)	22.02	1.46	19.75	19.67	64.49	(24.09)	86.77	120.16	79.38	14.76
1927	Wet	(184.10)	176.95	148.23	22.59	(16.63)	(1.07)	(16.32)	(17.06)	(104.11)	43.26	42.01	38.69	11.04
1928	Above Normal	50.09	49.32	43.16	37.49	(14.41)	(17.12)	(12.75)	24.66	(444.72)	141.97	139.26	121.56	9.88
1929	Critical	89.91	88.39	57.32	(91.59)	(101.12)	(19.64)	51.92	39.12	45.85	(331.92)	(287.61)	(249.15)	(59.04)
1930	Dry	(46.36)	(14.73)	579.13	47.27	3.48	4.08	(4.75)	(3.64)	(331.46)	62.32	59.94	40.41	32.97
1931	Critical	33.63	25.61	19.75	9.57	4.38	8.86	(0.84)	(1.05)	(0.99)	(9.40)	(381.93)	(334.74)	(52.26)
1932	Dry	(54.79)	127.67	517.60	18.57	0.23	5.23	2.50	0.41	45.27	46.22	127.35	64.96	75.10
1933	Critical	30.88	38.56	54.16	103.28	27.18	(3.23)	(16.99)	(10.19)	(0.88)	(16.31)	(17.67)	(15.71)	14.42
1934	Critical	(22.31)	(22.16)	(6.46)	(0.64)	5.88	13.41	21.04	27.76	29.82	29.07	(34.14)	(2.80)	3.21
1935	Below Normal	57.13	36.29	25.81	8.00	5.91	9.13	14.88	18.93	(249.76)	116.39	128.28	118.13	24.09
1936	Below Normal	116.22	110.18	89.15	38.65	(9.26)	(154.83)	65.61	(1.87)	43.84	43.77	43.75	55.22	36.70
1937	Below Normal	46.19	44.20	43.28	(51.00)	12.52	67.95	(7.42)	(14.14)	46.06	37.79	34.88	38.15	24.87
1938	Wet	37.58	36.81	(49.37)	(27.70)	8.08	(18.83)	(0.85)	(142.11)	(33.90)	40.09	14.86	69.97	(5.45)
1939	Dry	38.12	41.96	27.84	44.98	(0.10)	(10.71)	(52.24)	7.88	94.47	44.68	36.23	45.26	26.53
1940	Above Normal	39.82	(58.64)	89.61	25.27	(16.93)	(4.66)	(0.24)	(0.29)	43.43	44.69	44.66	44.65	20.95
1941	Wet	44.78	45.26	20.88	(0.03)	(5.37)	(29.51)	(0.02)	(1.75)	45.24	45.71	45.75	45.73	21.39
1942	Wet	46.28	45.73	22.18	(6.26)	(3.24)	(3.66)	0.52	(2.04)	43.55	42.80	43.21	58.74	23.98
1943	Wet	44.07	42.95	44.82	(29.97)	(1.67)	11.92	13.94	(0.92)	38.97	44.80	44.17	42.64	24.64
1944	Dry	48.28	45.35	37.50	(32.09)	(69.92)	(23.95)	(1.19)	(0.75)	29.25	28.52	30.49	27.63	9.93
1945	Below Normal	26.67	27.00	27.20	28.95	(14.80)	(80.42)	0.84	0.90	46.78	46.66	46.63	47.98	17.03
1946	Below Normal	47.38	48.77	50.11	45.85	0.29	2.18	2.70	2.83	48.86	48.41	48.68	47.33	32.78
1947	Dry	47.75	48.17	47.82	50.48	1.02	(0.76)	(0.87)	1.64	19.93	20.74	20.85	20.03	23.07
1948	Below Normal	17.96	17.92	16.92	7.80	(9.61)	(3.25)	0.45	13.57	(0.19)	0.22	0.37	0.24	5.20
1949	Dry	0.32	0.36	0.16	(0.13)	0.13	(0.46)	(0.14)	0.56	1.57	1.79	1.70	1.56	0.62
1950	Below Normal	0.04	0.97	0.69	(4.56)	(5.00)	(1.58)	(0.11)	(0.14)	19.73	19.62	19.62	19.64	5.74
1951	Above Normal	19.64	19.68	(7.01)	0.00	7.77	0.00	0.00	0.00	45.84	45.85	45.85	45.84	18.62
1952	Wet	45.85	45.84	45.85	43.98	0.13	(0.58)	(2.74)	(28.98)	(48.81)	22.45	18.24	43.09	15.36
1953	Wet	19.70	23.74	70.49	40.29	(3.65)	(73.08)	(133.08)	(10.66)	38.23	36.02	36.64	37.91	6.88
1954	Above Normal	38.79	42.55	46.59	74.98	31.40	21.30	3.97	6.92	39.49	8.55	15.09	14.62	28.69
1955	Dry	14.89	14.35	13.81	13.95	0.14	(0.74)	(3.88)	(4.74)	0.02	0.28	(0.36)	(3.19)	3.71
1956	Wet	1.20	1.62	(28.68)	(92.84)	0.02	0.21	0.49	0.47	46.34	46.29	46.31	47.17	5.72
1957	Above Normal	46.29	46.26	46.21	45.84	(0.19)	(0.34)	0.22	1.60	43.53	44.58	44.59	44.54	30.26
1958	Wet	44.55	44.48	44.46	44.35	0.01	(0.64)	(3.19)	(5.15)	41.77	45.78	45.78	45.51	28.98
1959	Below Normal	45.85	45.32	45.11	45.80	(5.80)	(21.21)	(13.62)	(16.42)	(86.70)	24.15	22.04	22.62	8.93
1960	Dry	21.06	18.04	20.18	18.31	(2.27)	1.10	1.05	(1.40)	26.05	(7.69)	22.17	(16.06)	8.38
1961	Dry	(8.33)	(8.69)	(5.59)	10.67	9.44	3.70	1.15	1.40	1.45	1.44	7.34	(0.57)	1.12
1962	Below Normal	0.39	(0.17)	(0.29)	0.01	0.00	0.00	0.01	0.00	44.34	44.34	44.34	44.34	14.78
1963	Wet	44.34	44.34	44.34	44.34	(0.01)	(0.02)	0.00	(0.01)	45.84	45.84	45.84	45.84	30.06
1964	Dry	45.86	45.84	45.77	45.82	(0.23)	1.42	(0.28)	(0.29)	0.40	0.44	0.51	0.47	15.48
1965	Wet	0.65	0.47	0.52	0.71	1.41	(3.82)	0.19	1.27	35.27	49.14	49.08	48.80	15.31
1966	Below Normal	47.95	47.03	47.16	41.48	(4.28)	(1.99)	0.03	0.15	33.05	34.28	34.32	34.26	26.12
1967	Wet	34.53	34.12	34.06	33.18	(0.43)	(0.18)	(2.57)	(6.02)	(15.08)	44.65	44.27	43.52	20.34
1968	Below Normal	42.66	11.03	20.01	55.62	(0.06)	3.00	0.36	9.50	51.07	55.50	54.77	50.98	29.54
1969	Wet	28.93	41.69	35.48	(153.02)	26.68	15.36	(8.38)	6.35	(4.00)	42.12	42.06	42.19	9.62
1970	Wet	43.01	42.55	43.22	(2.32)	3.85	(2.13)	(17.51)	2.84	48.85	49.73	48.68	48.80	25.80
1971	Wet	48.56	48.28	47.96	45.76	(10.32)	2.27	(0.97)	(1.24)	19.35	28.36	28.21	28.26	23.71
1972	Below Normal	28.11	28.13	28.14	28.50	0.32	0.10	(0.08)	(0.24)	0.49	0.45	0.50	0.54	9.58
1973	Above Normal	0.69	0.69	0.73	1.35	0.51	0.99	(0.79)	0.08	45.93	45.69	45.70	45.83	15.62
1974	Wet	44.92	45.16	45.49	48.45	(0.02)	(40.21)	(3.48)	(5.98)	39.09	38.88	38.67	56.87	25.65
1975	Wet	39.53	40.27	42.78	32.37	(8.02)	(28.54)	7.02	7.08	53.34	52.79	53.16	52.49	28.69
1976	Critical	52.27	52.38	51.15	53.96	6.30	1.16	(2.91)	(3.53)	(0.74)	(4.80)	2.29	(5.77)	16.81
1977	Critical	(5.35)	(4.83)	(3.98)	(0.71)	(0.47)	(0.17)	19.38	0.05	0.60	(0.01)	(0.45)	(0.58)	0.29
1978	Above Normal	(0.57)	(0.54)	1.05	(0.03)	(11.73)	(29.70)	(8.38)	14.35	34.09	68.50	63.37	57.69	15.68
1979	Below Normal	44.73	42.45	32.95	(63.36)	(190.44)	(5.84)	81.56	6.46	50.35	50.22	48.54	74.44	14.34
1980	Above Normal	78.16	55.60	51.28	(98.80)	15.54	26.78	(27.57)	(24.94)	19.67	(11.26)	(15.38)	69.45	11.54
1981	Dry	21.62	22.73	29.67	62.30	(1.82)	69.25	12.47	16.06	152.75	42.23	16.33	52.29	41.32
1982	Wet	60.55	51.14	50.41	47.93	(0.53)	7.20	0.10	(6.58)	36.89	45.80	45.78	45.28	32.00
1983	Wet	15.74	56.52	4.42	0.00	0.00	0.00	0.00	0.00	0.00	0.00	45.85	45.85	14.03
1984	Wet	(3.47)	0.00	0.00	0.00	0.11	0.07	0.04	0.03	45.87	45.87	45.88	45.92	15.03
1985	Dry	45.88	45.87	45.90	45.83	(0.01)	(0.03)	0.01	0.01	31.40	31.40	31.39	31.40	25.75
1986	Wet	31.40	31.40	31.39	31.39	(71.12)	(169.99)	51.03	(0.24)	44.65	45.84	68.37	8.49	8.55
1987	Dry	50.49	51.12	45.34	45.85	0.05	0.21	(13.29)	(17.50)	2.64	(1.07)	4.69	7.57	14.68
1988	Critical	11.88	14.06	16.48	18.75	(1.63)	(0.34)	0.01	0.01	0.02	0.26	0.01	0.02	4.96
1989	Dry	0.01	0.05	(0.02)	(0.08)	(0.12)	(0.17)	(0.55)	(0.69)	(4.04)	(0.05)	(24.71)	6.58	(1.98)
1990	Critical	5.92	5.04	4.88	(0.16)	(0.06)	0.01	0.07	0.10	0.11	0.06	0.10	0.08	1.35
1991	Critical	0.04	0.03	0.00	0.00	(0.04)	(0.04)	(0.07)	(7.60)	0.04	2.37	1.76	1.40	(0.18)
1992	Critical	0.75	(7.45)	5.14	2.27	(0.05)	(0.09)	(0.03)	(0.04)	(0.05)	(0.72)	0.99	(2.32)	(0.13)
1993	Above Normal	(2.12)	(3.52)	6.75	(0.24)	(0.58)	(1.47)	(0.07)	0.78	37.38	48.04	47.80	48.03	15.07
1994	Critical	48.04	46.25	45.80	42.33	(3.05)	(1.32)	(0.13)	0.02	1.67	0.56	0.91	0.56	15.14
1995	Wet	0.00	0.09	0.57	0.66	(0.09)	(0.99)	(3.89)	(87.94)	26.06	45.41	43.41	39.30	5.22
1996	Wet	45.79	44.81	38.42	(341.38)	(305.45)	(149.42)	(18.74)	(19.70)	28.81	31.14	30.98	32.95	(48.48)
1997	Wet	31.92	32.85	29.83	(2.72)	(0.02)	(3.16)	2.98	0.49	45.64	48.17	47.24	46.96	23.35
1998	Wet	47.43	47.34	46.98	46.94	10.80	(3.51)	(3.15)	(30.19)	(21.82)	19.90	25.63	13.82	13.82
1999	Wet	60.84	14.46	31.82	47.13	2.24	(54.91)	(35.86)	1.61	47.58	47.33	47.46	45.43	21.26
2000	Above Normal	47.77	46.39	46.83	49.26	1.89	(6.50)	(1.68)	3.17	47.62	49.22	48.72	48.05	31.73
2001	Dry	43.15	43.25	33.32	23.29	(19.07)	(5.36)	3.07	4.03	8.86	15.13	8.21	7.65	13.79
2002	Dry	6.65	5.94	5.49	4.78	0.36	(0.31)	(2.05)	(2.07)	(1.57)	(1.40)	(1.67)	1.56	1.31
2003	Above Normal	(1.38)	18.79	(20.06)	6.95	5.71	2.11	(0.09)	(0.09)	22.33	22.27	22.25	22.27	8.42
Average		29.41	36.59	49.98	12.43	(6.72)	(7.69)	2.28	(6.83)	(0.45)	21.25	20.36	22.64	14.44
Wet		25.95												

Percent Difference in Energy Use (GWh) At Pumping Plant at System Total: Alternative1_2005 minus Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September
1922	Above Normal	0%	0%	0%	23%	1%	0%	2%	4%	8%	8%	8%	8%
1923	Below Normal	10%	12%	10%	0%	1%	17%	31%	-51%	-70%	23%	22%	22%
1924	Critical	38%	33%	54%	39%	34%	20%	13%	15%	-23%	-86%	-90%	-88%
1925	Dry	81%	202%	258%	23%	16%	-29%	-3%	-14%	-12%	-11%	-13%	-11%
1926	Dry	-15%	-15%	-11%	8%	1%	6%	4%	10%	-4%	11%	16%	12%
1927	Wet	-39%	30%	36%	9%	-4%	0%	-2%	-2%	-14%	5%	5%	5%
1928	Above Normal	8%	8%	6%	5%	-2%	-3%	-2%	4%	-59%	17%	16%	15%
1929	Critical	14%	16%	10%	-12%	-15%	-5%	16%	10%	12%	-88%	-85%	-85%
1930	Dry	-27%	-11%	292%	31%	2%	1%	-1%	-1%	-56%	8%	10%	6%
1931	Critical	9%	8%	8%	4%	2%	4%	0%	0%	0%	-2%	-89%	-91%
1932	Dry	-27%	71%	146%	8%	0%	1%	1%	0%	8%	6%	19%	12%
1933	Critical	7%	11%	18%	43%	8%	-1%	-4%	-2%	0%	-3%	-3%	-3%
1934	Critical	-8%	-10%	-2%	0%	2%	6%	5%	5%	6%	6%	-45%	-7%
1935	Below Normal	19%	6%	5%	3%	2%	3%	2%	3%	-52%	12%	13%	13%
1936	Below Normal	18%	20%	19%	15%	-2%	-16%	10%	0%	6%	5%	5%	7%
1937	Below Normal	6%	7%	6%	-6%	1%	7%	-1%	-2%	6%	4%	4%	5%
1938	Wet	5%	5%	-8%	-3%	1%	-2%	0%	-17%	-4%	5%	2%	10%
1939	Dry	6%	8%	4%	5%	0%	-1%	-7%	1%	30%	5%	5%	5%
1940	Above Normal	6%	-15%	13%	13%	-7%	-1%	0%	0%	7%	5%	5%	5%
1941	Wet	7%	9%	4%	0%	-1%	-3%	0%	0%	7%	6%	6%	6%
1942	Wet	8%	10%	4%	-1%	0%	0%	0%	0%	6%	5%	5%	8%
1943	Wet	7%	8%	9%	-3%	0%	1%	2%	0%	5%	5%	5%	5%
1944	Dry	7%	8%	5%	-5%	-10%	-5%	0%	0%	5%	4%	4%	5%
1945	Below Normal	7%	5%	8%	10%	-5%	-8%	0%	0%	6%	5%	5%	6%
1946	Below Normal	6%	7%	6%	5%	0%	0%	0%	0%	7%	6%	6%	6%
1947	Dry	7%	8%	9%	6%	0%	0%	0%	0%	3%	2%	2%	2%
1948	Below Normal	3%	3%	4%	2%	-2%	-1%	0%	3%	0%	0%	0%	0%
1949	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1950	Below Normal	0%	0%	0%	-2%	-2%	0%	0%	0%	23%	2%	2%	2%
1951	Above Normal	3%	3%	-1%	0%	1%	0%	0%	0%	6%	6%	5%	6%
1952	Wet	7%	7%	8%	5%	0%	0%	0%	-5%	-7%	3%	2%	6%
1953	Wet	4%	5%	8%	4%	0%	-7%	-16%	-2%	6%	4%	4%	5%
1954	Above Normal	7%	9%	8%	12%	5%	3%	1%	1%	5%	1%	2%	2%
1955	Dry	3%	3%	2%	4%	0%	0%	-1%	-1%	0%	0%	0%	0%
1956	Wet	0%	0%	-6%	-9%	0%	0%	0%	0%	6%	5%	5%	6%
1957	Above Normal	7%	8%	7%	5%	0%	0%	0%	0%	53%	5%	5%	5%
1958	Wet	6%	8%	9%	18%	0%	0%	0%	-1%	5%	5%	5%	5%
1959	Below Normal	6%	7%	6%	5%	-1%	-2%	-2%	-2%	-23%	3%	2%	3%
1960	Dry	3%	3%	5%	7%	-1%	0%	0%	0%	5%	-1%	3%	-2%
1961	Dry	-1%	-1%	-1%	3%	3%	1%	0%	0%	0%	0%	1%	0%
1962	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	50%	5%	5%	5%
1963	Wet	6%	6%	9%	11%	0%	0%	0%	0%	6%	6%	5%	6%
1964	Dry	7%	7%	6%	6%	0%	0%	0%	0%	0%	0%	0%	0%
1965	Wet	0%	0%	0%	0%	0%	-1%	0%	0%	5%	6%	6%	7%
1966	Below Normal	8%	8%	7%	5%	0%	0%	0%	0%	5%	4%	4%	4%
1967	Wet	6%	6%	7%	10%	0%	0%	0%	-1%	-2%	5%	5%	5%
1968	Below Normal	6%	2%	3%	6%	0%	0%	0%	1%	7%	7%	6%	7%
1969	Wet	5%	8%	6%	-21%	3%	2%	-1%	1%	-1%	5%	5%	6%
1970	Wet	6%	9%	8%	0%	0%	0%	-3%	0%	7%	6%	6%	7%
1971	Wet	8%	7%	9%	5%	-1%	0%	0%	0%	3%	3%	3%	4%
1972	Below Normal	5%	6%	5%	10%	0%	0%	0%	0%	0%	0%	0%	0%
1973	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	6%	5%	5%	6%
1974	Wet	6%	6%	8%	5%	0%	-4%	0%	-1%	5%	5%	4%	7%
1975	Wet	6%	7%	6%	3%	-1%	-3%	1%	1%	7%	6%	6%	7%
1976	Critical	7%	10%	8%	7%	1%	0%	0%	-1%	0%	-1%	0%	-1%
1977	Critical	-1%	-1%	-1%	0%	0%	0%	11%	0%	2%	0%	-1%	-1%
1978	Above Normal	-3%	0%	0%	0%	-4%	-5%	-1%	2%	5%	9%	8%	8%
1979	Below Normal	7%	8%	5%	-8%	-21%	-1%	13%	1%	7%	6%	6%	10%
1980	Above Normal	12%	10%	8%	-11%	2%	3%	-5%	-4%	3%	-1%	-2%	11%
1981	Dry	3%	5%	5%	7%	0%	10%	2%	2%	88%	4%	2%	6%
1982	Wet	10%	7%	10%	11%	0%	1%	0%	-1%	4%	5%	5%	5%
1983	Wet	2%	8%	0%	0%	0%	0%	0%	0%	0%	0%	7%	8%
1984	Wet	-1%	0%	0%	0%	0%	0%	0%	0%	6%	5%	5%	6%
1985	Dry	7%	6%	6%	5%	0%	0%	0%	0%	4%	4%	4%	4%
1986	Wet	5%	5%	6%	4%	-8%	-15%	8%	0%	6%	5%	8%	1%
1987	Dry	7%	9%	7%	5%	0%	0%	-3%	-3%	0%	0%	1%	2%
1988	Critical	5%	8%	7%	11%	-1%	0%	0%	0%	0%	0%	0%	0%
1989	Dry	0%	0%	0%	0%	0%	0%	0%	0%	-1%	0%	-3%	1%
1990	Critical	1%	1%	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1991	Critical	0%	0%	0%	0%	0%	0%	0%	-2%	0%	0%	0%	0%
1992	Critical	0%	-6%	4%	2%	0%	0%	0%	0%	0%	-1%	3%	-1%
1993	Above Normal	-1%	-8%	1%	0%	0%	0%	0%	0%	7%	5%	5%	6%
1994	Critical	8%	9%	7%	7%	-1%	0%	0%	0%	0%	0%	0%	0%
1995	Wet	0%	0%	0%	0%	0%	0%	-1%	-10%	3%	5%	5%	5%
1996	Wet	7%	7%	7%	-39%	-30%	-16%	-3%	-3%	4%	4%	4%	4%
1997	Wet	5%	6%	4%	0%	0%	0%	0%	0%	6%	6%	6%	6%
1998	Wet	8%	9%	7%	5%	1%	0%	0%	-4%	-3%	2%	2%	3%
1999	Wet	8%	2%	5%	5%	0%	-6%	-5%	0%	6%	6%	5%	6%
2000	Above Normal	8%	9%	7%	6%	0%	-1%	0%	0%	6%	6%	5%	6%
2001	Dry	7%	9%	6%	6%	-5%	-2%	1%	1%	2%	2%	2%	2%
2002	Dry	3%	2%	2%	3%	0%	0%	0%	0%	0%	0%	0%	0%
2003	Above Normal	0%	5%	-3%	4%	2%	1%	0%	0%	19%	2%	2%	3%
Average		5%	8%	14%	4%	0%	-1%	1%	-1%	2%	2%	0%	1%
Wet		4%	7%	6%	1%	-2%	-2%	-1%	-2%	3%	5%	5%	6%
Above Normal		4%	2%	4%	5%	0%	0%	0%	1%	5%	6%	5%	7%
Below Normal		7%	7%	6%	3%	-2%	0%	4%	-3%	-3%	6%	6%	7%
Dry		4%	17%	41%	7%	0%	-1%	0%	0%	4%	2%	3%	2%
Critical		7%	7%	10%	8%	3%	2%	3%	2%	0%	-15%	-26%	-23%

Energy Use (GWh) At Pumping Plant at Teerink: Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Total
1922	Above Normal	72.77	59.80	47.47	11.73	21.70	36.39	46.86	45.94	46.92	47.24	49.19	43.84	529.85
1923	Below Normal	39.49	35.19	30.53	62.67	60.49	60.45	43.21	48.84	49.11	52.12	53.21	46.49	581.80
1924	Critical	36.81	32.41	25.70	21.50	21.21	18.45	24.68	29.71	30.27	30.21	26.93	22.90	320.78
1925	Dry	11.64	8.43	7.11	6.06	9.43	30.08	40.48	52.84	53.31	56.87	57.19	49.88	383.32
1926	Dry	38.14	33.68	26.18	13.19	15.07	21.37	31.48	45.83	46.16	49.18	49.48	43.12	412.88
1927	Wet	32.55	28.57	22.00	12.14	19.63	42.83	50.18	49.94	51.09	51.35	53.23	47.61	461.12
1928	Above Normal	43.41	38.79	33.94	54.06	53.34	33.12	50.30	49.48	50.46	50.79	52.44	46.96	557.09
1929	Critical	42.49	38.02	33.20	49.47	46.12	25.87	20.82	27.17	27.46	27.57	24.59	20.34	383.12
1930	Dry	10.63	7.75	6.55	5.39	10.65	14.88	34.53	40.74	41.47	42.93	41.14	35.53	292.19
1931	Critical	23.55	19.44	14.71	10.18	11.86	14.13	28.04	34.09	34.75	34.84	31.02	26.11	282.72
1932	Dry	13.42	10.26	8.47	7.81	12.42	18.46	35.15	40.77	41.01	43.45	43.06	37.48	311.76
1933	Critical	27.00	23.32	17.75	11.16	12.87	17.30	31.37	39.44	40.43	40.95	37.48	32.08	331.15
1934	Critical	18.90	14.28	10.66	9.21	10.23	14.72	29.85	36.38	37.23	37.21	6.33	1.67	226.67
1935	Below Normal	20.62	37.31	27.82	8.71	12.02	17.59	45.37	53.07	33.49	61.47	61.59	53.87	432.93
1936	Below Normal	41.23	36.58	28.51	13.69	17.03	53.94	46.24	52.01	53.21	53.49	55.49	49.63	501.05
1937	Below Normal	45.38	40.60	35.55	55.67	60.86	59.61	45.47	49.79	50.96	51.43	53.42	47.30	596.04
1938	Wet	42.74	38.19	33.22	62.72	60.57	67.82	42.16	49.20	50.43	49.17	53.39	44.75	594.36
1939	Dry	39.95	35.51	31.68	62.94	60.79	71.71	51.13	51.12	23.30	60.46	44.70	58.80	592.09
1940	Above Normal	46.66	28.09	45.92	8.67	10.28	24.02	45.09	53.56	45.62	59.38	59.64	52.04	478.97
1941	Wet	39.94	35.30	27.50	19.75	25.67	63.36	37.84	42.96	43.78	44.46	46.64	40.88	468.08
1942	Wet	36.20	32.17	27.47	62.74	60.58	71.42	55.34	45.87	46.91	47.34	49.44	43.86	579.34
1943	Wet	39.51	35.15	30.37	53.66	60.53	58.40	52.79	51.64	52.74	53.31	55.60	49.37	593.07
1944	Dry	44.82	40.00	34.78	45.94	42.74	27.37	35.56	41.64	41.80	44.14	43.34	37.65	479.78
1945	Below Normal	26.56	22.63	17.30	13.24	14.46	65.16	46.13	49.92	51.10	51.39	53.23	47.62	458.74
1946	Below Normal	43.39	38.76	45.04	57.08	42.86	46.48	47.28	47.27	48.21	48.57	50.61	45.21	560.76
1947	Dry	40.95	36.55	31.77	54.49	53.17	34.47	49.06	52.64	53.37	55.40	56.27	49.75	567.89
1948	Below Normal	41.40	36.82	30.33	32.08	30.46	20.17	29.93	37.91	4.54	61.81	61.74	54.07	441.26
1949	Dry	41.44	36.73	28.65	14.50	15.37	19.72	49.12	51.94	52.88	54.63	55.54	49.18	469.70
1950	Below Normal	41.37	36.84	30.59	13.55	13.88	16.75	41.38	47.76	1.78	61.57	61.25	53.35	420.07
1951	Above Normal	40.78	35.91	33.66	62.37	55.52	66.45	42.80	48.78	49.88	50.11	52.22	46.68	585.16
1952	Wet	42.41	37.85	32.94	62.67	62.35	45.88	39.72	41.42	42.04	42.95	45.35	39.45	535.03
1953	Wet	34.63	30.70	45.83	62.77	60.59	71.48	58.02	46.09	46.19	47.79	49.21	43.55	596.85
1954	Above Normal	37.05	32.83	27.34	40.85	41.00	40.17	45.48	52.78	51.53	54.50	58.11	50.72	532.36
1955	Dry	38.84	34.26	26.62	14.30	16.99	22.72	38.41	44.44	44.53	47.63	47.86	41.73	418.33
1956	Wet	31.30	27.45	21.11	52.57	57.11	67.54	49.01	53.21	54.54	54.82	57.17	51.04	576.87
1957	Above Normal	46.66	41.71	36.37	63.23	60.11	40.44	38.11	33.18	1.98	58.76	58.30	50.89	529.74
1958	Wet	38.62	34.00	26.43	11.70	29.39	61.06	48.96	53.48	54.81	55.33	57.86	51.11	522.75
1959	Below Normal	46.48	41.44	35.98	63.21	60.99	65.72	43.54	50.21	25.97	59.33	59.42	51.96	604.25
1960	Dry	39.80	35.18	27.34	12.82	13.16	17.47	48.41	55.57	39.52	63.28	47.96	60.59	461.10
1961	Dry	47.57	42.31	33.41	16.87	17.71	17.36	41.09	47.38	47.87	50.99	43.38	29.14	435.08
1962	Below Normal	8.23	41.48	45.82	7.23	8.49	22.09	41.65	48.46	2.33	62.42	62.21	54.24	404.65
1963	Wet	41.50	36.60	28.61	25.90	30.15	40.39	46.58	46.88	47.78	48.11	50.16	44.84	487.50
1964	Dry	40.62	36.20	45.94	48.12	31.34	33.15	49.90	48.72	49.82	50.10	52.06	46.52	532.49
1965	Wet	42.39	37.80	33.01	50.66	53.48	43.89	45.83	45.50	44.87	47.15	48.91	43.55	537.04
1966	Below Normal	38.80	34.49	29.61	56.70	58.93	45.34	44.00	50.17	47.48	54.33	55.30	48.17	563.32
1967	Wet	37.57	33.06	25.92	16.27	33.12	42.19	49.92	49.85	50.96	51.47	53.67	47.65	491.65
1968	Below Normal	43.18	38.49	35.65	62.70	62.69	67.28	49.48	47.34	48.03	50.07	51.30	45.06	601.27
1969	Wet	36.95	32.62	26.47	45.16	60.23	68.24	42.41	47.01	48.01	48.65	51.20	44.99	551.94
1970	Wet	43.44	32.59	30.73	62.77	60.60	69.35	45.39	48.70	49.82	50.05	52.11	46.55	592.10
1971	Wet	42.33	37.75	32.88	62.67	60.49	51.82	42.32	49.74	49.67	53.67	54.41	47.30	585.05
1972	Below Normal	36.14	31.76	24.60	13.44	26.06	37.17	45.23	50.94	51.50	54.40	55.18	48.23	474.65
1973	Above Normal	38.09	33.63	26.64	19.94	37.84	50.13	44.88	50.24	51.46	51.54	53.57	47.88	505.84
1974	Wet	43.67	38.99	34.07	62.68	60.53	65.12	50.76	49.35	50.63	50.88	53.16	47.25	607.09
1975	Wet	42.81	38.10	33.02	62.97	60.90	60.70	50.09	49.08	50.25	50.35	52.20	46.76	597.23
1976	Critical	42.48	37.96	33.19	53.63	52.73	34.05	42.90	49.90	22.90	59.36	44.52	56.63	530.25
1977	Critical	43.55	38.64	30.09	12.65	13.08	13.61	12.91	2.98	1.88	2.40	2.14	1.70	175.63
1978	Above Normal	0.69	10.46	32.50	7.18	12.76	34.44	45.83	45.20	46.15	46.37	48.09	42.86	372.53
1979	Below Normal	38.73	34.43	29.95	52.98	58.56	51.28	43.26	47.72	48.86	49.05	50.93	45.37	551.12
1980	Above Normal	41.00	36.53	31.82	56.27	62.65	68.22	41.65	46.16	47.14	47.89	50.32	44.13	573.78
1981	Dry	39.42	35.09	30.07	61.68	61.00	45.40	41.87	49.36	10.73	61.41	56.46	55.21	547.70
1982	Wet	42.28	37.51	29.17	24.25	28.96	68.99	50.77	50.03	52.82	53.30	55.83	49.23	543.14
1983	Wet	47.79	42.91	65.70	62.77	60.59	68.20	35.60	37.60	44.12	44.69	37.66	37.28	584.91
1984	Wet	38.00	34.25	65.93	62.79	62.75	68.39	43.20	49.40	50.38	50.79	52.89	47.33	626.10
1985	Dry	43.01	38.44	45.78	55.64	56.90	52.96	46.68	46.61	47.75	47.89	49.68	44.39	575.73
1986	Wet	40.23	35.91	31.27	51.57	48.26	70.74	46.71	50.70	51.97	52.36	54.82	48.41	582.95
1987	Dry	43.85	39.23	33.99	63.27	60.51	33.94	30.77	37.66	38.70	38.43	34.39	29.31	484.05
1988	Critical	15.96	11.41	9.28	7.62	11.22	12.66	21.53	25.50	25.76	25.94	23.06	19.59	209.53
1989	Dry	9.65	7.09	6.01	4.92	9.72	12.59	47.12	55.46	42.40	62.62	57.97	56.45	372.00
1990	Critical	43.54	38.59	30.08	13.27	14.26	15.89	27.13	32.81	33.58	33.56	29.88	25.43	338.02
1991	Critical	13.36	9.45	7.92	6.75	9.37	12.33	21.85	24.82	15.73	29.98	26.44	22.68	200.68
1992	Critical	11.29	7.70	6.95	5.75	8.92	11.85	21.59	25.58	25.76	2.18	2.07	20.44	150.08
1993	Above Normal	27.11	2.65	32.35	7.74	23.38	35.24	45.93	48.44	33.84	53.71	55.05	48.73	414.17
1994	Critical	41.24	36.68	30.47	37.83	36.21	29.22	39.25	45.21	38.35	50.11	16.30	44.84	445.71
1995	Wet	9.96	29.71	55.82	7.15	20.38	31.23	53.19	52.35	53.62	54.07	56.36	50.07	473.91
1996	Wet	45.58	40.72	35.50	58.60	60.15	53.78	50.80	49.63	50.76	51.04	53.08	47.40	597.04
1997	Wet	43.14	38.55	33.65	62.68	60.52	70.94	44.99	46.97	47.91	48.37	50.62	44.83	593.17
1998	Wet	40.28	35.87	30.95	62.12	60.55	62.90	46.07	47.63	48.75	49.58	52.01	45.52	582.23
1999	Wet	42.86	42.81	39.59	62.76	60.57	64.69	47.91	48.79	49.79	50.29	52.44	46.84	609.34
2000	Above Normal	42.58	38.04	33.11	57.18	55.17	43.55	46.58	52.66	53.14	56.45	57.03	49.93	585.42
2001	Dry	39.45	34.95	27.77	20.69	20.15	18.53	31.04	38.24	39.25	39.35	35.15	29.91	374.48
2002	Dry	16.21	11.69	9.43	6.44	14.08	23.26	50.79	49.46	50.46	50.90			

Energy Use (GWh) At Pumping Plant at Teerink: Alternative1_ 2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Total
1922	Above Normal	72.77	59.80	47.47	16.77	21.94	36.63	47.92	47.58	52.08	52.53	54.82	48.84	559.15
1923	Below Normal	44.23	39.74	34.74	63.05	60.56	71.21	56.70	24.36	5.01	67.21	68.37	60.51	595.69
1924	Critical	50.95	45.59	38.06	34.61	30.39	22.20	28.02	34.16	23.78	2.26	2.04	1.67	313.73
1925	Dry	29.43	40.51	53.38	10.59	12.07	17.54	39.06	45.05	46.32	49.38	49.48	43.26	436.07
1926	Dry	32.71	28.88	22.45	15.20	15.26	22.79	33.04	50.64	44.78	56.35	56.55	49.23	427.88
1927	Wet	20.08	43.55	33.71	14.15	18.66	42.76	48.99	48.70	44.00	54.95	56.79	51.23	477.57
1928	Above Normal	47.08	42.45	37.61	56.81	52.26	32.00	49.61	51.56	18.97	62.01	63.24	56.61	570.21
1929	Critical	49.47	44.51	38.00	42.19	38.31	24.40	24.91	30.32	30.84	2.21	2.08	1.66	328.90
1930	Dry	10.93	8.23	51.78	9.29	10.92	15.21	34.16	40.48	18.27	48.05	45.49	39.43	332.24
1931	Critical	25.84	21.19	16.13	11.15	12.25	14.70	27.98	34.02	34.69	34.77	2.09	1.64	236.45
1932	Dry	11.93	20.96	48.61	9.47	12.57	19.12	35.36	40.80	44.32	46.96	46.87	41.28	378.25
1933	Critical	31.14	27.56	21.79	15.46	13.38	16.98	30.11	38.69	40.39	40.47	36.27	30.95	343.19
1934	Critical	17.14	12.85	10.28	9.12	10.63	15.77	31.39	38.43	39.42	39.38	2.07	1.67	228.15
1935	Below Normal	25.19	40.53	30.32	9.41	12.48	18.32	46.47	54.47	14.60	70.33	71.37	62.98	456.47
1936	Below Normal	49.32	44.25	35.28	16.52	16.67	41.00	51.21	51.88	56.42	56.70	58.70	52.86	530.81
1937	Below Normal	48.61	43.85	38.80	55.30	60.85	64.64	44.85	49.21	53.70	54.19	56.18	50.08	620.26
1938	Wet	45.51	41.00	32.71	62.71	60.57	66.60	42.81	46.17	47.38	51.26	53.69	47.45	597.86
1939	Dry	42.63	38.25	34.46	66.37	60.87	71.06	47.28	51.73	30.34	63.68	47.39	62.10	616.16
1940	Above Normal	50.08	24.25	52.70	10.37	8.90	23.59	45.07	53.53	48.80	62.65	62.91	55.31	498.16
1941	Wet	43.21	38.57	29.05	19.75	25.67	61.17	37.84	42.96	47.13	47.82	49.99	44.23	487.39
1942	Wet	39.55	35.52	29.10	62.73	60.57	71.16	55.38	45.72	50.10	50.52	52.59	47.06	600.00
1943	Wet	42.73	38.39	33.63	54.36	60.52	59.42	53.84	51.60	56.04	56.59	58.84	52.67	618.63
1944	Dry	48.14	43.34	38.14	43.40	37.45	25.56	35.47	41.58	43.93	46.22	45.34	39.66	488.23
1945	Below Normal	28.49	24.54	19.26	15.34	14.42	59.83	46.19	49.98	54.52	54.81	56.65	51.04	475.07
1946	Below Normal	46.80	42.17	48.74	60.43	42.86	46.64	47.48	47.47	51.78	52.13	54.19	48.76	589.45
1947	Dry	44.50	40.08	35.29	58.19	53.25	34.40	49.01	52.78	54.85	56.96	57.80	51.23	588.34
1948	Below Normal	42.71	38.13	31.58	32.67	29.77	19.91	29.96	38.86	4.41	61.87	61.81	54.11	445.79
1949	Dry	41.48	36.75	28.67	14.49	15.38	19.68	49.11	51.99	53.00	54.77	55.67	49.30	470.29
1950	Below Normal	41.45	36.91	30.64	13.18	13.48	16.62	41.37	47.75	3.22	63.00	62.69	54.78	425.09
1951	Above Normal	42.21	37.34	33.16	62.37	55.52	66.45	42.80	48.78	53.24	53.46	55.57	50.03	600.93
1952	Wet	45.76	41.20	36.29	66.02	62.35	45.87	39.72	39.82	40.34	44.50	46.61	41.20	549.68
1953	Wet	36.57	32.72	51.05	66.08	60.55	66.35	48.32	45.23	48.89	50.27	51.75	46.24	604.02
1954	Above Normal	40.21	36.01	30.73	46.35	43.31	41.86	45.78	53.17	54.34	55.16	59.24	51.80	557.96
1955	Dry	39.91	35.31	27.65	15.34	17.01	22.66	38.12	44.09	44.53	47.61	47.84	41.75	421.82
1956	Wet	31.38	27.55	21.26	45.35	57.12	67.55	49.04	53.24	57.93	58.21	60.56	54.43	583.62
1957	Above Normal	50.04	45.09	39.75	66.58	60.10	40.41	38.12	33.30	5.22	62.01	61.55	54.14	556.31
1958	Wet	41.87	37.25	29.68	14.94	29.39	61.01	48.96	53.49	58.16	58.68	61.22	54.46	549.11
1959	Below Normal	49.83	44.79	39.33	66.59	60.99	64.39	42.51	48.96	19.16	61.01	60.96	53.56	612.08
1960	Dry	41.35	36.75	28.88	14.15	12.98	17.56	48.47	55.45	41.30	62.69	49.41	59.39	468.38
1961	Dry	46.86	41.67	32.98	17.70	18.45	17.65	41.18	47.48	47.98	51.11	43.90	29.10	436.06
1962	Below Normal	8.21	41.48	45.83	7.23	8.49	22.09	41.65	48.46	5.57	65.66	65.45	57.48	417.60
1963	Wet	44.74	39.85	31.85	29.14	30.15	40.39	46.58	46.88	51.13	51.46	53.51	48.19	513.87
1964	Dry	43.97	39.55	49.30	51.47	31.31	33.26	49.88	48.70	49.85	50.13	52.09	46.55	546.06
1965	Wet	42.42	37.83	33.04	50.89	53.59	43.60	45.85	45.60	47.50	50.77	52.52	47.13	550.74
1966	Below Normal	42.31	37.98	33.06	59.73	58.61	45.20	44.00	50.18	49.91	56.85	57.81	50.68	586.32
1967	Wet	40.06	35.55	28.41	18.69	33.09	42.19	49.93	49.80	50.90	54.76	56.96	50.95	511.29
1968	Below Normal	46.49	39.30	36.74	66.05	62.69	67.48	49.61	48.17	51.91	54.38	55.50	48.98	627.30
1969	Wet	39.95	35.58	29.09	34.29	60.31	68.24	42.15	46.76	47.75	51.74	54.29	48.10	558.25
1970	Wet	46.54	35.72	33.87	62.77	60.60	69.17	44.10	48.91	53.39	53.62	55.68	50.10	614.47
1971	Wet	45.89	41.28	36.40	66.02	60.49	52.00	42.25	49.65	51.11	55.74	56.46	49.36	606.65
1972	Below Normal	38.19	33.82	26.66	15.52	26.08	37.18	45.22	50.92	51.54	54.43	55.22	48.26	483.04
1973	Above Normal	38.14	33.68	26.69	20.04	37.88	50.21	44.83	50.25	54.82	54.90	56.92	51.24	519.60
1974	Wet	47.03	42.35	37.42	66.03	60.53	65.01	50.50	48.90	53.49	53.71	55.93	50.17	631.07
1975	Wet	45.78	41.12	36.11	65.36	60.37	58.54	50.61	49.60	54.14	54.25	56.12	50.62	622.62
1976	Critical	46.34	41.77	36.96	57.58	53.19	34.13	42.69	49.64	22.84	59.03	44.69	56.19	545.05
1977	Critical	43.18	38.29	29.80	12.62	13.04	13.60	14.25	2.98	1.92	2.40	2.10	1.70	175.88
1978	Above Normal	0.69	10.44	32.54	7.18	12.77	33.61	45.78	46.90	51.11	52.09	53.49	47.80	394.40
1979	Below Normal	42.05	37.68	32.46	47.55	43.06	49.84	48.85	48.06	52.56	52.72	54.59	49.07	558.49
1980	Above Normal	44.73	40.24	35.53	54.00	62.65	70.09	39.54	44.43	48.68	49.37	51.55	45.73	586.54
1981	Dry	41.14	36.93	32.16	66.29	60.92	50.96	42.81	50.57	22.35	64.58	57.81	59.09	585.61
1982	Wet	46.10	41.28	32.88	27.76	29.13	69.00	50.78	50.04	56.18	56.66	59.20	52.59	571.60
1983	Wet	47.91	46.16	65.70	62.77	60.59	68.20	35.60	37.60	44.12	44.69	41.01	40.63	594.98
1984	Wet	38.00	34.25	65.93	62.79	62.75	68.39	43.21	49.41	53.74	54.14	56.25	50.68	639.54
1985	Dry	46.37	41.79	49.14	58.99	56.89	52.96	46.68	46.61	50.04	50.19	51.98	46.69	598.33
1986	Wet	42.53	38.21	33.56	53.87	48.26	54.74	50.35	50.72	55.35	55.74	58.20	51.78	593.31
1987	Dry	47.22	42.60	37.36	66.62	60.51	33.96	29.79	36.36	38.87	38.63	34.73	29.82	496.47
1988	Critical	16.84	12.43	10.49	8.98	11.13	12.63	21.53	25.50	25.77	25.94	23.06	19.59	213.89
1989	Dry	9.65	7.09	6.01	4.92	9.71	12.58	47.08	55.41	42.11	62.61	56.37	56.94	370.48
1990	Critical	43.95	38.96	30.37	13.26	14.25	15.90	27.13	32.82	33.59	33.56	29.89	25.44	339.12
1991	Critical	13.36	9.45	7.93	6.75	9.37	12.33	21.84	24.29	15.74	30.12	26.55	22.79	200.52
1992	Critical	11.35	7.19	7.32	5.96	8.92	11.85	21.58	25.58	25.76	2.18	2.07	20.29	150.05
1993	Above Normal	26.97	2.40	32.87	7.74	23.35	35.13	45.93	48.51	36.61	57.26	58.58	52.26	427.61
1994	Critical	44.78	40.08	33.83	40.90	35.97	29.11	39.25	45.21	38.47	50.15	16.35	44.88	458.98
1995	Wet	10.01	29.77	55.87	7.21	20.38	31.23	53.19	52.35	56.97	57.42	59.71	53.42	487.53
1996	Wet	48.94	44.07	38.46	33.79	36.74	43.20	49.77	48.58	53.00	53.28	55.29	49.76	554.88
1997	Wet	45.53	41.02	35.76	62.67	60.51	71.01	45.22	47.09	51.38	51.84	54.09	48.29	614.41
1998	Wet	43.75	39.33	34.40	65.56	60.54	62.84	46.02	45.75	46.71	47.43	52.97	47.06	592.36
1999	Wet	48.02	43.74	42.06	66.07	60.54	60.63	45.17	48.91	53.26	53.77	55.93	50.31	628.41
2000	Above Normal	46.04	41.49	36.55	60.78	55.49	43.18	46.49	52.94	56.67	60.12	60.65	53.46	613.86
2001	Dry	42.63	38.12	30.82	22.29	18.65	18.12	31.26	38.53	39.90	39.99	35.76	30.48	386.55
2002	Dry	16.70	12.14	9.84	6.79	14.12	23.24	50.64	49.31	50.35				

Difference in Energy Use (GWh) At Pumping Plant at Tracy: Alternative1_2005 minus Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September	Average
1922	Above Normal	0.00	0.00	0.00	0.00	0.05	0.09	0.00	0.00	0.00	0.00	0.00	0.00	0.01
1923	Below Normal	1.61	4.76	0.00	(0.73)	(2.41)	0.06	0.00	0.00	(4.72)	0.00	(1.67)	0.00	(0.26)
1924	Critical	0.00	(7.25)	(7.34)	6.41	0.00	0.00	0.00	0.01	0.01	0.00	4.21	0.03	(0.33)
1925	Dry	(0.03)	0.02	0.03	0.00	0.00	0.03	0.00	(0.01)	(4.77)	(0.66)	2.14	(1.06)	(0.36)
1926	Dry	0.10	3.64	0.03	0.00	0.00	0.00	0.00	0.48	0.00	5.55	(18.21)	0.89	(0.63)
1927	Wet	(0.07)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.20	(0.31)	0.07
1928	Above Normal	0.39	(0.19)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.13)	0.00	0.23	0.02
1929	Critical	0.01	0.32	0.00	0.00	0.00	0.15	0.00	0.00	0.00	(0.09)	0.00	0.12	0.04
1930	Dry	(0.09)	(0.71)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.14	0.00	(0.02)	(0.06)
1931	Critical	0.00	0.00	0.00	0.00	0.00	0.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1932	Dry	(0.02)	(0.47)	0.00	0.00	0.30	0.00	0.00	0.00	0.00	0.00	(0.01)	0.00	(0.02)
1933	Critical	15.48	10.71	0.04	(17.96)	(7.96)	0.00	0.00	0.00	(0.01)	0.00	(0.26)	(3.10)	(0.26)
1934	Critical	0.78	(2.22)	1.66	(0.23)	(0.24)	0.02	0.00	0.00	0.00	0.00	0.00	(0.06)	(0.02)
1935	Below Normal	(9.01)	0.12	(0.02)	0.00	0.00	0.00	0.00	0.00	(0.02)	(0.08)	(0.06)	(0.02)	(0.76)
1936	Below Normal	(0.02)	(0.03)	(0.01)	0.00	8.13	1.51	0.00	0.00	0.00	0.18	0.01	0.00	0.81
1937	Below Normal	(0.10)	0.05	0.28	17.13	0.01	8.19	(1.97)	(4.88)	(6.85)	(0.07)	(0.01)	0.00	0.98
1938	Wet	0.00	0.00	15.52	12.92	0.02	8.10	(3.86)	(26.54)	0.00	0.00	0.00	0.00	0.51
1939	Dry	0.29	7.36	0.00	0.00	(0.02)	0.00	0.89	(0.02)	0.00	(2.45)	(1.61)	0.00	0.37
1940	Above Normal	5.17	0.13	(0.15)	0.09	0.00	0.00	0.00	0.00	0.01	(0.04)	4.62	6.24	1.34
1941	Wet	0.08	(2.49)	0.00	0.00	0.00	0.00	0.00	(1.41)	(0.49)	0.00	0.00	0.00	(0.36)
1942	Wet	0.21	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.02
1943	Wet	(0.02)	0.00	0.00	0.00	0.00	0.00	(0.33)	(0.18)	4.86	0.00	0.00	0.00	0.36
1944	Dry	0.50	1.59	(0.13)	0.00	0.00	0.00	0.00	0.00	0.00	(1.34)	(1.16)	(0.16)	(0.06)
1945	Below Normal	(0.01)	0.00	0.00	0.00	(5.28)	5.06	0.00	0.00	0.00	0.00	0.00	0.00	(0.02)
1946	Below Normal	(4.88)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.41)
1947	Dry	(0.02)	0.00	(0.04)	0.01	0.00	0.00	0.00	0.00	0.00	0.00	(0.54)	(0.33)	(0.08)
1948	Below Normal	0.12	(0.01)	(0.03)	0.00	0.00	0.00	0.00	0.00	0.00	0.12	0.00	0.00	0.02
1949	Dry	0.00	0.00	(0.01)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.00
1950	Below Normal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.02	(0.06)	0.01	0.00	0.00
1951	Above Normal	0.00	0.00	0.00	(0.11)	4.45	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.36
1952	Wet	0.00	(0.01)	0.00	(0.51)	0.14	0.00	(2.12)	(5.26)	0.00	0.00	0.00	0.00	(0.65)
1953	Wet	(0.61)	1.76	0.00	(6.59)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.45)
1954	Above Normal	0.02	(1.36)	0.01	0.00	0.00	0.00	0.00	0.00	0.00	(0.01)	0.00	0.00	(0.11)
1955	Dry	0.14	0.09	0.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00	(0.14)	0.00	0.01
1956	Wet	(0.05)	(0.40)	0.00	0.00	0.00	6.58	0.00	0.00	0.00	0.00	0.00	0.00	0.51
1957	Above Normal	0.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.01)	0.00
1958	Wet	0.00	0.00	0.00	0.00	0.00	8.12	(2.56)	(4.12)	0.00	0.00	0.00	0.00	0.12
1959	Below Normal	(0.01)	0.00	(0.02)	(0.01)	0.00	1.99	0.01	0.00	0.00	0.00	0.00	(0.25)	0.14
1960	Dry	0.03	0.01	(0.03)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.15)	0.03	(0.01)
1961	Dry	(0.02)	(0.04)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.00
1962	Below Normal	0.00	0.01	0.00	(0.01)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1963	Wet	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.48)	(0.04)
1964	Dry	0.19	0.00	0.00	0.00	(0.01)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.02
1965	Wet	0.00	0.00	0.00	0.00	0.00	0.00	(0.01)	0.00	0.00	0.00	0.00	0.00	0.00
1966	Below Normal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.82)	(0.07)
1967	Wet	(0.01)	0.00	0.00	0.00	0.00	0.00	(2.21)	(4.23)	0.00	0.00	0.00	0.48	(0.50)
1968	Below Normal	(0.88)	31.90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	2.59
1969	Wet	0.00	0.43	0.00	(7.53)	1.28	0.00	(3.90)	3.89	0.00	0.00	0.00	2.72	(0.26)
1970	Wet	(0.06)	0.00	0.00	0.00	(3.50)	0.24	0.00	0.00	0.00	0.08	0.00	0.08	(0.26)
1971	Wet	(0.08)	(0.06)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.01)
1972	Below Normal	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1973	Above Normal	(0.03)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	15.79	1.31
1974	Wet	(9.79)	0.00	0.00	(2.83)	0.00	13.96	(0.03)	0.00	(0.02)	0.00	0.00	0.00	0.11
1975	Wet	(0.04)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1976	Critical	0.00	0.28	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.48	0.09	0.03	0.07
1977	Critical	(0.52)	(0.07)	(0.07)	(0.08)	(0.08)	0.00	0.00	0.00	(0.03)	0.00	0.18	0.00	(0.06)
1978	Above Normal	(0.06)	(0.06)	(0.02)	0.00	(3.52)	(2.34)	(4.65)	(4.89)	(1.48)	0.00	0.00	0.00	(1.42)
1979	Below Normal	(0.07)	9.14	0.27	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.78
1980	Above Normal	(2.79)	2.18	0.00	(5.16)	5.38	(0.23)	0.01	0.00	(0.79)	0.00	0.00	17.25	1.32
1981	Dry	(6.36)	(10.34)	0.00	0.00	0.00	(6.59)	0.00	0.00	0.00	0.00	(0.06)	(1.35)	(2.06)
1982	Wet	(0.01)	0.00	0.00	0.00	0.00	8.11	0.00	(5.35)	0.00	0.00	0.00	0.00	0.23
1983	Wet	0.00	0.00	0.00	17.40	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.45
1984	Wet	0.00	0.00	0.00	0.00	0.30	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.02
1985	Dry	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1986	Wet	0.00	0.00	0.00	0.00	0.00	4.47	(0.34)	(2.75)	(1.22)	0.00	0.00	0.00	0.01
1987	Dry	0.03	4.50	(0.08)	0.00	0.00	0.00	0.00	0.00	0.00	(0.58)	(0.71)	(0.07)	0.26
1988	Critical	0.02	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.58)	(0.08)	0.13	(0.04)
1989	Dry	0.02	0.00	(0.07)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.25	(0.04)	0.01
1990	Critical	(0.01)	(0.02)	(0.01)	0.00	(0.01)	0.00	0.00	0.00	0.00	0.01	0.03	0.00	0.00
1991	Critical	0.00	0.02	(0.04)	0.00	0.01	0.00	(0.01)	0.00	0.00	(0.46)	0.25	(0.03)	(0.02)
1992	Critical	(0.02)	0.03	0.00	(0.18)	0.00	0.00	0.00	0.00	0.00	0.00	(0.02)	(0.06)	(0.02)
1993	Above Normal	0.01	(0.01)	(0.01)	0.00	(0.01)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1994	Critical	(0.01)	(0.19)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	(0.02)
1995	Wet	0.01	0.00	(0.01)	(0.02)	0.00	0.00	(3.11)	(25.60)	0.00	0.00	0.00	0.00	(2.39)
1996	Wet	(0.04)	21.87	0.00	0.00	0.00	0.00	0.00	(0.05)	0.00	0.00	0.00	0.00	1.82
1997	Wet	(1.18)	0.00	0.00	0.00	0.00	0.57	0.00	0.00	0.69	(1.80)	0.00	0.00	(0.14)
1998	Wet	(0.03)	0.00	0.00	(0.04)	0.00	0.00	(2.04)	(4.03)	0.00	0.00	0.00	0.00	(0.51)
1999	Wet	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(1.06)	(0.09)
2000	Above Normal	0.70	0.00	0.12	0.00	0.00	0.00	0.00	0.00	0.00	0.04	0.00	0.00	0.07
2001	Dry	(0.07)	0.00	1.49	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.90)	0.02	0.04
2002	Dry	0.00	0.00	0.00	0.00	(0.01)	0.00	0.00	0.00	0.00	0.00	0.00	(0.38)	(0.03)
2003	Above Normal	0.00	0.05	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.07	0.01
Average		(0.14)	0.92	0.14	0.15	(0.04)	0.71	(0.33)	(1.02)	(0.18)	0.01	(0.16)	0.40	0.04
Wet		(0.45)	0.81	0.60	0.49	(0.07)	1.93	(0.79)	(2.91)	0.15	(0.07)	0.05	0.06	(0.02)
Above Normal		0.28	0.06	(0.00)	(0.43)	0.53	(0.21)	(0.39)	(0.41)	(0.19)	(0.01)	0.39	3.30	0.24
Below Normal		(0.95)	3.28	0.03	1.17	0.03	1.20	(0.14)	(0.35)	(0.83)	0.01	(0.12)	(0.08)	0.27
Dry		(0.30)	0.31	0.07	0.00	0.01	(0.36)	0.00	0.08	(0.27)	0.17	(1.22)	(0.23)	(0.14)
Critical		1.31	0.14	(0.48)	(1.00)	(0.69)	0.02	(0.00)	0.00	(0.00)	(0.05)	0.37	(0.24)	(0.06)

Percent Difference in Energy Use (GWh) At Pumping Plant at Tracy: Alternative1_2005 minus Existing_2005

Year	Year Type	October	November	December	January	February	March	April	May	June	July	August	September
1922	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1923	Below Normal	3%	8%	0%	-1%	-4%	0%	0%	0%	-10%	0%	-3%	0%
1924	Critical	0%	-11%	-13%	13%	0%	0%	0%	0%	0%	0%	23%	0%
1925	Dry	0%	0%	0%	0%	0%	0%	0%	0%	-11%	-1%	4%	-2%
1926	Dry	0%	6%	0%	0%	0%	0%	0%	4%	0%	11%	-42%	2%
1927	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	2%	-1%
1928	Above Normal	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1929	Critical	0%	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1930	Dry	0%	-2%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1931	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1932	Dry	0%	-1%	0%	0%	1%	0%	0%	0%	0%	0%	0%	0%
1933	Critical	34%	26%	0%	-32%	-35%	0%	0%	0%	0%	0%	0%	-5%
1934	Critical	2%	-7%	4%	-3%	-2%	0%	0%	0%	0%	0%	0%	0%
1935	Below Normal	-22%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1936	Below Normal	0%	0%	0%	0%	38%	5%	0%	0%	0%	0%	0%	0%
1937	Below Normal	0%	0%	0%	52%	0%	50%	-12%	-27%	-33%	0%	0%	0%
1938	Wet	0%	0%	30%	107%	0%	27%	-11%	-42%	0%	0%	0%	0%
1939	Dry	1%	65%	0%	0%	0%	0%	0%	8%	0%	0%	-5%	-3%
1940	Above Normal	10%	0%	0%	0%	0%	0%	0%	0%	0%	0%	7%	13%
1941	Wet	0%	-6%	0%	0%	0%	0%	0%	-7%	-1%	0%	0%	0%
1942	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1943	Wet	0%	0%	0%	0%	0%	0%	-2%	-2%	9%	0%	0%	0%
1944	Dry	1%	3%	0%	0%	0%	0%	0%	0%	0%	-2%	-3%	0%
1945	Below Normal	0%	0%	0%	0%	-10%	8%	0%	0%	0%	0%	0%	0%
1946	Below Normal	-8%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1947	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	-1%	-1%
1948	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1949	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1950	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1951	Above Normal	0%	0%	0%	0%	28%	0%	0%	0%	0%	0%	0%	0%
1952	Wet	0%	0%	0%	-1%	0%	0%	-10%	-16%	0%	0%	0%	0%
1953	Wet	-1%	3%	0%	-14%	0%	0%	0%	0%	0%	0%	0%	0%
1954	Above Normal	0%	-2%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1955	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1956	Wet	0%	-1%	0%	0%	0%	24%	0%	0%	0%	0%	0%	0%
1957	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1958	Wet	0%	0%	0%	0%	0%	14%	-8%	-14%	0%	0%	0%	0%
1959	Below Normal	0%	0%	0%	0%	0%	4%	0%	0%	0%	0%	0%	0%
1960	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1961	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1962	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1963	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	-1%
1964	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1965	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1966	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	-1%
1967	Wet	0%	0%	0%	0%	0%	0%	-8%	-15%	0%	0%	0%	1%
1968	Below Normal	-1%	98%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1969	Wet	0%	1%	0%	-12%	2%	0%	-10%	7%	0%	0%	0%	5%
1970	Wet	0%	0%	0%	0%	-8%	1%	0%	0%	0%	0%	0%	0%
1971	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1972	Below Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1973	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	42%
1974	Wet	-15%	0%	0%	-4%	0%	26%	0%	0%	0%	0%	0%	0%
1975	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1976	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	1%	1%	0%
1977	Critical	-1%	0%	0%	0%	0%	0%	0%	0%	-1%	0%	0%	0%
1978	Above Normal	0%	0%	0%	0%	-6%	-3%	-19%	-23%	-2%	0%	0%	0%
1979	Below Normal	0%	16%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1980	Above Normal	-4%	5%	0%	-8%	9%	-1%	0%	0%	-1%	0%	0%	49%
1981	Dry	-10%	-16%	0%	0%	0%	-15%	0%	0%	0%	0%	0%	-2%
1982	Wet	0%	0%	0%	0%	0%	15%	0%	-15%	0%	0%	0%	0%
1983	Wet	0%	0%	0%	60%	0%	0%	0%	0%	0%	0%	0%	0%
1984	Wet	0%	0%	0%	0%	1%	0%	0%	0%	0%	0%	0%	0%
1985	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1986	Wet	0%	0%	0%	0%	0%	10%	-2%	-13%	-2%	0%	0%	0%
1987	Dry	0%	20%	0%	0%	0%	0%	0%	0%	0%	-1%	-2%	0%
1988	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	-1%	0%	0%
1989	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	1%	0%
1990	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1991	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	-1%	0%	0%
1992	Critical	0%	0%	0%	-1%	0%	0%	0%	0%	0%	0%	0%	0%
1993	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1994	Critical	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1995	Wet	0%	0%	0%	0%	0%	0%	-13%	-40%	0%	0%	0%	0%
1996	Wet	0%	71%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
1997	Wet	-3%	0%	0%	0%	0%	1%	0%	0%	2%	-3%	0%	0%
1998	Wet	0%	0%	0%	0%	0%	0%	-8%	-13%	0%	0%	0%	0%
1999	Wet	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	-2%
2000	Above Normal	2%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
2001	Dry	0%	0%	3%	0%	0%	0%	0%	0%	0%	0%	-2%	0%
2002	Dry	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	-1%
2003	Above Normal	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Average		0%	3%	0%	2%	0%	2%	-1%	-3%	-1%	0%	0%	1%
Wet		-1%	3%	1%	5%	0%	5%	-3%	-7%	0%	0%	0%	0%
Above Normal		1%	0%	0%	-1%	3%	0%	-2%	-2%	0%	0%	1%	9%
Below Normal		-2%	9%	0%	4%	2%	5%	-1%	-2%	-3%	0%	0%	0%
Dry		0%	4%	0%	0%	0%	-1%	0%	1%	-1%	0%	-3%	0%
Critical		3%	1%	-1%	-2%	-3%	0%	0%	0%	0%	0%	2%	0%