

**From:** [Brown, Dave](#)  
**To:** [Wendy Christensen](#); [Floyd, Benjamin](#)  
**Subject:** IWRMP  
**Date:** Friday, December 18, 2009 11:09:11 AM

---

Wendy,

I made this comment early on but do not find reference

Page 9 line 29

ASR, for Yakima and I am thinking for other municipalities, will not "replace" surface diversions (ASR water to come from surface diversions). ASR project would/could supply in drought years when prorated during storage control. Or ASR could supply water at different timing. ASR could supply water to groundwater source municipals when water is moved from Ag to municipal.

Dave Brown  
Water/Irrigation Manager  
City of Yakima  
509.575.6204

*"Water is Life and Infrastructure Makes it Happen"*