

# **Yakima River Basin Integrated Water Resource Management Plan**

## **Technical Memorandum:**

### **Appraisal Study of Kittitas Valley Delivery Systems for Groundwater Recharge and Creek Flows**

**U.S. Bureau of Reclamation  
Contract No. 08CA10677A ID/IQ**

***Prepared by***

HDR Engineering, Inc.  
Anchor QEA



**U.S. Department of the Interior  
Bureau of Reclamation  
Pacific Northwest Region  
Columbia-Cascades Area Office**



**State of Washington  
Department of Ecology  
Office of Columbia River**

April 2013

## **MISSION STATEMENTS**

### **U.S. Department of the Interior**

Protecting America's Great Outdoors and Powering Our Future

The U.S. Department of the Interior protects America's natural resources and heritage, honors our cultures and tribal communities, and supplies the energy to power our future.

### **Bureau of Reclamation**

The mission of the Bureau of Reclamation is to manage, develop, and protect water and related resources in an environmentally and economically sound manner in the interest of the American public.

### **Washington State Department of Ecology**

The Mission of the Washington State Department of Ecology is to protect, preserve and enhance Washington's environment, and promote the wise management of our air, land and water for the benefit of current and future generations.

If you need this document in a format for the visually impaired, call the Office of Columbia River at (509) 575-2490. Persons with hearing loss can call 711 for Washington Relay Service. Persons with a speech disability can call 877-833-6341.

# **Yakima River Basin Integrated Water Resource Management Plan**

## **Technical Memorandum:**

### **Appraisal Study of Kittitas Valley Delivery Systems for Groundwater Recharge and Creek Flows**

**U.S. Bureau of Reclamation  
Contract No. 08CA10677A ID/IQ**

**Prepared by**

HDR Engineering, Inc.  
Anchor QEA



**U.S. Department of the Interior  
Bureau of Reclamation  
Pacific Northwest Region  
Columbia-Cascades Area Office**



**State of Washington  
Department of Ecology  
Office of Columbia River**

April 2013

*This Page Intentionally Left Blank*

---

# Contents

<b>1.0</b>	<b>Introduction</b> .....	<b>1</b>
<b>2.0</b>	<b>Project Objectives and Design Flow</b> .....	<b>2</b>
2.1	Project Objectives.....	2
2.2	KRD Canal Capacities.....	2
2.3	Groundwater Recharge.....	3
2.4	System Operation.....	3
2.5	Tributary Flow Augmentation.....	4
2.6	Review of Pumping Capacity.....	4
<b>3.0</b>	<b>Pump Station Site Selection Criteria</b> .....	<b>5</b>
<b>4.0</b>	<b>Project Facilities Design Criteria</b> .....	<b>5</b>
4.1	Yakima River Intake.....	5
4.2	Yakima River Pump Station Capacity.....	6
4.3	Pump Station Hydraulics.....	6
4.4	Pipeline to Canal Outlet Structure.....	6
4.5	Main Canal and North Branch Canal Turnouts.....	7
<b>5.0</b>	<b>Local Site Geology</b> .....	<b>7</b>
<b>6.0</b>	<b>Facilities Description</b> .....	<b>8</b>
6.1	Intake and Fish Screens.....	9
6.1.1	Fish Screens.....	9
6.1.2	Intake Pipeline.....	9
6.2	Yakima River Pump Station.....	10
6.2.1	Pump Station.....	10
6.2.2	Pumps and Motors.....	10
6.2.3	Power.....	10
6.2.4	Flow Metering and Pump Operation.....	11
6.2.5	Hydraulic Surge Control.....	11
6.2.6	Security.....	11
6.3	Pump Discharge Manifolds and Pipeline.....	11
6.4	Pipeline Discharge Structure at North Branch Canal.....	12
6.5	Intake and Pump Station Characteristics.....	12
6.6	Canal Tributary and Recharge Turnouts.....	13
<b>7.0</b>	<b>Property Easements and Purchases</b> .....	<b>13</b>
<b>8.0</b>	<b>Preliminary Opinion of Probable Project Costs</b> .....	<b>14</b>
<b>9.0</b>	<b>Considerations for Design</b> .....	<b>16</b>
9.1	Special Considerations.....	16
9.2	General Considerations.....	16

9.3	Opinion of Probable Costs .....	16
9.4	Higher Capacity (300-cfs) Pump Station .....	17
9.4.1	Recharge Flows.....	17
9.4.2	Estimated Project Costs for a Larger Pump Station .....	18
<b>10.0</b>	<b>References .....</b>	<b>19</b>
<b>11.0</b>	<b>List of Preparers .....</b>	<b>20</b>

### List of Tables

Table 2-1.	Range of Canal Capacities .....	2
Table 2-2.	Estimated Available Canal Capacities during KRD Irrigation Season.....	3
Table 4-1.	Approximate Base Hydraulic Elevations (feet) .....	6
Table 6-1.	Structures Differing Design Criteria and Characteristics (100-cfs Pump Station)	12
Table 7-1.	Potential Property Purchase/Easements for Pump Station Sites.....	14
Table 8-1.	Preliminary OPPC Summary (\$ million) .....	15
Table 9-1.	Cumulative Median Water Volumes (acre-feet) Available for Groundwater Recharge for 100 cfs and 300 cfs Pump Stations.....	18
Table 9-2.	Cost Comparison Between 100-cfs and 300-cfs Pump Station at Site 1 (all costs in 2012 \$ million).....	19

### List of Figures

Figure 9-1.	Groundwater Recharge Volumes .....	17
-------------	------------------------------------	----

### Appendix A – Appendix Figures

Figure 1.	Site Locations
Figure 2.	Site Locations of Proposed Canal Turnouts
Figure 3.	Geology
Figure 4.	Swauk Creek Site 1
Figure 5.	Dudley Road Site 2
Figure 6.	Swauk Creek Site 1 Intake and Pump Station Plan
Figure 7.	River Intake and Canal Outlet Plan and Sections
Figure 8.	Pump Station Plan and Section
Figure 9.	Canal to Tributary Turnout
Figure 10.	Sites 1 and 2 Property Boundaries and Ownership

### Appendix B – Opinions of Probable Construction Costs

Preliminary Opinions of Probable Construction Costs

---

## 1.0 Introduction

This technical memorandum describes the design criteria, surface geology, facilities, property and easements needed for a proposed project under the Yakima River Basin Integrated Water Resource Management Plan (Integrated Plan) that would divert water from the Yakima River and pump it to the Kittitas Reclamation District (KRD) North Branch Canal. This flow would provide the flexibility to deliver water to five tributary creeks that cross the KRD Main Canal between Easton and Thorp and to replace flow from existing diversions from creeks that cross the North Branch Canal. The project could also provide flow to be delivered through the North Branch Canal to groundwater recharge sites that are under consideration in the Kittitas Valley. The Kittitas Valley Delivery project would benefit fish in the tributary streams as well as improve the efficiency of irrigation deliveries.

The goals of the Integrated Plan are to protect, mitigate and enhance fish and wildlife habitat; provide increased operational flexibility to manage in-stream flows to meet ecological objectives; and improve the reliability of the water supply for irrigation, municipal supply and domestic uses (Reclamation and Ecology, 2012).

The Kittitas Valley Delivery project is located in Kittitas County near Ellensburg, Washington. Using defined site selection criteria, two potential alternative pump station sites have been identified and compared. Site 1 is located near Swauk Creek, adjacent to State Route (SR) 10, approximately 5 miles northwest of Thorp, Washington. Site 2 is located adjacent to SR 10 and the North Thorp Highway at Dudley Road, approximately 3 miles northwest of Thorp.

At either site, the project would consist of a new screened intake structure on the Yakima River, a pump station with a total capacity of 100 cubic feet per second (cfs), a discharge pipeline, and a canal discharge structure at the North Branch Canal. Figure 1 shows the two alternative intake and pump station sites.

Other facilities would be constructed on the KRD Main Canal upstream from the proposed pump station to discharge water to tributaries and on the North Branch Canal downstream from the pump station to discharge water to groundwater recharge sites. Other facilities at creek crossings along the North Branch Canal could be constructed to replace existing creek diversions provided enough conveyance capacity exists in the North Branch Canal to serve those diversions. Additional geotechnical and surveying of a selected site (Site 1 or 2) would be required during the preliminary design phase.

Although this report is based upon diverting up to 100 cfs, there have also been discussions between KRD and Reclamation about diverting as much as 300 cfs. Further discussion of a potential higher capacity system is included in Section 9.0 - Design Considerations.

---

## 2.0 Project Objectives and Design Flow

### 2.1 Project Objectives

The proposed project would convey water from the Yakima River to the North Branch Canal. A pumping capacity of 100 cfs is used for the appraisal study and cost-estimating. Although higher volumes could be considered, the 100-cfs pumping capacity in this report is based upon available capacity in the North Branch Canal to serve potential groundwater recharge sites near Naneum Creek and in Badger Pocket without substantial upgrades to increase capacity of the North Branch Canal. This flow diversion would also provide flexibility to deliver water to five tributaries (Big Creek, Little Creek, Spex Arth Creek, Tillman Creek and Peterson Creek) that cross the Main Canal from Easton to Thorp. This would provide additional in-stream flows to benefit fish habitat during August or when low-flow conditions occur. The existing North Branch Canal capacity would be used to convey this flow when full canal capacity is not needed to deliver irrigation water.

### 2.2 KRD Canal Capacities

Table 2-1 provides the range of total canal capacities along the Main Canal and North Branch Canal, which decrease from upstream to downstream.

Table 2-2 shows estimates of available canal capacity by month during the KRD irrigation season (mid-April to mid-October). The estimates in Table 2-2 were obtained by reviewing flow records for the canals (including Naneum Creek Gauge, Caribou Creek Gauge, and Johnson Siphon Gauge) and comparing typical operating conditions to total canal capacity. Appendix Figure 2 shows the locations of the canal reaches and canal gauges referenced in Table 2-1 and Table 2-2, as well as proposed turnout and pump station sites. If the pump station were to operate prior to the start of the irrigation season, the available canal capacity in the North Branch Canal would equal its canal capacity shown in Table 2-1.

**Table 2-1. Range of Canal Capacities**

REACH	CAPACITIES (CFS)
Main Canal Capacity from Diversion Dam to Bifurcation	1,320-1,145
North Branch Canal Capacity from Bifurcation to Caribou Creek	925-400
North Branch Canal Capacity at Johnson Siphon	260

Source: Satnik, personal communication (2012)



**Table 2-2. Estimated Available Canal Capacities during KRD Irrigation Season**

MONTH	ESTIMATED AVAILABLE CAPACITY (CFS)		
	Main Canal from Diversion Dam to Bifurcation	North Branch from Bifurcation to Caribou Creek	Johnson Siphon
April	340-1,145	100-400	50-260
May	340	20-80	0
June	190-280	20-80	0
July	30-50	0	0
August	0	0	0
September	140	100-125	50
October	300-1,145	100-400	30-50

Source: Satnik, personal communication (2012)

## 2.3 Groundwater Recharge

The groundwater recharge program is planned to operate early in the year, after winter conditions have passed and before the annual start of “storage control” in Yakima Project operations. Two potential recharge sites in the KRD that have been identified for initial consideration (Reclamation and Ecology, 2011) are described below.

During the early irrigation season, flow would be released from the North Branch Canal to groundwater recharge sites as shown in Appendix Figure 2. Because groundwater recharge sites are downstream from the pump station, flow would be released only when capacity in the North Branch Canal is available. At least 100 cfs of unused flow capacity is available from the Naneum gauge to the Caribou gauge along the North Branch Canal in April. In May and June the available capacity ranges from approximately 20 to 80 cfs. In July through early September during periods of peak irrigation demand, the North Branch Canal runs full with no available capacity. When irrigation demands decline from mid-September to the end of the irrigation season in mid-October, the North Branch Canal has at least 100 cfs of unused flow capacity.

Further downstream along the North Branch Canal at Johnson Siphon, approximately 50 cfs of unused flow capacity exists in April. The Johnson Siphon is a constriction that limits the ability to deliver flow to the Badger Pocket groundwater recharge site. That would allow 50 cfs to be delivered to both groundwater recharge sites in April. Johnson Siphon typically does not have any available capacity in May through early September. From mid-September to the end of the irrigation season in mid-October, the Johnson Siphon typically has between 30 and 50 cfs of unused flow capacity.

## 2.4 System Operation

Prior to the start of the irrigation season in April, the North Branch Canal may be able to operate before the Main Canal is ready to operate. In March, the Main Canal typically experiences severe snow and ice conditions that prevent operations, while the North Branch Canal lies at a lower elevation and is less affected by snow and ice. A pump station at either site could potentially

---

deliver 100 cfs to the North Branch Canal to supply groundwater recharge areas during March and April (after thawing and prior to the start of the irrigation season).

It appears that the Main Canal could divert and convey additional flow April through June that could supply the groundwater recharge areas. However additional review of the availability of water from Kachess or Keechelus reservoirs is needed to determine whether they could provide that additional flow. A pump station on the Yakima River is advantageous as it would provide water from either from one of the upper Yakima River reservoirs (Keechelus, Kachess or Cle Elum) or from unregulated runoff from tributaries that join the Yakima River upstream from the proposed pump station sites.

## **2.5 Tributary Flow Augmentation**

In addition, flow would be delivered to five tributaries along the Main Canal during August or when low-flow conditions occur. Those tributaries are Big Creek, Little Creek, Spex Arth Creek, Tillman Creek and Peterson Creek. That water would need to be replaced by pumping from the Yakima River at a pump station since the Main Canal does not typically have available capacity during August or when water demand is high. The exact flow rate that needs to be delivered has not been determined at this time, but is likely in the range of 10 to 25 cfs, based on supplying 2 to 5 cfs at each of the five creeks.

The delivery of water to those tributaries would benefit adult and juvenile coho and steelhead and rearing spring Chinook that are present in the creeks. These benefits would result from increased streamflow during migration, spawning, and rearing periods. The increased streamflow would help address streamflow and water temperature quality problems that negatively affect fish passage and survival in the tributaries during low-flow conditions during the irrigation season.

Another potential use of the pumped water is to replace water diverted from creeks that cross the North Branch Canal to allow for removal of irrigation diversions and to reduce use of the creeks for irrigation water conveyance. These creeks are Dry Creek, Naneum Creek, Reecer Creek, Cooke Creek, Currier Creek, Caribou Creek, Wilson Creek and Park Creek.

However, more extensive modifications to existing irrigation systems that divert from those creeks may be needed prior to using water from the North Branch Canal. In addition, sufficient capacity in the North Branch does not appear to be available in July through early September to replace tributary diverters. For those reasons, this project is focused on supplying tributaries crossing the Main Canal and supplying groundwater recharge in the Naneum Creek and Badger Pocket areas.

## **2.6 Review of Pumping Capacity**

In summary, a pumping capacity of 100 cfs is a reasonable first criterion to use for preliminary concept-level design and cost estimating. Other flows up to 300 cfs could be considered, but would require further evaluation of the availability of Yakima River water, the additional pumping costs, and the canal upgrades that would be needed to convey the additional water to the recharge sites. The final design pumping capacity should be reviewed after the capacities and operations of the groundwater recharge sites have been determined. This final pumping capacity should be established prior to advancing to the next phase of project design.

---

## 3.0 Pump Station Site Selection Criteria

The two alternative pump station sites were selected using the following criteria:

- Proximity to and on the same side of the river as the North Branch Canal.
- Ease of access to a major highway (SR 10).
- An apparently stable section of the Yakima River with sufficient water depth for a fish-screened intake.
- Utilize existing KRD property or easements, if possible.
- Minimize impacts on property owners (Site 2 is a developed parcel).
- Avoid trenchless crossings of highway and/or railroad, if possible.
- Ability to locate the pump station motors and electrical room above the floodplain.
- Relatively flat area with room for construction of the intake and pump station.
- The shortest possible feasible alignment for the discharge pipeline to the canal.
- Proximity to electrical power lines.

Based upon these criteria, the following two alternative sites (see Appendix Figure 1) were selected for this appraisal level comparative analysis:

**Site 1 at Swauk Creek** is approximately 5 miles northwest of Thorp, adjacent to SR 10, and near the existing North Branch Canal deep tunnel crossing of the Yakima River and the existing U.S. Bureau of Reclamation river gauge (YRWW).

**Site 2 at Dudley Road** is approximately 3 miles northwest of Thorp, adjacent to SR 10 and near the intersection of the North Thorp Highway and Dudley Road.

## 4.0 Project Facilities Design Criteria

### 4.1 Yakima River Intake

The following Yakima River flow information and design criteria were used for the Yakima River intake conceptual design:

- **Yakima River Flows** – Based on average daily flow data from 1990 to present for the Bureau of Reclamation stream Gauge YRWW at Site 1; the flows in the Yakima River have typically varied between approximately 600 cfs (exceeded 90 percent of the time) and 3,900 cfs (exceeded 10 percent of the time). The minimum, average, and maximum recorded flows were 256 cfs, 1,961 cfs, and 21,384 cfs (January 8, 2009), respectively. These are similar to longer-term average daily flows recorded 15 miles upstream at USGS gauge 12479500 at Cle Elum, Washington from 1949 through 1990. Flows are typically lowest in October and November and highest from June through August.
- **River Elevation (NAVD 88 datum)** – The Yakima River water elevation varies with flow rate, but for this conceptual-level analysis, based on USGS mapping of the site, the normal river elevation during pumping was estimated to be approximately

elevation 1,750 at Site 1 and elevation 1,674 at Site 2. The 100-year flood at Site 1 is approximately elevation 1,757 at Site 1 and elevation 1,683 at Site 2.

- **Fish Screening** – The facility would require fish screens to prevent fish from entering the pump station intake. The screen structure, including inclined stainless steel wedge-wire screen, would be designed for 100 cfs capacity with a 0.4 feet per second (fps) approach velocity, 1.75 millimeters or less clear slot openings, and a 2-fps sweeping velocity. Allowing for 20 percent more screen area to account for structural supports results in 300 square feet of fish screen.
- **Fish-Screen Cleaning** – An automatic air-burst system would be used to clean debris that accumulates on the screen surface. After air-bursting, the debris would be carried downstream by normal streamflow currents. A nearby air compressor and controls system would supply pressurized air for the cleaning system manifold.

## 4.2 Yakima River Pump Station Capacity

The pump station would be configured with four 25-cfs pumps that would pump in 25 cfs increments from 0 to 100 cfs. The pump station is a noncritical facility that will only be operated periodically, and major maintenance can be done when the pump station is not in service. Therefore, a standby pump is not required, and the firm capacity with one of the pumps out of service would be approximately 75 cfs. Using four equally sized pumps would minimize the required spare-parts inventory and allow for interchanging parts, if needed.

## 4.3 Pump Station Hydraulics

A pipeline would convey the pumped 100 cfs flow from the pump station to a new outlet structure at the North Branch Canal. Table 4-1 shows the approximate preliminary hydraulic elevations for the pumping system that would be located at either Site 1 or Site 2. The approximate elevations shown in the table are based on LiDAR and USGS data adjusted to the NAVD 88 vertical datum. These approximate elevations are used only to develop and compare relative pumping heads and costs. Surveying of the selected site would be required to determine site topography prior to beginning preliminary design.

**Table 4-1. Approximate Base Hydraulic Elevations (feet)**

HYDRAULIC CHARACTERISTIC	SWAUK CREEK (SITE 1)	DUDLEY ROAD (SITE 2)
River Water Surface Elevation	1,750	1,670
Canal Water Surface Elevation	2,100	2,090
100-Year Flood Elevation	1,757	1,683

## 4.4 Pipeline to Canal Outlet Structure

A concrete outlet structure would be constructed adjacent to the existing North Branch Canal to transition flow from the pipeline into the canal.

---

If the Yakima River pressure tunnel upstream from the Swauk Creek Site 1 outlet location is dewatered during the operation of the pump station, a check structure would be required on the North Branch Canal upstream from canal discharge structure to prevent backflow and filling of the tunnel while pumping. If the tunnel is kept full of water, a canal check structure may not be required.

For the Dudley Road Site 2, a gated or stoplogged check structure would be constructed in the canal just upstream from the canal discharge structure to prevent pumped flow from backflowing up the canal. This would only be used for pumping during periods when the canal is not already being used for normal irrigation. The check structure stoplogs would be removed, or gates opened, to allow normal flow through canal operations when this pump system is not operating.

#### **4.5 Main Canal and North Branch Canal Turnouts**

New canal turnouts would be constructed in the Main Canal and North Branch Canal to discharge water to tributaries and/or groundwater recharge sites.

New canal turnouts would be constructed on the Main Canal at one or more of the following four tributaries: Big Creek, Little Creek, Spex Arth Creek and Tillman Creek.

Peterson Creek currently has a connection to the Main Canal (Peterson Wasteway) and can be supplied water without a new canal turnout.

Additionally, new canal turnouts would be constructed on the North Branch Canal to supply groundwater recharge projects in the Naneum Creek and Badger Pocket areas.

### **5.0 Local Site Geology**

The geology of the area is shown on the USGS geologic map of the East Half of the Yakima Quadrangle (Schuster 1994) and in a USGS hydrogeologic report (Jones et al. 2006). The Washington Division of Geology and Earth Resources (2005) published the same geologic mapping information in the form of a GIS dataset layer.

As summarized in Jones et al. (2006), the Yakima River Basin is part of the Yakima Fold belt, which is a highly folded and faulted region underlain by various consolidated rocks, ranging in age from Precambrian to Tertiary, and unconsolidated materials and volcanic rocks of Quaternary age. In the Yakima River Basin, the headwater areas in the Cascade Range include metamorphic, sedimentary, and intrusive and extrusive igneous rocks.

The central, eastern, and southwestern parts of the basin are composed of basalt lava flows of the Columbia River Basalt Group (CRBG) with some intercalated sediments that are discontinuous and weakly consolidated. The lowlands are underlain by unconsolidated and weakly consolidated valley-fill composed of glacial, glacio-fluvial, lacustrine, and alluvium deposits that exceed 1,000 feet thick in places. Wind-blown deposits, called loess, occur locally along the lower valley.

**Figure** shows surface geology information for Site 1 and for Site 2 from the Washington State Department of Natural Resources. Based on that information, the pump stations and pipelines would be founded in one of the following surface geologic units:

---

### **Swauk Creek (Site 1):**

- Intake Pipeline and Pump Station: Grande Ronde Basalt, and/or alluvium.
- Pipeline: Crossing Grande Ronde Basalt, alluvium, and/or pre-Fraser alpine glacial outwash.
- Outlet Structure: Pre-Fraser alpine glacial outwash.

### **Dudley Road (Site 2):**

- Intake Pipeline and Pump Station: Alluvium and/or Fraser-age alpine glacial outwash.
- Pipeline: Fraser-age alpine glacial outwash, volcanoclastic deposits or rocks, and/or continental sedimentary deposits or rocks, conglomerate.
- Outlet Structure: Continental sedimentary deposits or rocks, conglomerate.

Both Site 1 and Site 2 intakes and pump stations would be located in areas of surficial alluvium materials, but likely be founded on either volcanic (Site 1) or sedimentary rock (Site 2). However, the below surface geology is not available and the feasibility of all the proposed structures and pipelines would need to be investigated by conducting detailed, site-specific geotechnical and geological investigations during preliminary design.

## **6.0 Facilities Description**

This section provides a more detailed description of the conceptual facilities required to convey water from the Yakima River near Swauk Creek (Site 1) or from the Yakima River near the intersection of the North Thorp Highway and Dudley Road (Site 2) northeast to the existing North Branch Canal.

Figure 4 and Figure 5 show more detailed plans for Sites 1 and 2, respectively.

In summary, the project includes the following components:

- Fish-screened intake in the Yakima River with air-burst cleaning.
- Pipe to connect the intake to the pump station clearwell.
- Pump station containing four equally sized pumps with a total maximum pumping capacity of 100 cfs.
- Pipeline from the pump station to a discharge structure in the bank of the existing North Branch Canal.
- Pipeline discharge structure (and if necessary, canal check structure) to discharge pumped water into the North Branch Canal.
- Main Canal and North Branch Canal turnout structures to discharge water from the Main Canal to tributaries and from the North Branch Canal to groundwater infiltration facilities.
- Pipelines or canals from the canal turnout structures to tributaries and/or groundwater infiltration points.

Primary access to the project area would be via Interstate 90 and SR 10 to the project site, which is located along SR 10 between 3 and 5 miles northwest of Thorp.

---

Preliminary site plans have been prepared for both Site 1 and Site 2. The project facilities described below generally apply to facilities that would be constructed at either site. The detailed figures are based on the installation of these facilities at Site 1. Figure 6 shows a larger scale of the Site 1 fish-screened intake and pump station site plan. The Site 2 facilities would be similar, but oriented as shown in the Figure 5.

## **6.1 Intake and Fish Screens**

The Site 1 intake and fish screens would be located just upstream from Swauk Creek on the north bank of the river, approximately 5 miles northwest of Thorp. The Site 2 intake would be located near the intersection of the North Thorp Highway and Dudley Road. Figure 7 shows plan and section views of the inlet and outlet structures, including the fish screen that could be used at each location.

### **6.1.1 Fish Screens**

The fish screen design concept is intended to comply with federal and state fisheries agencies criteria for a 100-cfs-capacity fish screen. The concrete fish intake and screen structure would be approximately 18 feet wide by 42 to 50 feet long. It would be parallel to the stream bank to allow water to enter through the screen while the natural current carries debris past the screen. The need for a screen-protecting trash rack will be investigated during preliminary design.

The screen is arranged at a 45-degree vertical angle to optimize underwater screen area and allow for air-burst cleaning of the screen. The screen criteria approach velocity is 0.4 fps, resulting in a total required net screen area of 250 square feet. The required screen length was determined using an assumed minimum water depth of 6 feet, a 45-degree angled screen, and about 40 percent more area for structural supports and air-burst manifold, resulting in a screen length of 40 to 48 feet. The screen panels could be removed for repair or replacement with a spare panel. The screen material would be stainless steel wedge-wire or profile bar with an open slot width of 1.75 millimeters.

Flow-control baffles behind the screen panel would be adjusted to maintain uniform velocities through the screen panels. Water-surface elevations would be measured upstream and downstream from the screens to monitor head losses through the screens and control and trigger the automatic air-burst cleaning system. The compressed air-burst cleaning cycle would be activated by a water-surface elevation difference through the screens of 1.2 inches or less. Screen-cleaning cycles could also be timed to occur more frequently or activated manually. Debris cleaned from the screen would be carried downstream by the natural river current.

### **6.1.2 Intake Pipeline**

The intake for Site 1 would contain two 42-inch sluice gates and two short 42-inch-diameter pipes that would then connect to a 200-foot-long, 54-inch-diameter steel pipeline that would convey flow under Swauk Creek to the Yakima River Pump Station. Site 2, would be similar, but, the connecting pipeline between the intake and pump station would be approximately 100 feet shorter.

---

## 6.2 Yakima River Pump Station

The Yakima River Pump Station would pump up to 100 cfs of water from the Yakima River intake (at either Site 1 or Site 2) through a 48-inch-diameter steel pipeline to the North Branch Canal. Figure 8 shows preliminary pump station plan and section views.

### 6.2.1 Pump Station

The 55-foot-long, 36-foot-wide pump station would have a concrete clearwell and foundation, concrete masonry unit (CMU) walls, steel roof support structure and metal roof. The pump station would contain four 25-cfs vertical turbine pumps, valves, and pipe manifold. An access driveway would facilitate maintenance access and loading and unloading of equipment, using the building bridge crane. The sloping metal roof of the pump station would have removable hatches to allow installation and/or removal of the pumps using a crane set up next to the building. The pump station ceiling would be high enough that motors can be removed with a portable jib crane inside the building.

The clearwell would contain the pumps and maintain adequate submergence on the pump bowl during pumping. The clearwell water surface elevation would vary depending on the flow in the river and losses through the fish screens and forebay during pumping.

An adjacent 24-foot-wide, 36-foot-long electrical room would be integrally attached to the pump station building, making the combined “L”-shaped building a total of 60 feet wide. The electrical room would contain the pump station electrical power and control panels.

### 6.2.2 Pumps and Motors

The 25-cfs, vertical-turbine pumps would be selected based on the total dynamic head (TDH) of the pumping system. TDH is the net static head from the clearwell water surface to the canal water surface at the discharge structure, plus the losses in the discharge pipeline. The design set-points for the pumps would be for an estimated average TDH of the average static head plus the hydraulic losses in the pumping suction and discharge systems. The selected pump TDH is based on a conceptual-level hydraulic analysis of the discharge piping, valve, and pipeline losses.

The pump station capacity would vary slightly with changes in TDH and pump efficiencies as the river elevation changes. The pumps would be equipped with soft motor starters to reduce power-system impacts. For conceptual purposes, a combined pump and motor efficiency of 85 percent was used to determine the required approximate 1,250 horsepower capacity of the pump motor.

### 6.2.3 Power

Both alternative sites are served by transmission lines operated by Puget Sound Energy (PSE). Site 1 has a 34.5-kV transmission line along SR10. This line was recently upgraded from 12- to 34.5-kV to help serve local area wind farm development. There is also a 115-kV transmission line located across the Yakima River from the site. Site 2 is currently still being served by a three phase 12-kV power line along the North Thorp Highway.

At Site 1, the power demand for the four 1,250-HP pumps would be on the order of 950 kilowatts (kW) for each pump – or 3.8 megawatts (mW) if all pumps were operating. At Site 2, the power demand for the four 1,450-HP pumps would be on the order of 1,100 kilowatts (kW)



---

for each pump – or 4.4 megawatts (mW) if all pumps were operating. PSE representatives said that this would be a very large load for them at either location, which are approximately half-way between their connections to high voltage transmission lines. PSE would need to determine their ability to serve either pump station site; which would depend upon the pump loads as well as how the pump station is to be operated – including the frequency of motor starts and stops. It is assumed that motor soft starters would be required for constant speed pumps and perhaps even VFDs may be required to mitigate for motor starts and stops.

For purposes of this report, it was assumed that at Site 1 an electrical substation and switchyard adjacent to the pump station would accept power from the three-phase 34.5-kV power lines and that the pumps could be constant speed pumps with soft starts. It is yet to be determined if it would be feasible to connect the larger pumps at Site 2 through an electrical substation to the existing 12-kV power lines along the North Thorp Highway. Assumptions used for power service will need to be further verified by PSE.

A 300 cfs pump station at Site 1 would require up to 12.4 mW of power which would likely have to be connected through a new substation and power lines connecting to a 115-kV or larger PSE transmission line.

#### **6.2.4 Flow Metering and Pump Operation**

The pump station would have flow meters on each pump and automated data acquisition and control systems to operate the pumps. In addition to local manual operation, the pump station could be remotely monitored and automatically controlled or operated under a pre-programmed plan.

#### **6.2.5 Hydraulic Surge Control**

Some measures would be required to control and minimize surge pressures in the event of a rapid change in flow due to a power failure or other reasons. Although this study does not include a surge analysis, the conceptual plans and estimates include pump-control valves, and/or a surge tank.

#### **6.2.6 Security**

The intake and pump station would require some level of perimeter security. It is expected that security measures would include fencing and possibly remote camera monitoring and/or a building alarm system.

### **6.3 Pump Discharge Manifolds and Pipeline**

Each pump would discharge through a 30-inch-diameter pipe that includes a pump-control valve in the pump station and pump isolation valve. Each pump-discharge pipe would connect to a header pipe and then to the 48-inch-diameter steel pipe conveying the flow to the North Branch Canal.

At the end of each pumping season the discharge pipeline could be slowly drained back into the Yakima River through a drain valve and pipe at the pump station. If needed, combination air-release/vacuum valves would be located at any pipeline high points to allow movement of air into and out of the pipeline.

## 6.4 Pipeline Discharge Structure at North Branch Canal

The transmission pipeline would discharge into the North Branch Canal discharge structure as shown in Figure 9. The flow from the pipe would discharge into a 25-foot-long hydraulic transition structure next to the North Branch Canal and then flow over a weir from the discharge structure into the adjacent canal. The discharge structure would also have a 48-inch sluice gate that would be closed to prevent entry when not in use and to prevent water from entering the pipeline when the canal is used for normal irrigation.

An upstream check structure with removable stoplogs would be installed in the canal just upstream from the discharge structure to prevent water from going upstream during groundwater recharge pumping. The check structure stoplogs would be removed during irrigation season.

## 6.5 Intake and Pump Station Characteristics

The sizes of the structures are similar for Site 1 and Site 2.

Table 6-1 shows the differing characteristics of the intake, pump station, and pipeline discharge structure for both sites. Elevations and lengths shown in the table are preliminary unsurveyed approximations.

Site 2 would have approximately 70 feet more pumping head than Site 1. As a result, to pump the same flow volumes, Site 2 would require approximately 20 percent more in pumping energy than Site 1.

**Table 6-1. Structures Differing Design Criteria and Characteristics (100-cfs Pump Station)**

CHARACTERISTIC	SWAUK CREEK (SITE 1)	DUDLEY ROAD (SITE 2)
Intake Top Slab Elevation (feet)	1,758	1,680
Intake Bottom Slab Elevation	1,740	1,662
Intake Structure Length (feet)	42	50
54-inch Intake Pipeline Length (feet)	200	100
Pump Station Floor Elevation	1,762	1,684
Clearwell Floor Elevation	1,736	1,658
Approximate Static Head (feet)	350	420
Approximate Static Head (psi)	155	182
48-Inch Pipeline Length (feet)	2,600	2,000
100 cfs Dynamic Head* (feet)	365	435
Pump/Motor Horsepower (4 each)	1,250	1,450

\* Not including hydraulic surge pressures that would be determined during final design surge analysis.

---

## 6.6 Canal Tributary and Recharge Turnouts

This section describes the proposed locations and typical configuration of canal turnouts for discharging water to tributaries and for groundwater recharge. Figure 2 shows the locations of the proposed turnouts. Additional turnouts or turnouts at different locations may be included in future project phases.

A canal turnout typically consists of the following:

- A precast or cast-in-place concrete inlet inset into the canal bank with a gate for flow control.
- High-density polyethylene (HDPE), PVC pipe and/or unlined or concrete-lined canal to transport water between the canal and the tributary or groundwater recharge area.
- Erosion protection at tributary discharge locations.

Some tributary locations may require a fish screen or other fish barrier to prevent fish from traveling up the tributary outlet to the canal. Figure 9 shows a plan and section of a typical turnout (inlet and outlet).

The turnout and pipe size would depend on the amount of flow desired to be discharged. It is likely that flow discharged to tributaries would range from a few cfs to about 10 cfs. For a 5-cfs discharge, the turnout would likely have a 14- to-16-inch-diameter pipe and gate. For a 10-cfs discharge, the turnout would likely have a 20-inch-diameter pipe and gate.

The outlet pipe from the canal would spill to the tributary. Erosion protection would likely be needed at the outlet to prevent the tributary bed or bank from eroding. This could consist of rock or wood placed to dissipate the energy from the pipe discharge.

For flow discharged to groundwater recharge sites, the turnout may need to supply up to 100 cfs. The design of the groundwater recharge sites is not complete so these are conservative estimates. A 100-cfs turnout would likely have a 48-inch-diameter pipe or a concrete-lined trapezoidal canal with a 4-foot bottom width and a 4-foot depth, assuming a slope of 0.05 percent, canal side slopes of 1.5:1 (Horizontal:Vertical), Manning's roughness coefficient of 0.014, and 1 foot of freeboard. The pipe or canal outlet would be located in the groundwater infiltration area. The facilities needed for those areas would need to be determined in future studies.

## 7.0 Property Easements and Purchases

The Kittitas County Assessor's website was used to compile property ownership information to estimate the cost of property acquisition and easements for the project facilities. Information was compiled by using GIS tools on the website. Data was then collected for each parcel along the route and combined with parcel data from other surrounding parcels not on the route to determine realistic property values. Figure 10 shows the known parcel boundaries and parcel ownership at Sites 1 and 2.

For this conceptual study, the property analysis is based on the following assumptions:

- Parcels where the pipelines cross open space would need a 30-foot permanent easement and a 50-foot temporary construction easement.

- Approximately 0.5 to 1 acre of purchased property would be needed for the new intake and pump station and approximately 1 to 2 acres of permanent easement for the pipeline. It was assumed the discharge structure would be on existing KRD property adjacent to the canal.

Table 7-1 lists potential property owners and purchase/easements based on the information in Figure 10.

Based on the preliminary evaluation, Site 1 (Swauk Creek) would require a 0.4 acre site purchase (from BNSF Railway Co.), 2.6 acres of temporary easements, and 1.9 acres of permanent easements from BNSF, Washington State Department of Transportation (SR 10), and the Bureau of Land Management.

Site 2 (Dudley Road) would require a 0.8-acre private parcel purchase, 1.5 acres of private parcel temporary easements, 1 acre of private parcel permanent easements, and a 0.10-acre permanent easement along SR 10.

**Table 7-1. Potential Property Purchase/Easements for Pump Station Sites**

PROJECT AREA	SWAUK CREEK (SITE 1)		DUDLEY ROAD (SITE 2)	
	Property Owner	Acquisition Need (acres)	Property Owner	Acquisition Need (acres)
Intake, Intake Pipeline, and Pump Station	BNSF Railway Co. (151736)	0.40 purchase or lease	Der Yuen (577934)	0.85 purchase
Discharge Pipeline	BNSF Railway Co.	0.52 TE* 0.32 PE	Pollock (11558)	0.28 TE 0.17 PE
			Basterrechea (506636)	0.04 TE 0.03 PE
	WSDOT (SR 10 ROW)	0.46 TE 0.34 PE	WSDOT (SR 10 ROW)	0.16 TE 0.10 PE
	US (BLM (897734)	1.65 TE 1.00 PE	Pearson (18506)	0.62 TE 0.37 PE
			Havens (18508)	0.32 TE 0.19 PE
New Access Roads	BNSF Railway Co.	Included in PS and pipeline	Der Yuen (577934)	0.23 TE 0.14 PE
Power Line				Included in road

\*TE = Temporary Easement; PE = Permanent Easement

## 8.0 Preliminary Opinion of Probable Project Costs

Preliminary conceptual project information was used to develop opinions of probable construction costs (OPCCs). The OPCC below includes a 25-percent contingency and a 7.75-percent Kittitas County sales tax. Estimated property/easement acquisition costs were added

along with percentage of construction cost allowances for administrative/legal (5 percent), permitting/environmental (6 percent), surveying/geotech (6 percent), engineering/design (15 percent), and construction management (10 percent). The sum of these values then represents the total approximate opinion of probable project costs.

At this preliminary appraisal study level of project definition, the estimate is considered to be an Association for the Advancement of Cost Engineering (AACE) Class 4 estimate. The expected accuracy range is from -30 to +50 percent. Table 8-1 summarizes major cost items. The detailed estimates are included in the appendix.

Operations and maintenance costs have not been quantified for this appraisal study, but would generally be similar for the two alternatives. An exception would be the relative pumping power/energy costs. Because Site 2 has a higher pumping head, Site 2 would use approximately 20 percent more energy than Site 1.

**Table 8-1. Preliminary OPPC Summary (\$ million)**

COST ITEM	SWAUK CREEK (SITE 1)	DUDLEY ROAD (SITE 2)
Intake, Pipeline, Pump Station, Outlet*	\$11.0	\$9.8
Tributary Turnouts	\$0.42	\$0.42
<b>Subtotal Construction Costs</b>	<b>\$11.4</b>	<b>\$10.2</b>
Property/Easement Acquisition	\$0.12	\$0.15
5% Project Legal/Administration	\$0.57	\$0.51
6% Permitting/Environmental	\$0.69	\$0.61
6% Surveying/Geotech	\$0.69	\$0.61
15% Engineering/Design	\$1.7	\$1.5
10% Construction Management	\$1.1	\$1.0
<b>Approximate Total Project Costs</b>	<b>\$16.3</b>	<b>\$14.6</b>
<b>Range (-30% to +50%) of Project Costs</b>	<b>\$11.4 to \$24.5</b>	<b>\$10.2 to \$21.9</b>

\* Includes 7.75% sales tax and 25% contingency

The estimated mean annual volume for the 100-cfs pump station would be approximately 38,800 acre-feet (See Section 9.4.1, Table 9-1). Using an estimated average energy cost of 6.0 cents per kilowatt-hour (kWh), including capacity charges, would result in annual pumping costs of approximately \$1.08 million for Site 1 and \$1.28 million for Site 2 – a \$200,000 annual difference. With a 0.5 percent annual net discount rate (discount rate minus energy cost escalation rate), the present values of the annual pumping costs over 30 years are \$30.0 million and \$35.7 million respectively – a \$5.7-million difference.

Based upon these assumptions, the present value of the pumping energy savings for Site 1 more than makes up for its higher construction cost (approximately \$1.7 million higher).

---

## 9.0 Considerations for Design

### 9.1 Special Considerations

Special considerations for implementing this project are as follows:

- Determining the feasibility of all of the project concepts.
- Permitting and constructing a new intake on the Yakima River west of Thorp.
- The feasibility of Confined intake Site 1 between the river and railroad, then crossing under Swauk Creek.
- Permission for Crossing under the BNSF railroad tracks (Site 1).
- Crossing under SR 10 (Site 1 could cross under an existing, elevated, dry wash crossing).
- Minimizing impacts on the Yakima River.
- Providing adequate power to the pump station.
- Defining the amount of water actually needed at each of the recharge sites and tributary stream crossings.

In addition to the items listed above, a larger, 300-cfs pump station would present the following significant challenges:

- Siting a much larger fish screened intake in the Yakima River.
- Siting a larger pump next to the river.
- Power transmission and likely large substation upgrades.

### 9.2 General Considerations

General considerations for implementing this project are as follows:

- Confirming the overall system operational criteria and project hydraulics for existing and future flows with additional surveying as required.
- Obtaining more detailed geotechnical information for the entire length of the project, including a geotechnical exploration program for critical areas, structures, and tunnels.
- Exploring permitting and engineering requirements for constructing a new diversion dam on the Yakima River.
- Further investigating and refining design for fish screens at the Yakima River diversion.
- Further definition of the power/energy supply costs for the 100 cfs and 300 cfs options. Both may require significant transmission line/substation upgrades.

### 9.3 Opinion of Probable Costs

As the project design advances, opinions of probable construction costs (OPCCs) should also be updated and refined.


## 9.4 Higher Capacity (300-cfs) Pump Station

There have been additional discussions between KRD and Reclamation considering a larger 300-cfs pumping and groundwater recharge conveyance system. Although this report focuses on a 100-cfs pump station, this section presents the additional information regarding this larger pump station option.

### 9.4.1 Recharge Flows

Figure 9-1 and Table 9-1 describe the water volumes that could be delivered to the groundwater recharge sites for both the 100- and 300-cfs pump stations. Figure 9-1 shows the monthly median volumes as well as the range of volumes could be expected for each pump station size. Table 9-1 shows the estimated cumulative median monthly water volumes that could be supplied to the groundwater recharge sites for each pump station capacity given the estimated available KRD canal capacity.

**Figure 9-1. Groundwater Recharge Volumes**



**Table 9-1. Cumulative Median Water Volumes (acre-feet) Available for Groundwater Recharge for 100 cfs and 300 cfs Pump Stations**

Median Monthly Volumes (acre-feet)		
Month	100 cfs Capacity	300 cfs Capacity
February	5,540	16,630
March	11,680	35,050
April	17,610	51,180
May	20,900	55,730
June	23,870	59,950
July	25,440	61,610
August	27,290	63,480
September	32,740	73,240
October	38,800	88,200

The duration the recharge sites would be operated depends on the time it would take the water to get back to the Yakima River as useful water supply for in-stream flow or irrigation. They may not be operated past May or June.

**9.4.2 Estimated Project Costs for a Larger Pump Station**

A larger pump station would have proportionally higher construction and engineering costs. Depending upon the cost item, the costs for a 300-cfs facility may increase by factors from two to three times, or more over the costs for the 100-cfs facility.

An example is the cost for the supply of the pumps and motors. A pump manufacturer (Fairbanks Morse) quotation for the 100-cfs facility for four 25 cfs pumps and motors was approximately \$900,000 for Site 1 and \$1 million for Site 2 (November 2012). For a 300-cfs facility, the same manufacturer did not have pumps capable of serving the higher pumping head at Site 2. They could provide seven 43-cfs pumps for Site 1 to meet the 300-cfs demand. The budgetary quote (January 2013) for those seven pumps and motors was approximately \$4 million – more than four times the cost of the pumps for the 100-cfs facility.

The larger pump station would also have much higher power/energy demands. Preliminary discussions with Puget Sound Energy indicate that they have higher voltage lines (34.5 kV and 115 kV) available in the Site 1 area that are currently not as close to Site 2. It is uncertain if the smaller pump station would require a substation, but it is almost certain that the larger pump station would require a substation from either the 34.5 kV or 115 kV lines.

Table 9-2 compares approximate relative costs of the 100-cfs and 300-cfs pump stations located at Site 1. Due to the higher pumping head and pump capacity limitations, higher energy costs, and power supply limitations at Site 2; the following cost comparison was only done for Site 1.

Using an average 80.8 percent combined motor/pump efficiency and \$0.06 per kWh, the average Site 1 annual pumping energy costs would be approximately \$1.08 million for the 100 cfs (38,800 acre-feet-per-year) and \$2.45 million for the 300 cfs (88,200 acre-feet-per-year) pump stations.



**Table 9-2. Cost Comparison between 100-cfs and 300-cfs Pump Station at Site 1  
(all costs in 2012 \$ million)**

COST ITEM	SWAUK CREEK SITE 1 100 cfs	SWAUK CREEK SITE 1 300 cfs
Intake, Pipeline, Pump Station, Outlet*	\$11.0	\$30.5
Tributary Turnouts	\$0.42	\$0.80
<b>Subtotal Construction Costs</b>	<b>\$11.4</b>	<b>\$31.3</b>
Property/Easement Acquisition	\$0.12	\$0.20
5% Project Legal/Administration	\$0.57	\$1.6
6% Permitting/Environmental	\$0.69	\$1.9
6% Surveying/Geotech	\$0.69	\$1.9
15% Engineering/Design	\$1.7	\$4.7
10% Construction Management	\$1.1	\$3.1
<b>Approximate Total Project Costs</b>	<b>\$16.3 million</b>	<b>\$44.6 million</b>
<b>Range (-30% to +50%) of Project Costs</b>	<b>\$11.4 to \$24.5 million</b>	<b>\$31.2 to \$66.9 million</b>

## 10.0 References

Bureau of Reclamation, 1929-1930. North Branch Canal Siphon and Tunnel Drawings, Yakima Project – Washington, Kittitas Division, U.S. Department of the Interior, Bureau of Reclamation, Denver Colorado, May 1929 through January 1930.

Bureau of Reclamation and Washington State Department of Ecology (Reclamation and Ecology). 2011. *Groundwater Infiltration Appraisal Level Study Technical Memorandum*. March 2011. U.S. Department of the Interior, Bureau of Reclamation, and Washington State Department of Ecology.

Bureau of Reclamation and Washington State Department of Ecology (Reclamation and Ecology). 2012. *Yakima River Basin Integrated Water Resource Management Plan Framework for Implementation Report*. October 2012. U.S. Department of the Interior, Bureau of Reclamation, and Washington State Department of Ecology.

Jones, M.A., Vaccaro, J.J., and Watkins, A.M. (2006). *Hydrogeologic Framework of Sedimentary Deposits in Six Structural Basins, Yakima River Basin, Washington*, Prepared in Corporation with the Bureau of Reclamation, Washington State Department of Ecology, and Yakama Nation, U.S. Geological Survey Scientific Investigations Report 2006-5116, 24 p.

Satnik, Roger (2012). Re: KRD North Branch Flow. E-mail communication with Adam Hill, Anchor QEA. August 17, 2012.

Washington Division of Geology and Earth Resources (2005), Digital 1:100,000-Scale Geology of Washington State, Version 1.0: Washington Division of Geology and Earth Resources, Open File Report 2005-3, scale 1:100000.

---

## 11.0 List of Preparers

NAME	BACKGROUND	RESPONSIBILITY
HDR ENGINEERING, INC.		
Jim Peterson	Professional Engineer	Task Manager
Keith Goss	Professional Engineer	Task Engineer
John Nelson	Professional Engineer	Intake QC Reviewer
Richard Glassen	Cost Estimator	Cost Estimate
Stan Schweissing	Professional Engineer	QC Reviewer
ANCHOR QEA		
Bob Montgomery	Professional Engineer	Water Resources
Adam Hill	Professional Engineer	Water Resources


---

# Appendix A

## Appendix Figures


---

*This Page Intentionally Left Blank*



C:\Jobs\110492-02\_01\_YakimaRiver\_Ellensburg\_Thorp\Maps2012\_11\Fig1\_Vicinity.mxd 11/16/2012 4:12:14 PM

**Site Locations**  
Figure 1




---

*This Page Intentionally Left Blank*



Q:\Jobs\110492-02.01\_YakimaRiver\_Elensburg\_Thorpe\Maps\2013\_02\Fig2\_Turnouts.mxd ahill 2/28/2013 9:21:43 AM



**LEGEND**

- Turnout Locations
- Relevant Gauge Locations
- Pump Station Sites
- KRD Main Canal
- KRD North Branch Canal
- KRD South Branch Canal
- Laterals
- Rivers
- Creeks



Site Locations of Proposed Canal Turnouts  
Figure 2



---

*This Page Intentionally Left Blank*






Q:\Jobs\110492-02.01\_YakimaRiver\_Eliensburg\_ThorpeMaps2012\_11\Fig3\_Geology.mxd\_sifox 11/16/2012 2:54:49 PM

<ul style="list-style-type: none"> <li><span style="color: brown;">—</span> 100-ft Contours</li> <li><span style="color: magenta;">- - *</span> Syncline—Identity and existence certain, location concealed</li> </ul>	<p><b>Surficial Geology</b></p> <ul style="list-style-type: none"> <li><span style="color: brown;">■</span> Mv(gN2), Mv(gR2); Miocene Columbia River Basalt Group, Grande Ronde Basalt</li> <li><span style="color: orange;">■</span> Mvc(e); Pliocene-Oligocene volcanoclastic rocks, lahars, tuffs, and tuff breccias</li> <li><span style="color: yellow;">■</span> PLcg(t); Quaternary-Miocene continental sedimentary rocks</li> <li><span style="color: lightgreen;">■</span> Qa; Quaternary alluvium, dune sand, loess, and artificial fill</li> </ul>	<ul style="list-style-type: none"> <li><span style="color: yellow;">■</span> Qao(lb); Quaternary alpine glacial deposits, Fraser-age or younger</li> <li><span style="color: lightyellow;">■</span> Qapo(ki), Qaop(ks), Qapt(ks); Pleistocene alpine glacial deposits, pre-Fraser</li> <li><span style="color: yellow;">■</span> Qls; Quaternary alluvial fans, beach deposits, undifferentiated sedimentary deposits, lacustrine deposits, landslides, peat, terraced deposits, and talus</li> <li><span style="color: cyan;">■</span> wtr; Water</li> </ul>
--	---	---

**NOTES:**  
 1. Contours derived from USGS 10-meter DEM converted to NAVD88 feet (assumed vertical change = +1.125 meters).  
 2. Surficial Geology information from the Washington State Department of Natural Resources (DNR).




**Geology**  
Figure 3

---

*This Page Intentionally Left Blank*






Q:\Jobs\110492-02\_01\_YakimaRiver\_Ellensburg\_Thorpe\Mapa\2012\_09\Revised\Fig3\_Swauc.mxd ahil 10/2/2012 2:33:00 PM

**LEGEND**  
 □ Kittitas County Tax Parcels

**NOTES:**  
 1. Parcel boundaries are from Kittitas County GIS. Kittitas County has indicated that parcel boundaries are off by as much as 100 feet in rural areas.



**Swauk Creek Site 1**  
 Figure 4




---

*This Page Intentionally Left Blank*




**LEGEND**

-  20-ft Contours
-  100-ft Contours
-  Kittitas County Tax Parcels



**NOTES:**  
 1. Parcel boundaries are from Kittitas County GIS. Kittitas County has indicated that parcel boundaries are off by as much as 100 feet in rural areas.  
 2. Contours derived from LIDAR data collected by FEMA in 2011 (NAVD88 feet).



**Dudley Road Site 2**  
 Figure 5

C:\pwworking\seald0826678\KRD PS.dwg, Overall Dudley, 1/28/2012 1:59:37 PM, kgoss

Q:\Jobs\110492-02.01\_YakimaRiver\_Ellensburg\_Thorpe\Maps\2012\_11\Fig5\_Dudley.mxd isfox 11/16/2012 11:32:35 AM




---

*This Page Intentionally Left Blank*

Q:\lobat\10492-02\_01\_YakimaRiver\_Ellenburg\_Thorpe\Maps\2012\_11\Fig6\_SwaucDetail.mxd jobx 11/16/2012 11:35:27 AM




Swauk Creek Site 1 Intake and Pump Station Plan  
Figure 6




---

*This Page Intentionally Left Blank*







**INTAKE PLAN**




**INTAKE SECTION A-A**



**OUTLET PLAN**






**OUTLET SECTION B-B**



DESIGNED	-----
DRAWN	-----
CHECKED	-----
TECH. APPR.	NAME - TITLE
APPROVED	ADMINISTRATIVE APPROVAL - NAME - TITLE
BOISE, ID	06.25.2009

---

*This Page Intentionally Left Blank*



ALWAYS THINK SAFETY


U.S. DEPARTMENT OF THE INTERIOR  
BUREAU OF RECLAMATION  
YANPAH RIVER BASIN STUDY

Kititaa Reclamation District  
Pump Station Plan and Section  
Figure 8


DESIGNED	-----
DRAWN	-----
CHECKED	-----
TECH. APPR.	NAME - TITLE
APPROVED	-----
ADMINISTRATIVE APPROVAL	NAME - TITLE
BOISE, ID	06.25.2009

---


*This Page Intentionally Left Blank*



**A PLAN VIEW**  
NOT TO SCALE



**B SECTION**  
NOT TO SCALE



**C SECTION**  
NOT TO SCALE

ALWAYS THINK SAFETY

U.S. DEPARTMENT OF THE INTERIOR  
BUREAU OF RECLAMATION  
KITITIAS VALLEY DELIVERY SYSTEM

CANAL TO TRIBUTARY TURNOUT  
FIGURE 9

DESIGNED	-----
DRAWN	-----
CHECKED	-----
TECH. APPR.	NAME - TITLE
APPROVED	ADMINISTRATIVE APPROVAL - NAME - TITLE
BOISE, ID	10.11.2012

FIGURE 9

---


*This Page Intentionally Left Blank*





C:\Jobs\110492-02.01\_YakimaRiver\_Elensburg\_Thorp\Maps\2012\_11\Fig10\_PropOwn.mxd sfox 11/16/2012 2:26:00 PM

**NOTES:**  
 1. Parcel boundaries are from Kittitas County GIS. Kittitas County has indicated that parcel boundaries are off by as much as 100 feet in rural areas.  
 2. Ownership names are included on potential property purchase/easements required for project.



**Sites 1 and 2 Property Boundaries and Ownership**  
 Figure 10



---

*This Page Intentionally Left Blank*



---

## **Appendix B**

### **Preliminary Opinions of Probable Construction Costs**

---

*This Page Intentionally Left Blank*

**KRD Canal GW Recharge from Yakima**  
**Intake from YR Pump to KRD Canal**  
**Yakima WA, 98903**  
**Conceptual Swauk Creek**  
**Estimate WorkArea Report**

Labor Rate Table - 4th Qtr 2012 Union  
Equipment Rate Table - 4th Qtr 2012  
City Index - 989-WA-YAKIMA

CONC2012

CONC2012

KRD Canal GW  
Recharge from Yakima  
Intake from YR Pump  
to KRD Canal  
Yakima  
WA, 98903  
Conceptual  
Swauk Creek  
1  
40  
20  
4th Qtr 2012 Union  
4th Qtr 2012

Any opinions of probable construction cost or cost estimates provided by HDR, Inc. are made on the basis of information available to HDR, Inc. and on the basis of cost estimator's experience and qualifications, and represents its judgment as an experienced and qualified professional engineer. However, since HDR, Inc. has no control over the cost of labor, materials, equipment or services furnished by others, or over the contractor(s)' methods of determining prices, or over competitive bidding or market conditions, HDR, Inc. does not guarantee that proposals, bids or actual project or construction cost will not vary from opinions of probable cost or cost estimates prepared by HDR, Inc.

989-WA-YAKIMA

Labor Rate Table - 4th Qtr 2012 Union  
Equipment Rate Table - 4th Qtr 2012  
City Index - 989-WA-YAKIMA

Description	Quantity						Total	
		Labor	Material	Subcontract	Equipment	Other		
		Amount	Amount	Amount	Amount	Amount	Amount	
<b>001 PUMP STATION SITE 1 - SWAUK CREEK</b>								
<b>DIVISION 01 GENERAL REQUIREMENTS</b>								
01500.000	Temporary Facilities & Controls	12.00	mo				912,497	912,497
<b>DIVISION 01 GENERAL REQUIREMENTS</b>							<b>912,497</b>	<b>912,497</b>
<b>DIVISION 02 SITE CONSTRUCTION</b>								
02110.010	Site Clearing - Intake, PS, Outlet Sites	3.00	ac	14,462			13,444	27,906
02200.050	Earthwork - Fine Grading - Intake, PS, Outlet	2,500.00	cy	24,626			17,191	41,816
02200.505	Earthwork, Structural Excavation - Pump Station inside Sheeting	4,666.66	cy	71,958			97,173	169,131
02200.510	Earthwork, Structural Excavation - Pump Station @Gde	219.00	cy	365			427	792
02200.535	Earthwork, Structural Excavation-Intake, Outlet	985.00	cy	528			1,279	1,807
02200.605	Earthwork, Structural Backfill, Native, compaction, Pump Station	4,666.00	cy	69,100			81,179	150,279
02200.610	Earthwork, Structural Backfill, Native,Pump Station @ Gde	80.00	cy	190			135	325
02200.635	Earthwork, Structural Backfill, Native Matl, compaction-Intake, Outlet	985.00	cy	1,922			1,560	3,482
02361.000	Driven Steel Sheet Piling	8,564.00	sf	60,281	148,795		56,505	265,580
02361.200	Cofferdam - Shore Driven	1,920.00	sf	7,781	38,020		7,295	53,096
02513.000	Asphaltic Concrete Vehicular Paving	1,600.00	sy	4,524	26,021		4,370	34,915
02585.000	Groundwater Dewatering Wells	120.00	vlf	17,489	5,778		2,791	26,058
<b>DIVISION 02 SITE CONSTRUCTION</b>				<b>273,225</b>	<b>218,614</b>		<b>283,347</b>	<b>775,186</b>
4,796.80	Labor hours							
3,520.244	Equipment hours							
<b>DIVISION 03 CONCRETE</b>								
03002.115	Concrete_Foundations - River Intake Slab, Turndowns, Wall Fdn	84.00	cy	20,226	21,141		866	42,233

AACE Classification Accuracy Range

Upper Range +40%

Lower Range -20%

**KRD Canal GW Recharge from Yakima**  
Intake from YR Pump to KRD Canal  
Yakima WA, 98903  
Conceptual Swauk Creek  
**Estimate WorkArea Report**

Labor Rate Table - 4th Qtr 2012 Union  
Equipment Rate Table - 4th Qtr 2012  
City Index - 989-WA-YAKIMA

Description	Quantity						Total
		Labor	Material	Subcontract	Equipment	Other	
		Amount	Amount	Amount	Amount	Amount	Amount
03002.120 Concrete_Foundations - Outlet Section B-B	56.00 cy	8,722	13,776		977		23,474
03002.125 Concrete_Foundations - Canal Gate Gd Beam	5.00 cy	978	1,220		52		2,249
03002.130 Concrete_Foundations - Pump Station Wetwell	137.00 cy	20,535	37,473		1,591		59,599
03002.310 Concrete_Walls Exterior - River Intake	175.00 cy	59,455	40,890		2,655		103,000
03002.315 Concrete_Walls Exterior -Outlet Section B-B	37.00 cy	12,600	8,841		561		22,002
03002.330 Concrete_Walls Exterior Pump Station Wetwell	237.00 cy	76,747	64,225		2,388		143,360
03002.430 Concrete_Walls Interior - Pump Station Wetwell	30.00 cy	13,904	7,499		262		21,666
03002.605 Concrete_Elevated Slab-River Intake	12.00 cy	4,006	3,782		145		7,932
03002.615 Concrete_Elevated Slab - Outlet Section B-B	4.00 cy	1,196	1,149		48		2,393
03002.705 Concrete_Slab on Grade - Screen Cleaning Equipment Pad	1.00 cy	191	242		17		450
03002.730 Concrete_Slab on Grade - Pump Station	138.00 cy	16,010	28,335		1,063		45,409
03002.830 Concrete_Equipment Pads - Pump Station	8.00 cy	1,443	1,741		14		3,198
<b>DIVISION 03 CONCRETE</b>		<b>236,014</b>	<b>230,312</b>		<b>10,639</b>		<b>476,966</b>
4,808.131 Labor hours							
294.813 Equipment hours							
<b>DIVISION 04 MASONRY</b>							
04220.030 Concrete Masonry - 12" Split Face CMU	5,280.00 sf	61,249	59,740		1,142		122,131
04220.080 Concrete Masonry (8" CMU)	748.00 sf	6,595	4,441		151		11,188
<b>DIVISION 04 MASONRY</b>		<b>67,844</b>	<b>64,181</b>		<b>1,293</b>		<b>133,319</b>
1,632.152 Labor hours							
76.84 Equipment hours							
<b>DIVISION 05 METALS</b>							
05505.000 Metal Fabrications	1.00 ls	698	1,908		54		2,660

Upper Range +40%

AACE Classification Accuracy Range

Lower Range -20%

Labor Rate Table - 4th Qtr 2012 Union  
Equipment Rate Table - 4th Qtr 2012  
City Index - 989-WA-YAKIMA

Description	Quantity		Labor	Material	Subcontract	Equipment	Other	Total	
			Amount	Amount	Amount	Amount	Amount	Amount	
05522.000	Aluminum Railings	110.00	lf	1,324	6,436		103	7,863	
05900.000	Miscellaneous Metal	1.00	ls	1,710	6,853		48	8,611	
<b>DIVISION 05 METALS</b>			<b>3,732</b>	<b>15,197</b>		<b>205</b>	<b>19,134</b>		
51.11	Labor hours								
12.771	Equipment hours								
<b>DIVISION 07 THERMAL &amp; MOISTURE PROTECTION</b>									
07412.000	Metal Roofing	3,096.00	sf	14,116	30,025		424	44,565	
07720.000	Roof Hatches (Scuttle)			751	3,680			4,431	
<b>DIVISION 07 THERMAL &amp; MOISTURE PROTECTION</b>			<b>14,867</b>	<b>33,705</b>		<b>424</b>	<b>48,995</b>		
303.76	Labor hours								
10.43	Equipment hours								
<b>DIVISION 08 DOORS &amp; WINDOWS</b>									
08110.030	Metal Doors & Frames (3070)	2.00	ea	409	3,136			3,545	
08110.060	Metal Doors & Frames (6070)	1.00	ea	376	3,046			3,422	
08305.000	Access Doors	1.00	ea	391	5,538			5,930	
<b>DIVISION 08 DOORS &amp; WINDOWS</b>			<b>1,176</b>	<b>11,721</b>			<b>12,897</b>		
24.21	Labor hours								
<b>DIVISION 09 FINISHES</b>									
08110.030	Metal Doors & Frames (3070)	2.00	ea	27	4			31	
08110.060	Metal Doors & Frames (6070)	1.00	ea	27	4			31	
09904.030	Painting and Protective Coatings - CMU	6,794.00	sf	4,633	2,602			7,235	
09904.033	Painting and Protective Coatings - Bar Joists, Metal Deck	1.00	ls	680	384			1,064	
<b>DIVISION 09 FINISHES</b>			<b>5,367</b>	<b>2,994</b>			<b>8,361</b>		
187.931	Labor hours								
<b>DIVISION 11 EQUIPMENT</b>									
11072.000	Pumping Equipment: Vertical Turbine (Line Shaft)	4.00	ea	24,299	866,000	15,126	21,253	4,396	931,074
<i>Budget Pricing good until November 2013</i>									
<b>DIVISION 11 EQUIPMENT</b>			<b>24,299</b>	<b>866,000</b>	<b>15,126</b>	<b>21,253</b>	<b>4,396</b>	<b>931,074</b>	
544.000	Labor hours								
256.000	Equipment hours								
<b>DIVISION 13 SPECIAL CONSTRUCTION</b>									

Upper Range +40%

AACE Classification Accuracy Range

Lower Range -20%

Labor Rate Table - 4th Qtr 2012 Union  
Equipment Rate Table - 4th Qtr 2012  
City Index - 989-WA-YAKIMA

Description	Quantity		Labor	Material	Subcontract	Equipment	Other	Total
			Amount	Amount	Amount	Amount	Amount	Amount
13442.100	Instrumentation and Integration	1.00	Is	6,413	50,099		315	56,827
	Subcontract							
15509.100	Fish Screen Fixed Plate Inclined	360.00	sf			691,284		691,284
<b>DIVISION 13 SPECIAL CONSTRUCTION</b>				<b>6,413</b>	<b>50,099</b>	<b>691,284</b>	<b>315</b>	<b>748,111</b>
106.000	Labor hours							
21.00	Equipment hours							
<b>DIVISION 15 MECHANICAL</b>								
02110.040	Site Clearing - Force Main	3.58	ac	9,838			17,146	26,984
02140.020	Dewatering - Intake	15.00	dys	11,176	577		10,512	22,265
02221.020	Trenching, Backfilling, Compacting for Utilities - Pump Station Intake	3,219.00	cy	9,457			19,617	29,074
02221.040	Trenching, Backfilling and Compacting for Utilities - FM	6,799.00	cy	36,280	7,759		46,000	90,039
02221.060	Trenching, Backfilling, Compacting for Utilities - Air Piping	105.00	cy	412	119		590	1,121
02445.000	Horizontal Bore and Jack	240.00	lf	68,422	112,243	31,620	29,003	241,287
03002.905	Concrete_Pipe Encasement and Blocking	13.23	cy	1,169	2,360		7	3,535
15062.020	Pipe: Ductile - Pump Station Intake	600.00	lf	65,324	357,098		53,770	133 476,325
15062.040	Pipe: Ductile - PS FM	2,600.00	lf	241,700	741,605		203,495	46 1,186,847
15062.100	Pipe: Ductile - Interior with Valves, Couplings, Hangers and Supports	1.00	ls	24,385	175,443			999 200,827
15066.000	Pipe: Stainless Steel - Screen Air cleaning Pipng	80.00	lf	12,761	12,801		346	25,909
15103.000	Butterfly Valves	5.00	ea	7,532	74,318		737	82,587
15111.000	Pump Control Valves	4.00	ea	7,781	120,396		2,904	131,081
15111.100	Surge Relief Valves	1.00	ea	1,012	18,099		363	19,474
15115.000	Water Control Gates	2.00	ea	5,487	30,839		1,494	37,819
15605.000	HVAC: Equipment	1.00	ls	3,018	9,772			12,790
<b>DIVISION 15 MECHANICAL</b>				<b>505,755</b>	<b>1,663,429</b>	<b>31,620</b>	<b>385,983</b>	<b>1,178 2,587,965</b>
9.735.16	Labor hours							
3.393.38	Equipment hours							
<b>DIVISION 16 ELECTRICAL</b>								
16000.110	Electrical Subcontractor - Process	1.00	ls	33,638	306,000		1,668	341,306

AACE Classification Accuracy Range

Upper Range +40%

Lower Range -20%

Labor Rate Table - 4th Qtr 2012 Union  
 Equipment Rate Table - 4th Qtr 2012  
 City Index - 989-WA-YAKIMA

Description	Quantity	Labor	Material	Subcontract	Equipment	Other	Total
		Amount	Amount	Amount	Amount	Amount	Amount
<b>DIVISION 16 ELECTRICAL</b>							
556.00 Labor hours		33,638	306,000		1,668		341,306
111.20 Equipment hours							
<b>001 PUMP STATION SITE 1 - SWAUK CREEK</b>		<b>1,172,329</b>	<b>3,462,252</b>	<b>738,030</b>	<b>705,128</b>	<b>918,071</b>	<b>6,995,810</b>
<b>100.00 CFS</b>							
22,745.243 Labor hours							
7,696.671 Equipment hours							

Upper Range +40%

AACE Classification Accuracy Range

Lower Range -20%



Labor Rate Table - 4th Qtr 2012 Union  
 Equipment Rate Table - 4th Qtr 2012  
 City Index - 989-WA-YAKIMA

**Partial Totals**

Description	Amount	Totals	Hours	Rate
Labor	1,172,329		22,745.243 hrs	
Material	3,462,252			
Subcontract	738,030			
Equipment	705,128		7,696.671 hrs	
Other	918,071			
Contractor's Fee	1,049,372			15.000 %
Contractor's Bonds & Insurance	120,678			1.500 %
Undefined SOW (Contingency)	1,224,879			15.000 %
<b>Subtotal</b>		<b>9,390,739</b>		
Escal Mid-Pnt Const (NOTINCLU)				
Sales Tax Estimate (TOTAL)	727,782			7.750 %
<b>Current OPCC Estimate Budget</b>		<b>10,118,521</b>		

**KRD Canal GW Recharge from Yakima**  
Intake from YR Pump to KRD Canal  
Yakima WA, 98903  
Conceptual Dudley Road  
**Estimate WorkArea Report**

Labor Rate Table - 4th Qtr 2012 Union  
Equipment Rate Table - 4th Qtr 2012  
City Index - 989-WA-YAKIMA

CONC2012

CONC2012

KRD Canal GW  
Recharge from Yakima  
Intake from YR Pump  
to KRD Canal  
Yakima  
WA, 98903  
Conceptual  
Dudley Road  
1  
40  
20  
4th Qtr 2012 Union  
4th Qtr 2012

Any opinions of probable construction cost or cost estimates provided by HDR, Inc. are made on the basis of information available to HDR, Inc. and on the basis of cost estimator's experience and qualifications, and represents its judgment as an experienced and qualified professional engineer. However, since HDR, Inc. has no control over the cost of labor, materials, equipment or services furnished by others, or over the contractor(s)' methods of determining prices, or over competitive bidding or market conditions, HDR, Inc. does not guarantee that proposals, bids or actual project or construction cost will not vary from opinions of probable cost or cost estimates prepared by HDR, Inc.

989-WA-YAKIMA

Labor Rate Table - 4th Qtr 2012 Union  
Equipment Rate Table - 4th Qtr 2012  
City Index - 989-WA-YAKIMA

Description	Quantity						Total
		Labor	Material	Subcontract	Equipment	Other	
		Amount	Amount	Amount	Amount	Amount	Amount
<b>002 PUMP STATION SITE 2 - DUDLEY ROAD</b>							
<b>DIVISION 01 GENERAL REQUIREMENTS</b>							
01500.000	Temporary Facilities & Controls	12.00 mo				812,510	812,510
<b>DIVISION 01 GENERAL REQUIREMENTS</b>						<b>812,510</b>	<b>812,510</b>
<b>DIVISION 02 SITE CONSTRUCTION</b>							
02110.010	Site Clearing - Intake, PS, Outlet Sites		14,462		13,444		27,906
02200.050	Earthwork - Fine Grading - Intake, PS, Outlet		24,626		17,191		41,816
02200.505	Earthwork, Structural Excavation - Pump Station inside Sheeting		71,958		97,173		169,131
02200.510	Earthwork, Structural Excavation - Pump Station @Gde		365		427		792
02200.535	Earthwork, Structural Excavation-Intake, Outlet		528		1,279		1,807
02200.605	Earthwork, Structural Backfill, Native, compaction, Pump Station		69,100		81,179		150,279
02200.610	Earthwork, Structural Backfill, Native, Pump Station @ Gde		190		135		325
02200.635	Earthwork, Structural Backfill, Native Matl, compaction-Intake, Outlet		1,922		1,560		3,482
02361.000	Driven Steel Sheet Piling		60,281	148,795		56,505	265,580
02361.200	Cofferdam - Shore Driven		7,781	38,020		7,295	53,096
02513.000	Asphaltic Concrete Vehicular Paving		4,524	26,021		4,370	34,915
02585.000	Groundwater Dewatering Wells		17,489	5,778		2,791	26,058
<b>DIVISION 02 SITE CONSTRUCTION</b>			<b>273,225</b>	<b>218,614</b>		<b>283,347</b>	<b>775,186</b>
4,796.80	Labor hours						
3,520.244	Equipment hours						
<b>DIVISION 03 CONCRETE</b>							
03002.115	Concrete_Foundations - River Intake Slab, Turndowns, Wall Fdn		20,226	21,141		866	42,233

AACE Classification Accuracy Range

Upper Range +40%

Lower Range -20%

Labor Rate Table - 4th Qtr 2012 Union  
Equipment Rate Table - 4th Qtr 2012  
City Index - 989-WA-YAKIMA

Description	Quantity	Labor	Material	Subcontract	Equipment	Other	Total
		Amount	Amount	Amount	Amount	Amount	Amount
03002.120 Concrete_Foundations - Outlet Section B-B		8,722	13,776		977		23,474
03002.125 Concrete_Foundations - Canal Gate Gd Beam		978	1,220		52		2,249
03002.130 Concrete_Foundations - Pump Station Wetwell		20,535	37,473		1,591		59,599
03002.310 Concrete_Walls Exterior - River Intake		59,455	40,890		2,655		103,000
03002.315 Concrete_Walls Exterior -Outlet Section B-B		12,600	8,841		561		22,002
03002.330 Concrete_Walls Exterior Pump Station Wetwell		76,747	64,225		2,388		143,360
03002.430 Concrete_Walls Interior - Pump Station Wetwell		13,904	7,499		262		21,666
03002.605 Concrete_Elevated Slab-River Intake		4,006	3,782		145		7,932
03002.615 Concrete_Elevated Slab - Outlet Section B-B		1,196	1,149		48		2,393
03002.705 Concrete_Slab on Grade - Screen Cleaning Equipment Pad		191	242		17		450
03002.730 Concrete_Slab on Grade - Pump Station		16,010	28,335		1,063		45,409
03002.830 Concrete_Equipment Pads - Pump Station		1,443	1,741		14		3,198
<b>DIVISION 03 CONCRETE</b>		<b>236,014</b>	<b>230,312</b>		<b>10,639</b>		<b>476,966</b>
4,808.131 Labor hours							
294.813 Equipment hours							
<b>DIVISION 04 MASONRY</b>							
04220.030 Concrete Masonry - 12" Split Face CMU		61,249	59,740		1,142		122,131
04220.080 Concrete Masonry (8" CMU)		6,595	4,441		151		11,188
<b>DIVISION 04 MASONRY</b>		<b>67,844</b>	<b>64,181</b>		<b>1,293</b>		<b>133,319</b>
1,632.152 Labor hours							
76.84 Equipment hours							
<b>DIVISION 05 METALS</b>							
05505.000 Metal Fabrications		698	1,908		54		2,660

Labor Rate Table - 4th Qtr 2012 Union  
Equipment Rate Table - 4th Qtr 2012  
City Index - 989-WA-YAKIMA

Description	Quantity	Labor	Material	Subcontract	Equipment	Other	Total
		Amount	Amount	Amount	Amount	Amount	Amount
05522.000 Aluminum Railings		1,324	6,436		103		7,863
05900.000 Miscellaneous Metal		1,710	6,853		48		8,611
<b>DIVISION 05 METALS</b>		<b>3,732</b>	<b>15,197</b>		<b>205</b>		<b>19,134</b>
51.11 Labor hours							
12.771 Equipment hours							
<b>DIVISION 07 THERMAL&amp; MOISTURE PROTECTION</b>							
07412.000 Metal Roofing		14,116	30,025		424		44,565
07720.000 Roof Hatches (Scuttle)		751	3,680				4,431
<b>DIVISION 07 THERMAL&amp; MOISTURE PROTECTION</b>		<b>14,867</b>	<b>33,705</b>		<b>424</b>		<b>48,995</b>
303.76 Labor hours							
10.43 Equipment hours							
<b>DIVISION 08 DOORS &amp; WINDOWS</b>							
08110.030 Metal Doors & Frames (3070)		409	3,136				3,545
08110.060 Metal Doors & Frames (6070)		376	3,046				3,422
08305.000 Access Doors		391	5,538				5,930
<b>DIVISION 08 DOORS &amp; WINDOWS</b>		<b>1,176</b>	<b>11,721</b>				<b>12,897</b>
24.21 Labor hours							
<b>DIVISION 09 FINISHES</b>							
08110.030 Metal Doors & Frames (3070)		27	4				31
08110.060 Metal Doors & Frames (6070)		27	4				31
09904.030 Painting and Protective Coatings - CMU		4,633	2,602				7,235
09904.033 Painting and Protective Coatings - Bar Joists, Metal Deck		680	384				1,064
<b>DIVISION 09 FINISHES</b>		<b>5,367</b>	<b>2,994</b>				<b>8,361</b>
187.931 Labor hours							
<b>DIVISION 11 EQUIPMENT</b>							
11072.000 Pumping Equipment: Vertical Turbine (Line Shaft)		28,349	995,000	15,126	28,338	4,396	1,071,208
Budget Pricing good until November 2013							
<b>DIVISION 11 EQUIPMENT</b>		<b>28,349</b>	<b>995,000</b>	<b>15,126</b>	<b>28,338</b>	<b>4,396</b>	<b>1,071,208</b>
624.00 Labor hours							
320.00 Equipment hours							
<b>DIVISION 13 SPECIAL CONSTRUCTION</b>							

Upper Range +40%

AACE Classification Accuracy Range

Lower Range -20%

Labor Rate Table - 4th Qtr 2012 Union  
Equipment Rate Table - 4th Qtr 2012  
City Index - 989-WA-YAKIMA

Description	Quantity						Total
		Labor	Material	Subcontract	Equipment	Other	
		Amount	Amount	Amount	Amount	Amount	Amount
13442.100 Instrumentation and Integration		6,413	50,099		315		56,827
15509.100 Fish Screen Fixed Plate Inclined				691,284			691,284
<b>DIVISION 13 SPECIAL CONSTRUCTION</b>		<b>6,413</b>	<b>50,099</b>	<b>691,284</b>	<b>315</b>		<b>748,111</b>
106.000 Labor hours							
21.00 Equipment hours							
<b>DIVISION 15 MECHANICAL</b>							
02110.040 Site Clearing - Force Main	2.50 ac	6,870			11,973		18,844
02140.020 Dewatering - Intake	5.00 dys	3,810	289		3,528		7,626
02221.020 Trenching, Backfilling, Compacting for Utilities - Pump Station Intake	1,031.00 cy	3,026			6,277		9,304
02221.040 Trenching, Backfilling and Compacting for Utilities - FM	5,230.00 cy	27,903	5,949		35,384		69,235
02221.060 Trenching, Backfilling, Compacting for Utilities - Air Piping	105.00 cy	412	119		590		1,121
02445.000 Horizontal Bore and Jack	160.00 lf	45,614	69,443	21,080	17,848		153,985
03002.905 Concrete_Pipe Encasement and Blocking	8.50 cy	751	1,516		4		2,271
15062.020 Pipe: Ductile - Pump Station Intake	220.00 lf	21,359	127,661		17,006	52	166,078
15062.040 Pipe: Ductile - PS FM	2,000.00 lf	181,854	514,914		153,025	46	849,839
15062.100 Pipe: Ductile - Interior with Valves, Couplings, Hangers and Supports		24,385	175,443			999	200,827
15066.000 Pipe: Stainless Steel - Screen Air cleaning Pipng		12,761	12,801		346		25,909
15103.000 Butterfly Valves		7,532	74,318		737		82,587
15111.000 Pump Control Valves		7,781	120,396		2,904		131,081
15111.100 Surge Relief Valves		1,012	18,099		363		19,474
15115.000 Water Control Gates	1.00 ea	5,487	23,295		1,494		30,276
15605.000 HVAC: Equipment		3,018	9,772				12,790
<b>DIVISION 15 MECHANICAL</b>		<b>353,577</b>	<b>1,154,014</b>	<b>21,080</b>	<b>251,479</b>	<b>1,097</b>	<b>1,781,247</b>
6,752.81 Labor hours							
2,090.403 Equipment hours							
<b>DIVISION 16 ELECTRICAL</b>							
16000.110 Electrical Subcontractor - Process		33,638	306,000		1,668		341,306

AACE Classification Accuracy Range

Upper Range +40%

Lower Range -20%

Labor Rate Table - 4th Qtr 2012 Union  
 Equipment Rate Table - 4th Qtr 2012  
 City Index - 989-WA-YAKIMA

Description	Quantity	Labor	Material	Subcontract	Equipment	Other	Total
		Amount	Amount	Amount	Amount	Amount	Amount
<b>DIVISION 16 ELECTRICAL</b>							
556.00 Labor hours		33,638	306,000		1,668		341,306
111.20 Equipment hours							
<b>002 PUMP STATION SITE 2 - DUDLEY ROAD</b>		<b>1,024,201</b>	<b>3,081,837</b>	<b>727,490</b>	<b>577,709</b>	<b>818,003</b>	<b>6,229,240</b>
<b>100.00 CFS</b>							
19,842.893 Labor hours							
6,457.695 Equipment hours							

Upper Range +40%

AACE Classification Accuracy Range

Lower Range -20%

**Partial Totals**

Description	Amount	Totals	Hours	Rate
Labor	1,024,201		19,842.893 hrs	
Material	3,081,837			
Subcontract	727,490			
Equipment	577,709		6,457.695 hrs	
Other	818,003			
Contractor's Fee	934,386			15.000 %
Contractor's Bonds & Insurance	107,454			1.500 %
Undefined SOW (Contingency)	1,090,662			15.000 %
<b>Subtotal</b>		<b>8,361,742</b>		
Escal Mid-Pnt Const (NOTINCLU)				
Sales Tax Estimate (TOTAL)	648,035			7.750 %
<b>Current OPCC Estimate Budget</b>		<b>9,009,777</b>		



**KRD Canal GW Recharge from Yakima**  
**Intake from YR Pump to KRD Canal**  
**Yakima WA, 98903**  
**Conceptual KRD Canal Turnouts**  
**Estimate WorkArea Report**

Labor Rate Table - 4th Qtr 2012 Union  
Equipment Rate Table - 4th Qtr 2012  
City Index - 989-WA-YAKIMA

CONC2012

CONC2012

KRD Canal GW  
Recharge from Yakima  
Intake from YR Pump  
to KRD Canal  
Yakima  
WA, 98903  
Conceptual  
KRD Canal Turnouts  
1  
40  
20  
4th Qtr 2012 Union  
4th Qtr 2012

Any opinions of probable construction cost or cost estimates provided by HDR, Inc. are made on the basis of information available to HDR, Inc. and on the basis of cost estimator's experience and qualifications, and represents its judgment as an experienced and qualified professional engineer. However, since HDR, Inc. has no control over the cost of labor, materials, equipment or services furnished by others, or over the contractor(s)' methods of determining prices, or over competitive bidding or market conditions, HDR, Inc. does not guarantee that proposals, bids or actual project or construction cost will not vary from opinions of probable cost or cost estimates prepared by HDR, Inc.

989-WA-YAKIMA

Labor Rate Table - 4th Qtr 2012 Union  
Equipment Rate Table - 4th Qtr 2012  
City Index - 989-WA-YAKIMA

Description	Quantity						Total	
		Labor	Material	Subcontract	Equipment	Other		
		Amount	Amount	Amount	Amount	Amount	Amount	
<b>003 KRD CANAL TRIBUTARY TURNOUTS</b>								
<b>DIVISION 02 SITE CONSTRUCTION</b>								
02200.500	Earthwork, Structural Excavation	1,140.00 cy	866			1,878	2,744	
02200.600	Earthwork, Structural Backfill, Native Material includes compaction	875.00 cy	1,373			2,986	4,359	
02271.000	Stone Revetment (Rip Rap)	282.00 sy	15,733	4,617		3,921	24,271	
<b>DIVISION 02 SITE CONSTRUCTION</b>			<b>17,973</b>	<b>4,617</b>		<b>8,785</b>	<b>31,375</b>	
336.02	Labor hours							
75.222	Equipment hours							
<b>DIVISION 03 CONCRETE</b>								
03002.105	Concrete- Foundation-Turnout Inlet	28.00 cy	5,650	7,741		730	14,121	
03002.305	Concrete_Walls Exterior-Turnoout Inlet	60.00 cy	26,574	14,976		910	42,461	
<b>DIVISION 03 CONCRETE</b>			<b>32,224</b>	<b>22,717</b>		<b>1,640</b>	<b>56,582</b>	
659.523	Labor hours							
40.264	Equipment hours							
<b>DIVISION 15 MECHANICAL</b>								
02221.000	Trenching, Backfilling and Compacting for Utilities	792.00 cy	2,890			3,189	6,079	
15062.000	Pipe: Ductile	1.00 ls	6,551	42,588		3,706	52,943	
15064.000	Pipe: Plastic	400.00 lf	7,212	59,570			66,781	
15115.000	Water Control Gates	4.00 ea	3,817	11,772		1,039	16,628	
<b>DIVISION 15 MECHANICAL</b>			<b>20,469</b>	<b>113,929</b>		<b>7,934</b>	<b>142,431</b>	
387.354	Labor hours							
94.94	Equipment hours							
<b>003 KRD CANAL TRIBUTARY TURNOUTS</b>			<b>70,666</b>	<b>141,264</b>	<b>0</b>	<b>18,360</b>	<b>99</b>	<b>230,388</b>
<b>4.00 EA</b>								
1,382.893	Labor hours							
210.421	Equipment hours							

Upper Range +40%

AACE Classification Accuracy Range

Lower Range -20%

Labor Rate Table - 4th Qtr 2012 Union  
 Equipment Rate Table - 4th Qtr 2012  
 City Index - 989-WA-YAKIMA

**Partial Totals**

Description	Amount	Totals	Hours	Rate
Labor	70,666		1,382.893 hrs	
Material	141,264			
Subcontract				
Equipment	18,360		210.421 hrs	
Other	99			
Contractor's Fld Ovhd & Mob	34,558			15.000 %
Contractor's Fee	39,742			15.000 %
Contractor's Bonds & Insurance	4,570			1.500 %
Undefined SOW (Contingency)	46,389			15.000 %
<b>Subtotal</b>		<b>355,648</b>		
Escal Mid-Pnt Const (NOTINCLU)				
Sales Tax Estimate (TOTAL)	27,563			7.750 %
<b>Current OPCC Estimate Budget</b>		<b>383,211</b>		

<b>Yakima Basin Kittitas Valley Delivery Systems for Groundwater Recharge</b>			
<b>Kittitas Pump Station Budgetary Cost Comparison</b>			
<b>Item</b>	<b>100 cfs Cost Est</b>	<b>100 to 300 cfs Multiplier</b>	<b>300 cfs</b>
<b>General Requirements</b>	<b>\$912,497</b>	<b>2</b>	<b>\$1,824,994</b>
<b>Site Work</b>	<b>\$775,187</b>		<b>\$1,900,397</b>
Intake	\$350,023	3	\$1,050,069
Pump Station	\$355,442	2	\$710,884
Outlet	\$69,722	2	\$139,444
<b>Concrete</b>	<b>\$476,965</b>		<b>\$1,109,794</b>
Intake	\$155,864	3	\$467,592
Pump Station	\$273,232	2	\$546,464
Outlet	\$47,869	2	\$95,738
<b>Pump Station Masonry</b>	<b>\$133,319</b>	<b>2</b>	<b>\$266,638</b>
<b>Misc. Metals</b>	<b>\$19,134</b>	<b>2</b>	<b>\$38,268</b>
<b>PS Roofing and Hatches</b>	<b>\$48,995</b>	<b>2</b>	<b>\$97,990</b>
<b>Doors, Windows, Finishes</b>	<b>\$21,258</b>	<b>2</b>	<b>\$42,516</b>
<b>Pumps and Motors</b>	<b>\$931,074</b>	<b>4</b>	<b>\$3,724,296</b>
<b>Fish Screens</b>	<b>\$748,111</b>	<b>3</b>	<b>\$2,244,333</b>
<b>Mechanical Subtotal</b>	<b>\$2,587,964</b>		<b>\$5,446,889</b>
Pipelines	\$2,281,948	2	\$4,563,896
Valves	\$270,961	3	\$812,883
Other	\$35,055	2	\$70,110
<b>Electrical</b>	<b>\$341,306</b>	<b>2</b>	<b>\$682,612</b>
<b>Switchyard/Transmission</b>			<b>\$2,000,000</b>
<b>Subtotals</b>	<b>\$6,996,000</b>		<b>\$19,379,000</b>
15% Contractor's Fee	\$1,049,400		\$2,906,850
1.5% Bonds/Insurance	\$120,681		\$334,288
25% Undefined SOW	\$2,041,520		\$5,655,034
<b>Subtotals</b>	<b>\$10,208,000</b>		<b>\$28,275,000</b>
7.75% Sales Tax	\$791,120		\$2,191,313
<b>Total</b>	<b>\$10,999,000</b>		<b>\$30,466,000</b>
Tributary Turnouts	\$420,000		\$800,000
Property	\$120,000		\$200,000
5% Project Legal/Admin	\$570,950		\$1,563,300
6% Permtting/Env	\$685,140		\$1,875,960
6% Survey/Geotech	\$685,140		\$1,875,960
15% Engineering	\$1,712,850		\$4,689,900
10% Const. Management	\$1,141,900		\$3,126,600
<b>Totals</b>	<b>\$16,300,000</b>		<b>\$44,600,000</b>