

RECLAMATION

Managing Water in the West

Desalination and Water Purification Research
and Development Program Report No. 207

Updated and Extended Survey of U.S. Municipal Desalination Plants: Appendix B: Facility Summaries



U.S. Department of the Interior
Bureau of Reclamation
Technical Service Center
Denver, Colorado

December 2018

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Contents

Aliso Creek WRF, CA.....	3
Cal Pomona, CA	4
Cambria Project, CA	5
City Of Oxnard, CA	6
Claude ‘Bud’ Lewis Carlsbad Desalination Plant, CA.....	7
East Bay Mud Rare, CA	8
Irvine Ranch Wells 21/22 Desalter, CA.....	9
Irwin Water Works, CA.....	10
Mesa WRF, CA	11
Round Mountain WTP, CA.....	12
Santa Monica W TX Works, CA.....	13
Signal Hill, CA	14
Wochholz Regional WRF, CA.....	15
Arapahoe County Joint Water Purification Plant, CO	16
Northern WTP, CO.....	17
Sterling, CO.....	18
Babcock Ranch Water, FL	19
City of Deerfield Beach, FL	20
City of Labelle, FL	21
Clearwater RO Plant #2, FL.....	22
Coral Springs, FL	23
Dania Beach, WTP FL	24
Green Meadows, FI.....	25
Hialeah RO WTP, FL	26
Hood Road Membrane Water Plant – NF, FL.....	27
Hood Road Membrane Water Plant – RO, FL	28
Lake Worth, FL.....	29
North Cape Coral, RO WTP FL	30
North WTP – South Martin Regional District, FL	31
NSID RO WTP, FL.....	32
Oldsmar RO WTP, FL.....	33
Springtree WTP, FL	34
Tarpon Springs RO Facility, FL	35
Town of Davie WTP/WRF, FL.....	36
East Putnam County WTP, FL.....	37
Kings Bay Naval Base WTP, GA	38
Brimfield Water Plant, IL	39
City of Atkins WTP, IA.....	40
City of Pella, IA.....	41
Council Point WPP, IA	42
City of Hartley RO WTF, IA.....	43
City of Grimes WTP, IA	44

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Hills Water Supply, IA	45
PWWSD #26, KS	46
Clay Center, KS	47
Big Springs WTP, KS	48
Swansea WTP, MA	49
City of Allegan MI	50
Glassboro WTP, NJ	51
Keansburg Freese Street, WTP NJ	52
Craven County, NC	53
Dixon WTP, NC	54
Englehard Hyde County, NC	55
Skyco, NC	56
Tyrrell County Prison RO WTP, NC	57
New Frontier Way NF, NC	58
Valley City WTP, ND	59
Hillsboro WTP, ND	60
Emmons County WTP, ND	61
Bowling Green, OH	62
City of Delaware WTP, OH	63
Spencerville, OH	64
Pigeon Forge STP, TN	65
14 TH And C RO WTP, TX	66
25 th and Avenue G RO WTP, TX	67
Aransas Bay Utilities WTP, TX	68
Big Spring Water Advanced Treatment Plant, TX	69
Bob Elder WTP, TX	70
City of Benjamin RO WTP, TX	71
City of Evant RO WTP, TX	72
City of Granbury, TX	73
City of Roscoe WTP, TX	74
City of Rule, WTP TX	75
City of Wheeler, TX	76
Fort Hancock RO Plant 1, TX	77
Hamby-Abilene WWTP, TX	78
Joines Road WTP, TX	79
La Rusias WTP, TX	80
La Tierra RO WTP, TX	81
Mitchell County Desalination Plant, TX	82
Progresso WTP, TX	83
San Antonio, TX	84
Stephens Regional Special Utility District, TX	85
Victoria Road RO Plant, TX	86
Southwest GW TP, UT	87

Note that blue text indicates that information was not obtainable.

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Aliso Creek WRF, CA

GENERAL

- Facility name = Aliso Creek WRF
- Facility owner = South Coast Water District
- Purpose of facility = reuse (irrigation)
- Type of desalination technology = ultrafiltration/reverse osmosis
- Start year of RO operation = 2015
- Reason for RO facility as opposed to conventional treatment = TDS, nitrate, hardness,

TREATMENT CAPACITY

- RO Design production (mgd) = 0.65
- RO average production (mgd) = 0.50

TREATMENT PROCESS

- Source water = from the SCWD AWT facility (sand filter, chlorination) via their reservoir
- Raw water TDS (mg/l) = 1100-1500
- Pretreatment steps = sodium hypochlorite, UF, cartridge filter, sulfuric acid, antiscalant
- Feed pressure to RO (psi) = 165-230
- TDS of permeate (mg/l) = 800
- Membrane recovery (percent) = 85% for UF; 80% for RO
- Age of membrane at last replacement = on original membranes

BLENDING

- Blending = no

WASTE MANAGEMENT

- Concentrate disposal = to Coastal Treatment Plant ocean outfall
- Fate of cleaning wastewater = neutralized and send to WWTP

POST-TREATMENT

- Post-treatment of permeate = decarbonation (reduce CO₂ and increase pH); then pumped to AWT (Advanced Wastewater Treatment) system to reduce salinity
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Cal Pomona, CA

GENERAL

- Name of facility = Cal Pomona WTP
- Facility owner = Cal Pomona Department of Water Operations
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2017
- Reason for RO facility = for more sustainable water supply

TREATMENT CAPACITY

- RO Design production (mgd) = 0.41
- RO Average Production (mgd) =
- Plant Design production (mgd) =
- Plant average production (mgd) =

TREATMENT PROCESS

- Source = groundwater
- Raw water TDS (mg/l) = 800
- Feed pressure to RO (psi) = 120
- Pre-treatment steps = cartridge filters, antiscalant
- TDS of permeate (mg/l) =
- Membrane recovery (percent) = 75%
- Age of membrane at last replacement =

BLENDING

- Blending of permeate = yes
- Blend water source = bypass
- Blend ratio (permeate : other) = ~ 75 : 25
- TDS of blend =

WASTE MANAGEMENT

- Concentrate disposal = to brine line – LA sanitation
- Fate of cleaning wastewater =

POST-TREATMENT

- Post-treatment of permeate = chlorination, pH adjustment, CO₂ stripping
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Cambria Project, CA

GENERAL

- Name of facility = Cambria Emergency Water Supply Project
- Owner of facility = Cambria Community Services District (CCSD)
- Purpose of facility = emergency supply – drinking water
- Type of technology = UF/RO
- Start year of RO operation = 2014
- Reason for RO = emergency supply
- Current status = off line; system undergoing redesign considerations

TREATMENT CAPACITY

- RO Design production (mgd) = 0.58
- RO Average Production (mgd) =

TREATMENT PROCESS

- Source = groundwater
- Raw water TDS (mg/l) =
- Feed pressure (psi) =
- Pre-treatment steps =
- TDS of permeate (mg/l) =
- Membrane recovery (percent) =
- Age of membrane at last replacement =

BLENDING

- Blending = no

WASTE MANAGEMENT

- Concentrate disposal = to evaporation pond
- Fate of cleaning wastewater =

POST TREATMENT

- Post-treatment of permeate = advanced oxidation, disinfection, reinjection
- Post-treatment of concentrate =

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

City Of Oxnard, CA

GENERAL

- Name of facility = City of Oxnard Advanced Water Purification Facility (AWPF)
- Facility owner = City of Oxnard
- Purpose of facility = water reclamation
- Type of technology = reverse osmosis
- Start year of RO operation = 2015
- Reason for RO facility as opposed to conventional facility =

TREATMENT CAPACITY

- RO Design production (mgd) = 6.25
- RO Average Production (mgd) = production is based on demand; high flow average ~ 4;
low flow average ~ 1 - 2

TREATMENT PROCESS

- Source water = secondary effluent from WWTP
- Raw water TDS (mg/l) = varies between 2000-3500 $\mu\text{S}/\text{cm}$
- Feed pressure to RO (psi) = 190
- Pre-treatment steps = cartridge filter, microfiltration
- TDS of permeate (mg/l) =
- Membrane recovery (percent) = depends on demand; 85% at high flow
- Age of membrane at last replacement = on original membranes

BLENDING

- Blending = no

WASTE MANAGEMENT

- Concentrate disposal = to outfall
- Fate of cleaning wastewater =

POST-TREATMENT

- Post-treatment of permeate = UV, pH adjustment via decarbonation and lime
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Claude 'Bud' Lewis Carlsbad Desalination Plant, CA

GENERAL

- Name of facility = Claude 'Bud' Lewis Carlsbad Desalination Plant
- Facility owner = Poseidon Water
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2015
- Reason for RO facility as opposed to a conventional treatment facility = demand for drinking water

TREATMENT CAPACITY

- RO Design production (mgd) = 54
- RO average production (mgd) = 50

TREATMENT PROCESS

- Source water = seawater (used cooling water from power plant)
- Raw water TDS (mg/l) = 34,000
- Feed pressure (psi) =
- Pretreatment = multimedia filter, cartridge filters, microfiltration
- TDS of permeate (mg/l) =
- Membrane recovery (percent) = 50
- Age of membrane at last replacement = on original membranes

BLENDING

- Blending = no

WASTE MANAGEMENT

- Concentrate disposal = power plant outfall
- Fate of cleaning wastewater =
- Fate of backwash waste =

POST-TREATMENT

- Post treatment of permeate = stabilization, disinfection (chloramination), carbon dioxide and lime, fluoride
- Post-treatment of concentrate = blended with seawater leaving the power station

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

East Bay Mud Rare, CA

GENERAL

- Name of facility = RARE Water Plant
- Facility owner = East Bay Municipal Utility District
- Type of facility = water reclamation facility at Chevron refinery
- Type of technology = reverse osmosis
- Start year of RO operation = 2010
- Reason for treatment = for reuse – Chevron boilers

TREATMENT CAPACITY

- RO Design production (mgd) = 3.5
- RO Average Production (mgd) = 3.2

TREATMENT PROCESS

- Source water = secondary-treated wastewater from nearby West County Wastewater District
- Raw water TDS (mg/l) = 600-700
- Pretreatment = Amiad filters, MF, cartridge filters
- Feed pressure to RO (psi) = 150-200
- TDS of permeate (mg/l) =
- Membrane recovery (percent) = 85%
- Age of membrane at last replacement = about 5 years

BLENDING

- Blending of permeate = no

WASTE MANAGEMENT

- Concentrate disposal = to refinery WWTP; after primary treatment some goes to wetlands, some goes to outfall at San Pablo Bay
- Fate of membrane cleaning solutions = neutralization and discharged to sewer
- Fate of MF reject = discharged to sewer

POST-TREATMENT

- Post-treatment of permeate = sent to Chevron for reuse in boilers
- Post-treatment of concentrate = sent to refinery WWTP

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Irvine Ranch Wells 21/22 Desalter, CA

GENERAL

- Name of facility = Wells 21/22 Desalter
- Facility owner = Irvine Ranch Water District
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2013
- Reason for RO facility as opposed to a conventional treatment facility = TDS, nitrate

TREATMENT CAPACITY

- RO Design production (mgd) = 1.44
- RO average production (mgd) = 0.29
- Plant (RO + blend) production (mgd) =
- Plant average production (mgd) =

TREATMENT PROCESS

- Source water = groundwater
- Raw water TDS (mg/l) = 790-820
- Feed pressure to RO (psi) = 145-175 (depends on wells used)
- Pretreatment = antiscalant, cartridge filter
- TDS of permeate ($\mu\text{S}/\text{cm}$) = permeate usually ~ 300-350
- Membrane recovery (percent) = 85%
- Age of membrane at last replacement = original membranes

BLENDING

- Blending = yes
- Bending source = raw water bypass
- Blend ratio (permeate : other) = currently 77 : 23
- TDS of blend (mg/l) =

WASTE MANAGEMENT

- Concentrate disposal = pipeline to OCSD WWTP
- Fate of cleaning wastewater = same

POST-TREATMENT

- Post treatment of permeate = chloramination, caustic for pH adjustment
- Post-treatment of concentrate = none

Municipal Desalination Facility Survey
Appendix B. Individual Facility Information

Irwin Water Works, CA

GENERAL

- Name of facility = Irwin Water Works
- Facility owner = Fort Irwin
- Type of facility = drinking water
- Type of technology = primarily EDR; concentrate (in water recovery operation) is then lime softened followed by MF, RO, IX, and MVC evaporation; product water from water recovery is recycled to front of EDR
- Type of operation = EDR is either batch or continuous; water recovery is generally batch
- Start year of EDR operation = 2016
- Reason for system as opposed to a conventional water treatment facility = highly variable volume flow; nitrate, silica, TDS; removal of fluoride and arsenic (in presence of silica and TDS)

TREATMENT CAPACITY

- Plant design production (mgd) = 6.0
- Plant design average production (mgd) = 1.9-2.0

TREATMENT PROCESS

- Source water = groundwater
- Raw water TDS (mg/l) = 720
- Pre-treatment steps = chlorination at well or raw water booster stations, cartridge filters before EDR; degasification, strainer prior to MF/RO; IX before evaporator
- TDS of permeate (mg/l) = 100
- System water recovery (percent) = ~92% from EDR; ~99+% overall
- Age of membrane at last replacement = EDR membrane not replaced; 3rd stage RO replaced last year (after ~ 18 months)

BLENDING

- Blending = not currently used

WASTE MANAGEMENT

- Concentrate disposal = evaporation pond
- Fate of cleaning, backwash wastes, and other process wastes = evaporation ponds

POST TREATMENT

- Post treatment of permeate = additional CO₂ and lime for stabilization, hypochlorite for disinfection
- Post-treatment of concentrate = lime softening followed by MF, RO, IX, MVC evaporation

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Mesa WRF, CA

GENERAL

- Name of facility = Mesa WRF
- Facility owner = Mesa Water District
- Purpose of facility = drinking water
- Type of technology = nanofiltration
- Start year of NF operation = 2012
- Reason for NF facility = remove color

TREATMENT CAPACITY

- NF Design production (mgd) = 8.6
- RO or NF Average Production (mgd) =

TREATMENT PROCESS

- Source water = groundwater
- Raw water TDS (mg/l) = 390-460
- Feed pressure (psi) =
- Pre-treatment steps = sand filter, antiscalant, cartridge filter
- TDS of permeate (mg/l) = 330-410
- Membrane recovery (percent) = 98%
- Age of membrane at last replacement = on original membranes

BLENDING

- Blending = no

WASTE MANAGEMENT

- Concentrate disposal = to sanitary sewer; some concentrate is recycled
- Fate of cleaning wastewater = to sewer

POST-TREATMENT

- Post treatment of permeate = pH adjustment, air stripping, pH adjustment again, chloramination
- Post-treatment of concentrate = antifoam agent

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Round Mountain WTP, CA

GENERAL

- Name of facility = Round Mountain WTP
- Facility owner = Camrosa Water District
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2014
- Reason for RO facility = TDS, increased water demand, reduces import need

TREATMENT CAPACITY

- RO Design production (mgd) = 1
- RO Average Production (mgd) = close to 1
- Plant (RO + blend) design production (mgd) =
- Plant average production (mgd) =

TREATMENT PROCESS

- Source = ground water
- Feed water TDS (mg/l) = 1200
- Feed pressure to RO (psi) = 125-150
- Pre-treatment steps = iron-manganese oxidation (chlorine); dichlorination (bisulfate); antiscalant; cartridge filter
- TDS of permeate (mg/l) =
- Membrane recovery (percent) = 75
- Age of membrane at last replacement = had membranes replaced under warranty during startup due to start-up issues

BLENDING

- Blending = yes
- Blend water source = bypass
- Blend ratio (permeate : other) = about 600 gpm : 85 gpm
- TDS of blend =

WASTE MANAGEMENT

- Concentrate disposal = discharge to SMP pipeline going to outfall
- Fate of cleaning wastewater = neutralization prior to sewer disposal

POST-TREATMENT

- Post treatment of permeate = blend; pH adjustment (caustic); chlor-amination
- Post treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Santa Monica W TX Works, CA

GENERAL

- Facility name = Santa Monica Arcadia Water Treatment Plant
- Facility owner = City of Santa Monica
- Purpose of facility = Drinking Water
- Type of desalination technology = reverse osmosis
- Start year of RO operation = 2011
- Reason for RO facility as opposed to a conventional water treatment facility = TDS

TREATMENT CAPACITY

- RO Design production (mgd) = 10
- RO Average Production (mgd) = 6.9
- Plant Design (RO + blend) production (mgd) =
- Plant average production (mgd) =

TREATMENT PROCESS

- Source water = groundwater
- Raw water TDS (mg/l) = 500
- Pre-treatment steps = greensand filter, GAC, cartridge filters, antiscalant
- Feed pressure (psi) = 90
- Conductivity of permeate ($\mu\text{S}/\text{cm}$) = 200 $\mu\text{S}/\text{cm}$ MAX.
- Membrane recovery (percent) = 82%
- Age of membrane at last replacement = Approximately 6 years

BLENDING

- Blending = Yes
- Blend water source = bypass after same filtering process
- Blend ratio (permeate : other) = 80 : 20
- Conductivity of blend = Approximately 400 $\mu\text{S}/\text{cm}$

WASTE MANAGEMENT

- Concentrate disposal = sewer
- Fate of cleaning solution waste = sewer
- Fate of backwash wastes = sewer

POST-TREATMENT

- Post treatment of permeate = blended, air stripper, caustic, fluoride, chloramination
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Signal Hill, CA

GENERAL

- Name of Facility = Signal Hill WTP
- Facility owner = City of Signal Hill
- Purpose of facility = drinking water
- Type of technology = nanofiltration
- Start year of NF operation = 2017
- Reason for NF treatment as opposed to conventional treatment = color

TREATMENT CAPACITY

- NF Design production (mgd) = 1.8
- NF Average Production (mgd) = 0.9 (running 1 of 2 skids)

TREATMENT PROCESS

- Source water = groundwater
- Raw water TDS (mg/l) =
- Feed pressure into NF (psi) = 77
- Pretreatment = 25 micron filter
- TDS of permeate (mg/l) =
- Membrane recovery (percent) = 98
- Age of membrane at last replacement = have original membrane

BLENDING

- Blending = no

WASTE MANAGEMENT

- Concentrate disposal = sanitary sewer
- Fate of cleaning wastewater = sewer

POST-TREATMENT

- Treatment of concentrate = none
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Wochholz Regional WRF, CA

GENERAL

- Name of facility = Wochholz Regional WRF
- Facility owner = Yucaipa Valley Water District
- Purpose of facility = WRF - reuse
- Type of technology = MF/reverse osmosis
- Start year of RO operation = 2017
- Reason for RO facility as opposed to a conventional treatment facility = for reuse (landscape irrigation)

TREATMENT CAPACITY

- RO Design production (mgd) = 2
- RO average production (mgd) = 2
- Plant Design production (mgd) = 8
- Plant Average Production (mgd) = 4

TREATMENT PROCESS

- Source water = groundwater
- Raw water TDS (mg/l) = depends; currently on well water
- Feed pressure to RO (psi) = 80
- Pretreatment = antiscalant, cartridge filters, sulfuric acid,
- TDS of permeate (mg/l) = no target currently
- Membrane recovery (percent) = 80
- Age of membrane at last replacement =

BLENDING

- Blending = yes
- Blend water source = same, bypass goes through MF
- Blend ratio (permeate : other) = 50 : 50
- TDS of blend = no target currently

WASTE MANAGEMENT

- Concentrate disposal = surface water via brine line
- Fate of cleaning wastewater = recirculate back to front of process

POST-TREATMENT

- Post treatment of permeate = blend, UV
- Post-treatment of concentrate = none

Municipal Desalination Facility Survey
Appendix B. Individual Facility Information

Arapahoe County Joint Water Purification Plant, CO

GENERAL

- Name of facility = Arapahoe County Joint Water Purification Plant (JWPP)
- Facility owner =
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2010
- Reason for the RO facility as opposed to a conventional treatment facility =
- Operational status = RO plant ran about 1 year; shut down due to selenium violation; will implement a biological Sn removal in 2019; currently running only an MF facility

TREATMENT CAPACITY

- RO Design production (mgd) = 9
- RO Average Production (mgd) =
- Plant (RO + blend) design production (mgd) =
- Plant average production (mgd) =

TREATMENT PROCESS

- Source water = groundwater
- Raw water TDS (mg/l) =
- Feed pressure (psi) =
- Pretreatment steps =
- TDS of permeate (mg/l) =
- Membrane recovery (percent) =
- Age of membrane at last replacement =

BLENDING

- Blending = yes
- Blend water source = MF permeate
- Blend ratio (RO permeate : other) = 50 : 50
- TDS of blend =

WASTE MANAGEMENT

- Concentrate disposal = discharge to surface water
- Fate of cleaning wastewater =

POST-TREATMENT

- Post-treatment of permeate =
- Post-treatment of concentrate =

Municipal Desalination Facility Survey
Appendix B. Individual Facility Information

Northern WTP, CO

GENERAL

- Facility name = Northern WTP
- Facility owner = East Cherry Creek Village
- Purpose of facility = drinking water
- Type of desalination technology = reverse osmosis
- Start year of RO operation = 2012
- Reason for RO facility as opposed to conventional treatment = TDS, hardness

TREATMENT CAPACITY

- RO Design production (mgd) = 7
- RO average production (mgd) = 6.5
- Plant design production (mgd) = 11
- Plant average production (mgd) = 7.7

TREATMENT PROCESS

- Source water = groundwater
- Raw water TDS (mg/l) = 900 - 1100
- Feed pressure to RO (psi) = 140-170
- Pretreatment steps = cartridge filtration, antiscalant
- TDS of permeate (mg/l) =
- Membrane recovery (percent) = 75%
- Age of membrane at last replacement = low pressure membranes are original; one replacement on one high pressure skid

BLENDING

- Blending = yes
- Blend Water source = bypass (UV treated)
- Blend ratio (permeate : other) = 70:30
- TDS of blend = 250 - 300

WASTE MANAGEMENT

- Concentrate disposal = deep well injection
- Fate of cleaning wastewater =

POST-TREATMENT

- Post-treatment of permeate = disinfection (sodium hypochlorite) pH adjustment (caustic)
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Sterling, CO

GENERAL

- Facility name = City of Sterling WTF
- Facility owner = City of Sterling
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2013
- Reason for treatment = TDS, uranium, hardness

TREATMENT CAPACITY

- RO Design production (mgd) = 9.6
- RO Average Production (mgd) = 4
- Plant Design production (mgd) =
- Plant average production (mgd) =

TREATMENT PROCESS

- Source water = groundwater
- Raw water conductivity ($\mu\text{S}/\text{cm}$) = 700 – 1900
- Feed pressure to RO (psi) = 112-130
- Pretreatment = 25 micron filter, antiscalant
- TDS of permeate (mg/l) =
- Membrane recovery (percent) = 82%
- Age of membrane at last replacement =

BLENDING

- Blending = yes
- Blend water source = groundwater, same wells except for one that only goes to the RO; filtered at 1 micron
- Blend ratio = 80 : 20
- TDS of blend =

WASTE MANAGEMENT

- Concentrate disposal = deep well injection; portion to sewer
- Fate of cleaning wastewater =

POST-TREATMENT

- Post-treatment of permeate = bioscrub to remove odor, stabilization, disinfection, pH adjustment
- Post-treatment of concentrate = 25 μ screen, antiscalant

Municipal Desalination Facility Survey
Appendix B. Individual Facility Information

Babcock Ranch Water, FL

GENERAL

- Name of facility = Babcock Ranch Water
- Facility owner = BRW Utilities
- Purpose of facility = drinking water
- Type of technology = nanofiltration
- Start year of NF operation = 2017
- Reason for NF facility as opposed to a conventional treatment facility = hardness, color

TREATMENT CAPACITY

- NF Design production (mgd) = 0.25
- NF average production (mgd) =
- Plant Design production (mgd) =
- Plant Average Production (mgd) =

TREATMENT PROCESS

- Source water = groundwater
- Raw water conductivity ($\mu\text{S}/\text{cm}$) = 800-950
- Feed pressure (psi) = 108-117
- Pretreatment = antiscalant, cartridge filters, sulfuric acid,
- TDS of permeate (mg/l) = 200-250, depends on wells
- Membrane recovery (percent) = 84%
- Age of membrane at last replacement = had to replace original membrane due to super chlorination incident at start-up

BLENDING

- Blending = yes
- Blend water source = raw water bypass
- Blend ratio (permeate : other) = ~ 8 : 1
- Target TDS of blend =

WASTE MANAGEMENT

- Concentrate disposal = combined with effluent from WWTP; goes to pond, used for irrigation
- Fate of cleaning wastewater = same; haven't cleaned yet

POST-TREATMENT

- Post treatment of permeate = blending, degasification, disinfection, caustic, CO₂
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

City of Deerfield Beach, FL

GENERAL

- Facility name = City of Deerfield Beach West WTP
- Facility owner = City of Deerfield Beach
- Purpose of facility = drinking water
- Type of desalination technology = NF and reverse osmosis
- Start year of RO operation = 2012 (for RO)
- Reason for RO facility as opposed to conventional treatment =

TREATMENT CAPACITY

- RO Design production (mgd) = 3
- RO average production (mgd) =
- Plant design (RO + NF) production (mgd) = 14.5 (RO = 3, NF = 11.5)
- Plant average production (mgd) =

TREATMENT PROCESS

- Source water = groundwater and NF concentrate (up to 30%)
- Raw water conductivity ($\mu\text{S}/\text{cm}$) = 1800-2000
- Feed pressure to RO (psi) = 186-210 (high level where less NF concentrate in feed)
- Pretreatment steps = acid, antiscalant, cartridge filter (5 μ)
- TDS of permeate (mg/l) =
- Membrane recovery (percent) = 78%
- Age of membrane at last replacement = no replacement yet on RO

BLENDING

- Blending of permeate = no bypass blending; blend with NF permeate
- Blend Water source = NF permeate
- Blend ratio (permeate : other) = 3 : 11.5
- TDS of blend =

WASTE MANAGEMENT

- Concentrate disposal = deep well injection
- Fate of cleaning waste = sanitary sewer

POST-TREATMENT

- Post-treatment of RO permeate = orthophosphate, caustic, chlorine
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

City of Labelle, FL

GENERAL

- Name of facility = City of Labelle WTP
- Facility owner = City of Labelle
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2014
- Reason for RO facility as opposed to conventional treatment = previously out of compliance with THMs, etc.; new source water requires TDS removal

TREATMENT CAPACITY

- RO Design production (mgd) = 1.5
- RO Average Production (mgd) = 0.75
- Plant (RO + blend) Design production (mgd) = 1.68
- Plant average production (mgd) =

TREATMENT PROCESS

- Source water = groundwater
- Raw water conductivity ($\mu\text{S}/\text{cm}$) = depends on which of 2 wells used; 3400 & 4300
- Pretreatment steps = antiscalant, cartridge filters
- Feed pressure (psi) = 150-160
- TDS of permeate (mg/l) = <100
- Membrane recovery (percent) = 70%
- Age of membrane at last replacement = on original membranes

BLENDING

- Blending = yes
- Blend water source = raw water
- Blend ratio (permeate : other) = 10-12%
- Conductivity of blend = 700 $\mu\text{S}/\text{cm}$

WASTE MANAGEMENT

- Concentrate disposal = deep well injection
- Fate of cleaning wastewater =

POST-TREATMENT

- Post-treatment of permeate = degasification (for H₂S), chlorine, fluoride
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Clearwater RO Plant #2, FL

GENERAL

- Name of facility = RO Plant #2
- Facility owner = City of Clearwater
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2015
- Reason for RO facility as opposed to a conventional treatment facility = TDS, iron, hardness

TREATMENT CAPACITY

- RO Design production (mgd) = 6.25
- RO average production (mgd) = 2.5 (original design flaw led to serious scaling early on; now operating 1 skid; in a redesign phase – RFQs)
- Plant Design production (mgd) =
- Plant Average Production (mgd) =

TREATMENT PROCESS

- Source water = groundwater
- Raw water TDS (mg/l) = 2800-4500 (dependent on well mix)
- Feed pressure (psi) = 180-190
- Pretreatment = antiscalant, cartridge filters
- TDS of permeate (mg/l) =
- Membrane recovery (percent) = 80
- Age of membrane at last replacement = design flaw led to scaling issue early on with damage to some membranes; still using original membranes on operating skid

BLENDING

- Blending = yes
- Blend water source = surficial aquifer
- Blend ratio (permeate : other) =
- TDS of blend =

WASTE MANAGEMENT

- Concentrate disposal = deep well injection
- Fate of cleaning wastewater = sanitary sewer

POST-TREATMENT

- Post treatment of permeate = ozone (sulfide removal), chloramination, caustic
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Coral Springs, FL

GENERAL

- Name of Facility = Coral Springs RO WTP
- Facility owner = Coral Springs Improvement District
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2016
- Reason for RO facility as opposed to conventional treatment = better water quality

TREATMENT CAPACITY

- RO Design production (mgd) = 6.75
- RO Average Production (mgd) = ~4
- Plant Design production (mgd) =
- Plant average production (mgd) =

TREATMENT PROCESS

- Source water = groundwater
- Raw water TDS (mg/l) = 600-700
- Feed pressure to RO (psi) = 93-105
- Pretreatment = sand strainer, cartridge filter, antiscalant
- TDS of permeate (mg/l) = 20-45
- Membrane recovery (percent) = 85%
- Age of membrane at last replacement = on original membranes

BLENDING

- Blending = yes
- Blend water source = raw water bypass after sand strainer and cartridge filters
- Blend ratio (permeate : other) = 85-92 : 8-15
- TDS of blend = 140

WASTE MANAGEMENT

- Concentrate disposal = to tail end of WWTP for deep well injection
- Fate of cleaning wastewater = same; just did first cleaning

POST-TREATMENT

- Post-treatment of permeate =
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Dania Beach, WTP FL

GENERAL

- Name of facility = Dania Beach WTP
- Facility owner = City of Dania Beach
- Purpose of facility = drinking water
- Type of technology = nanofiltration
- Start year of NF operation = 2012
- Reason for NF facility as opposed to a conventional treatment facility = iron removal, softening

TREATMENT CAPACITY

- NF Design production (mgd) = 2.0
- NF Average Production (mgd) = 1.0
- Plant Design (NF + blend) production (mgd) = 5
- Plant average production (mgd) = 2.2

TREATMENT PROCESS

- Source water = purchased from Broward County Large User System
- Raw water TDS (mg/l) = 400
- Pretreatment steps = sulfuric acid 93%, antiscalant
- Feed pressure (psi) = 42
- TDS of permeate (mg/l) = 50-60
- Membrane recovery (percent) = 90%
- Age of membrane at last replacement = on original elements; cleaning cycle is 18-24 months

BLENDING

- Blending = yes
- Blend water source = bypass
- Blend ratio (permeate : other) = 2 : 3
- TDS of blend = 130-150

WASTE MANAGEMENT

- Concentrate disposal = sanitary sewer
- Fate of cleaning wastewater =

POST-TREATMENT

- Post-treatment of permeate =
- Post-treatment of concentrate =

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Green Meadows, Fl

GENERAL

- Name of facility = Green Meadows WTP
- Facility owner = Lee County Utilities
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of NF operation = 2018
- Reason for treatment = Plant expansion & replacement of old existing facility

TREATMENT CAPACITY

- RO Design production (mgd) = 7.5
- RO Average Production (mgd) = New plant, not on line yet.
- Plant Design (RO + blend) production (mgd) This will vary, blending will be with IX and RO treated water.
- Plant average production (mgd) = New plant, not on line yet.

TREATMENT PROCESS

- Source water = groundwater
- Raw water TDS (mg/l) = 1860
- Feed pressure (psi)? 167
- Pretreatment = sand filter, cartridge filter, antiscalant, acid
- Target TDS of permeate (mg/l) 35.8
- Membrane recovery (percent) 85%
- Age of membrane at last replacement = New plant

BLENDING

- Blending = yes
- Blend water source = bypass and IX treated surficial water
- Blend ratio (permeate : other) = roughly 9 : 6
- Target TDS of blend? 223 mg/l

WASTE MANAGEMENT

- Concentrate disposal = deep well injection
- Fate of cleaning waste = deep well injection
- Fate of backwash waste Deep Injection Well

POST-TREATMENT

- Post-treatment of permeate – Sulfuric acid, degasification, disinfection (chlorine & ammonia) pH control (caustic soda), fluoride, and corrosion inhibitor
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Hialeah RO WTP, FL

GENERAL

- Name of facility = Hialeah RO WTP
- Facility owner = City of Hialeah
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2013
- Reason for RO facility as opposed to conventional treatment =

TREATMENT CAPACITY

- RO Design production (mgd) = 7.5
- RO Average Production (mgd) =

TREATMENT PROCESS

- Source water = groundwater
- Raw water conductivity ($\mu\text{S}/\text{cm}$) = 5000-5500
- Feed pressure to RO (psi) = 180-194
- Pretreatment = acid, antiscalant, cartridge filters
- TDS of permeate (mg/l) =
- Membrane recovery (percent) = 80%
- Age of membrane at last replacement = still have original membranes

BLENDING

- Blending of permeate = no

WASTE MANAGEMENT

- Concentrate disposal = deep well injection
- Fate of cleaning waste = deep well injection

POST-TREATMENT

- Post-treatment of permeate = lime, caustic, chlorine
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Hood Road Membrane Water Plant – NF, FL

GENERAL

- Facility name = Hood Road Membrane Water Plant
- Facility owner = Seacoast Water Authority
- Purpose of facility = drinking water
- Type of desalination technology = nanofiltration
- Start year of NF operation = 2015
- Reason for NF facility as opposed to conventional treatment = replace lime softening (an RO facility also opened at the same location)

TREATMENT CAPACITY

- NF Design production (mgd) = 26
- NF average production (mgd) = varies with demand; at higher demand, NF portion is greater; 17.5
- Plant design production (mgd) = 29.5 (3.5 RO and 26 NF)
- Plant average production (mgd) = varies with demand

TREATMENT PROCESS

- Source water = surficial groundwater
- Raw water conductivity ($\mu\text{S}/\text{cm}$) = 800
- Feed pressure to NF (psi) = 95
- Pretreatment steps = sand filter, antiscalant, cartridge filters, acid (sulfuric)
- Conductivity permeate ($\mu\text{S}/\text{cm}$) = 350
- Membrane recovery (percent) = 80%
- Age of membrane at last replacement = on original membranes

BLENDING

- Blending = no raw water blend

WASTE MANAGEMENT

- Concentrate disposal = irrigation (blended with WWTP effluent); when not possible, disposal is to deep well injection
- Fate of cleaning and backwash waste = sewer

POST-TREATMENT

- Post-treatment of permeate = degassing, disinfection (chloramination), pH adjustment (caustic), corrosion inhibitor (phosphate)
- Post-treatment of concentrate = blend with WWTP effluent

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Hood Road Membrane Water Plant – RO, FL

GENERAL

- Facility name = Hood Road Membrane Water Plant
- Facility owner = Seacoast Water Authority
- Purpose of facility = drinking water
- Type of desalination technology reverse osmosis
- Start year of RO operation = 2015
- Reason for RO facility as opposed to conventional treatment = replace lime softening (an NF facility also opened at the same location)

TREATMENT CAPACITY

- RO Design production (mgd) = 3.5
- RO average production (mgd) = 2.5
- Plant (RO + NF) design production (mgd) = 29.5 (3.5 RO + 26 NF)
- Plant average production (mgd) = varies with demand

TREATMENT PROCESS

- Source water = groundwater
- Raw water conductivity ($\mu\text{S}/\text{cm}$) = 6000
- Feed pressure to RO (psi) = 240
- Pretreatment steps = antiscalant, cartridge filter, acid (sulfuric)
- TDS of permeate (mg/l) =
- Membrane recovery (percent) = 75%
- Age of membrane at last replacement = on original membranes

BLENDING

- Blending = no raw water blend

WASTE MANAGEMENT

- Concentrate disposal = deep well injection
- Fate of cleaning and backwash waste = sewer

POST-TREATMENT

- Post-treatment of permeate = degasification, disinfection (chloramination), pH adjustment (caustic), corrosion inhibitor (phosphate)
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Lake Worth, FL

GENERAL

- Facility name = City of Lake Worth RO Plant
- Facility owner = City of Lake Worth
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2011
- Reason for treatment = TDS, uranium; preparing for the future; need new source of water

TREATMENT CAPACITY

- RO Design production (mgd) = 4.5
- RO average production (mgd) = 2.7 (for 2017)
- Plant design capacity (mgd) = 17.4 (4.5 for RO; 12.9 for lime softening)
- Plant average production (mgd) = ~ 5.5

TREATMENT PROCESS

- Source water = groundwater
- Raw water TDS = 3000-4000 mg/l
- Feed pressure to RO (psi): stage one = 200; stage 2 = 230
- Pretreatment = cartridge filter; sulfuric acid, antiscalant
- **TDS of permeate (mg/l) =**
- Membrane recovery (percent) = 75%
- Age of membrane at last replacement = still on membranes installed in 2011

BLENDING

- Blending = yes
- Blend water source = lime softened water
- Blend ratio (permeate : other) = currently about 2.5 mgd : 3.0 mgd
- **TDS of blend =**

WASTE MANAGEMENT

- Concentrate disposal = deep well injection; backup is sewer
- **Fate of cleaning and backwash waste =**

POST-TREATMENT

- Post-treatment of permeate = aeration to remove H₂S; chlorine and ammonia for disinfection
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

North Cape Coral, RO WTP FL

GENERAL

- Facility name = North Cape Coral RO WTP
- Facility owner = City of Cape Coral
- Purpose of facility = drinking water
- Type of desalination technology = reverse osmosis
- Start year of RO operation = 2010
- Reason for RO facility as opposed to conventional treatment = TDS

TREATMENT CAPACITY

- RO Design production (mgd) = 12
- RO average production (mgd) =
- Plant design (RO + blend) production (mgd) =
- Plant average production (mgd) = 8.5

TREATMENT PROCESS

- Source water = groundwater
- Raw water TDS (mg/l) = 2700
- Feed pressure to RO (psi) = 160
- Pretreatment steps = sulfuric acid, scale inhibitor, cartridge filters
- TDS of permeate (mg/l) = 100-118
- Membrane recovery (percent) = 80%
- Age of membrane at last replacement = on original membranes

BLENDING

- Blending = yes
- Blend Water source = same source, raw water
- Blend ratio (permeate : other) = 15-25% other
- TDS of blend =

WASTE MANAGEMENT

- Concentrate disposal = deep well injection
- Fate of cleaning = neutralize, then deep well

POST-TREATMENT

- Post-treatment of permeate = blend, degasification (for H₂S removal), chlorine (disinfection and residual H₂S removal), caustic (pH adjustment)
- Post-treatment of concentrate = neutralize

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

North WTP – South Martin Regional District, FL

GENERAL

- Name of facility = North WTP
- Facility owner = South Martin Regional District
- Purpose of facility = drinking water
- Type of technology = nanofiltration
- Start year of NF operation = 2012
- Reason for NF facility as opposed to conventional treatment = hardness and color removal

TREATMENT CAPACITY

- NF Design production (mgd) = 0.41
- NF Average Production (mgd) =
- Plant Design (NF + blend) production (mgd) =
- Plant average production (mgd) =

TREATMENT PROCESS

- Source water = groundwater
- Raw water TDS (mg/l) =
- Feed pressure to NF (psi) =
- Pretreatment steps =
- TDS of permeate (mg/l) =
- Membrane recovery (percent) =
- Age of membrane at last replacement =

BLENDING

- Blending = yes
- Blend water source = bypass (chemically dosed raw water)
- Blend ratio (permeate : other) =
- TDS of blend =

WASTE MANAGEMENT

- Concentrate disposal = sanitary sewer
- Fate of cleaning wastewater =

POST-TREATMENT

- Post-treatment of permeate =
- Post-treatment of concentrate =

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

NSID RO WTP, FL

GENERAL

- Name of facility = NSID NF WTP
- Facility Owner =
- Purpose of facility = drinking water
- Type of technology = nanofiltration
- Start year of NF operation = 2016
- Reason for NF facility as opposed to a conventional treatment plant treatment = color, taste, TOC, H₂S

TREATMENT CAPACITY

- NF Design production (mgd) = 6.57
- NF Average Production (mgd) =
- Plant (NF + blend) Design production (mgd) =
- Plant average production (mgd) =

TREATMENT PROCESS

- Source water = groundwater
- Raw water TDS (mg/l) =
- Feed pressure (psi) =
- Pretreatment = strainer, cartridge filters, sulfuric acid, scale inhibitor
- TDS (mg/l) or conductivity (μ S/cm) of permeate =
- Membrane recovery (percent) =
- Age of membrane at last replacement =

BLENDING

- Blending = yes
- Blend water source = same source after cartridge filtration
- Blend ratio (permeate : other) = bypass is 5 to 20 % of the final product
- TDS (mg/l) of blend =

WASTE MANAGEMENT

- Concentrate disposal = to river
- Fate of cleaning wastewater =

POST-TREATMENT

- Post-treatment of permeate = sulfuric acid, degasification (for H₂S), disinfection (sodium hypochlorite), stability (NaOH), corrosion inhibitor, ammonium sulfide to form chloramine
- Post-treatment of concentrate =

Municipal Desalination Facility Survey
Appendix B. Individual Facility Information

Oldsmar RO WTP, FL

GENERAL

- Name of facility = Oldsmar RO WTP
- Facility owner = City of Oldsmar
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2012
- Reason for RO facility as opposed to a conventional facility = TDS reduction

TREATMENT CAPACITY

- RO Design production (mgd) = 3.0 design, 2.0 permitted
- RO Average Production (mgd) = 1
- Plant (RO + blend) Design production (mgd) = 3.3
- Plant average production (mgd) = 1.3

TREATMENT PROCESS

- Source water = groundwater
- Raw water conductivity ($\mu\text{S}/\text{cm}$) = 2800 - 3500
- Pretreatment = cartridge filter, antiscalant
- Feed pressure to RO (psi) = 135-145
- TDS of permeate (mg/l) = 75 - 100
- Membrane recovery (percent) = 75%
- Age of membrane at last replacement = on original membranes

BLENDING

- Blending = yes
- Blend water source = conventional plant product
- Blend ratio (permeate : other) = 90 : 10
- TDS of blend = 350-375

WASTE MANAGEMENT

- Concentrate disposal = deep well injection
- Fate of cleaning wastewater = neutralization, sent to sewer

POST-TREATMENT

- Post-treatment of permeate = degasification, CO₂/caustic, chlorine fluoride, corrosion inhibitor
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Springtree WTP, FL

GENERAL

- Name of facility = Springtree Sunrise WTP
- Facility owner = City of Springtree
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2012
- Reason for RO facility as opposed to a conventional WTP = TDS

TREATMENT CAPACITY

- RO Design production (mgd) = 1.5
- RO Average Production (mgd) = plant is not in production every day; when in operation the average is close to design; 2017 average was 0.389 mgd
- Plant (RO + blend) Design production (mgd) = RO = 1.5; lime treatment plant = 24; total = 25.5
- Plant average production (mgd) = 2017 average was 10.06 mgd

TREATMENT PROCESS

- Source water = groundwater
- Raw water TDS (mg/l) = 1605
- Feed pressure to RO (psi) = ~160
- Pretreatment steps = antiscalant, cartridge filters
- TDS of permeate (mg/l) = 55
- Membrane recovery (percent) = 75
- Age of membrane at last replacement = on original membranes

BLENDING

- Blending = yes
- Blend water source = lime softened raw water (shallower aquifer)
- Blend ratio (permeate : other) = 1.5 : 11
- TDS of blend = ~ 70

WASTE MANAGEMENT

- Concentrate disposal = deep well injection
- Fate of cleaning waste water =

POST-TREATMENT

- Post-treatment of permeate = degasification, chloramination, fluoride
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Tarpon Springs RO Facility, FL

GENERAL

- Name of facility = Tarpon Springs RO Facility
- Facility owner = City of Tarpon Springs
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2015
- Reason for RO facility as opposed to conventional treatment = TDS

TREATMENT CAPACITY

- RO Design production (mgd) = 6.4
- RO Average Production (mgd) = 2.5
- Plant design production (mgd) =
- Plant average production (mgd) = ~2.5

TREATMENT PROCESS

- Source water = groundwater
- Raw water conductivity ($\mu\text{S}/\text{cm}$) = 18,000-20,000
- Feed pressure to RO (psi) = first stage = 350; second stage = 450
- Pretreatment = acid, antiscalant, cartridge filters
- Conductivity of permeate ($\mu\text{S}/\text{cm}$) = 297
- Membrane recovery (percent) = ~72%
- Age of membrane at last replacement = on original membranes

BLENDING

- Blending = yes
- Blend Water source = bypass
- Blend ratio (permeate : other) = presently, only 5 gpm
- TDS of blend =

WASTE MANAGEMENT

- Concentrate disposal = deep well injection
- Fate of cleaning waste = deep well; haven't cleaned yet

POST-TREATMENT

- Post-treatment of permeate = pH adjustment (CO_2), Alkalinity and hardness (lime and caustic), disinfectant (hypochlorite), fluoride
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Town of Davie WTP/WRF, FL

GENERAL

- Facility Name = Town of Davie RO WTP
- Facility owner = Town of Davie
- Purpose of facility = drinking water
- Type of desalination technology = reverse osmosis
- Start year of RO operation = 2013
- Reason for RO facility as opposed to conventional treatment = no new permits for surficial aquifer

TREATMENT CAPACITY

- RO Design production (mgd) = 6.0
- RO average production (mgd) = 2.6

TREATMENT PROCESS

- Source water = groundwater
- Raw water conductivity ($\mu\text{S}/\text{cm}$) = 7000-9000
- Feed pressure to RO (psi) = 230
- Pretreatment steps = cartridge filter, antiscalant
- TDS of permeate (mg/l) = 300-450
- Membrane recovery (percent) = 80%
- Age of membrane at last replacement = still has original membranes

BLENDING

- Blending = no

WASTE MANAGEMENT

- Concentrate disposal = deep well injection
- Fate of cleaning and backwash waste = haven't cleaned yet; it will go to deep well

POST-TREATMENT

- Post-treatment of permeate = aerated, disinfected (sodium hypochlorite), fluoridated.
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

East Putnam County WTP, FL

GENERAL

- Name of facility = East Putnam County WTP
- Facility owner = East Putnam County
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2010
- Reason for RO facility as opposed to a conventional treatment facility = needed alternative source

TREATMENT CAPACITY

- RO Design production (mgd) = 1
- RO average production (mgd) = 0.225
- Plant (RO + blend) design production (mgd) =
- Plant average Production (mgd) =

TREATMENT PROCESS

- Source water = groundwater
- Raw water TDS (mg/l) = 800
- Feed pressure (psi) =
- Pretreatment = antiscalant, cartridge filters, sulfuric acid,
- TDS of permeate (mg/l) = 25
- Membrane recovery (percent) = 80
- Age of membrane at last replacement = 9 years (just replaces)

BLENDING

- Blending = yes
- Blend water source = bypass
- Blend ratio (permeate : other) = ~ 2.4 : 1
- TDS of blend = 250

WASTE MANAGEMENT

- Concentrate disposal = surface water (St. Johns River)
- Fate of cleaning wastewater = sewer

POST-TREATMENT

- Post treatment of permeate = degasification, sodium hypochlorite, fluoride
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Kings Bay Naval Base WTP, GA

GENERAL

- Name of facility = Kings Bay Naval Base WTP
- Facility owner = Kings Bay Naval Base
- Purpose of facility = drinking water
- Type of technology = nanofiltration
- Start year of RO operation = 2011
- Reason for RO facility as opposed to a conventional treatment facility =

TREATMENT CAPACITY

- RO design production (mgd) = 2.0
- RO average production (mgd) =

TREATMENT PROCESS

- Source water =
- Raw water TDS (mg/l) =
- Feed pressure (psi) =
- Pretreatment = acid, antiscalant
- TDS of permeate (mg/l) =
- Membrane recovery (percent) =
- Age of membrane at last replacement =

BLENDING

- Blending =
- Blending source =
- Blend ratio (permeate : other) =
- TDS of blend (mg/l) =

WASTE MANAGEMENT

- Concentrate disposal = sewer
- Fate of cleaning wastewater =

POST-TREATMENT

- Post treatment of permeate =
- Post-treatment of concentrate =

Municipal Desalination Facility Survey
Appendix B. Individual Facility Information

Brimfield Water Plant, IL

GENERAL

- Facility name = Brimfield Water Plant
- Facility owner = City of Brimfield
- Purpose of facility = drinking water
- Type of desalination technology = reverse osmosis
- Start year of RO operation = 2012
- Reason for RO facility as opposed to conventional treatment = TDS, organics, radionuclides

TREATMENT CAPACITY

- RO Design production (mgd) = 0.25
- RO average production (mgd) =
- Plant design production (mgd) =
- Plant average production (mgd) =

TREATMENT PROCESS

- Source water = groundwater
- Raw water conductivity ($\mu\text{S}/\text{cm}$) =
- Feed pressure to RO (psi) =
- Pretreatment steps =
- TDS of permeate (mg/l) =
- Membrane recovery (percent) =
- Age of membrane at last replacement =

BLENDING

- Blending =
- Blend Water source =
- Blend ratio (permeate : other) =
- TDS of blend =

WASTE MANAGEMENT

- Concentrate disposal = sewer
- Fate of cleaning wastewater =

POST-TREATMENT

- Post-treatment of permeate =
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

City of Atkins WTP, IA

GENERAL

- Name of facility = City of Atkins WTP
- Facility owner = City of Atkins
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2010
- Reason for RO facility = NH₃, system easy to expand in future

TREATMENT CAPACITY

- RO design production (mgd) = 0.58
- RO average production (mgd) =

TREATMENT PROCESS

- Source = groundwater
- Raw water conductivity ($\mu\text{S}/\text{cm}$) = 820
- Feed pressure to RO (psi) =
- Pretreatment steps = 25 μ followed by 1 μ woven filter, antiscalant
- TDS of permeate (mg/l) =
- Membrane recovery (percent) =
- Age of membrane at last replacement =

BLENDING

- Blending = no

WASTE MANAGEMENT

- Concentrate disposal = sewer
- Fate of cleaning wastewater =

POST-TREATMENT

- Post-treatment of permeate = CaCl₂, NaHCO₃, caustic, chlorine, orthophosphate
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

City of Pella, IA

GENERAL

- Facility name = City of Pella WTP
- Facility owner = City of Pella
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of NF operation = 2017
- Reason for RO facility as opposed to conventional treatment = current source had degraded over the years and had limited available water; had to go to different aquifer and RO was best treatment approach

TREATMENT CAPACITY

- RO design production (mgd) = 3
- RO average production (mgd) = 1.4
- Plant (RO + blend) production (mgd) = 6, if 3 mgd of lime softened water is added in an emergency
- Plant average production (mgd) = 1.8

TREATMENT PROCESS

- Source water = groundwater
- Raw water conductivity (mg/l) = 685
- Feed pressure to RO (psi) = first stage = 101; second stage = 105
- Pretreatment steps = antiscalant
- TDS of permeate (mg/l) =
- Membrane recovery (percent) = 80%
- Age of membrane at last replacement = on original membranes

BLENDING

- Blending = yes
- Blend Water source = bypass
- Blend ratio (permeate : other) = 80 : 20
- TDS of blend = 230

WASTE MANAGEMENT

- Concentrate disposal = to river
- Fate of cleaning wastewater =

POST-TREATMENT

- Post-treatment of permeate = pH adjustment (caustic), chlorine, fluoride
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Council Point WPP, IA

GENERAL

- Facility name = Council Point WPP
- Facility owner = Council Bluffs Water Works
- Purpose of facility = drinking water
- Type of desalination technology = reverse osmosis
- Start year of RO operation = 2013
- Reason for RO facility as opposed to conventional treatment = TDS, organics

TREATMENT CAPACITY

- RO Design production (mgd) = 5
- RO average production (mgd) = 1.68
- Plant design production (mgd) = 5
- Plant average production (mgd) = 2.4

TREATMENT PROCESS

- Source water = groundwater
- Raw water TDS (mg/l) = 550 -800
- Feed pressure to RO (psi) = 150
- Pretreatment steps = iron and manganese oxidation and UF filtration, antiscalant
- TDS of permeate (mg/l) = target is hardness
- Membrane recovery (percent) = 75%
- Age of membrane at last replacement = 3 years

BLENDING

- Blending = yes
- Blend Water source = bypass
- Blend ratio (permeate : other) = 70 : 30
- TDS of blend (mg/l) = target is hardness; TDS = 300-400

WASTE MANAGEMENT

- Concentrate disposal = surface water (Missouri River)
- Fate of cleaning and backwash waste =

POST-TREATMENT

- Post-treatment of permeate = disinfection, pH adjustment
- Post-treatment of concentrate = none

Municipal Desalination Facility Survey
Appendix B. Individual Facility Information

City of Hartley RO WTF, IA

GENERAL

- Facility name = RO WTF
- Facility owner = City of Hartley
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2010
- Reason for RO facility as opposed to conventional treatment = hardness, sulfate, TDS

TREATMENT CAPACITY

- RO Design production (mgd) = 0.44
- RO average production (mgd) = summer = 0.17; winter = 0.11
- Plant design production (mgd) =
- Plant average production (mgd) =

TREATMENT PROCESS

- Source water = groundwater
- Raw water TDS (mg/l) = 2100
- Pretreatment steps = antiscalant, cartridge filters
- Feed pressure to RO (psi) = ~158
- TDS of permeate (mg/l) =
- Membrane recovery (percent) = 75-77
- Age of membrane at last replacement = on original membranes

BLENDING

- Blending = yes
- Blend Water source = bypass
- Blend ratio (permeate : other) = 90 :10
- TDS of blend = 400

WASTE MANAGEMENT

- Concentrate disposal = sewer
- Fate of cleaning and backwash waste = sewer

POST-TREATMENT

- Post-treatment of permeate = aeration, chlorine, caustic, corrosion inhibitor, fluoride
- Post-treatment of concentrate = none

Municipal Desalination Facility Survey
Appendix B. Individual Facility Information

City of Grimes WTP, IA

GENERAL

- Facility name = Grimes WTP
- Facility owner = City of Grimes
- Purpose of facility = drinking water
- Type of desalination technology = reverse osmosis
- Start year of RO operation = 2017
- Reason for RO facility as opposed to conventional treatment = better quality

TREATMENT CAPACITY

- RO Design production (mgd) = 0.8
- RO average production (mgd) =
- Plant (permeate + blend) design production (mgd) =
- Plant average production (mgd) =

TREATMENT PROCESS

- Source water = groundwater
- Raw water TDS (mg/l) = 110
- Pretreatment steps = bag filter, cartridge filter, antiscalant
- Feed pressure to RO (psi) =
- Membrane recovery (percent) = 85%
- TDS of permeate (mg/l) =
- Age of membrane at last replacement = on original membranes

BLENDING

- Blending = yes
- Blend Water source = lime softened water; source water from a different aquifer
- Blend ratio (permeate : other) = 2 : 1
- TDS of blend (mg/l) = 80

WASTE MANAGEMENT

- Concentrate disposal = sanitary sewer (to WWTP)
- Fate of cleaning wastewater = haven't had to clean yet

POST-TREATMENT

- Post-treatment of permeate = blend, chloramination, corrosion inhibitor
- Post-treatment of concentrate = blend with lime softening waste

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Hills Water Supply, IA

GENERAL

- Name of facility = Hills Water Supply
- Facility owner = Hills Municipal Water
- Purpose of facility = drinking water
- Type of desalination technology = reverse osmosis
- Start year of RO operation = 2015
- Reason for the RO facility as opposed to a conventional facility = perchlorate, ammonia, TDS, hardness

TREATMENT CAPACITY

- RO design production (mgd) = 0.317
- RO average Production (mgd) =

TREATMENT PROCESS

- Source = groundwater
- Raw water TDS (mg/l) =
- Pre-treatment steps =
- Feed pressure to RO (psi) =
- TDS of permeate (mg/l) =
- Membrane recovery (percent) =
- Age of membrane at last replacement =

BLENDING

- Blending of permeate = no

WASTE MANAGEMENT

- Concentrate disposal = sewer
- Fate of cleaning wastewater =

POST-TREATMENT

- Post-treatment of permeate =
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

PWWSD #26, KS

GENERAL

- Facility name = PWWSD #26
- Facility owner = Strong City
- Purpose of facility = drinking water
- Type of desalination technology = reverse osmosis
- Start year of RO operation = 2015
- Reason for RO facility as opposed to conventional treatment = hardness

TREATMENT CAPACITY

- RO Design production (mgd) = 0.46 (2 RO skids; typically run both in summer; currently run 1 about 16 hr/day)
- RO average production (mgd) = 0.12
- Plant design (RO + blend) production (mgd) = 0.6
- Plant average production (mgd) = 0.14

TREATMENT PROCESS

- Source water = groundwater
- Raw water conductivity ($\mu\text{S}/\text{cm}$) = 820-915
- Feed pressure to RO (psi) = 150
- Pretreatment steps = chlorination, green sand filter, dichlorination (bisulfite), antiscalant, cartridge filters
- TDS of permeate (mg/l) = 15
- Membrane recovery (percent) = 80%
- Age of membrane at last replacement = on original membranes

BLENDING

- Blending = yes
- Blend Water source = raw water through the green sand filter
- Blend ratio (permeate : other) = 80 : 20
- TDS of blend (mg/l) = 200

WASTE MANAGEMENT

- Concentrate disposal = surface water (river)
- Fate of cleaning wastes = to sanitary sewer; clean only once every 3 years
- Fate of backwash waste = to settling tank, solids to lagoon and evaporation pond; retentate back to front of process before the green sand filters

POST-TREATMENT

- Post-treatment of permeate = caustic, chlorine
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Clay Center, KS

GENERAL

- Name of facility = Clay Center PUC Treatment RO Plant
- Facility owner = City of Clay Center
- Type of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2010
- Reason for RO facility = will meet present and future needs

TREATMENT CAPACITY

- RO design production (mgd) = 1.67
- RO average Production (mgd) = 0.41
- Plant (RO + blend) design production (mgd) = 1.95
- Plant average production (mgd) = 0.49

TREATMENT PROCESS

- Source water = groundwater
- Raw water conductivity ($\mu\text{S}/\text{cm}$) = 1430
- Feed pressure (psi) to RO =
- Pretreatment steps = greensand filter, cartridge filter, antiscalant
- TDS of permeate (mg/l) =
- Membrane recovery (percent) = 75
- Age of membrane at last replacement = on original membranes

BLENDING

- Blending = yes
- Blend water source = bypass
- Blend ratio (permeate : other) = ~ 80 : 20
- TDS of blend =

WASTE MANAGEMENT

- Concentrate disposal = surface (discharge to river)
- Fate of cleaning wastewater =

POST-TREATMENT

- Post-treatment of permeate = decarbonation, Caustic, chlorine
- Concentrate treatment = none

Municipal Desalination Facility Survey
Appendix B. Individual Facility Information

Big Springs WTP, KS

GENERAL

- Name of facility = Big Springs WTP
- Facility owner = Douglas County RWD #3
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2014
- Reason for the RO facility as opposed to a conventional facility = hardness removal, TDS

TREATMENT CAPACITY

- RO Design production (mgd) = 1.14
- RO Average Production (mgd) = 0.31
- Plant (RO + blend) design production (mgd) =
- Plant average production (mgd) = 0.67

TREATMENT PROCESS

- Source water = groundwater
- Raw water TDS (mg/l) = 280
- Feed pressure to RO (psi) = 146
- Pretreatment =
- TDS of permeate (mg/l) =
- Membrane recovery (percent) =
- Age of membrane at last replacement = almost 4 years; replacement needed due to process upset

BLENDING

- Blending = yes
- Blend water source = bypass after the Fe-Mn oxidation step
- Blend ratio (permeate : other) = ~ 75:25
- TDS of blend =

WASTE MANAGEMENT

- Concentrate disposal = discharge to a lagoon and then to a river
- Cleaning wastewater fate = goes to lagoon

POST-TREATMENT

- Post-treatment of permeate = caustic, chloramination
- Treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Swansea WTP, MA

GENERAL

- Name of facility = Swansea Desalination Treatment Facility
- Facility owner = Swansea Water District
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2013
- Reason for RO facility as opposed to a conventional treatment facility = TDS

TREATMENT CAPACITY

- RO Design production (mgd) = 1.2
- RO average production (mgd) = 0.4
- Plant (RO + blend) design production (mgd) = 2.18
- Plant Average Production (mgd) = 0.85

TREATMENT PROCESS

- Source water = surface water
- Raw water TDS (mg/l) =
- Feed pressure (psi) = 250 – 550 depending on conductivity
- Pretreatment = intake screen, caustic, coagulant, strainers, microfiltration
- TDS of permeate (mg/l) =
- Membrane recovery (percent) = 30 – 50 depending on feed conductivity
- Age of membrane at last replacement = on original membranes

BLENDING

- Blending = yes
- Blend water source = groundwater
- Blend ratio (permeate : other) = 40 : 60
- TDS of blend = 250

WASTE MANAGEMENT

- Concentrate disposal = surface water – returned to River on high tide events
- Fate of cleaning wastewater = neutralized, mixed with concentrate
- Fate of backwash waste = through sand lined lagoon then mixed with concentrate

POST-TREATMENT

- Post treatment of permeate = caustic, soda ash, chlorine
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

City of Allegan MI

GENERAL

- Name of facility = City of Allegan WTP
- Facility owner = City of Allegan
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2011
- Reason for RO = hardness; less complicated/less labor intense than lime softening

TREATMENT CAPACITY

- RO Design production (mgd) = 2.25
- RO Average Production (mgd) = ~ 1.2; perhaps 0.9 in winter and 1.5 in summer
- Plant (RO + blend) Design production (mgd) =
- Plant average production (mgd) =

TREATMENT PROCESS

- Source water = groundwater
- Raw water conductivity ($\mu\text{S}/\text{cm}$) = 700
- Feed pressure (psi) = 40 from wells; 150 to RO
- Pretreatment steps = spiral wound filter, antiscalant
- TDS (mg/l) or conductivity ($\mu\text{S}/\text{cm}$) of permeate =
- Membrane recovery (percent) =
- Age of membrane at last replacement = still on original membranes

BLENDING

- Blending = yes
- Blend water source = bypass (treated for iron removal)
- Blend ratio (permeate : other) = 70:30
- TDS of blend =

WASTE MANAGEMENT

- Concentrate disposal = discharge to river
- Fate of cleaning wastewater = have not had to clean membranes yet since installation

POST-TREATMENT

- Post-treatment of permeate = fluoride, orthophosphate
- Treatment of concentrate = none

Municipal Desalination Facility Survey
Appendix B. Individual Facility Information

Glassboro WTP, NJ

GENERAL

- Facility name = Borough of Glassboro WTP
- Facility owner = Borough of Glassboro
- Purpose of facility = drinking water
- Type of technology = reverse osmosis/VSEP
- Start year of RO operation = 2012
- Reason for RO facility as opposed to conventional treatment = high sodium

TREATMENT CAPACITY

- RO/VSEP Design production (mgd) = 1.13
- RO average production (mgd) =
- Plant design production (mgd) = ~ 1.5
- Plant average production (mgd) = ~ 1

TREATMENT PROCESS

- Source water = groundwater
- Raw water conductivity ($\mu\text{S}/\text{cm}$) =
- Feed pressure to RO (psi) = ~ 200 to RO
- Pretreatment steps = 1 μ prefilters
- TDS of permeate (mg/l) =
- Membrane recovery (percent) =
- Age of membrane at last replacement = on original membranes

BLENDING

- Blending = yes
- Blend Water source = bypass
- Blend ratio (permeate : other) = varies, but roughly 1 : 1
- TDS of blend =

WASTE MANAGEMENT

- Concentrate disposal = sanitary sewer
- Fate of cleaning wastewater =

POST-TREATMENT

- Post-treatment of permeate = chlorine and orthophosphate
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Keansburg Freese Street, WTP NJ

GENERAL

- Name of facility = Freese Street WTP
- Facility owner = City of Keansburg
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2011
- Reason for RO facility as opposed to a conventional treatment facility = TDS

TREATMENT CAPACITY

- RO Design production (mgd) = 1.15
- RO average production (mgd) = 0.85
- Plant (RO + blend) design production (mgd) =
- Plant average production (mgd) =

TREATMENT PROCESS

- Source water = groundwater
- Raw water TDS (mg/l) = 1200-1300
- Feed pressure (psi) = 180-200
- Pretreatment = antiscalant, cartridge filters, sulfuric acid,
- TDS of permeate (mg/l) = 40
- Membrane recovery (percent) = 85
- Age of membrane at last replacement =

BLENDING

- Blending = yes
- Blend water source = bypass
- Blend ratio (permeate : other) = 400 : 100 (gpm)
- TDS of blend =

WASTE MANAGEMENT

- Concentrate disposal = surface water
- Fate of cleaning wastewater = same

POST-TREATMENT

- Post treatment of permeate = chlorine, caustic
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Craven County, NC

GENERAL

- Facility name = Craven County Potable Water Supply and Treatment Facility
- Facility Owner = Craven County
- Purpose of facility = drinking water
- Type of desalination technology = nanofiltration
- Start year of NF operation = 2017
- Reason for NF plant = reduce reliance on Black Creek Aquifer; remove THM and HAA5 precursors

TREATMENT CAPACITY

- NF design production (mgd) = 3
- NF average production (mgd) = 1.33

TREATMENT PROCESS

- Source water = ground water
- Raw water TDS (mg/l) = 296
- Feed pressure to NF (psi) = 38-52
- Pretreatment steps = antiscalant, cartridge filters
- TDS of permeate (mg/l) =
- Concentrate TDS (mg/l) = 800 – 1200 depending on well combo
- Age of membrane at last replacement = on original membranes

BLENDING

- Blending = no

WASTE MANAGEMENT

- Concentrate disposal = discharge to Neuse River (tidally influenced)
- Fate of cleaning wastewater =

POST-TREATMENT

- Post treatment of permeate = calcite stabilization, chlorination
- Post-treatment of concentrate = none

Municipal Desalination Facility Survey
Appendix B. Individual Facility Information

Dixon WTP, NC

GENERAL

- Name of facility = Dixon WTP
- Facility owner = ONWASA (Onslow Water and Sewer Authority)
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of NF operation = 2013
- Reason for treatment = silica removal with side benefit of TOC reduction

TREATMENT CAPACITY

- RO Design production (mgd) = 3
- RO Average Production (mgd) = 2
- Plant (RO + bypass) Design production (mgd)= 4
- Plant average production (mgd) = 2.5

TREATMENT PROCESS

- Source = groundwater
- Raw water conductivity ($\mu\text{S}/\text{cm}$) = ~400
- Feed pressure (psi) = 82 – 98
- Pretreatment steps = greensand filter, antiscalant, cartridge filter
- TDS of permeate (mg/l) = 25
- Membrane recovery (percent) = 70 – 80
- Age of membrane at last replacement = on original membranes

BLENDING

- Blending = yes
- Blend water source = same source; bypass after greensand filter
- Blend ratio (permeate : other) = 73 : 27
- TDS of blend (mg/l) = < 250

WASTEWATER MANAGEMENT

- Concentrate disposal = surface (discharge to ponds which empty into a creek)
- Fate of cleaning wastewater = same as with concentrate

POST-TREATMENT

- Concentrate treatment = none
- Permeate = pH adjustment (caustic), disinfection, corrosion control, fluoride

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Englehard Hyde County, NC

GENERAL

- Facility name = Englehard WTP
- Facility owner = Hyde County Water Maintenance and Solids Waste Department
- Purpose of facility = drinking water
- Type of desalination technology = reverse osmosis
- Start year of RO operation = 2011
- Reason for RO facility as opposed to conventional treatment =

TREATMENT CAPACITY

- RO Design production (mgd) = 0.432
- RO average production (mgd) =

TREATMENT PROCESS

- Source water = groundwater
- Raw water conductivity ($\mu\text{S}/\text{cm}$) = 973
- Feed pressure to RO (psi) =
- Pretreatment steps = antiscalant
- TDS of permeate (mg/l) = ~25
- Membrane recovery (percent) =
- Age of membrane at last replacement = on original membranes

BLENDING

- Blending = no

WASTE MANAGEMENT

- Concentrate disposal = discharge to surface water (creek)
- Fate of cleaning wastewater =

POST-TREATMENT

- Post-treatment of permeate = acid, lime, phosphate, chlorine
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Skyco, NC

GENERAL

- Facility name = Skyco WTP
- Facility owner = Dare County
- Purpose of facility = drinking water
- Type of desalination technology = nanofiltration
- Start year of NF operation = 2017
- Reason for the NF facility as opposed to a conventional facility = less complicated than the IX facility and found a membrane to remove bromide to address byproduct issue and iron

TREATMENT CAPACITY

- NF Design production (mgd) = 3
- RO average production (mgd) =
- Plant design production (mgd) = 5
- Plant average production (mgd) = 2.5

TREATMENT PROCESS

- Source water = groundwater
- Raw water TDS (mg/l) = 545
- Feed pressure to NF (psi) = 108
- Pretreatment steps = 5 micron cartridge filter, antiscalant
- TDS of permeate (mg/l) = 50
- Membrane recovery (%) = 80
- Age of membrane at last replacement = on original membranes

BLENDING

- Blending = yes
- Blend Water source = product from IX facility; improves hardness
- Blend ratio (permeate : other) = at MAX production = 3 : 2
- Target TDS of blend (mg/l) = 170

WASTE MANAGEMENT

- Concentrate disposal = to surface water
- Fate of cleaning and backwash waste = mixed with concentrate

POST-TREATMENT

- Post-treatment of permeate = caustic, hypochlorite, corrosion inhibitor (zinc ortho phosphate)
- Post-treatment of concentrate = none; concentrate mixed with backwash prior to discharge

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Tyrrell County Prison RO WTP, NC

GENERAL

- Name of facility = Tyrrell County Prison RO WTP
- Facility owner = Tyrrell County Prison
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2010
- Reason for RO facility as opposed to a conventional treatment facility =

TREATMENT CAPACITY

- RO design production (mgd) = 0.432
- RO average production (mgd) =

TREATMENT PROCESS

- Source water =
- Raw water TDS (mg/l) =
- Feed pressure (psi) =
- Pretreatment =
- TDS of permeate (mg/l) =
- Membrane recovery (percent) =
- Age of membrane at last replacement =

BLENDING

- Blending =
- Blending source =
- Blend ratio (permeate : other) =
- TDS of blend (mg/l) =

WASTE MANAGEMENT

- Concentrate disposal = surface
- Fate of cleaning wastewater =

POST-TREATMENT

- Post treatment of permeate =
- Post-treatment of concentrate =

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

New Frontier Way NF, NC

GENERAL

- Name of facility = New Frontier Way NF Plant
- Facility owner = City of Jacksonville
- Purpose of facility = drinking water
- Type of technology = nanofiltration
- Start year of NF operation = 2010
- Reason for NF facility as opposed to a conventional facility = softening, organic removal

TREATMENT CAPACITY

- NF Design production (mgd) = 8
- NF Average Production (mgd) = 3.5
- Plant (NF + blend) Design production (mgd) =
- Plant average production (mgd) =

TREATMENT PROCESS

- Source water = groundwater
- Raw water conductivity ($\mu\text{S}/\text{cm}$) = 884
- Pretreatment = antiscalant, cartridge filters; acid added to bypass used for blending
- Feed pressure to NF (psi) = 57
- TDS of permeate (mg/l) = 85
- Membrane recovery (percent) = 75
- Age of membrane at last replacement =

BLENDING

- Blending =yes
- Blend water source = bypass
- Blend ratio (permeate : other) 90 :10
- TDS of blend (mg/l) = 280-320

WASTE MANAGEMENT

- Concentrate disposal = to river
- Fate of cleaning wastewater =

POST-TREATMENT

- Post treatment of permeate = bioscrubbing to remove odor, stabilization, disinfection, pH
- Post-treatment of concentrate = none⁷⁷

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Valley City WTP, ND

GENERAL

- Name of facility = Valley City WTP
- Facility owner = Valley City
- Purpose of facility = drinking water
- Type of technology = UF/NF
- Start year of NF operation = 2012
- Reason for UF/NF as opposed to conventional treatment = TDS, sulfate; replaced lime softening

TREATMENT CAPACITY

- NF Design production (mgd) = 4.65
- NF Average Production (mgd) =
- Plant (NF + blend) Design production (mgd) =
- Plant average production (mgd) =

TREATMENT PROCESS

- Source waters = ground and surface waters
- Raw water TDS (mg/l) or conductivity ($\mu\text{S}/\text{cm}$) =
- Pretreatment steps = sodium permanganate (for Fe/Mn), coagulant, sulfuric acid; all this before the UF; cartridge filter, antiscalant after the UF
- Feed pressure to NF (psi) = 180
- conductivity of permeate ($\mu\text{S}/\text{cm}$) = 50
- Membrane recovery (percent) = currently 85% on UF (scaling issues; considering antiscalant prior to UF); 85% on NF
- Age of membrane at last replacement = original membranes

BLENDING

- Blending = yes
- Blend water source = raw water treated through the UF step
- Blend ratio (permeate : other) = ~ 50 : 50
- TDS of blend =

WASTE MANAGEMENT

- Concentrate disposal = to surface water unless low receiving water flow; then to lagoon
- Fate of cleaning wastewater = same

POST-TREATMENT

- Post-treatment of permeate = blend, fluoride, caustic, chloramination
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Hillsboro WTP, ND

GENERAL

- Name of facility = City of Hillsboro WTP
- Facility owner = City of Hillsboro
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2012
- Reason for RO facility as opposed to a conventional treatment facility = hardness, SO₄, TDS

TREATMENT CAPACITY

- RO design production (mgd) = 0.85
- RO average production (mgd) =

TREATMENT PROCESS

- Source water =
- Raw water TDS (mg/l) =
- Feed pressure (psi) =
- Pretreatment =
- TDS of permeate (mg/l) =
- Membrane recovery (percent) =
- Age of membrane at last replacement =

BLENDING

- Blending =
- Blending source =
- Blend ratio (permeate : other) =
- TDS of blend (mg/l) =

WASTE MANAGEMENT

- Concentrate disposal =
- Fate of cleaning wastewater =

POST-TREATMENT

- Post treatment of permeate =
- Post-treatment of concentrate =

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Emmons County WTP, ND

GENERAL

- Name of facility = Emmons County WTP
- Facility Owner = South Central Regional Water District
- Purpose of facility = drinking water
- Type of technology = UF/RO
- Start year of RO operation = 2012
- Reason why UF/RO as opposed to a conventional WTP = hardness

TREATMENT CAPACITY

- RO design production (mgd) = 1.2
- RO average Production (mgd) = 0.4
- Plant (RO + blend) design production (mgd) = 2.0
- Plant average production (mgd) = 0.7

TREATMENT PROCESS

- Source = Lake Oahe
- Raw water TDS (mg/l) = 500
- Feed pressure (psi) = 120
- Pretreatment steps = ozone(oxidation), coagulation/sedimentation, ultrafiltration, antiscalant
- TDS of permeate (mg/l) = 30
- Membrane recovery (percent) = 80
- Age of membrane at last replacement = 6 years

BLENDING

- Blending = yes
- Blend water source = bypass
- Blend ratio (permeate : other) = 60 : 40
- TDS of blend (mg/l) = 250

WASTE MANAGEMENT

- Concentrate disposal = surface (discharge to lake)
- Fate of cleaning wastewater = with concentrate

POST-TREATMENT

- Post-treatment of concentrate = none
- Post-treatment of permeate = blend, ozone, chlorine

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Bowling Green, OH

GENERAL

- Name of facility = Bowling Green WTP
- Facility owner = City of Bowling Green
- Purpose of facility = drinking water plant
- Type of technology = reverse osmosis
- Start year of RO operation = 2012
- Reason for RO treatment = THMs, TOC

TREATMENT CAPACITY

- RO Design production (mgd) = 3
- RO Average Production (mgd) = 1
- Plant (RO + blend) Design production (mgd) = 14
- Plant average production (mgd) = 4.8

TREATMENT PROCESS

- Source water = surface water (Maumee River)
- Raw water conductivity ($\mu\text{S}/\text{cm}$) = 650 $\mu\text{S}/\text{cm}$
- Pre-treatment steps = antiscalant, cartridge filters, microfiltration
- Feed pressure (psi) = 75
- Conductivity of permeate ($\mu\text{S}/\text{cm}$) 16
- Membrane recovery (percent) = 78
- Age of membrane at last replacement = on original membranes

BLENDING

- Blending = Yes
- Blend water source = with lime softened/GAC treated water
- Blend ration (permeate : other) = 25 : 75
- TDS of blend =

WASTE MANAGEMENT

- Concentrate disposal = to lagoon and then river
- Fate of cleaning wastewater = same: lagoon and river

POST-TREATMENT

- Post treatment of permeate = blend, pH adjustment, chlorination
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

City of Delaware WTP, OH

GENERAL

- Name of facility = City of Delaware WTP
- Facility owner = City of Delaware
- Purpose of facility = drinking water plant
- Type of technology = UF/NF and NF (separate NF lines)
- Start year of RO operation =
- Reason for RO treatment = Fe, Mn

TREATMENT CAPACITY

- NF Design production (mgd) = 6
- NF Average Production (mgd) = 3.8

TREATMENT PROCESS

- Source water = surface water and GW
- Raw water conductivity ($\mu\text{S}/\text{cm}$) =
- Pre-treatment steps = on surface water = coagulation, UF; on GW = filters to remove Fe, Mn
- Feed pressure (psi) =
- Target conductivity of permeate ($\mu\text{S}/\text{cm}$) =
- Membrane recovery (percent) =
- Age of membrane at last replacement =

BLENDING

- Blending = no

WASTE MANAGEMENT

- Concentrate disposal = surface water
- Fate of cleaning wastewater =

POST-TREATMENT

- Post treatment of permeate = chlorine, corrosion inhibitor, fluoride
- Post-treatment of concentrate =

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Spencerville, OH

GENERAL

- Name of facility = Spencerville WTP
- Facility owner = City of Spencerville
- Purpose of facility = drinking water
- Type of technology = nanofiltration
- Start year of NF operation = 2014
- Reason for the NF facility as opposed to a conventional facility = better water quality, capability of meeting future concerns, present concerns with TDS increases from ion exchange systems

TREATMENT CAPACITY

- NF Design production (mgd) = 0.49
- NF Average Production (mgd) =
- Plant (NF + blend) Design capacity (mgd) =
- Plant average production (mgd) =

TREATMENT PROCESS

- Source water = ground water
- Raw water conductivity ($\mu\text{S}/\text{cm}$) = 1095 – 1518
- Pretreatment = aeration, chlorination, sand filters, dechlorination, antiscalant
- Feed pressure to NF (psi) = 122
- TDS of permeate (mg/l) = 74
- Membrane recovery (percent) = 70%
- Age of membrane at last replacement = still have original membranes

BLENDING

- Blending = yes
- Blend water source = sand-filtered raw water
- Blend ratio (permeate : other) = 90 : 10
- TDS of blend =

WASTEWATER MANAGEMENT

- Concentrate disposal = to sewer
- Fate of cleaning wastewater =

POST TREATMENT

- Post-treatment of permeate = disinfections, pH adjustment
- Post-treatment of concentrate = add acid to lower pH

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Pigeon Forge STP, TN

GENERAL

- Name of facility = Pigeon Forge STP
- Facility owner = City of Pigeon Forge (or Veolia?)
- Type of facility = WWTP
- Type of technology = nanofiltration
- Purpose = to thicken digester content for next digester
- Start year of NF operation = 2015

TREATMENT CAPACITY

- NF Design production (mgd) = 0.4
- NF average production (mgd) =

TREATMENT PROCESS

- Feed pressure to NF (psi) =
- TDS of permeate (mg/l) =
- Membrane recovery (percent) =
- Age of membrane at last replacement = on original membranes

BLENDING

- Blending = no

WASTE MANAGEMENT

- Concentrate disposal = passed on to next digester
- Fate of effluent = discharge to river

POST-TREATMENT

- Post-treatment of permeate = disk filter, chlorinated, dechlorinated (bisulfite); later this year will recycle to front of process due to high phosphorus content

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

14TH And C RO WTP, TX

GENERAL

- Name of facility = 14th and C RO WTP
- Facility owner = BW Primoris
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2016
- Reason for RO facility as opposed to a conventional treatment facility = TDS, arsenic

TREATMENT CAPACITY

- RO Design production (mgd) = 0.65
- RO average production (mgd) = 0.5 – 0.65
- Plant Design production (mgd) =
- Plant Average Production (mgd) =

TREATMENT PROCESS

- Source water = groundwater
- Raw water TDS (mg/l) = summer ~ 2500; rest of year ~ 1100
- Feed pressure (psi) = 225-250
- Pretreatment = antiscalant, cartridge filters, sulfuric acid
- TDS of permeate (mg/l) = 40-50
- Membrane recovery (percent) = 65-70%
- Age of membrane at last replacement = on original membranes

BLENDING

- Blending = yes
- Blend water source = raw water bypass
- Blend ratio (permeate : other) = 2 : 1
- TDS of blend = 740

WASTE MANAGEMENT

- Concentrate disposal = to gulch, percolations into ground
- Fate of cleaning wastewater = send membranes off site

POST-TREATMENT

- Post treatment of permeate = blend, chlorine, caustic
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

25th and Avenue G RO WTP, TX

GENERAL

- Name of facility = 25TH and Avenue G RO WTP
- Facility owner = BW Primoris
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2016
- Reason for RO facility as opposed to a conventional treatment facility = TDS, arsenic
- Present status = offline since start; replaced by coagulation process just for As

TREATMENT CAPACITY

- RO Design production (mgd) = 1.15
- RO average production (mgd) =
- Plant Design production (mgd) =
- Plant Average Production (mgd) =

TREATMENT PROCESS

- Source water = groundwater
- Raw water TDS (mg/l) =
- Feed pressure (psi) =
- Pretreatment =
- TDS of permeate (mg/l) =
- Membrane recovery (percent) =
- Age of membrane at last replacement =

BLENDING

- Blending =
- Blend water source =
- Blend ratio (permeate : other) =
- TDS of blend =

WASTE MANAGEMENT

- Concentrate disposal = to gulch, percolations into ground
- Fate of cleaning wastewater =

POST-TREATMENT

- Post treatment of permeate =
- Post-treatment of concentrate =

Municipal Desalination Facility Survey
Appendix B. Individual Facility Information

Aransas Bay Utilities WTP, TX

GENERAL

- Name of facility = Aransas Bay Utilities WTP
- Facility owner = Aransas Bay Utilities
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2011
- Reason for RO facility as opposed to a conventional treatment facility =

TREATMENT CAPACITY

- RO design production (mgd) = 0.20
- RO average production (mgd) =
- Plant (RO + blend) design production (mgd) =
- Plant Average Production (mgd) =

TREATMENT PROCESS

- Source water = groundwater
- Raw water TDS (mg/l) =
- Feed pressure (psi)?
- Pretreatment = antiscalant, cartridge filters, sulfuric acid,
- TDS of permeate (mg/l) =
- Membrane recovery (percent) =
- Age of membrane at last replacement =

BLENDING

- Blending =
- Blend water source =
- Blend ratio (permeate : other) =
- TDS of blend =

WASTE MANAGEMENT

- Concentrate disposal = surface
- Fate of cleaning wastewater =

POST-TREATMENT

- Post treatment of permeate =
- Post-treatment of concentrate =

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Big Spring Water Advanced Treatment Plant, TX

GENERAL

- Name of facility = Big Spring Advanced Treatment Plant
- Facility owner = Colorado River Municipal Water District
- Purpose of facility = drinking water supply
- Type of technology = MF/reverse osmosis
- Start year of RO operation = 2013
- Reason for RO facility as opposed to a conventional treatment facility = draught dried up a source water lake; new drinking water source needed

TREATMENT CAPACITY

- RO Design production (mgd) = 2.38
- RO average production (mgd) = 1.2

TREATMENT PROCESS

- Source water = reservoir water which received water from WWTP
- Raw water TDS (mg/l) = 1845
- Feed pressure (psi) = 150
- Pretreatment = MF, disinfection (chemical and UV), pH adjustment, antiscalant
- TDS of permeate (mg/l) =
- Membrane recovery (percent) = 75%
- Age of membrane at last replacement =

BLENDING

- Blending = no

WASTE MANAGEMENT

- Concentrate disposal = surface water
- Fate of cleaning wastewater =
- Fate of backwash waste =

POST-TREATMENT

- Post treatment of permeate = UV oxidation; 5-20% is blended with surface water from one of the reservoirs and then treated again at the Big Springs WTP; the rest of the permeate goes to meet an industry need
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Bob Elder WTP, TX

GENERAL

- Name of facility = Bob Elder WTP
- Facility owner = City of Milsap
- Purpose of facility = drinking water
- Type of technology = MF/reverse osmosis
- Start year of RO operation = 2014
- Reason for RO facility as opposed to a conventional treatment facility =

TREATMENT CAPACITY

- RO Design production (mgd) =
- RO average production (mgd) =

TREATMENT PROCESS

- Source water = surface water
- Raw water TDS (mg/l) = 1255
- Feed pressure (psi) = 148
- Pretreatment = MF, cartridge filter, dichlorination, antiscalant
- TDS of permeate (mg/l) =
- Membrane recovery (percent) = 70%
- Age of membrane at last replacement =

BLENDING

- Blending = yes
- Blending source =
- Blend ratio (permeate : other) =
- TDS of blend (mg/l) =

WASTE MANAGEMENT

- Concentrate disposal = surface water
- Fate of cleaning wastewater =
- Fate of backwash waste =

POST-TREATMENT

- Post treatment of permeate = blending, pH adjustment, disinfection
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

City of Benjamin RO WTP, TX

GENERAL

- Name of facility = City of Benjamin RO WTP
- Facility owner = City of Benjamin
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2012
- Reason for RO facility as opposed to a conventional treatment facility =

TREATMENT CAPACITY

- RO Design production (mgd) = 0.072
- RO average production (mgd) = 0.0576

TREATMENT PROCESS

- Source water = groundwater
- Raw water TDS (mg/l) =
- Feed pressure (psi) = 165
- Pretreatment = cartridge filter
- TDS of permeate (mg/l) =
- Membrane recovery (percent) = 71
- Age of membrane at last replacement =

BLENDING

- Blending = yes
- Blending source =
- Blend ratio (permeate : other) =
- TDS of blend (mg/l) =

WASTE MANAGEMENT

- Concentrate disposal = evaporation pond
- Fate of cleaning wastewater =

POST-TREATMENT

- Post treatment of permeate = pH adjustment, disinfection
- Post-treatment of concentrate =

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

City of Evant RO WTP, TX

GENERAL

- Name of facility = City of Evant RO WTP
- Facility owner = City of Evant
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2010
- Reason for RO facility as opposed to a conventional treatment facility =

TREATMENT CAPACITY

- RO Design production (mgd) = 0.08
- RO average production (mgd) = 0.065

TREATMENT PROCESS

- Source water = groundwater
- Raw water TDS (mg/l) = 1100
- Feed pressure (psi) = 190
- Pretreatment = cartridge filter, media filter, antiscalant
- TDS of permeate (mg/l) = 800
- Membrane recovery (percent) = 80
- Age of membrane at last replacement =

BLENDING

- Blending = no

WASTE MANAGEMENT

- Concentrate disposal = sanitary sewer
- Fate of cleaning wastewater =

POST-TREATMENT

- Post treatment of permeate = disinfection
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

City of Granbury, TX

GENERAL

- Name of facility = City of Granbury WTP
- Facility owner = City of Granbury
- Facility type = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2017
- Reason for RO treatment = high bromide

TREATMENT CAPACITY

- RO Design production (mgd) = 2.5
- RO Average Production (mgd) = 0.7
- Plant Design production (mgd) = 2.5
- Plant average production (mgd) = 0.875

TREATMENT PROCESS

- Source water = surface (lake)
- Raw water conductivity ($\mu\text{S}/\text{cm}$) = 1330
- Feed pressure to RO (psi) = 115-120
- Pretreatment steps in front of RO = MF, cartridge filter, antiscalant
- TDS of permeate (mg/l) = 30
- Membrane recovery (percent) = 75
- Age of membrane at last replacement = on original membranes (start-up was November 2017)

BLENDING

- Blending = yes
- Blend water source = bypass, MF treated
- Blend ratio (permeate:other) = 75 : 25
- TDS of blend (mg/l) = 250

WASTE MANAGEMENT

- Concentrate disposal = surface (discharge to lake)
- Fate of cleaning waste = mixed with concentrate

POST-TREATMENT

- Post-treatment of permeate = pH adjustment, chloramination
- Concentrate treatment = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

City of Roscoe WTP, TX

GENERAL

- Facility name = City of Roscoe WTP
- Facility owner = City of Roscoe
- Purpose of facility = drinking water
- Type of desalination technology = reverse osmosis
- Start year of RO operation = 2013
- Reason for RO facility as opposed to conventional treatment = nitrate, hardness,

TREATMENT CAPACITY

- RO design production (mgd) = 0.36
- RO average production (mgd) =
- Plant design production (mgd) =
- Plant average production (mgd) =

TREATMENT PROCESS

- Source water = groundwater
- Raw water conductivity ($\mu\text{S}/\text{cm}$) =
- Pretreatment steps =
- Feed pressure to RO (psi) =
- TDS of permeate (mg/l) =
- Membrane recovery (percent) =
- Age of membrane at last replacement =

BLENDING

- Blending =
- Blend Water source =
- Blend ratio (permeate : other) =
- TDS of blend =

WASTE MANAGEMENT

- Concentrate disposal = sewer
- Fate of cleaning wastewater = sewer

POST-TREATMENT

- Post-treatment of permeate =
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

City of Rule, WTP TX

GENERAL

- Name of facility = City of Rule WTP
- Facility owner = City of Rule
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2015
- Reason for RO facility as opposed to a conventional treatment facility =

TREATMENT CAPACITY

- RO Design production (mgd) = 0.0854
- RO average production (mgd) = 0.04

TREATMENT PROCESS

- Source water = groundwater
- Raw water TDS (mg/l) =
- Feed pressure (psi) = 120
- Pretreatment = cartridge filter, antiscalant
- TDS of permeate (mg/l) =
- Membrane recovery (percent) = 68%
- Age of membrane at last replacement =

BLENDING

- Blending = no

WASTE MANAGEMENT

- Concentrate disposal = sewer
- Fate of cleaning wastewater =
- Fate of backwash waste =

POST-TREATMENT

- Post treatment of permeate = disinfection
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

City of Wheeler, TX

GENERAL

- Name of facility = City of Wheeler TP
- Facility owner = City of Wheeler
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2016
- Reason for RO treatment as opposed to conventional treatment = nitrates

TREATMENT CAPACITY

- RO Design production (mgd) = 0.5
- RO Average Production (mgd) =
- Plant (RO + blend) design production (mgd) =
- Plant average production (mgd) =

TREATMENT PROCESS

- Source water = groundwater
- Raw water conductivity ($\mu\text{S}/\text{cm}$) = depends on wells used; 750-900
- Pre-treatment steps = antiscalant, cartridge filters
- Feed pressure to RO (psi) = 127-140
- Conductivity of permeate ($\mu\text{C}/\text{cm}$) = 15
- Membrane recovery (percent) = 75
- Age of membrane at last replacement = on original membranes

BLENDING

- Blending = yes
- Blend water source = bypass
- Blend ratio (permeate : other) = ~ 300 : 150
- TDS of blend = target is based on nitrate rather than conductivity

WASTE MANAGEMENT

- Concentrate disposal = to water job locations and roads
- Fate of cleaning wastewater = same as concentrate

POST-TREATMENT

- Post-treatment of permeate = chlorine
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Fort Hancock RO Plant 1, TX

GENERAL

- Name of facility = Fort Hancock RO Plant 1
- Facility owner = Fort Hancock Water Control & Improvement District
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2012
- Reason for RO facility as opposed to a conventional treatment facility =

TREATMENT CAPACITY

- RO Design production (mgd) = 0.43
- RO average production (mgd) = 0.04

TREATMENT PROCESS

- Source water = groundwater
- Raw water TDS (mg/l) =
- Feed pressure (psi) = 180
- Pretreatment = cartridge filter
- TDS of permeate (mg/l) =
- Membrane recovery (percent) = 78%
- Age of membrane at last replacement =

BLENDING

- Blending = yes
- Blending source =
- Blend ratio (permeate : other) =
- TDS of blend (mg/l) =

WASTE MANAGEMENT

- Concentrate disposal = evaporation pond
- Fate of cleaning wastewater =

POST-TREATMENT

- Post treatment of permeate = pH adjustment, disinfection
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Hamby-Abilene WWTP, TX

GENERAL

- Facility name = Hamby-Abilene WWTP
- Facility owner = City of Abilene
- Purpose of facility = originally additional source water during draught (up to 7 mgd of highly treated water goes to lake for clean water supply); now main purpose is for reuse (landscaping, irrigation)
- Type of desalination technology = MBR/ozone/reverse osmosis; up to 22 mgd goes through MBR; a portion (up to 2.8 mgd) of MBR effluent goes to ozone treatment, portion (up to 4.2 mgd) goes to RO; these 2 streams eventually combined and discharged to water supply lake; water treated only by MBR provided for reuse and eventually it is discharged to a Creek and to different lake.
- Start year of RO operation = 2015
- Plant status = was shut down for 1.5 years after rains came; started up again about 3 months ago; currently down due to cartridge filter problem

TREATMENT CAPACITY

- RO design production (mgd) = 4.2
- RO average production (mgd) =
- Plant (RO + blend) design production (mgd) = 7 (RO = 4.2; Ozone = 2.8)
- Plant average production (mgd) =

TREATMENT PROCESS

- Source water = WWTP influent
- Raw water conductivity ($\mu\text{S}/\text{cm}$) = 3200
- Feed pressure to RO (psi) = 127
- Pretreatment steps before RO = MBR, ozone, cartridge filter, antiscalant
- Conductivity of permeate ($\mu\text{S}/\text{cm}$) = 131
- Membrane recovery (percent) = 82%
- Age of membrane at last replacement = on original membranes

BLENDING

- Blending of permeate = yes
- Blend Water source = same source water, treated by MBR then ozone
- Blend ratio (permeate : other) = ~ 4.2 : 2.8
- TDS of blend =

WASTE MANAGEMENT

- Concentrate disposal = evaporation pond
- Fate of cleaning waste = neutralization tank, then to front end of process

POST-TREATMENT

- Post-treatment of concentrate = none
- Post-treatment of permeate = blend, chlorination, aeration, dechlorination

Municipal Desalination Facility Survey
Appendix B. Individual Facility Information

Joines Road WTP, TX

GENERAL

- Facility name = Joines Road WTP
- Facility owner = Military Highway Water Supply Corporations
- Purpose of facility = drinking water
- Type of desalination technology = microfiltration/reverse osmosis
- Start year of RO operation = 2014
- Reason for RO facility as opposed to conventional treatment =

TREATMENT CAPACITY

- RO Design production (mgd) = 1.44
- RO average production (mgd) =
- Plant design production (mgd) =
- Plant average production (mgd) =

TREATMENT PROCESS

- Source water = groundwater
- Pretreatment steps =
- Raw water conductivity ($\mu\text{S}/\text{cm}$) =
- Feed pressure to RO (psi) =
- Membrane recovery (percent) =
- TDS of permeate (mg/l) =
- Age of membrane at last replacement =

BLENDING

- Blending =
- Blend Water source =
- Blend ratio (permeate : other) =
- TDS of blend =

WASTE MANAGEMENT

- Concentrate disposal = to surface water via drainage ditch
- Fate of cleaning wastewater =

POST-TREATMENT

- Post-treatment of permeate =
- Post-treatment of concentrate =

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

La Rusias WTP, TX

GENERAL

- Facility name = La Rusias WTP
- Facility owner = Military Highway Water Supply Corporations
- Purpose of facility = drinking water
- Type of desalination technology = microfiltration/reverse osmosis
- Start year of RO operation = 2017
- Reason for RO facility as opposed to conventional treatment =

TREATMENT CAPACITY

- RO Design production (mgd) = 1.44
- RO average production (mgd) =
- Plant (RO + blend) design production (mgd) =
- Plant average production (mgd) =

TREATMENT PROCESS

- Source water = groundwater
- Pretreatment steps =
- Raw water conductivity ($\mu\text{S}/\text{cm}$) =
- Feed pressure to RO (psi) =
- Membrane recovery (percent) =
- TDS of permeate (mg/l) =
- Age of membrane at last replacement =

BLENDING

- Blending =
- Blend Water source =
- Blend ratio (permeate : other) =
- TDS of blend =

WASTE MANAGEMENT

- Concentrate disposal = to surface water via drainage ditch
- Fate of cleaning wastewater =

POST-TREATMENT

- Post-treatment of permeate =
- Post-treatment of concentrate =

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

La Tierra RO WTP, TX

GENERAL

- Name of facility = La Tierra RO WTP
- Facility owner = BW Primoris
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2016
- Reason for RO facility as opposed to a conventional treatment facility = TDS, arsenic

TREATMENT CAPACITY

- RO Design production (mgd) = 0.65
- RO average production (mgd) = 0.5 – 0.65
- Plant Design production (mgd) =
- Plant Average Production (mgd) =

TREATMENT PROCESS

- Source water = groundwater
- Raw water TDS (mg/l) = 1000 - 1200
- Feed pressure (psi) = 220-250
- Pretreatment = antiscalant, cartridge filters, sulfuric acid
- TDS of permeate (mg/l) = 40-50
- Membrane recovery (percent) = 65-72%
- Age of membrane at last replacement = on original membranes

BLENDING

- Blending = yes
- Blend water source = raw water bypass
- Blend ratio (permeate : other) = 2 : 1
- TDS of blend = 250

WASTE MANAGEMENT

- Concentrate disposal = to gulch, percolations into ground
- Fate of cleaning wastewater = send membranes off site

POST-TREATMENT

- Post treatment of permeate = blend, chlorine, caustic
- Post-treatment of concentrate = none

Mitchell County Desalination Plant, TX

GENERAL

- Name of facility = Mitchell County Desalination Plant
- Facility owner = Mitchell County
- Facility type = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2017
- Reason for RO treatment =

TREATMENT CAPACITY

- RO Design production (mgd) = 0.25
- RO Average Production (mgd) =
- Plant Design production (mgd)=
- Plant average production (mgd) =

TREATMENT PROCESS

- Source water =
- Raw water conductivity ($\mu\text{S}/\text{cm}$) =
- Feed pressure to RO (psi) =
- Pretreatment steps in front of RO =
- Target TDS of permeate (mg/l) =
- Membrane recovery (percent) =
- Age of membrane at last replacement =

BLENDING

- Blending =
- Blend water source =
- Blend ratio (permeate:other) =
- Target TDS of blend (mg/l) =

WASTE MANAGEMENT

- Concentrate disposal =
- Fate of cleaning waste =

POST-TREATMENT

- Post-treatment of permeate =
- Concentrate treatment =

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Progresso WTP, TX

GENERAL

- Facility name = Progresso WTP
- Facility owner = Military Highway Water Supply Corporations
- Purpose of facility = drinking water
- Type of desalination technology = microfiltration/reverse osmosis
- Start year of RO operation = 2011
- Reason for RO facility as opposed to conventional treatment =

TREATMENT CAPACITY

- RO Design production (mgd) = 0.52
- RO average production (mgd) =
- Plant (RO + blend) design production (mgd) =
- Plant average production (mgd) =

TREATMENT PROCESS

- Source water = groundwater
- Pretreatment steps =
- Raw water TDS (mg/l) or conductivity ($\mu\text{S}/\text{cm}$) =
- Feed pressure to RO (psi) =
- Membrane recovery (percent) =
- TDS of permeate (mg/l) =
- Age of membrane at last replacement =

BLENDING

- Blending =
- Blend Water source =
- Blend ratio (permeate : other) =
- TDS of blend =

WASTE MANAGEMENT

- Concentrate disposal = to surface water via drainage ditch
- Fate of cleaning wastewater =

POST-TREATMENT

- Post-treatment of permeate =
- Post-treatment of concentrate =

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

San Antonio, TX

GENERAL

- Name of facility = H2OAKS Center Brackish Groundwater Desalination Plant
- Facility owner = City of San Antonio
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2016
- Reason for RO facility as opposed to a conventional treatment facility =

TREATMENT CAPACITY

- RO Design production (mgd) = 10
- RO average production (mgd) = 7.22
- Plant Design production (mgd) = 12
- Plant Average Production (mgd) =

TREATMENT PROCESS

- Source water = groundwater
- Raw water TDS (mg/l) = 1300
- Feed pressure (psi) =
- Pretreatment = antiscalant, cartridge filters, sulfuric acid,
- TDS of permeate (mg/l) = 30-50
- Membrane recovery (percent) = 90%
- Age of membrane at last replacement =

BLENDING

- Blending = yes
- Blend water source = bypass
- Blend ratio (permeate:other) = 10 : 2
- TDS of blend = <320

WASTE MANAGEMENT

- Concentrate disposal = deep well injection
- Fate of cleaning wastewater =

POST-TREATMENT

- Post treatment of permeate = calcite contactor (for Ca), sulfuric acid, degasification, stabilization (NaOH), disinfection (chlorine)
- Post-treatment of concentrate = none

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Stephens Regional Special Utility District, TX

GENERAL

- Name of facility = Stephens Regional SUD WTP
- Facility owner = Stephens Regional Special Utility District
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2013
- Reason for RO facility as opposed to a conventional treatment facility =

TREATMENT CAPACITY

- RO design production (mgd) = 0.4
- RO average production (mgd) =

TREATMENT PROCESS

- Source water = surface water (lake)
- Raw water TDS (mg/l) =
- Feed pressure (psi) =
- Pretreatment =
- TDS of permeate (mg/l) =
- Membrane recovery (percent) =
- Age of membrane at last replacement =

BLENDING

- Blending =
- Blending source =
- Blend ratio (permeate : other) =
- TDS of blend (mg/l) =

WASTE MANAGEMENT

- Concentrate disposal = evaporation ponds
- Fate of cleaning wastewater =

POST-TREATMENT

- Post treatment of permeate =
- Post-treatment of concentrate =

Municipal Desalination Facility Survey
Appendix B. Individual Facility Information

Victoria Road RO Plant, TX

GENERAL

- Name of facility = Victoria Road RO Plant
- Facility owner = North Alamo Supply Corporation
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2012
- Reason for RO facility as opposed to a conventional treatment facility =

TREATMENT CAPACITY

- RO Design production (mgd) = 2.25
- RO average production (mgd) = 2.25

TREATMENT PROCESS

- Source water = groundwater
- Raw water TDS (mg/l) = 4000
- Feed pressure (psi) = 150
- Pretreatment = cartridge filter
- Target TDS of permeate (mg/l) = 150
- Membrane recovery (percent) = 75%
- Age of membrane at last replacement =

BLENDING

- Blending = no

WASTE MANAGEMENT

- Concentrate disposal =
- Fate of cleaning wastewater =

POST-TREATMENT

- Post treatment of permeate = gas removal, pH adjustment, corrosion control, disinfection
- Post-treatment of concentrate =

**Municipal Desalination Facility Survey
Appendix B. Individual Facility Information**

Southwest GW TP, UT

GENERAL

- Name of facility = Southwest Groundwater Treatment Plant
- Facility owner = Jordan Valley Water Conservation District
- Purpose of facility = drinking water
- Type of technology = reverse osmosis
- Start year of RO operation = 2012
- Reason for RO treatment as opposed to conventional treatment = TDS, sulfate

TREATMENT CAPACITY

- RO Design production (mgd) = 8.25 installed – but currently limited to 5.5
- RO Average Production (mgd) = 4
- Plant (RO + blend) Design production (mgd) = ~ 7.5
- Plant average production (mgd) = 5.5

TREATMENT PROCESS

- Source = groundwater
- Raw water TDS (mg/l) = 800
- Feed pressure (psi) = 130-190
- Pre-treatment steps = cartridge filter, antiscalant
- TDS of permeate (mg/l) =
- Membrane recovery (percent) = 80
- Age of membrane at last replacement = lead elements replaced after ~ 5 years

BLENDING

- Blending = yes
- Blend water source = raw water bypass after 1 μ cartridge filter
- Blend ratio (permeate : other) = 4 : 1.5
- TDS of blend = 225

WASTE MANAGEMENT

- Concentrate disposal = 26-mile pipeline to Great Salt Lake
- Fate of cleaning wastewater = sewer

POST-TREATMENT

- Post-treatment of permeate = caustic, disinfection
- Treatment of concentrate = none