HYDRAULIC MODEL STUDIES OF PUMP INTAKE MANIFOLD AND EVAPORATION TRAYS SAN DIEGO SALINE WATER TEST FACILITY OFFICE OF SALINE WATER

D. L. King Division of Research Office of Chief Engineer Bureau of Reclamation

November 1969

Prepared for Office of Saline Water Washington, D.C. 20240



REC-OCE-69-3

HYDRAULIC MODEL STUDIES OF PUMP INTAKE MANIFOLD AND EVAPORATION TRAYS

SAN DIEGO SALINE WATER TEST FACILITY OFFICE OF SALINE WATER

Prepared for the Office of Saline Water

by

D. L. King

November 1969

HYDRAULICS BRANCH DIVISION OF RESEARCH

UNITED STATES DEPARTMENT OF THE INTERIOR * BUREAU OF RECLAMATION Office of Chief Engineer . Denver, Colorado

ACKNOWLEDGMENTS

These studies were conducted by the author under the supervision of W. E. Wagner, Head, Applied Hydraulics Section. T. J. Rhone performed the tests concerning velocity distribution in the evaporation trays. Close cooperation was maintained with the Hydraulic Machinery Branch, Division of Design, Office of Chief Engineer, USBR. Paul Tomalin, Office of Saline Water, Washington, D.C., represented that agency. Paul Buckingham represented Fluor Corporation. The studies were performed in the Hydraulics Branch, under Harold M. Martin, Chief (retired).

The information contained in this report regarding commercial products may not be used for advertising or promotional purposes and is not to be construed as an endorsement of any product by the Bureau of Reclamation.

ABSTRACT

The San Diego Saline Water Test Facility includes a test module to aid designing a multistage flash distillation desalting plant. The module contains evaporation, collection, and recirculation components. Design of the intake for recirculation pumps required special attention to maintain sufficient net positive suction head on the pumps while operating with a fluid near the flashing point. With improper intake design, vortex formation or water surface drawdown could result in reduction of suction head, cavitation on pump impellers, and severe pump vibration from entrainment of vapor. Tests performed on a 1:8.93 hydraulic model of a pump intake manifold enabled recommendations for several modifications to the preliminary design, alleviating vortex formation and vapor entrainment. Brine mixing devices in the last 2 stages of the evaporation trays were tested for effects on velocity distribution.

DESCRIPTORS-/ *pump intakes/ centrifugal pumps/ open channels/ velocity distribution/ hydraulic models/ hydraulics/ *model tests/ vortices/ open channel flow/ distillation/ appurtenances/ flash distillation/ desalination

IDENTIFIERS-/ *intake systems & manifolds/ Office of Saline Water/ San Diego Saline Fac, Calif/ multistage flash distill

CONTENTS

Abstract				 	
Purpose				 	
Conclusions				 	1
Application				 	1
Introduction				 	1
Investigation		• • •		 	
Model Configuration				 	1
The Preliminary Design				 	1
The Modified Design				 	2
Evaporation Tray Mixing Devices	•••	• • •	,	 • • • • • • • •	

Figure

1	1:8.93 Model of the Preliminary Design
2, 3, 4	Preliminary Design, Manifold Depth = 5 ft
5	Preliminary Design, Manifold Depth = 6 ft
6	Preliminary Design, Manifold Depth = 7 ft
7	Preliminary Design, Air-entrainment and Drawdown Tests
8	Preliminary Design with Horizontal Perforated Baffle
9	Model of Modified Design
10	Modified Design, Manifold Depth = 5 ft
11	Modified Design, Manifold Depth = 6 ft
12	Modified Design, Manifold Depth = 7 ft
13	Modified Design, Manifold Denth = 5 ft $3/4$ 0 17
14	Recommended Manifold Baffle Arrangement and Transition Pier Shape
15	Flow Conditions with Manifold Baffle
16	Model with Mixing Devices
17	Velocity Distribution in Evaporation Trave
• •	Zi Courty Distribution in Evaporation Trays

x.

.

٠

PURPOSE

The tests were performed to determine tendencies for vortex formation and vapor entrainment in the pump intake manifold, and to develop modifications or appurtenances to alleviate these tendencies. The effect of mixing devices on velocity distribution in the evaporation trays was also determined.

CONCLUSIONS

1. The preliminary design exhibited tendencies toward vortex formation and vapor entrainment in the pump intake manifold.

2. Flow improving modifications were developed which consisted of changing the location and orientation of the pump suction line, widening and streamlining the transitions between the evaporation trays and the manifold, and installing a vertical solid baffle above the intake to the pump suction line.

3. The tendency toward vapor entrainment was reduced, but not eliminated.

4. The overflow weir portion of the mixing devices improved the distribution of flow in the evaporation trays, but some asymmetry remained.

APPLICATION

The study was performed specifically for the Office of Saline Water. However, the results should be of general interest to designers of pump intakes.

INTRODUCTION

The San Diego Saline Water Test Facility includes a test module to aid in the design of a multistage flash distillation desalination plant. The module is a full-scale facility and includes a portion of the complete plant, with representation of the evaporation, collection, and recirculation components.

The design of the intake for the recirculating pump would not normally be of major concern. However, two considerations occur in the design of multistage flash distillation plants which warrant special attention. First, for cost efficiency, minimum excavation is desired for installation of the recirculating pumps. Second, it is necessary to maintain sufficient net positive suction head (NPSH) on the pumps even though they are operating with a fluid which is at its flashing point. With improper intake design, vortex formation or water surface drawdown could result in reduction of suction head, and cavitation on the pump impellers. Also, entrainment of vapor could cause severe vibration of the pump.

INVESTIGATION

Model Configuration

The 1:8.93 model represented the final two test stages (Numbers 8 and 9) of the test module, the pump intake manifold, and a portion of the pump suction line. Water was recirculated as in the prototype, and provisions were included for simulating the brine blowdown (waste water), product water, and raw water makeup discharges. The recirculated flow was measured with a standard orifice meter and the makeup water was measured with an orifice plate in the discharge line of a centrifugal pump. A centrifugal pump was also used for the recirculated flow. The gate valves in the blowdown and product lines were calibrated for control of those discharges.

Fresh water from the laboratory supply reservoir was used for the tests. Since the prototype module operates with concentrated brine at elevated temperature and near-vacuum pressure conditions, the model test results were necessarily partly qualitative.

The Preliminary Design

The preliminary design is shown in Figure 1. The model was designed according to Fluor Corporation's Drawing No. 4L-5003. The model was tested for a maximum recirculated discharge of 171.5 cfs (4.85 cms) (prototype), a brine blowdown discharge of 8.5 cfs (0.24 cms), a makeup discharge of 14.5 cfs (0.41 cms), and a product discharge of 6.0 cfs (0.17 cms). The recirculated discharge minus the product discharge results in a rate of flow in the evaporation trays of 165.5 cfs (4.68 cms). The trays were installed horizontally for these tests, and each tray carried 25 percent of the total discharge. The recirculating pump and manifold were designed for this condition, which will ultimately occur in the full-scale plant. However, only three trays will act as evaporators in the test module.

A minimum manifold water depth of 5 feet {1.52 m} occurs temporarily during startup. Figure 2 shows an overall view and an end view of flow conditions in the manifold with the minimum depth. Air entrainment

(vapor entrainment in the prototype) was severe, and large quantities of air were pulled into the pump suction line. A closeup view of the suction line transition is shown in Figure 3. Some of the air entrainment originated on the downstream side of the manifold, where the flow tended to climb the conduit wall and air was "folded" into the water. However, most of the air entrainment occurred at the entrance to the manifold. Figure 4 shows the contracting flow due to the shape of the entrance. This contraction resulted in higher flow velocities which, with the drop in elevation, produced strong surface turbulence in the manifold.

A zero-pitch (plane) vane in the pump suction line showed no tendency toward consistent swirling action in the suction line. The vane wavered back and forth, but rotation in either direction did not develop. This observation held for other manifold water depths.

For a manifold water depth of 6 feet (1.83 m), air entrainment was much less severe, as shown in Figure 5. Surface turbulence was reduced because of the smaller elevation difference between the water surface in the evaporation trays and the manifold water surface.

With the maximum depth of 7 feet (2.13 m) in the manifold, air entrainment was negligible and operation was entirely satisfactory, Figure 6.

The discharge was increased above the maximum design value to determine tendencies toward vortex formation above the suction line. The manifold water depth was held constant at 7 feet (2.13 m). Small, unstable vortices formed on the water surface above the suction line for recirculating discharges less than about 370 cfs (10.47 cms) (216 percent of maximum). These vortices entrained small quantities of air but did not exhibit a constant direction of rotation. The intensity of the surface action increased with an increasing discharge. At $\Omega = 370$ cfs (10.47 cms) the direction of rotation was predominantly clockwise. Similar conditions were observed, with increased strength of rotation, up to $\Omega = 460$ cfs (13.02 cms) (268 percent of maximum).

Figure 7 shows the results of air entrainment and water surface drawdown tests for discharges up to the maximum of 171.5 cfs (4.85 cms). For a given discharge, the manifold water depth at which significant amounts of air began to be entrained was determined. The water surface drawdown above the suction line was measured at manifold water depths of 6 and 7 feet (1.83 and 2.13 m) for various discharges. At a water depth of 5 feet (1.52 m), the water surface was too rough to allow a reasonably accurate measurement of the drawdown. The curves indicate that a maximum drawdown on the order of approximately 1 foot (0.30 m) might be expected.

Tests on the preliminary design indicated that air entrainment in the manifold might be reduced by streamlining the sides and bottom of the transition between the evaporation trays and the manifold, and by widening the transition to reduce the flow velocity. Also, use of a perforated baffle, as shown in Figure 8, helped alleviate air entrainment during operation at the minimum manifold water depth. A four-vane flow straightener, placed in the suction line transition immediately below the manifold, did not inhibit vortex formation.

The Modified Design

The model was modified to include widened, streamlined transitions from the evaporation trays to the manifold. The location and orientation of the pump suction line were revised to correspond with Fluor's Drawings No. 4-5503 and 4-5504. The prototype slope of 0.4 foot (0.12 m) per stage was installed in the evaporation trays. The evaporation tray mixing baffles were temporarily simulated with metal blocks placed in the trays. The revised model is shown in Figure 9. Some of the features shown will be described later.

At the minimum manifold water depth of 5 feet (1.52 m), air entrainment was essentially the same as observed in the preliminary design. Although the streamlined transition section eliminated acceleration of the flow through the section, the higher tray velocity due to the slope allowed turbulent surface flow to continue into the manifold. Also, a well-established vortex tended to form above the suction line. Flow conditions are shown in Figure 10. With a manifold water depth of 6 feet (1.83 m), air entrainment was greatly reduced, but the tendency continued for vortex formation above the suction line, Figure 11. At a depth of 7 feet (2.13 m), Figure 12, performance was satisfactory. A thin horizontal vortex formed near the manifold centerline, but very little air was drawn into the suction line.

Similar conditions were observed with 75 percent of the flow through the three right trays. Flow conditions at the minimum manifold water depth are shown in Figure 13.

A vertical baffle wall suspended from the crown of the

manifold above the suction line was successful in alleviating the vortex. The minimum wall dimensions necessary to maintain control of the vortex are: 20 feet (6.10 m) wide and 5 feet (1.52 m) high. Thickness of the baffle is not important. Figure 14 shows the proposed baffle arrangement and pier shape. Flow conditions with the baffle are shown in Figure 15. This photograph also shows the vaned flow straightener in the suction line transition. The straightener was reinstalled as an additional safeguard against vortex formation.

The baffle, even if extended the full length of the manifold, did not control air entrainment. A horizontal perforated plate, used successfully in the preliminary design, was also ineffective.

Evaporation Tray Mixing Devices

The model was modified to include the longitudinal structural members between the trays and the interstage dividers between Stages 7 and 8, and Stages 8 and 9. Each divider consisted of a wall across the three evaporation trays, Figure 16. The bottom of the wall was approximately 2 feet (0.61 m) above the invert. At the bottom of the wall was fastened an adjustable plate (hereafter referred to as the underflow weir) which could be lowered to within I0 inches (0.25 m) of the tray invert. An 8-inch-high (0.20-m) overflow weir was installed 2 feet 9 inches (.,84 m) (prototype) downstream from the underflow weir. This device was designed for the purpose of maintaining a well-mixed brine solution.

Velocity measurements were made with a miniature current meter about 14 feet (4.27 m) downstream from the start of Stage 9 (approximately 5 feet (1.52 m) upstream from the transition into the manifold). The test flow rate was 820,000 pounds per hour per foot of width through the three trays (about 165.5 cfs (4.68 cms) total flow). The underflow weirs were set at 16 inches (0.41 m) above the invert and the manifold depth was maintained at 7 feet (2.13 m). Velocities were measured with and without the overflow weirs. Flow depth at the measuring section was about 2 feet (0.61 m) for both conditions.

The test results, Figure 17, showed that the overflow weirs resulted in a more uniform distribution of velocity across the depth of flow, as compared to the distribution with the underflow weirs alone. The transverse asymmetry was also reduced by the overflow weirs. The apparent reduction in average velocity with the overflow weirs was probably due to the slightly increased depth at the measuring station.



SALINE WATER TEST FACILITY 1:8.93 Scale Model Preliminary Design Photo P800-D-65468 3





SALINE WATER TEST FACILITY 1:8.93 Scale Model Preliminary Design Manifold Depth = 5 feet Q = 171.5 cfs Top Photo P800-D-65469 Bottom Photo P800-D-65470



SALINE WATER TEST FACILITY 1:8.93 Scale Model Preliminary Design Manifold Depth = 5 feet Q = 171.5 cfs Photo P800-D-65471





SALINE WATER TEST FACILITY 1:8.93 Scale Model Preliminary Design Manifold Depth = 5 feet Q = 171.5 cfs Top Photo P800-D-65472 Bottom Photo P800-D-65473 FIGURE 5 REPORT HYD-597



SALINE WATER TEST FACILITY 1:8.93 Scale Model Preliminary Design Manifold Depth = 6 feet Q = 171.5 cfs Top Photo P800-D-65474 Bottom Photo P800-D-65475

FIGURE 6 REPORT HYD-597





SALINE WATER TEST FACILITY 1:8.93 Scale Model Preliminary Design Manifold Depth = 7 feet Q = 171.5 cfs Top Photo P800-D-65476 Bottom Photo P800-D-65477



FIGURE 8 REPORT HYD-597





SALINE WATER TEST FACILITY 1:8.93 Scale Model Preliminary Design with Horizontal Perforated Baffle Manifold Depth = 5 feet Q = 171.5 cfs Top Photo P800-D-65478 Bottom Photo P800-D-65479

20



SALINE WATER TEST FACILITY 1:8.93 Scale Model Modified Design Photo P800-D-65480

FIGURE 10 REPORT HYD-597





SALINE WATER TEST FACILITY 1:8.93 Scale Model Modified Design Manifold Depth = 5 feet Q = 171.5 cfs Top Photo P800-D-65481 Bottom Photo P800-D-65482

FIGURE 11 REPORT HYD-597





SALINE WATER TEST FACILITY 1:8.93 Scale Model Modified Design Manifold Depth = 6 feet Q = 171.5 cfs Top Photo P800-D-65483 Bottom Photo P800-D-65484



SALINE WATER TEST FACILITY 1:8.93 Scale Model Modified Design Manifold Depth = 7 feet Q = 171.5 cfs Photo P900-D-65485



SALINE WATER TEST FACILITY 1:8.93 Scale Model Modified Design Manifold Depth = 5 feet Q = 128.6 cfs Photo P800-D-65486

FIGURE 14 REPORT HYD-597





SALINE WATER TEST FACILITY 1:8.93 Scale Model Flow Conditions with Manifold Baffle Manifold Depth = 5 feet Q = 171.5 cfs Photo P800-D-65487



SALINE WATER TEST FACILITY 1:8.93 Scale Model Evaporation Tray Mixing Devices Photo P800-D-65488



.

7-1750 (10-64)

CONVERSION FACTORS-BRITISH TO METRIC UNITS OF MEASUREMENT

The following conversion factors adopted by the Bureau of Reclamation are those publiahed by the American Society for Testing and Materials (ASTM Metric Practice Guide, January 1964) except that additional factors (*) commonly used in the Bureau have been added. Further discussion of definitions of quantities and units is given on pages 10-11 of the ASTM Metric Practice Guide.

The metric units and conversion factors adopted by the ASTM are based on the "International System of Units" (designated SI for Systeme International d'Unites), fixed by the International Committee for Weights and Measures; this system is also known as the Giorgi or MKSA (meter-kilogram (mass)-second-ampere) system. This system has been adopted by the International Organization for Standardization in ISO Recommendation R-31.

The metric technical unit of force is the kilogram-force; this is the force which, when applied to a body having a mass of 1 kg, gives it an acceleration of 9.80665 m/sec/sec, the standard acceleration of free fall toward the sarth's center for sea level at 45 deg latitude. The metric unit of force in SI units is the newton (N), which is defined as that force which, when applied to a body having a mass of 1 kg, gives it an acceleration of 1 m/sec/sec. These units must be distinguished from the (inconstant) local weight of a body having a mass of 1 kg; that is, the weight of a body is that force with which a body is attracted to the earth and is equal to the mass of a body multiplied by the acceleration due to gravity. However, because it is general practice to use "pound" rather than the technically correct term "pound-force," the term "kilogram" (or derived mass unit) has been used in this guide instead of "kilogram-force" in expressing the conversion factors for forces. The newton unit of force will find increasing use, and is

Multiply	To obtain			
	LENGTH			
Mil	25.4 (exactly). 25.4 (exactly). 2.54 (exactly). 30.48 (exactly). 0.3048 (exactly). 0.3048 (exactly).	Micron Millimeters Centimeters Centimeters Maters		
Yards,	0.9144 (exactly)	Meters Meters Meters Kilometers		
	AREA			
Square inches Square feet Square yards Acres	6.4516 (exactly) 929.03 (exactly)* 0.092903 (exactly) 0.836127 0.40469* 0.0040469* 2.58999	Square centimeters Square meters 		
	VOLUME			
Cubic inches	16.3871 0.0283168 0.764555	Cubic centimeters Cubic meters Cubic meters		
	CAPACITY	····		
Liquid pints (U.S.)	29.5737 29.5729 0.473179 0.473166	Cubic centimeters Milliliters Cubic decimeters Liters		
Callons (U.S.)	0.946358 3,785.43* 3,78543 3,78533	Liters Cubic centimeters Cubic decimeters Liters		
Cubic feet	0.00378543* 4.54609 4.54596 28.3160	Cubic meters Cubic decimeters Liters Liters		
Auro-feet.	/64.55* 1,233.5* ,233,500*	Liters Cubic meters Liters		

Table 1

Table II

QUANTITIES AND UNITS OF MECHANICS

Multiply	By	To obtain	Hultiply	By	To obtain	
	MASS		PORCE*			
Grains (1/7,000 lb) Troy ounces (480 grains).			Pounds	0.453592*	. Eilograms . Newtons . Dyneż	
Poundes (avdp)	0.45359237 (exactly)	Kilograms		WORK AND ENERGY*		
Short tans (2,000 lb) 07.185	Mitagrems Metric tons Kilogrems	British thermal units (Btu) 0.252*				
	FORCE/AHEA		Foot-pounds	1.35582*	. Joules	
Pounds per square inch .	0.070307	Kilograms per square centimeter		POWER		
Pounds per square foot		Hericas per square contineter Kilograme per square meter Newtons per square meter	Rorsspower	745.700,	Watts Watts Watts	
	MASS/VOLUME (DENSITY)			HEAT TRANSFER		
Ounces per cubic inch Pounds per cubic foot	1.72999 16.0185 	Grems per cubic centimeter Kilogrems per cubic meter Grems per cubic centimeter Grems per cubic centimeter	Btu in./hr ft ² deg F (k, thermal conductivity) Btu ft/hr ft ² deg F	1.442	<u>Milliwatts/cm</u> deg C Kg cal/hr m deg C Kg cal m/hr m ² deg C	
	WASS/CAPACITY		Btu/hr ft2 deg F (C; thermal	0.568	Milliwatts/cm ² deg C	
Ounces per gallon (U.S.). 7.4393 Ources per liter Ounces per gallon (U.K.). 6.2362 Orans per liter Pounds per gallon (U.S.). 119.829 Orans per liter Pounds per gallon (U.K.). 99.779 Orans per liter BENDING MORENT OR TORQUE Diverse per liter		Control Linder). Deg F hr ft ² /Btu (R, thermal resistance). Btu/lb deg F (c, heat capacity). Btu/lb deg F Ft ² /hr (thermal diffusivity)	4.882	Kg cal/hr m ² deg C Deg C cm ² /milliwatt J/g deg C Cal/gram deg C Cm ² /sec		
Inen-pounds	1.12985 x 106	Centimeter-dynes	<u></u>	WATER VAPOR TRANSMISSION		
Foot-pounds 0.138255 Mail 1.35582 x 107		Grains/hr ft ² (water vapor transmission),	16.7	Grams/24 hr m ² Metric perms Metric perm-centimeters		
VELOCITY Peet per second 30.48 (exactly) 0.3048 (exactly)* 0.3048 (exactly)*		Centimeters per second		Table III	· .	
Feet per year				OTHER QUANTITIES AND UNITS	To obtain	
	0.44704 (exactly)	Meters per second	Wiltiply	БУ	10 0000	
	ACCELERATION*	Mahara	day (seepege)	304.8∗	Liters per square meter per day	
Feet per second		MOVETS DET BECCHAR-	Found-seconds per square foot	4.8824*	Kilogram second per square meter	
FLOM Gubic feet per second (second- feet)	Cubic meters per second Liters per second Liters per second	Square feet per second (viscosity) Fehrenheit degrees (shange)* Volts per mil	0.02903* (exactly) 5/9 exactly 0.03937 10.764 0.001662	Square meters per second Celsius or Kelvin degrees (change), Kilovolts per millimeter Lumens per equare meter Cha-square millimeters per meter		
			Millicuries per subis foot Millicuries per square foot Gallons per square yard Pounds per inch	35, 3147** 10.7639* 4,527219* 0,17858*	Millicuries per cubic meter Milliamps per square meter Liters per square meter 	

GPO 845-237

ABSTRACT

The San Diego Saline Water Test Facility includes a test module to aid designing a multistage flash distillation desalting plant. The module contains evaporation, collection, and recirculation components. Design of the intake for recirculation pumps required special attention to maintain sufficient net positive suction head on the pumps while operating with a fluid near the flashing point. With improper intake design, vortex formation or water surface drawdown could result in reduction of suction head, cavitation on pump impellers, and severe pump vibration from entrainment of vapor. Tests performed on a 1:8.93 hydraulic model of a pump intake manifold enabled recommendations for several modifications to the preliminary design, alleviating vortex formation and vapor entrainment. Brine mixing devices in the last 2 stages of the evaporation trays were tested for effects on velocity distribution.

ABSTRACT

The San Diego Saline Water Test Facility includes a test module to aid designing a multistage flash distillation desalting plant. The module contains evaporation, collection, and recirculation components. Design of the intake for recirculation pumps required special attention to maintain sufficient net positive suction head on the pumps while operating with a fluid near the flashing point. With improper intake design, vortex formation or water surface drawdown could result in reduction of suction head, cavitation on pump impellers, and severe pump vibration from entrainment of vapor. Tests performed on a 1:8.93 hydraulic model of a pump intake manifold enabled recommendations for several modifications to the preliminary design, alleviating vortex formation and vapor entrainment. Brine mixing devices in the last 2 stages of the evaporation trays were tested for effects on velocity distribution.

ABSTRACT

The San Diego Saline Water Test Facility includes a test module to aid designing a multistage flash distillation desalting plant. The module contains evaporation, collection, and recirculation components. Design of the intake for recirculation pumps required special attention to maintain sufficient net positive suction head on the pumps while operating with a fluid near the flashing point. With improper intake design, vortex formation or water surface drawdown could result in reduction of suction head, cavitation on pump impellers, and severe pump vibration from entrainment of vapor. Tests performed on a 1:8.93 hydraulic model of a pump intake manifold enabled recommendations for several modifications to the preliminary design, alleviating vortex formation and vapor entrainment. Brine mixing devices in the last 2 stages of the evaporation trays were tested for effects on velocity distribution.

ABSTRACT

The San Diego Saline Water Test Facility includes a test module to aid designing a multistage flash distillation desalting plant. The module contains evaporation, collection, and recirculation components. Design of the intake for recirculation pumps required special attention to maintain sufficient net positive suction head on the pumps while operating with a fluid near the flashing point. With improper intake design, vortex formation or water surface drawdown could result in reduction of suction head, cavitation on pump impellers, and severe pump vibration from entrainment of vapor. Tests performed on a 1:8.93 hydraulic model of a pump intake manifold enabled recommendations for several modifications to the preliminary design, alleviating vortex formation and vapor entrainment. Brine mixing devices in the last 2 stages of the evaporation trays were tested for effects on velocity distribution.

HYD-597

King, D L

HYDRAULIC MODEL STUDIES OF PUMP INTAKE MANIFOLD AND EVAPORATION TRAYS-SAN DIEGO SALINE WATER TEST FACILITY-OFFICE OF SALINE WATER. Bur Reclam Lab Rep HYD-597, Hydraul Br, Nov 1969. Bureau of Reclamation, Denver, 21 p, 17 fig, 3 tab

DESCRIPTORS-/ *pump intakes/ centrifugal pumps/ open channels/ velocity distribution/ hydraulic models/ hydraulics/ *model tests/ vortices/ open channel flow/ distillation/ appurtenances/ flash distillation/ desalination

IDENTIFIERS-/ *intake systems & manifolds/ Office of Saline Water/ San Diego Saline Fac, Calif/ multistage flash distill

HYD-597

King, D L 🕠

HYDRAULIC MODEL STUDIES OF PUMP INTAKE MANIFOLD AND EVAPORATION TRAYS-SAN DIEGO SALINE WATER TEST FACILITY-OFFICE OF SALINE WATER. Bur Reclam Lab Rep HYD-597, Hydraul Br, Nov 1969. Bureau of Reclamation, Denver, 21 p, 17 fig, 3 tab

DESCRIPTORS-/ *pump intakes/ centrifugal pumps/ open channels/ velocity distribution/ hydraulic models/ hydraulics/ *model tests/ vortices/ open channel flow/ distillation/ appurtenances/ flash distillation/ desalination

IDENTIFIERS-/ *intake systems & manifolds/ Office of Saline Water/ San Diego Saline Fac, Calif/ multistage flash distill

HYD-597

King, D L

HYDRAULIC MODEL STUDIES OF PUMP INTAKE MANIFOLD AND EVAPORATION TRAYS-SAN DIEGO SALINE WATER TEST FACILITY-OFFICE OF SALINE WATER. Bur Reclam Lab Rep HYD-597, Hydraul Br, Nov 1969. Bureau of Reclamation, Denver, 21 p, 17 fig, 3 tab

DESCRIPTORS-/ *pump intakes/ centrifugal pumps/ open channels/ velocity distribution/ hydraulic models/ hydraulics/ *model tests/ vortices/ open channel flow/ distillation/ appurtenances/ flash distillation/ desalination

IDENTIFIERS-/ *intake systems & manifolds/ Office of Saline Water/ San Diego Saline Fac, Calif/ multistage flash distill

HYD-597

King, D L

HYDRAULIC MODEL STUDIES OF PUMP INTAKE MANIFOLD AND EVAPORATION TRAYS-SAN DIEGO SALINE WATER TEST FACILITY-OFFICE OF SALINE WATER. Bur Reclam Lab Rep HYD-597, Hydraul Br, Nov 1969. Bureau of Reclamation, Denver, 21 p, 17 fig, 3 tab

DESCRIPTORS-/ *pump intakes/ centrifugal pumps/ open channels/ velocity distribution/ hydraulic models/ hydraulics/ *model tests/ vortices/ open channel flow/ distillation/ appurtenances/ flash distillation/ desalination

IDENTIFIERS-/ *intake systems & manifolds/ Office of Saline Water/ San Diego Saline Fac, Calif/ multistage flash distill